

Power, Energy & Grid Of the Future



SCE Distributed Energy Resources

April 8, 2008

High-Megawatt Power Converter Technology Roadmap Workshop

Power, Energy & Grid Of the Future – Presentation Overview

- SCE DER Activity
- Inverter Interface – What Do I Want
- Beyond DER Activity

SCE DER Activity

- Prime Mover - MTG Generator Testing
- **Grid Interface** – Interconnection Criteria, Advanced Inverter Development Input ‘Utility Perspective’
- Advanced Operating Concepts – Microgrids, DER as System Asset, Smart Grid

SCE DER Activity – Grid Interface

- IEEE Draft Std 1547.4, Intentional DG Islands
 - A KEY SCE PARTICIPATION DRIVER:
Concepts Relevant to Accomplishing *Feasible* High Renewable Penetration
 - DoE OE RDSI Proposal ‘Catalina Renewable DG’:
Demonstration of High Renewable Penetration
- 20% BY 2010 California’s Renewable Portfolio Standard
 - 20% renewables with significant intermittent content will require more than ‘business as usual’
 - 4,000 MW Wind
 - 1,000 MW Solar
 - Energy Storage with Advanced PCS, A Solution?


Inverter Interface – What Do I Want

- Starting Point - Do No Harm. Safety first. Mission accomplished...but...
- Moving Toward - System Support from DER. High renewable penetration, grid reliability support, grid-side power quality support
- Inverter Needs - Magnitude, Grid Interactive, Reliable, Cost Competitive, Innovation Incentive Rate

Beyond DER Activity

- SCE's Circuit of the Future D-FACTS: "What and Why"
- Phasor Measurement Unit (PMU) Application Development: PMU Assisted System Restoration
- Advanced Energy Storage for Wind Integration
- SCE 250 MW PV Project: Interface Specification

SCE's Circuit of the Future



SCE's Circuit of the Future

D-FACTS

D-SVC Performance Specification, Overview

WHAT DO WE WANT?

- Fast response and mitigation of temporary voltage sags
 - Respond and mitigate infrequent temporary deep sags -7 to -12%, (15/year recorded, EPRI DPQ Study)
 - Don't try to fix very infrequent serious events: block device if sag exceeds -12% (Rule 21-based limit)

INPUT FOR DEVELOPMENT OF SPECIFICATION:


- Emulate organization/headings from relevant sections of I
 - "Existing Power System Characteristics" (3.8)
 - "Electrical Performance Requirements" (3.9)
 - "SVC Operating Characteristics" (3.10)

But, much less detail needed. And, distribution vs. transmission IEEE PQ Std vs. WECC T-Planning Criteria.

All stated quantities for proposed D-SVC spec refer to or are relevant to distribution:

- SCE CPUC Tariff Rule 2
- SCE Voltage Fluctuation Limit Criteria
- IEEE 1559 PQ Monitoring Standard
- IEEE 519 Harmonic Limits

D-SVC Operation Illustration, Cleared Fault Voltage & Time Thresholds



PMU Assisted System Preservation

**Mega
Storage**

Energy Storage System Impact

O.C




East-of-River/Southern California Import Transmission Nomogram

Based upon:
Three Palo Verde units
All transmission facilities in service

Reduction in SCIT Import Limit For Palo Verde Status:	
3 units on Line	0 MW
2 units on Line	200 MW
1 unit on Line	400 MW
0 unit on Line	700 MW

NO MARGIN



BC

R

V

M

A

V

L

S

- SCIT NOMOGRAM
 - Dynamic Stability and Transient Voltage Constrained
 - Constraint Based on Total MW-S Inertia in So Cal Load Center
 - RELIABILITY, AND COMMERCIAL, IMPLICATIONS

Advanced Energy Storage for Wind Integration

- Operating the CAISO system with 20% Renewables - 6700 MW of wind presents significant challenges

Tehachapi – April 2005






Figure 2b: Scenario 1, bus frequency vs. time



try, March 2008 FINAL DRAFT FOR REVIEW

Figure 5b: Scenario 4, bus frequency vs. time

Figure 2d: Scenario 1, storage system generation vs. time

Figure 5d: Scenario 4, storage system generation vs. time

Inverter Interface – Early Feature List for SCE’s 250 MW PV Project

4/1/08 UPDATED INVERTER FEATURE LIST (GRID-INTERFACE FOCUS)
FUNDAMENTAL AND RELEVANT NOW

- 1) UL 1741/IEEE 1547/Rule 21 Compliant
- 2) Better than 96% inverter efficiency
- 3) Control/Optimize PV Array Maximum Power Point

FEATURES TO ENABLE 15+% PENETRATION, GOING 'BEYOND UL/IEEE/Rule 21'

- 4) Active participation in voltage regulation

FEATURES TO IMPROVE POWER QUALITY, SERVICE RELIABILITY, 'ADDED VALUE' ANCILLARY-TYPE SERVICES FROM THE RESOURCE

- 5) Respond to voltage transients to actively mitigate voltage sag's via dynamic VAR injection/modulation (STATCOM)
- 6) Respond to stability transients to damp system-side power oscillations thru dynamic Q and P modulation (Storage & UPFC)
- 7) High voltage inverter switches/configuration for direct connect to 480 V
- 8) User specified, location-specific, fault duty multiplier (1 to 'X' times full load current)
- 9) Participate in wide-area VAR/voltage control schemes
- 10) Literate in multiple communication protocols (DNP3, Modbus, IEC 68150)

COMMERCIAL

- 11) Inverter cost below 100\$/KVA
- 12) 'Commoditize' and 'modularize' commercial hi-power hi-functionality inverters

SCE's 250 MW PV Project

- Filed w/ CPUC, Ratebase 250 MW PV, \$875 Million
- 50 MW/year, 5 Years
- 2 MW Pilot Project, In Service August 2008
- 1-2 MW Increments
- 3.5 \$/Watt
- Connect on grid-side at 12 kV
- Non-utility roof space, equipment suppliers, installers, O&M services
- Support CA Solar Initiative targets. Of 805 MW available in SCE's service territory only about 50 MW deployed. Average CSI installed cost for residential over \$8/Watt