

**NIST Office of Weights and Measures (OWM) Analysis
Specifications and Tolerances (S&T)
2023 NCWM Interim Meeting Agenda**

The NIST OWM Analysis is submitted to assist the Weights and Measures community as it deliberates on items before the Conference. OWM offers these comments and recommendations based upon information and input available as of the date of this report.

Language shown in bold face print by ~~striking out~~ information to be deleted and underlining information to be added. Requirements that are proposed to be nonretroactive are printed in *bold faced italics*.

For additional information or assistance please contact an OWM Technical Advisor:

Mrs. Tina Butcher, S&T Committee, tina.butcher@nist.gov or (301) 975-2196
Mr. Rick Harshman, S&T Committee, richard.harshman@nist.gov or (301) 975-8107
Mr. Jan Konijnenburg, NIST Associate, jan.konijnenburg@nist.gov
Ms. Diane Lee, S&T Committee, diane.lee@nist.gov or (301) 975-4405
Ms. Juana Williams, S&T Committee, juana.williams@nist.gov or (301) 975-3989

Subject Series List for the Specifications and Tolerances Committee

Handbook 44 – General Code.....	GEN Series
Scales.....	SCL Series
Belt-Conveyor Scale Systems	BCS Series
Automatic Bulk Weighing Systems	ABW Series
Weights.....	WTS Series
Automatic Weighing Systems	AWS Series
Weigh-In-Motion Systems used for Vehicle Enforcement Screening	WIM Series
Liquid-Measuring Devices	LMD Series
Vehicle-Tank Meters	VTM Series
Liquefied Petroleum Gas and Anhydrous Ammonia Liquid-Measuring Devices.....	LPG Series
Hydrocarbon Gas Vapor-Measuring Devices.....	HGV Series
Cryogenic Liquid-Measuring Devices	CLM Series
Milk Meters	MLK Series
Water Meters	WTR Series
Mass Flow Meters	MFM Series
Carbon Dioxide Liquid-Measuring Devices.....	CDL Series
Hydrogen Gas-Metering Devices	HGM Series
Electric Vehicle Refueling Systems	EVF Series
Vehicle Tanks Used as Measures	VTU Series
Liquid Measures	LQM Series
Farm Milk Tanks	FMT Series
Measure-Containers.....	MRC Series
Graduates.....	GDT Series
Dry Measures	DRY Series
Berry Baskets and Boxes.....	BBB Series
Fabric-Measuring Devices.....	FAB Series
Wire-and Cordage-Measuring Devices	WAC Series
Linear Measures	LIN Series
Odometers	ODO Series
Taximeters	TXI Series
Timing Devices	TIM Series
Grain Moisture Meters (a).....	GMA Series
Grain Moisture Meters (b).....	GMB Series
Near-Infrared Grain Analyzers.....	NIR Series
Multiple Dimension Measuring Devices.....	MDM Series
Electronic Livestock, Meat, and Poultry Evaluation Systems and/or Devices.....	LVS Series
Transportation Network Measuring Systems	TNS Series
Other Items.....	OTH Series

Table A
Table of Contents

Reference Key	Title of Item	S&T Page
Subject Series List for the Specifications and Tolerances Committee2		
Table 1. Glossary of Acronyms and Terms7		
Table 2. Reporting Structure8		
GEN – General Code9		
GEN-23.1	G-N.3. Test Methods9	9
	OWM Executive Summary for GEN-23.1 – G-N.3. Test Methods 10	10
SCL – Scales14		
SCL-22.2	A UR.1. Selection Requirements, UR.1.X. Cannabis 14	14
SCL-23.1	S.1.12. Manual Weight Entries 24	24
	OWM Executive Summary for SCL-23.1 – S.1.12. Manual Weight Entries25	25
SCL-23.2	Table S.6.3.a. Marking Requirements, and Table S.6.3.b. Notes for Table S.6.3.a. Marking Requirements29	29
	OWM Executive Summary for SCL-23.2 – Table S.6.3.a. Marking Requirements, and Table S.6.3.b. Notes for Table S.6.3.a. Marking Requirements29	29
SCL-23.3	Verification Scale Division e: Multiple Sections Including, T.N.1.3., Table 6., T.N.3., T.N.4., T.N.6., T.N.8., T.N.9., T.1., T.2., S.1.1.1., T.N.1.2., Table S.6.3.a., Table S.3.6.b., Appendix D, S.1.2.2., Table 3., S.5.4., UR.3., Table 8.32	32
WIM – Weigh-in-Motion Systems – Tentative Code43		
WIM-23.1	Remove Tentative Status and Amend Numerous Sections Throughout.....43	43
	OWM Executive Summary for WIM-23.1 – Remove Tentative Status and Amend Numerous Sections Throughout 44	44
	Section 2.25. Weigh-In-Motion Systems Used for Vehicle Screening and Enforcement—Tentative Code 46	46
LMD – Liquid Measuring Devices62		
LMD-23.3	Automatic Temperature Compensation Task Group 62	62
	OWM Executive Summary for LMD-23.1 – Automatic Temperature Compensation Task Group 62	62
LMD-23.4	N.3.5. Wholesale Devices.....63	63
	OWM Executive Summary for LMD-23.4 – N.3.5. Wholesale Devices.66	66
VTM – Vehicle Tank Meters72		
VTM-18.1	S.3.1 Diversion of Measured Liquid and S.3.1.1. Means for Clearing the Discharge Hose and UR.2.6. Clearing the Discharge on a multiple-product, single discharge hose... 72	72
	OWM Executive Summary for VTM-18.1 – S.3.1 Diversion of Measured Liquid and S.3.1.1. Means for Clearing the Discharge Hose and UR.2.6. Clearing the Discharge on a multiple-product, single discharge hose. 73	73
VTM-20.2	A Table T.2. Tolerances for Vehicle Mounted Milk Meters.....85	85
	OWM Executive Summary for VTM-20.2 – Table T.2. Tolerances for Vehicle Mounted Milk Meters. 85	85
LPG – Liquefied Petroleum Gas and Anhydrous Liquid-Measuring Devices99		
LPG-15.1	D N.3. Test Drafts.....99	99
	OWM Executive Summary for LPG-15.1 – N.3. Test Drafts. 100	100
LPG-22.3	W S.2.5. Zero-Set-Back Interlock., S.2.5.2. Zero -Set-Back Interlock for Stationary Customer -Operated Electronic Retail Motor-Fuel Devices. 110	110

OWM Executive Summary for LPG-22.3 – S.2.5. Zero-Set-Back Interlock., S.2.5.2. Zero -Set-Back Interlock for Stationary Customer -Operated Electronic Retail Motor-Fuel Devices.	113
LPG-23.1 S.2.5. Zero-Set-Back Interlock.....	118
OWM Executive Summary for LPG-23.1 – S.2.5. Zero-Set-Back Interlock.....	119
LPG-23.2 S.2.6. Automatic Timeout.....	122
OWM Executive Summary for LPG-23.2 – S.2.6. Automatic Timeout.	123
MLK – Milk Meters.....	126
MLK-23.2 Table T.1. Tolerances for Milk Meters.....	126
OWM Executive Summary for MLK-23.2 – Table T.1. Tolerances for Milk Meters	126
MFM – Mass Flow Meters	129
MFM-15.1 D N.3. Test Drafts.....	129
OWM Executive Summary for MFM-15.1 – N.3. Test Drafts.	130
HGM – Hydrogen Gas-Measuring Devices	140
HGM-23.1 UR.3.8. Safety Requirement	140
OWM Executive Summary for HGM-23.1 – UR.3.8. Safety Requirement.....	141
EVF – Electric Vehicle Fueling Systems.....	144
EVF-21.1 D A.1. General.....	144
OWM Executive Summary for EVF-21.1 – A.1. General	145
EVF-21.5 D T.2. Load Test Tolerances.....	151
OWM Executive Summary for EVF-21.5 – T.2. Load Test Tolerances.....	152
EVF-23.1 S.2.5.1. Money-Value Divisions Digital, S.8.(a) Minimum Measured Quantity, S.5.3.(d) Abbreviations and Symbols; Joule, N.1. No Load Test, T.5. No Load Test, N.2. Starting Load Test, T.6. Starting Load, Appendix D–megajoule	158
Source: NIST USNWG EVF&S-EVFE Subgroup.....	158
EVF-23.2 S.2.7. Indication of Delivery.....	166
OWM Executive Summary for EVF-23.2 – S.2.7. Indication of Delivery	167
EVF-23.3 S.2.7. Indication of Delivery.....	170
OWM Executive Summary for EVF-23.3 – S.2.7. Indication of Delivery	170
EVF-23.4 S.5. Markings, and N.5. Test of an EVSE System.....	173
OWM Executive Summary for EVF-23.4 S.5. – Markings and N.5. Test of an EVSE System.	176
EVF-23.5 S.5.2. EVSE Identifications and Marking Requirements and T.2. Load Accuracy Test tolerances	182
OWM Executive Summary for EVF-23.5 – S.5.2. EVSE Identifications and Marking Requirements and T.2. Load Accuracy Test Tolerances.....	183
EVF-23.6 S.5.2. EVSE Identification and Marking Requirements and T.2. Tolerances.....	191
OWM Executive Summary for EVF-23.6 – S.5.2. EVSE Identification and Marking Requirements., and T.2. Tolerances.	196
EVF-23.7 N.1. No Load Test, N.2. Starting Load Test, N.5.2. Accuracy Testing, and Appendix D: maximum deliverable amperes	208
OWM Executive Summary for EVF-23.7 – N.1. No Load Test, N.2. Starting Load Test N.5.2. Accuracy Testing, and Appendix D: maximum deliverable amperes	210
GMA – Grain Moisture Meters 5.56 (a).....	216
GMA-19.1 D Table T.2.1. Acceptance and Maintenance Tolerances Air Oven Method for All Grains and Oil Seeds.	216

OWM Executive Summary for GMA-19.1 – Table T.2.1. Acceptance and Maintenance Tolerances Air Oven Method for All Grains and Oil Seeds. 217

Item GMA-19.1–Table T.2.1. Acceptance and Maintenance Tolerances Air Oven Method for All Grains and Oil Seeds. 217

GMA-23.1 N.1.3. Meter to Like-Type Meter Method Transfer Standards and Table T.2.2. Acceptance and Maintenance Tolerances Meter to Like-Type Meter Method 221

OWM Executive Summary for GMA-23.1 – N.1.3. Meter to Like-Type Meter Method Transfer Standards and Table T.2.2. Acceptance and Maintenance Tolerances Meter to Like-Type Meter Method 222

Multiple Dimension Measuring Devices224

MDM-22.1 D S.1.7. Minimum Measurement 224

OWM Executive Summary for MDM-22.1 – S.1.7. Minimum Measurement..... 225

OTH – Other Items231

OTH-16.1 D Electric Watthour Meters Code under Development 231

OWM Executive Summary for OTH-16.1 – Electric Watthour Meters Code Under Development.. 231

Block 1 Items (B1) Minimum Draft Size When Using a Field Standard Meter237

OWM Executive Summary for Block 1 Items (B1) – Minimum Draft Size When Using a Field Standard Meter 238

B1: LMD-23.1 N.3.5. Wholesale Devices..... 241

B1: VTM-23.1 N.3. Test Drafts..... 241

B1: MLK-23.1 N.3. Test Drafts..... 241

Item Block 2 (B2) Define True Value for Use in Error Calculations244

B2: SCL-20.3 A S.5.4. Relationship of Minimum Load Cell Verification Interval to the Scale Division 246

B2: SCL-20.4 A Table 3. Parameters of Accuracy Classes. 247

B2: SCL-20.5 A Table S.6.3.a. Marking Requirements, Note 3..... 248

B2: SCL-20.6 A T.N.1.2. Accuracy Classes and T.N.1.3. Scale Division..... 249

B2: SCL-20.7 A Table 6. Maintenance Tolerances 249

Item Block 3 (B3) Tolerances for Distance Testing in Taximeters and Transportation Network Systems255

OWM Executive Summary for Item Block 3 (B3) – Tolerances for Distance Testing in Taximeters and Transportation Network Systems TXI-20.1 T. Tolerances and TNS-20.1 T. Tolerances..... 256

Item B3 – TXI-20.1 T. Tolerances and TNS-20.1 T. Tolerances..... 256

B3: TXI-20.1 D T. Tolerances..... 257

B3: TNS-20.1 D T. Tolerances..... 257

Item Block 4 (B4) Electronically Captured Tickets or Receipts260

OWM Executive Summary for Item Block 4 (B4) – Electronically Captured Tickets or Receipts... 261

B4: GEN-21.2 D G-S.5.6. Recorded Representations. 262

B4: LMD-21.2 D S.1.6.5. Money Value Computations., UR.3. Use of a Device. 262

B4: VTM-21.1 D S.1.1. Primary Elements., UR.2. User Requirements..... 265

B4: LPG-21.1 D S.1.1. Primary Elements., UR.2. User Requirements..... 266

B4: CLM-21.1 D S.1.4.1. ~~Printed Ticket~~Recorded Representation., UR.2.6.3. ~~Printed Ticket~~Recorded Representation..... 268

B4: MLK-21.1 D S.1.4.2. ~~Printed Ticket~~ Recorded Representation., UR.2.6.3. ~~Printed Ticket~~Recorded Representation..... 269

B4: MFM-21.2 D S.6. ~~Printer~~Recorded Representations., UR.2.6. ~~Ticket Printer, Customer Ticket,~~ Recorded Representation., UR.3.4. ~~Printed Ticket.~~ Recorded Representation. 269

B4: CDL-21.1 D S.1.4.1. Printed Ticket Recorded Representations., UR.2.4.2. Tickets or Invoices . Recorded Representation.	270
B4: HGM-21.1 D S.2.6. Recorded Representations, Point of Sale Systems., S.6. Printer. Recording Element., UR.3.2. Vehicle-mounted Measuring Systems Ticket Printer Recording Element., UR.3.3. Printed Ticket. Recorded Representation.	270
B4: OTH-21.2 D Appendix D – Definitions.: recorded representations, recording element.	271
Block 5 Items (B5) Test Drafts.....	277
OWM Executive Summary for Block 5 Items (B5) – Test Drafts	278
B5: LMD-23.2 N.3.5. Wholesale Devices.....	279
B5: VTM-23.2 N.3. Test Drafts.....	279
Item Block 6 (B6) Commercial and Law Enforcement, Axle and Axle Group Weights...281	
B6: SCL-22.1 Recorded Representation of Axle or Axle Group Weights.....	284
B6: SCL-22.3 D UR.3.3. Single-Draft Vehicle Weighing., and UR.3.4. Axle and Axle Group Weight Values.	285
Item Block 7 (B7) Tolerances on Tests Using Transfer Standards.....297	
OWM Executive Summary for Item Block 7 (B7) – Tolerances on Tests Using Transfer Standards	298
B7: CLM-22.1 D T.3. On Tests Using Type 2 Transfer Standards.	299
B7: CDL-22.1 D T.3. On Tests Using Type 2 Transfer Standards.	299
B7: HGM-22.1 D T.4. Tolerance Application on Tests Using Type 2 Transfer Standard Test Method.	299
Item Block 8 (B8) G-T.5. Tolerances on Tests When Transfer Standards are Used., Appendix A, Section 3.2. Tolerances for Standards., and Appendix D – Definitions: standards, field., transfer standard. and standard, transfer. Appendix A: Fundamental Considerations, 3. Testing Apparatus	302
B8: GEN-19.1 D G-T.5. Tolerances on Tests When Transfer Standards are Used., Appendix A, Section 3.2. Tolerances for Standards., and Appendix D – Definitions: standards, field., transfer standard . and standard, transfer.	302
B8: OTH-22.1 D Appendix A: Fundamental Considerations, 3. Testing Apparatus.....	302
OWM Executive Summary for Item Block 8 (B8) – G-T.5. Tolerances on Tests When Transfer Standards Are Used, Appendix A, Section 3.2. Tolerances for Standards., and Appendix D – Definitions: Standards, Field., and Standard, Transfer. Appendix A: Fundamental Considerations, 3. Testing Apparatus.....	304

Table 1.
Glossary of Acronyms and Terms

Acronym	Term	Acronym	Term
ABWS	Automatic Bulk Weighing System	NEWMA	Northeastern Weights and Measures Association
AAR	Association of American Railroads	NIST	National Institute of Standards and Technology
API	American Petroleum Institute	NTEP	National Type Evaluation Program
CNG	Compressed Natural Gas	OIML	International Organization of Legal Metrology
CWMA	Central Weights and Measures Association	OWM	Office of Weights and Measures
EPO	Examination Procedure Outline	RMFD	Retail Motor Fuel Dispenser
FHWA	Federal Highway Administration	S&T	Specifications and Tolerances
GMM	Grain Moisture Meter	SD	Secure Digital
GPS	Global Positioning System	SI	International System of Units
HB	Handbook	SMA	Scale Manufacturers Association
LMD	Liquid Measuring Devices	SWMA	Southern Weights and Measures Association
LNG	Liquefied Natural Gas	TC	Technical Committee
LPG	Liquefied Petroleum Gas	USNWG	U.S. National Work Group
MMA	Meter Manufacturers Association	VTM	Vehicle Tank Meter
MDMD	Multiple Dimension Measuring Device	WIM	Weigh-in-Motion
NCWM	National Conference on Weights and Measures	WWMA	Western Weights and Measures Association

Table 2. Reporting Structure
Source: Name and affiliation of submitter.
Submitter's Purpose and Justification: The submitter's concise statement as to the intent or purpose of this proposal. The justification describes the national importance, background on the issue, and may contain references to supporting data or documents. The justification may be summarized by OWM.
OWM Executive Summary: High level points that summarize the Technical Aspects of the item and recommendations pertaining to the Item Under Consideration.
Table 3. Summary of Recommendations
Item Under Consideration – The latest language that the Committee has moved forward as the Item membership is considering. OWM has applied the appropriate formatting according to NIST Handbooks.
NIST OWM Detailed Technical Analysis – A detailed analysis with background information and recommendations from the Office of Weights and Measures (OWM).
Summary of Discussions and Actions – An OWM summary of details and discussion on this Item. This includes discussion and decisions of the Standing Committee. This may also include information from sectors, trade associations, task groups, and subcommittees.
Regional Association Reporting - Taken directly from the Regional Association Meeting finalized report. <ul style="list-style-type: none"> • Each region will be identified separately. • The meetings within each region will be in chronological order.

Details of All Items
(In order by Reference Key)

GEN – General Code

GEN-23.1 G-N.3. Test Methods

Source: Seraphin Test Measure Company

Submitter’s Purpose and Justification:

There are several proposals on the S&T agenda with the objective to recognize meters for use as field standards or as transfer standards. This proposal offers an option to add a paragraph to the General Code to state that other field standards and transfer standards may be approved by the State weights and measures Director for use to test commercial devices, rather than adding paragraphs to each specific code for this purpose. Several device codes already contain references regarding transfer standards used to test commercial measurement devices (e.g., Cryogenic Liquid-Measuring Devices Code, Carbon Dioxide Liquid-Measuring Devices Code and Hydrogen Gas-Measuring Devices Code). Rather than revising a specific code in Handbook 44 every time a new field or transfer standard is proposed or developed, it is better to have an overall statement in the General Code that recognizes the use of other field and transfer standards that meet the requirements for use as field or transfer standards. The joint OWM/Seraphin proposal (GEN-19.1 and OTH-22.1) provides definitions and criteria to be included in Handbook 44 and in the Fundamental Considerations in Appendix A. It also prescribes the tolerances to be applied when using Type 2 transfer standards. For those who believe a specific statement in Handbook 44 is needed to recognize additional field and transfer standards, the proposed addition of G-N.3. will provide the reference they want without the need to change individual codes on a regular basis to recognize each particular field or transfer standard.

Some regulators may argue that if Handbook 44 does not specifically recognize a specific type of field or transfer standard, then the use of the field or transfer standard is not allowed. However, this approach would mean that every type of field or transfer standard must be specifically recognized in an HB44 code and then the Handbook must be changed every time a new standard is proposed to be recognized. The Fundamental Considerations already recognize the authority of the Director to recognize new standards and transfer standards for use to test commercial devices. Footnote 2 to Section 3.1. includes the statement, “This section shall not preclude the use of additional field standards and/or equipment, as approved by the Director, for uniform evaluation of device performance.”

Others may argue that this paragraph in the General Code is not needed, since (1) the definitions of field standard and transfer standard and (2) the Fundamental Considerations already provide for the recognition and use of other field standards and transfer standards.

The submitter requests that this be a retroactive section and request a Voting status for this item.

OWM Executive Summary for GEN-23.1 – G-N.3. Test Methods	
<p>OWM Recommendation: We recognize that GEN-23.1 could be used as a roadmap to what is being proposed in Block 8 to support those States needing a specific requirement in the handbook that address the use of Standards within a Jurisdiction. NIST OWM supports this as a Voting item along with the changes where it ensures continuity in terms, as described in the detailed technical analysis section.</p>	
<ul style="list-style-type: none"> • Some States have argued the need for specific requirements in NIST HB44 for specific standards that can be used for testing commercial devices and this new proposal would address that concern. • Item GEN-23-1 provides requirements in NIST HB 44 General Code for all standards to meet the guidance as specified in the fundamental considerations thereby eliminating the need for specific guidance for each type of standard used to test commercial devices. • Block 8 is a proposal to clarify the fundamental considerations concerning all standards use to test commercial devices. • With both GEN-23.1 and the Block 8 items, weights and measures Jurisdictions will have the necessary tools to determine the appropriate Standards for use when testing commercial devices and these proposed items eliminate the need for specific changes to NIST HB 44 Test Draft Sections as proposed in S&T Item LPG-15.1, MFM-15.1, and Block 1, and the technical problems associated with these proposed changes to NIST HB 44. See NIST OWM comments in this analysis concerning items LPG-15.1, MFM-15.1 and Block 1. 	

Table 3. Summary of Recommendations							
GEN-23.1 – G-N.3. Test Methods							
	V	D	W	A	I	Notes*	Comments
Submitter	✓						
OWM	✓						Supports with suggested changes as noted in our technical analysis
WWMA		✓					
SWMA		✓					
NEWMA	✓						
CWMA	✓						
NCWM							
	Letters of Support			Letters of Opposition		Notes	
Industry							
Manufacturers							
Retailers and Consumers							
Regulators							

Table 3. Summary of Recommendations							
GEN-23.1 – G-N.3. Test Methods							
	V	D	W	A	I	Notes*	Comments
<p>*Notes Key:</p> <ul style="list-style-type: none"> 1 – Submitted modified language 2 – Item not discussed 3 – No meeting held 4 – Not submitted on agenda 5 – No recommendation or not considered 							

Item Under Consideration:

Amend Handbook 44, General Code, as follows:

G-N.3. Test Methods. – Permissible test methods for verifying compliance of weighing and measuring systems with the provisions of the General Code and Specific Codes include, but are not limited to, test methods and apparatus that have been approved by the State Director of weights and measures as outlined in Appendix A - Fundamental Considerations, Section 3. Testing Apparatus.

NIST OWM Detailed Technical Analysis:

S&T Agenda item LPG-15.1 and MFM-15.1 are proposed changes to the test draft paragraphs in NIST HB 44, LPG code and MFM code with the purpose statement to accept meters for use as standards. Many comments were heard expressing technical concerns with the proposed changes and comments that acceptance of a standard used to test commercial devices within a jurisdiction is the responsibility Director within a weights and measures jurisdiction, which is specified in HB 44 Fundamental Considerations. The Director’s responsibilities are further clarified in S&T Agenda Item Block 8. As was pointed out by the submitter of this item, some regulators may argue that if Handbook 44 does not specifically recognize a specific type of field or transfer standard, then the use of the field or transfer standard is not allowed. However, this approach would mean that every type of field or transfer standard must be specifically recognized in a HB 44 code and then the Handbook must be changed every time a new standard is to be recognized.

This proposed paragraph is a change to the General Code that places a requirement in the HB 44 to meet the need of those regulators that need a specific requirement in the HB 44 and further supports what is in HB 44 Fundamental Considerations. This proposal also eliminates the need to place a paragraph in each section of HB 44 that addresses specific standards for use in testing commercial and law enforcement devices. As such, S&T Agenda items LPG-15.1, MFM-15.1, and Item Block 1 may be better addressed by this proposal and its companion proposal Block 8. NIST is also in support of the changes to the Item Under Consideration that were proposed by Mr. Bob Murnane at the CWMA meeting which replaces “State Director” with “Director” and also removes “of weights and measures” to match other language in the NIST HBs and is a more general title.

Summary of Discussions and Actions:

GEN-23.1 addresses the concern some states may have and/or have argued the need for specific requirements in NIST HB44 for standards that can be used for testing commercial devices. This proposed

General Code requirement along with item block 8 provides the requirements for use of various test standards to test commercial devices. LPG-15.1, MFM-15.1 and Block 1 are all proposed changes to Test Draft section in the handbook with a purpose statement “to allow field standard meters to be used to test and place into service dispensers and delivery system flow meters”. States already have the authority to select a test standard for use and changes to the test draft section of the handbook would not help but add to confusion as to which test draft applies. Also, one of the proposals prohibits a full test of the meter because the change prohibits testing at the minimum test draft. As noted in the NIST OWM technical analysis to Items LPG-15.1, MFM-15.1 and Block 1 the purpose for these items is more appropriately addressed in GEN-23.1 and Block 8.

At the CWMA 2022 Interim Meeting there were also suggested changes to the Item Under Consideration and these are addressed below:

- The proposed changes from the Central Weights and Measures Association to add as follows “... **of commercial weighing and measuring systems..**” may limit the scope of the field reference standard since NIST HB 44 does include other devices such as law enforcement devices. The CWMA also suggested striking the following “...~~State Directors for Weights and Measures...~~” and we concur with this change and note that Handbook 130 Uniform Weights and Measures Law, Section 1, Definitions 1.4 gives a State the latitude to define the position within an agency.
- As such, NIST OWM suggest the following change:

G-N.3. Test Methods. – Permissible test methods for verifying compliance of weighing and measuring systems with the provisions of the General Code and specific codes include, but are not limited to, test methods and apparatus that have been approved by the State Director of weights and measures as outlined in Appendix A - Fundamental Considerations, Section 3. Testing Apparatus.

Regional Association Reporting:

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received: Mr. Robert Murnane (Seraphin Test Measure Company) provided the reason for this addition and stated that rather than adding paragraphs for each code regarding use of testing equipment (it resides in Appendix A; puts it out there for everyone) putting it in the general code will keep us from having to go back to it. He recommended this as a Voting item.

Mr. Michael Keilty (Endress+Hauser) opposed this item. He noted that Mr. Murnane also submitted the item under Block 8 and stated that everything in this proposal is repeated in Block 8 by the fundamental considerations; it is redundant. Mr. Keilty recommended the item be withdrawn.

During open hearings there was testimony heard about redundancy between this item and Block 8.

The WWMA S&T Committee recommended that this item be assigned a Developing status with the recommendation that the submitters of GEN-23.1 and Block 8 make one cohesive item or develop them in tandem and reduce redundancies.

Southern Weights and Measures Association

The following comments were received during the 2022 SWMA Annual Meeting: Dr. Matt Curran (Florida) commented that he was not clear on who the submitter of this item is. He cautioned that this item would allow the use of a device not in the handbook and would lay the burden of responsibility for the use of that device solely on the Director. He also stated concern that this would move us away from uniformity.

Mr. Robert Murnane (Seraphin Test Measures), the submitter of this item, stated that the Handbook already gives the Director the authority to use any device, and that this would make it easier to adopt new technologies as they are developed. He recommended moving this forward as a Voting item.

Mr. Tim Chesser (Arkansas) echoed Mr. Curran's concerns. He also stated that he liked the item, and that it would give us some teeth when making accommodations for alternate test methods.

Mr. Keilty (Endress + Hauser) stated that we discuss new technology and how to deal with it in every meeting. He added that lines 12-15 were redundant to S&T Block 8 page 310, lines 33-46. He also stated that this issue is ultimately addressed by the Fundamental Considerations and recommended that the item be withdrawn.

Mr. Hal Prince (Florida) stated that he didn't see a need for this proposal. Mr. Ken Ramsburg (Maryland) echoed Mr. Prince.

The SWMA S&T Committee believes that the need for this item is ambiguous, and that it would be redundant to Block 8 if those items are added to the handbook as well.

The SWMA S&T Committee recommends that this item move forward as a Developing Item.

Northeastern Weights and Measures Association

At the 2022 Interim Meeting, Mr. Bob Murnane (Seraphin Test Measure) commented that the reason for this proposal is to put a reference in the General Code to Section 3 of the Fundamental Considerations. This would make it clear that directors have authority to use master meters and would eliminate the need to change all codes. Mr. Michael Keilty (Endress Hauser) commented that he believes this item is redundant in conjunction with the other blocked items authored by the submitter and recommends the item be withdrawn. Ms. Diane Lee (NIST OWM) commented that this item clarifies in General Code that the choice of master meter rests on individual states. NIST believes the item has merit. A full analysis has not been developed but will provide for Interim. Mr. Bob Murnane (Seraphin Test Measure) responded to Mr. Keilty's comments regarding redundancy and reiterated that this item would make it clear that directors have authority to use master meters and would eliminate the need to change all codes. Mr. Lou Sakin (Holliston, Massachusetts) recommended this item have a Voting status. Mr. Jim Willis (New York) indicated that this item will have a Voting status.

After hearing comments from the floor, the Committee agreed that the item has merit. The Committee agreed with the commenters that this item will give clarity as to the use of master meters and recommends a Voting status.

Central Weights and Measures Association

Mr. Bob Murnane (Seraphin): add "commercial" to line 12 between the words "of" and "weighing".

The CWMA S&T Committee believes this item is fully developed and recommended Voting status with the following changes:

G-N.3. Test Methods. – Permissible test methods for verifying compliance of commercial weighing and measuring systems with the provisions of the General Code and Specific Codes include, but are not limited to, test methods and apparatus that have been approved by the State Director of weights and measures as outlined in Appendix A - Fundamental Considerations, Section 3. Testing Apparatus.

SCL – SCALES

SCL-22.2 A UR.1. Selection Requirements, UR.1.X. Cannabis

Source: NCWM Cannabis Task Group

Submitter’s Purpose and Justification:

Establish uniform scale suitability requirements among the states for sales of cannabis.

As states legalize sales of cannabis in its various forms, the need has arisen for uniform standards for scale suitability. Uniform requirements from one state to the next, will strengthen each jurisdiction’s ability to effectively regulate the industry in a fair and equitable manner. Uniform standards also provide industry with expectations regardless of the jurisdiction, reducing potential conflict or confusion.

Some states may already have scale suitability requirements differing for those proposed here. The task group is hopeful that differences can be resolved so that the standards are the same in every jurisdiction.

The proposed suitability requirements are based on existing standards as set forth by the California Division of Standards, Division of Measurement Standards.

The submitter requested that this item be a Developing Item.

OWM Executive Summary for SCL-22.2 – UR.1. Selection Requirements, <u>UR.1.X. Cannabis</u>
<p>¹OWM Recommendation:</p> <p>Additional consideration and development of this item by the Cannabis Task Group and/or its Scales Focus Subgroup is needed. For this reason, OWM recommends this item remain assigned to the Task Group</p> <p><i>Note: The original proposal associated with this item has been replaced by the Scales Subgroup of the NCWM Cannabis Task Group (CTG) with the proposal shown in the Item Under Consideration. It is important to note, however, that when the revised proposal was submitted to the NCWM, just prior to the November 15, 2022 deadline, proposed new paragraph UR.3.1.2. Required Minimum Loads for Cannabis products was unintentionally omitted. The CTG plans to request the paragraph be included as part of the proposal during the 2023 NCWM Interim Meeting.</i></p> <p><i>No longer are maximum scale division values proposed for the weighing of cannabis products as was the case with the original proposal. Consequently, no longer do the comments and recommendations that OWM developed previously for this item apply.</i></p>

OWM Executive Summary for SCL-22.2 – UR.1. Selection Requirements, UR.1.X. Cannabis

The following represents OWM’s executive summary for the current proposal and provides justification for the “Assigned” status recommendation:

- Although OWM doesn’t believe it was the intent of the CTG Scales Focus Group, adding the terminology, “and weighing of all Cannabis products,” to each of the three accuracy class classifications in Table 7a (i.e., Class I, Class II, and Class III) leads one to believe that a scale of any one of those three accuracy classes would be permissible for use to weigh all cannabis products.
- It is OWM’s understanding that some participants of the CTG believe NIST HB 44 requirements cannot be applied to scales used commercially to weigh cannabis products unless Table 7a explicitly indicates such use. We do not share this opinion and note that the description in Table 7a for Class III scales specifies “All commercial weighing not otherwise specified...,” which would include scales used to weigh cannabis products. That is, the description of “Weighing Application or Scale Type” in HB 44 Scales Code Table 7a for Class III scales adequately captures scales used to weigh cannabis products.
- There are several commercial uses of scales excluded from Table 7a in which jurisdictions continually regulate those scales without concern. For example, scales used in a grocery store to weigh bakery items, meat products, delicatessen products, and produce are not explicitly identified in the existing table; yet these scales are regularly regulated by weights and measures officials throughout the US. The different uses of these scales are encompassed in the terminology, “All commercial weighing not otherwise specified...” as would be the case for scales used to weigh cannabis products.
- We take no position, however, on adding an additional example device type to HB 44 Scales Code Table 7a if others believe it is essential, since the title of the table specifies that the different device types listed are only “typical.” Yet, because the “Note” included at the bottom of Table 7a specifies a scale with a higher accuracy class than that specified as “typical” may be used, it is unnecessary to add the additional device type to more than one accuracy class classification in the table. Adding it to the Class III description alone would suffice given that Class I and Class II scales are of higher accuracy class. Additionally, we believe adding the additional device type description to the Accuracy Class I and Class II classifications would cause unnecessary confusion due to the Note explaining that a higher accuracy class may be used.
- OWM currently participates on the Scales Focus Subgroup of the NCWM Cannabis Task group. Most recently, several members of the subgroup have voiced support for the development of a scale suitability guidance document that could not only be used by the Cannabis industry, but other industries as well. We too would be in favor of developing such a document and believe it would be helpful in selecting a suitable scale.

¹ In contrast to hemp, marijuana remains a Schedule I substance under the Controlled Substances Act. NIST does not have a policy role related to the production, sale, distribution, or use of cannabis (including hemp and marijuana). NIST participates in the National Conference of Weights and Measures (NCWM) as part of NIST’s statutory mission to promote uniformity in state laws, regulations, and testing procedures.

Table 3. Summary of Recommendations							
SCL-22.2 – UR.1. Selection Requirements, UR.1.X. Cannabis							
	V	D	W	A	I	Notes*	Comments
Submitter							
OWM			✓				Refer to OWM’s technical analyses for reasons.
WWMA				✓			
SWMA				✓			
NEWMA	✓					1	
CWMA				✓			
NCWM							
	Letters of Support		Letters of Opposition		Notes		
Industry							
Manufacturers			✓		A&D Engineering (01-04-22)		
SMA					Support continued development. Refer to SMA’s position statement from its Fall 2022 Meeting.		
Retailers and Consumers							
Regulators	✓				Florida Dept Agriculture letter of support. (12-07-21)		
*Notes Key: 1 – Submitted modified language 2 – Item not discussed 3 – No meeting held 4 – Not submitted on agenda 5 – No recommendation or not considered							

Item Under Consideration:

Amend NIST Handbook 44, Scales Code as follows:

UR.1.1. General.

- (a) For devices marked with a class designation, the typical class or type of device for particular weighing applications is shown in Table 7a. Typical Class or Type of Device for Weighing Applications.
- (b) For devices not marked with a class designation, Table 7b. Applicable to Devices not Marked with a Class Designation applies.

Table 7a.	
Typical Class or Type of Device for Weighing Applications	
Class	Weighing Application or Scale Type
I	Precision laboratory weighing <u>and weighing of all <i>Cannabis</i> products</u>
II	Laboratory weighing, precious metals and gem weighing, grain test scales, <u>and weighing of all <i>Cannabis</i> products</u>
III	All commercial weighing not otherwise specified, grain test scales, retail precious metals and semi-precious gem weighing, grain-hopper scales, animal scales, postal scales, vehicle on-board weighing systems with a capacity less than or equal to 30 000 lb, and scales used to determine laundry charges, <u>and weighing of all <i>Cannabis</i> products</u>
III L	Vehicle scales (including weigh-in-motion vehicle scales), vehicle on-board weighing systems with a capacity greater than 30 000 lb, axle-load scales, livestock scales, railway track scales, crane scales, and hopper (other than grain hopper) scales
III	Wheel-load weighers and portable axle-load weighers used for highway weight enforcement
Notes: A scale with a higher accuracy class than that specified as “typical” may be used. <u>The use of italicized text in the references to “<i>Cannabis</i>” in this table is only to denote its proper taxonomic term; the italicized font does not designate a “nonretroactive” status as is the convention used throughout NIST Handbook 44.</u>	

(Amended 1985, 1986, 1987, 1988, 1992, 1995, 2012, and 2021)

UR.3.1.2 Required Minimum Loads for Cannabis products. – The recommended minimum loads specified in Table 8 shall be considered required minimum loads for scales used to weigh Cannabis and Cannabis-containing products.
[Nonretroactive as of January 1, 20XX]

NIST OWM Detailed Technical Analysis:

No additional technical analysis is being provided nor is needed beyond the recommendations made in the executive summary portion of this report.

Summary of Discussions and Actions:

During the 2022 NCWM Interim meeting, the Committee received somewhat a wide range of comments during open hearings. Most who commented supported further development of the item, although there were also several questions raised concerning the need for the proposed changes.

Mr. Doug Musick (Kansas) acknowledged that he agreed with the concept of the proposal while noting too that the NCWM had failed to adopt strong standards in that NISI Handbook 44 Scales Code Table 8 specifies “recommended” minimum loads, making them difficult to enforce. He also noted that HB 44 already addresses scale suitability, and that any proposal should address more than just a single commodity; but rather, all products of high cost.

Mr. Evan Foisy (A&D Engineering) read the position statement provided by A&D Engineering to the Committee in advance of the 2022 NCWM Interim Meeting as follows:

A&D opposes this item completely and recommends that it be withdrawn. The addition of such specific user requirements for a commodity is unprecedented for HB 44. We fail to see the rationale for including readability requirements for Cannabis when such requirements have never been required for gold or other precious metals with a higher dollar per gram value.

If the Committee decides that such specifications are warranted, A&D proposes that the requirements be changed to 0.01 g for net weightings up to 100 g capacity. The technology exists and is already in use to not limit the readability to 0.1 g for capacities from 10 g up to 100 g. Having different accuracy requirements for Cannabis consumers who purchase less than 10 g vs. those who purchase more than 10 g is not promoting fairness and equity in the market. The maximum that any state allows for a single user purchase is 2.5 oz (approximately 71 g). By offering 100 g x 0.01 g, the entire range of consumer purchases will be covered equally and consistently.

Example: Deli scales allow the same increment size whether you're getting 1 slice or 10. Cannabis should be no different.

The SMA supported continue development of the item with the recommendation that NIST Handbook 44 Scales Code Table 8 titled "Recommended Minimum Load" be considered in its further development. NIST OWM provided the Committee a high-level summary of its analysis of the item, many of the points of which questioned not only the need for the proposed change, but also the effect the change (if adopted) would have for setting a precedent for producers of other commodities to use in support of making similar changes to HB 44 intended to address products they produce. OWM, in its comments to the Committee, emphasized that HB 44 already provides the necessary tools (in the way of General Code and Scales Code requirements) for officials to be able to enforce scale suitability. It also provides officials the needed discretion to decide (at time of inspection), based on the many important factors needing to be considered, whether or not a scale is or is not suitable for its given application. OWM recommended, as an alternative to the proposal, the development of a scale suitability guide, which should include all important factors (and not just scale division value) that need to be considered when determining scale suitability.

Several who commented before the Committee also questioned use of the term "scale division" in the proposal and whether any maximum increments proposed should, instead, be based on "scale verification division."

In considering the comments received during open hearings, the Committee agreed to maintain the Assigned status of the item.

The NIST OWM Technical Advisors assigned to the S&T Committee opted to participate virtually in the 2022 NCWM Annual Meeting due to COVID-19. During S&T open hearings, there was an audio problem with the virtual platform being used by the NCWM that prevented those participating virtually to hear much of the open hearing testimony. With regard to this particular item, no testimony could be heard by those attending virtually. A member of the national S&T Committee, who had attended the 2022 NCWM Annual Meeting in person reported that the Committee was given an update from Mr. Charles Rutherford (NCWM Cannabis Task Group Co-Chair). In his update, Mr. Rutherford requested that this item remain Assigned to the Task Group for further discussion. The Scales Focus Group will be regrouping, with Mr. Lou Sakin (Towns of Holliston, Hopkinton, Northbridge, Massachusetts) as the Chair, for further development of the item. The Committee agreed that this item will retain an Assigned status.

Regional Association Reporting:

Western Weights and Measures Association

During the 2021 Annual Meeting Open Hearings the following comments were heard:

Mr. Josh Nelson (Ex-Officio NCWM S&T Committee) put forward to address some issues for cannabis, recommend developing - still needs work and continue to work forward.

Mr. Matt Douglas (California - DMS), California supports further development, add non retroactive date - subsection A states up to capacity... lists suitability requirements based on California, however, this info is not a standard.

Mr. Eric Golden (Cardinal Scales) in Section A, B, and C be better to say 0.1 g for net weightings up to 10 grams, then B 10 to 100 grams, then C say over 100, etc.

Mr. Kurt Floren (Los Angeles County, California) remarked that Mr. Golden stated perfectly what is lacking. There has to be ranges put in as to where the graduations are appropriate.

Ms. Erin Sullivan (Colorado Department of Agriculture) asked if this pertain to cannabis in any form or concentration?

Mr. Nelson remarked this is what is going into NIST HB44 - each jurisdiction has to define their own. For Oregon, medical is much different than retail. Retail has to abide by this and medical does not. Verbiage in A, B, and C does need additions.

Ms. Sullivan is this grows vs. dispensaries? Different products in processing facilities are weighed with many containers on the scales. Do states determine the regulation?

Mr. Nelson asked if it is up to the states to determine how to apply tares and increments in which product is weighed.

Mr. Kurt Floren (Los Angeles County, California): cannabis products: later we'll see proposed def. of cannabis and cannabis products, are we anticipating the adoption of the proposed language?

Mr. Nelson remarked it is not limited to flowers or bud. Mentions dabs. Is there a packaging requirement for the label? Oregon does. There must be a legal for trade scale that can prove they are meeting net contents. They must ensure that their process is being executed correctly. He thinks this is not limited to flower/bud.

Mr. t Floren this raises the point that further consideration needs to be put into terms. Brownies, cannabis infused pizza... and other items sold by weight. Are we setting the terms for pure cannabis product or are the scales being used for any cannabis containing product?

Mr. Nelson welcomes written input for this topic from anyone. Mr. Don Onwiler was a big proponent in this; Mr. Nelson will continue to develop this.

Mr. Golden asked for clarification on Mr. Nelson: geared towards net sales, packaging for the customer. Is this part of the track and trace program for growers or just for retail?

Mr. Nelson remarked this needs to be expanded upon, in Oregon. Even the growers have to do track and trace. Any scale weight that is used for the cannabis tracking system needs to be Weights and Measures compliant. Maybe has to address even a class III scale. They will look more into it.

Mr. Joe Moreo (Ag. Com. Sealer) stated over time we are going to need one level for concentrates, one for food, one for flower, one size fits all will not work.

Mr. Nelson agrees that one size does not fit all. This will start to give limitations as to what a particular weight will be. Not trying to pigeonhole any device into one category, just trying to figure out what works, that's the intent.

The WWMA S&T Committee recommended the item be assigned a Developmental status so that the submitter could continue to work on this as they commented during open hearings.

During the WWMA's 2022 Annual Meeting the following comments were received:

Mr. Charles Rutherford (NCWM Cannabis Task Group): Everything in this book isn't updated. They have added "and cannabis" to Table 7. cannabis talks about cannabis and hemp. They expect to finish soon. What is in the book is old and doesn't apply any more.

During open hearings, due to timing constraints, the Committee did not take comments on Assigned Items. The Committee did allow the source to provide updates on these items. An update from the NCWM Cannabis Task Group Co-Chair Charlie Rutherford was provided. The WWMA S&T Committee recommends that this item remain Assigned.

Southern Weights and Measures Association

During the 2021 Annual Meeting Open Hearing, Mr. Russ Vires (SMA) stated that they have no position on this item at this time.

Mr. Matt Curran (Florida) stated that he supports this as a Voting item. He also provided comments in support of this item from Mr. Eric Golden (Cardinal Scale). Cardinal offered some changes as well. The suggested changes are as follows:

UR.1.X. Cannabis. – The scale division for scales weighing Cannabis shall not exceed:

- (a) 0.01 g for net weighments ~~up to capacity~~ up to 10g,
 - (b) 0.1 g for net weighments greater than 10g, up to 100g, ~~capacity, and~~
 - (c) 1 g for net weighments greater than 100g, up to capacity.
- (Added 20XX)

Mr. Charlie Rutherford (Cannabis Committee) stated that he supports this item moving forward as a Voting item with the changes suggested by Cardinal Scale and Dr. Curran.

This Committee recommended that this item be moved forward as a Voting item if the changes suggested above are made.

During SWMA's fall 2022 Annual Meeting, Mr. Rutherford stated that Table 1A has been updated in the item. The SWMA S&T Committee recommended this item remain as an Assigned Item.

Northeastern Weights and Measures Association

During the 2021 Interim Meeting Open Hearing the following comments were heard.

Mr. Golden) made suggestions to change the language in this item to the following:

UR.1.X *Cannabis*

- (a) 0.01g for net weighments up to 10 g
- (b) 0.1g for net weighments greater that 10g , up to 100 g, and
- (c) 1 g for net weighments greater than 100g , up to capacity

Mr. Lou Sakin (Hopkinton/Northbridge, Massachusetts) commented that he agrees with changes above.

Discussions were heard regarding the agreement with table 8 in scale code as this requirement is more restrictive than table 8 parameters.

Mr. Golden commented that national uniformity would be good and many states have informational publications that outline requirements in their state for Cannabis scale requirements.

Mr. Jimmy Cassidy (Massachusetts) recommended Voting status with the changes above.

Mr. Matt Curran (Florida) commented that harmonization with table 8 would be a good idea if possible.

Mr. Sakin questioned if Cannabis should be in *italics*. The Committee suggests making the change to italics for *Cannabis*.

The NEWMA Specifications and Tolerances Committee recommended that this item be given Voting status with suggested edits.

During the 2022 Annual Meeting Open Hearings the following comments were heard:

Mr. James Cassidy (Massachusetts) commented as the Co-Chair of the NCWM Cannabis Task Group. He supported the Assigned status so the Task Group can continue to develop the item from comments received at the 2022 Interim. Mr. Russ Vires (SMA) supported continued development and indicated that a user requirement typically does not pertain to a specific commodity. Mr. Vires suggested the words “retail cannabis” should be added to the “Class II” section of Table 7a and the words “bulk cannabis processing and sales” should be added to the “Class III” section of Table 7a. Mrs. Tina Butcher (NIST OWM) read the following statement: “As a non-regulatory metrology institute, NIST defers to federal agencies with regulatory authority under the Controlled Substances Act (CSA) for the scheduling of drugs or other substances. NIST does not have a policy role related to the production, sale, distribution, or use of cannabis (including hemp and marijuana). While the 2018 Farm Bill removed hemp from the list of controlled substances under Schedule 1 of the CSA, marijuana remains on that list. NIST must respect that distinction even as it exercises its statutory authority to develop and disseminate national weights and measures standards for the production, distribution, and sale of products in the commercial marketplace. NIST remains committed to providing technical assistance to the weights and measures community. OWM has provided key technical points for the community to consider in its deliberations of cannabis-related proposals, and OWM would be happy to provide any necessary clarification. OWM comments are intended

to encourage technically sound application of legal metrology laws, regulations, and practices to the measurement and sale of these products.”

After hearing comments from the floor, the Committee recognized the need for further development of the item and recommended that the item retain an Assigned status. The Committee recommends the NCWM Cannabis Task Group work with the SMA and other stakeholders to further develop this item.

During NEWMA’s fall 2022 Interim Meeting, the following was reported:

The Committee recognized comments received the from Cannabis Task Group from the CTG Scales Focus Group Chair, Mr. Lou Sakin. Mr. Rutherford (NCWM Cannabis TG Co-Chair) commented that the Scales Focus Group is under new leadership and the Chair is Mr. Lou Sakin. Mr. Rutherford pointed out that the Item Under Consideration is not current and current language was sent to the NEWMA. Mr. Rutherford requested a Voting status for this item. Mr. Sakin indicated that the new language was submitted to SWMA and NEWMA. The TG chose to modify tables instead of changing the entire code. He believes that the item is fully developed and ready for a Voting status. Mr. Cassidy requested that this item move forward as Voting with changes as proposed in the submitted documentation.

After hearing comments from the floor, the Committee agreed that the item has merit. The Committee agreed that the item, with recommended changes below, is ready for a Voting status.

Section 2.20 UR.3.1.2 Required Minimum Loads for Cannabis products.

The recommended minimum loads specified in Table 8 shall be considered required minimum loads for scales used to weigh Cannabis and Cannabis-containing products.

[Nonretroactive as of January 1, 20XX]

and

Table 7a. Typical Class or Type of Device for Weighing Applications	
Class	Weighing Application or Scale Type
I	Precision laboratory weighing and weighing of all Cannabis products
II	Laboratory weighing, precious metals and gem weighing, grain test scales, and weighing of all Cannabis products
III	All commercial weighing not otherwise specified, grain test scales, retail precious metals and semi-precious gem weighing, grain-hopper scales, animal scales, postal scales, vehicle on-board weighing systems with a capacity less than or equal to 30 000 lb, and scales used to determine laundry charges, and weighing of all Cannabis products
III L	Vehicle scales (including weigh-in-motion vehicle scales), vehicle on-board weighing systems with a capacity greater than 30 000 lb, axle-load scales, livestock scales, railway track scales, crane scales, and hopper (other than grain hopper) scales
III	Wheel-load weighers and portable axle-load weighers used for highway weight enforcement
<p>Notes: A scale with a higher accuracy class than that specified as “typical” may be used. <u>The use of italicized text in the references to “Cannabis” in this table is only to denote its proper taxonomic term; the italicized font does not designate a “nonretroactive” status as is the convention used throughout NIST Handbook 44.</u></p>	

Table 7a.	
Typical Class or Type of Device for Weighing Applications	
Class	Weighing Application or Scale Type

(Amended 1985, 1986, 1987, 1988, 1992, 1995, 2012, and 2021)

Central Weights and Measures Association

During the 2021 Interim Meeting Open Hearing, the Committee heard comments from the floor. Mr. Loren Minnich (Kansas) stated he’s not sure of the intent and that it needs more developing. Mr. Golden agreed with it “e” or “d”, will send notes to Committee. Mr. Ivan Hankins (Iowa) would support item with Mr. Golden’s language. Mr. Golden continued by recommending the following change to which will add clarity to the listed weight ranges in SCL22.2 (in red):

SCL-22.2 UR.1. Selection Requirements, UR.1.X. Cannabis

UR.1.X. Cannabis. – The scale division verification scale interval, e, for scales weighing Cannabis shall not exceed:

- (a) 0.01g for net weighments ~~up to capacity up to 10g,~~**
 - (b) 0.1g for net weighments greater than 10g, up to 100g, ~~capacity, and~~**
 - (c) 1g for net weighments greater than 100g, up to capacity.**
- (Added 20XX)**

CWMA S&T Committee recommended as Voting Item with the proposed changes from Cardinal Scales.

During the 2022 CWMA Annual Meeting Open Hearings the following comments were heard:

Mr. Doug Musick (Kansas) welcomed the attempt to define suitability; recommended the following:
 SCL-22.2 UR.1. Selection Requirements, UR.1.X. Cannabis

UR.1.X. Cannabis. – A retail Cannabis scale shall not be used to weigh net loads smaller than 100 displayed scale divisions “d”,

- (a) 0.01g for net weighments 10g or less,
- (b) 0.1g for net weighments greater than 10g and up to 100g, and
- (c) 1g for net weighments greater than 100g.

(Added 20XX)

Mr. Russ Vires (SMA) stated the addition of a User Requirement is not the best approach in this situation; User Requirements do not typically apply to a specific commodity. Supported continuing as Developing and the following proposed changes should be considered instead:

- The words “retail cannabis” should be added to the “Class II” section of Table 7a.

- The words “bulk cannabis processing and sales” should be added to the “Class III” section of Table 7a.

Mr. Charlie Stutesman (Kansas) questioned why only metric units are referenced and not also include inch-pound units.

The CWMA S&T Committee recommended this item remain with the NCWM Cannabis Task Group and that the suggested changes are considered.

During the 2022 CWMA Interim Meeting open hearings, the following comments were heard:

Mr. Rutherford (ASTM International) remarked the old version is still listed in today’s agenda. Pushing the suitable scales discussion to a later date. The submitter provided updates to Table 7a. which add Cannabis verbiage to the weighing application column for Classes I, II, and III.

The CWMA S&T Committee recommended this item remain Assigned with the NCWM Cannabis Task Group.

SMA

During the 2021 fall meeting, the SMA supported the continued development of this item.

During the 2022 spring meeting, the SMA supported the continued development of this item.

Rationale: The addition of a User Requirement is not the best approach in this situation; User Requirements do not typically apply to a specific commodity. The following proposed changes should be considered instead:

- The words “retail cannabis” should be added to the “Class II” section of Table 7a.
- The words “bulk cannabis processing and sales” should be added to the “Class III” section of Table 7a.

During the 2022 fall meeting, the SMA supported the continued development of this item.

Rationale: The addition of a User Requirement is not the best approach in this situation; User Requirements do not typically apply to a specific commodity. The following proposed changes should be considered instead:

- The words “retail cannabis” should be added to the “Class II” section of Table 7a.
- The words “bulk cannabis processing and sales” should be added to the “Class III” section of Table 7a.

SCL-23.1 S.1.12. Manual Weight Entries

Source: NTEP Weighing Sector

Submitter’s Purpose and Justification:

Provide Specifications corresponding with User Requirements that limit how manual weight entries are allowed.

The instances in which manual weight entries are allowed are limited by UR.3.9. but there are no corresponding limitations in S.1.12. This addition will allow the evaluation of devices, software, or systems for compliance with these limitations and provide manufacturers specific requirements to comply with when designing a commercial device.

The submitter acknowledges that this is a complicated requirement to incorporate into the design of a device or system and some may argue that it should remain a user requirement.

The submitter requested a Voting status.

OWM Executive Summary for SCL-23.1 – S.1.12. Manual Weight Entries
<p>OWM Recommendation: NIST OWM is of the opinion that the current proposal incorporates user requirements in a specification which should be avoided. Therefore, NIST OWM recommends this item to be Developing.</p> <ul style="list-style-type: none"> • In the proposal, the restrictions laid down in UR.3.9 are implemented as requirements in S.1.12. However, they remain requirements on the application of the device which do not belong in the specifications of the scales code. • Furthermore, the condition “<i>When being used in a direct sale application</i>” is contradicting requirement (c) in the proposal. Generating labels for standard weight packages is in general not a direct sales application. • NIST OWM suggest to refer to UR.3.9 as a condition for specification S.1.12. e.g., “<i>S.1.12. Manual Weight Entries.</i> – <i>A device when being used for direct sale <u>in an application mentioned in UR.3.9</u> shall accept ...</i>”

Table 3. Summary of Recommendations							
SCL-23.1 – S.1.12. Manual Weight Entries							
	V	D	W	A	I	Notes*	Comments
Submitter	✓						
OWM		✓					
WWMA		✓					
SWMA		✓					
NEWMA						5	
CWMA	✓						
NCWM							
	Letters of Support			Letters of Opposition			Notes
Industry							

Table 3. Summary of Recommendations							
SCL-23.1 – S.1.12. Manual Weight Entries							
	V	D	W	A	I	Notes*	Comments
Manufacturers							
Retailers and Consumers							
Regulators							
*Notes Key: 1 – Submitted modified language 2 – Item not discussed 3 – No meeting held 4 – Not submitted on agenda 5 – No recommendation or not considered							

Item Under Consideration:

Amend Handbook 44, Scales Code, as follows:

*S.1.12. Manual Weight Entries. – ~~A device~~ ~~When~~ being used ~~in a~~ ~~for~~ direct sale application and when in a zero-balance condition, a device or a Point-of-Sale System** shall accept an entry of a manual gross or net weight value only when: ~~the scale gross or net* weight indication is at zero.~~*

(a) a point-of-sale system interfaced with a scale is giving credit for a weighed item;

(b) an item is pre-weighed on a legal for trade scale and marked with the correct net weight;

(c) a device or system is generating labels for standard weight packages;

(d) postal scales or weight classifiers are generating manifests for packages to be picked up at a later time; or

(e) livestock and vehicle scale systems generate weight tickets to correct erroneous tickets.

*Recorded **representations for** manual weight entries, except those on labels generated for packages of standard weights, shall identify the weight value as a manual weight entry by one of the following terms: “Manual Weight,” “Manual Wt,” or “MAN WT.” The use of a symbol to identify multiple manual weight entries on a single document is permitted, provided that the symbol is defined on the same page on which the manual weight entries appear and the definition of the symbol is automatically printed by the recording element as part of the document.*

*[Nonretroactive as of January 1, 1993] [*Nonretroactive as of January 1, 2005] **[*Nonretroactive as of January 1, 20XX]***

*(Added 1992) (Amended 2004 **and 20XX**)*

NIST OWM Detailed Technical Analysis:

Item SCL-23-1 proposes that the conditions stated in UR.3.9 are copied to the scales specification section. UR.3.9 states:

Manual entries are permitted in the following applications only when:

- (a) a point-of-sale system interfaced with a scale is giving credit for a weighed item;*
- (b) item is pre-weighed on a legal-for-trade scale and marked with the correct net weight;*
- (c) a device or system is generating labels for standard weight packages;*
- (d) postal scales or weight classifiers are generating manifests for packages to be picked up at a later time; or*
- (e) livestock and vehicle scales generate weight tickets to correct erroneous tickets.*

The justification given by the submitter consists of two elements:

- The ability to evaluate the restrictions on manual weight entry during type evaluation.
- To provide specific requirements to the manufacturer.

In the proposal, the requirements from UR.3.9 are literally copied into S.1.12. However, as these requirements are written they remain requirements on the device application and not the device itself. Therefore, they remain user requirements.

The key here is that the requirements in UR.3.9 should not be implemented in S.1.12 as requirements but as conditions instead. As a matter of fact, one of the restrictions is already mentioned as a condition in S.1.12. The current specification states: “*A device **when being used for direct sale** shall accept an entry of a manual gross or net weight value only when ...*”. This means that the manual weight entry can only exist on devices used for direct sale. Yet, it is considered a condition and not a requirement.

During type evaluation the manufacturer can be asked about its intended application (if this is not already clear by the instruments characteristics). The fact that the conditions for manual weight entry are laid down in the user requirement section instead of the specification sections does not mean they cannot be taken into consideration during type evaluation. Furthermore, the limitation of a manual weight entry function can be mentioned in the NTEP Certificate of Conformance.

Regarding the second part of the justification (provide guidance to the manufacturer), the user requirements in UR.3.9 are part of the scales code of HB44 and therefore already available to the manufacturer. Simply copying the user requirements to the specification section as proposed seems to have little added value.

Regional Association Reporting:

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received:

Mr. Kurt Floren (County of Los Angeles, California) commented the item needs further development and explanation of the application. It was mentioned the item is going in the scales code and will impact specific performance requirements. Mr. Floren commented on the direct sale application and reference the sub sections when making further comments. He noted the direct sale application would not be known until after the device is installed. Questions arose on subsection “A”, which speaks to the interface, the purpose remains unclear. Subsection “C” references the pre-packing and labeling of standard packages which does

not meet a direct sale application. Subsections “B” and “D” are not direct sale applications and require further clarification. Mr. Floren believes the item is not ready for Voting and supports a Developing status.

Mr. Raymond Johnson (Fairbanks Scales, representing the Scale Manufacturers Association) commented the SMA has not met and has not formulated a position on this item. The SMA is scheduled to meet in November 2022.

Mr. Matt Douglas (State of California, Division of Measurement Standards) agreed with Mr. Floren and his previous comments. He further commented the language needs a lot of wordsmithing to address concerns, including addressing the retroactive status which would require an introduction of a third retroactive date with double asterisk. Section S.12 is for direct sales, and it is not clear how the language applies to this method of sale. Mr. Douglas also noted the content should be broken into two sections.

During open hearings the Committee heard testimony that the SMA has not evaluated this proposal and has not taken a position or developed comments on the item. The Committee heard several questions and concerns regarding the direct sale application which conflicts with the subsections, along with the non-retroactive date formatting. The Committee believes these concerns should be addressed for the item to move forward.

The WWMA S&T Committee recommended that this item be assigned a Developing status.

Southern Weights and Measures Association

No comments were received on this item during the 2022 SWMA Annual Meeting.

The SWMA S&T Committee recommended this item move forward as a Developing Item.

Northeastern Weights and Measures Association

No comments were heard from the floor. The Committee does not have a recommendation as to the status of this item.

Central Weights and Measures Association

Mr. Loren Minich (Kansas) remarked it should not change the application, it just makes it easier to understand how it’s applied. A, B, C, D are now user requirements. This communicates with manufacturers so they understand how they should be designed. Changing to S specification so that it applies to manufacturing. It is only allowed in direct sale manual weight entries.

Mr. Greg VanderPlaats (Minnesota) suggested a change, move “when in zero balance condition” to the list so it’s more understood that manual entry is only allowed when at zero balance condition.

The CWMA S&T Committee believes this item is fully developed and recommends Voting status.

SMA

At the 2022 Fall Meeting the SMA supported the item. Rationale: this item provides clarity in the specification when a manual weight entry is permitted.

SCL-23.2 Table S.6.3.a. Marking Requirements, and Table S.6.3.b. Notes for Table S.6.3.a. Marking Requirements

Source: NTEP Weighing Sector

Submitter’s Purpose and Justification:

Add an additional marking requirement for single draft weigh-in-motion vehicle scale to include a vehicle type restriction.

As discussed at the NTEP Weighing Sector Meeting, multiple vehicle types are tested during the NTEP publication 14 test. If a specific vehicle type is failed or not tested, there needs to be a restriction on the vehicle types passed on the certificate. This restriction must also be marked on the device.

The Sector requested that this be a Voting Item in 2023.

OWM Executive Summary for SCL-23.2 – Table S.6.3.a. Marking Requirements, and Table S.6.3.b. Notes for Table S.6.3.a. Marking Requirements
OWM Recommendation: The analysis is based on the revised proposal that was posted on the NCWM website on 12/19/2022. NIST OWM is of the opinion that the item is fully developed. Therefore, NIST OWM recommends making it a Voting item.

Table 3. Summary of Recommendations							
SCL-23.2 – Table S.6.3.a. Marking Requirements, and Table S.6.3.b. Notes for Table S.6.3.a. Marking Requirements							
	V	D	W	A	I	Notes*	Comments
Submitter	✓						
OWM		✓					The regional recommendations are based on the original proposal.
WWMA		✓					
SWMA		✓					
NEWMA						5	
CWMA		✓					
NCWM							
	Letters of Support			Letters of Opposition			Notes
Industry							
Manufacturers							
Retailers and Consumers							
Regulators							

Table 3. Summary of Recommendations							
SCL-23.2 – Table S.6.3.a. Marking Requirements, and Table S.6.3.b. Notes for Table S.6.3.a. Marking Requirements							
	V	D	W	A	I	Notes*	Comments
*Notes Key: 1 – Submitted modified language 2 – Item not discussed 3 – No meeting held 4 – Not submitted on agenda 5 – No recommendation or not considered							

Item Under Consideration:

<u>Table S.6.3.a.</u>					
<u>Marking Requirements</u>					
	<u>Weighing Equipment</u>				
<u>To Be Marked With ↓</u>	<u>Weighing, Load-Receiving, and Indicating Element in Same Housing or Covered on the Same CC1</u>	<u>Indicating Element not Permanently Attached to Weighing and Load-Receiving Element or Covered by a Separate CC</u>	<u>Weighing and Load-Receiving Element Not Permanently Attached to Indicating Element or Covered by a Separate CC</u>	<u>Load Cell with CC (11)</u>	<u>Other Equipment or Device (10)</u>
Minimum and Maximum Speed (25)		<u>X</u>	X		
Maximum Speed Change (26)		<u>X</u>	X		
Vehicle Direction Restriction (27)		<u>X</u>	X		
<u>Vehicle Type Restriction (28)</u>		<u>X</u>			

And

Table S.6.3.b.

Notes for Table S.6.3.a. Marking Requirements

28. Weigh-in-Motion vehicle scales must be marked with a vehicle type restriction, if applicable, which shall be readily apparent when viewing the reading face of the scale indicator.

(Added 20XX)

NIST OWM Detailed Technical Analysis:

This detailed technical analysis is based on the revised proposal that was posted on the NCWM website on 12/19/2022.

This item originated during a discussion at the 2022 Weighing Sector meeting about the suitability of certain single draft weigh-in-motion (DS-WIM) vehicle scales to weigh tanker trucks carrying a liquid product. Some SD-WIM vehicle scales may not be able to weigh these trucks properly due to the dynamic behavior of the fluid in the tank.

In case a scale fails the test with a tanker truck carrying liquid product, or the scale has never been tested with a tanker truck, the device application should be limited to non-liquid carrying vehicles only. Such limitation should be marked on the instrument making the operator aware of the limitation.

Although the proposal originated because of inaccurate weighments of trucks carrying liquids, restrictions may be imposed on any vehicle type that cannot be accurately weighed on a certain installation. Therefore, it is important that the proposed marking requirement can be applied to any type of vehicle. To avoid confusion with the vehicle types defined by FHWA, the proposed requirement does not use the term “Vehicle Type”.

NIST OWM supports the proposed move of the markings for “Minimum and Maximum Speed”, “Maximum Speed Change” and “Vehicle Direction Restriction” to the indicating element. It makes sense that all these markings are grouped together with the proposed marking for vehicle restrictions. And since the markings should be clearly visible to the operator, they should be affixed to the indicating element instead of the weighing and load-receiving element, as proposed by the originator of this item.

Regional Association Reporting (based on the original proposal):

Western Weights and Measures Association

The WWMA S&T Committee recommended this item move forward as a Developing Item.

Southern Weights and Measures Association

No comments were received on this item during the 2022 SWMA Annual Meeting.

The SWMA S&T Committee recommended this item move forward as a Developing Item.

Northeastern Weights and Measures Association

No comments were heard from the floor.

The NEWMA S&T Committee does not have a recommendation as to the status of this item.

Central Weights and Measures Association

Mr. Loren Minich (Kansas) remarked if the installation isn't tested with all vehicle configurations, then the use would be restricted to only the vehicles that were evaluated during type evaluation. This new marking requirement would be visible to the operator. May it also apply to field testing, and not just type evaluation?

Mr. Lenny Goebel (Illinois) questions if the limitation / marking would apply to different axle configurations for different vehicles.

Mr. Doug Musick (Kansas) stated he does not like the word "type". Does it differentiate between liquids and solids in a tanker? He recommends item be Developing.

The CWMA S&T Committee recommended this as a Developing Item. The submitter should consider clarifications related to the comments provided.

SMA

During the 2022 Fall Meeting the SMA supported the item. Rationale: The Weighing Sector has already reviewed and placed this into the test method.

SCL-23.3 Verification Scale Division e: Multiple Sections Including, T.N.1.3., Table 6., T.N.3., T.N.4., T.N.6., T.N.8., T.N.9., T.1., T.2., S.1.1.1., T.N.1.2., Table S.6.3.a., Table S.3.6.b., Appendix D, S.1.2.2., Table 3., S.5.4., UR.3., Table 8.

Source: NCWM Verification Scale Division e Task Group

Submitter's Purpose and Justification:

To update Handbook 44, Section 2.20 Scales and relevant portions of OIML R76, using items from the S&T Block 2 items as a reference point to:

1. Clarify how error is determined in relation to the verification scale division (e) and the scale division (d)
2. Clarify which is the proper reference; the verification scale division (e) or the scale division (d) throughout this section
3. Ensure proper selection of a scale in reference to the verification scale division (e) and the scale division (d)
4. Clarify the relationship between the verification scale division (e) or the scale division (d)

<p>OWM Executive Summary for SCL-23.3 – Verification Scale Division e: Multiple Sections Including, T.N.1.3., Table 6., T.N.3., T.N.4., T.N.6., T.N.8., T.N.9., T.1., T.2., S.1.1.1., T.N.1.2., Table S.6.3.a., Table S.3.6.b., Appendix D, S.1.2.2., Table 3., S.5.4., UR.3., Table 8.</p>
--

<p>OWM Recommendation: This item is new and incorporates the NCWM's Verification Scale Division (e) Task Group's recommendations from its July 21, 2021 into the Committee's 2023 agenda (NCWM Publication 15). Since the changes proposed by this item represent the TG's most recent recommendations,</p>
--

OWM Executive Summary for SCL-23.3 – Verification Scale Division e: Multiple Sections Including, T.N.1.3., Table 6., T.N.3., T.N.4., T.N.6., T.N.8., T.N.9., T.1., T.2., S.1.1.1., T.N.1.2., Table S.6.3.a., Table S.3.6.b., Appendix D, S.1.2.2., Table 3., S.5.4., UR.3., Table 8.

OWM recommends the committee reconcile the changes proposed by this item with those in the Block 2 items and then withdraw Block 2 from its agenda.

- We are pleased that the TG has recommended the Committee assign this item to the TG for further development. OWM looks forward to participating on the TG and sharing its perspective of the proposed changes with its members.

Item Under Consideration:

Amend Handbook 44 Scales Code as follows:

Part 1. Amendment of T.N.1.3. and related sections

T.N.1. Principles.

T.N.1.1. Design. – The tolerance for a weighing device is a performance requirement independent of the design principle used.

T.N.1.2. Accuracy Classes. – Weighing devices are divided into accuracy classes according to the number of scale divisions (n) and the value of the scale division (d).

T.N.1.3. Verification Scale Division. – The tolerance for a weighing device is ~~related to the value of the scale division (d) or the value in the order of magnitude~~ of the verification scale division (e) and is generally expressed in terms of ~~d or e~~.

(Amended 20XX)

Appendix D. Definitions

~~scale division, number of (n). – See “verification scale division, number of (n).” Quotient of the capacity divided by the value of the verification scale division. [2.20]~~

$$n = \frac{\text{Capacity}}{e}$$

(Amended 20XX)

~~Verification scale division, value of (e). – A value, expressed in units of weight (mass) and specified by the manufacturer of a device, by which the tolerance values and the accuracy class applicable to the device are determined. The verification scale division is applied to all scales, in particular to ungraduated devices since they have no graduations. **The verification scale division (e) may be different from the displayed scale division (d) for certain other devices used for weight classifying or weighing in pre-determined amounts, and certain other Class I and II scales.**[2.20]~~

(Amended 20XX)

verification scale division, number of (n). – Quotient of the capacity divided by the value of the verification scale division. [2.20]

$$n = \text{Capacity} / e$$

(Added 20XX)

Table 6. Maintenance Tolerances (All values in this table are in scale divisions)				
Tolerance in <u>Verification</u> Scale Divisions (e)				
	1	2	3	5
Class	Test Load <u>Applied</u>			
I	0 - 50 000	50 001 - 200 000	200 001 +	
II	0 - 5 000	5 001 - 20 000	20 001 +	
III	0 - 500	501 - 2 000	2 001 - 4 000	4 001 +
III	0 - 50	51 - 200	201 - 400	401 +
III L	0 - 500	501 - 1 000	(Add 1 e for each additional 500 e or fraction thereof)	

(Amended 20XX)

T.N.3. Tolerance Values.

T.N.3.1. Maintenance Tolerance Values. – The maintenance tolerance values are as specified in Table 6. Maintenance Tolerances.

T.N.3.2. Acceptance Tolerance Values. – The acceptance tolerance values shall be one-half the maintenance tolerance values.

T.N.3.3. Wheel-Load Weighers and Portable Axle-Load Weighers of Class III. – The tolerance values are two times the values specified in T.N.3.1. Maintenance Tolerance Values and T.N.3.2. Acceptance Tolerance Values.

(Amended 1986)

T.N.3.4. Crane and Hopper (Other than Grain Hopper) Scales. – The maintenance and acceptance tolerances shall be as specified in T.N.3.1. Maintenance Tolerance Values and T.N.3.2. Acceptance Tolerance Values for Class III L, except that the tolerance for crane and construction materials hopper scales shall not be less than 1 ~~e~~ or 0.1 % of the scale capacity, whichever is less.

(Amended 1986 **and 20XX**)

T.N.4. Agreement of Indications.

T.N.4.3. Single Indicating Element/Multiple Indications. – In the case of an analog indicating element equipped with two or more indicating means within the same element, the difference in the weight indications for any load other than zero shall not be greater than one-half the value of the **verification** scale division (**e**) (~~e~~) and be within tolerance limits.

(Amended 1986 **and 20XX**)

T.N.6. Sensitivity. – This section is applicable to all nonautomatic-indicating scales marked I, II, III, III L, or IIII.

T.N.6.1. Test Load.

- (a) The test load for sensitivity for nonautomatic-indicating vehicle, axle-load, livestock, and animal scales shall be 1 ~~d~~ e for scales equipped with balance indicator, and 2 ~~d~~ e or 0.2 % of the scale capacity, whichever is less, for scales not equipped with balance indicators.
- (b) For all other nonautomatic-indicating scales, the test load for sensitivity shall be 1 ~~d~~ e at zero and 2 ~~d~~ e at maximum test load.

(Amended 20XX)

T.N.8. Influence Factors. – The following factors are applicable to tests conducted under controlled conditions only, provided that:

- (a) types of devices approved prior to January 1, 1986, and manufactured prior to January 1, 1988, need not meet the requirements of this section;
- (b) new types of devices submitted for approval after January 1, 1986, shall comply with the requirements of this section; and
- (c) all devices manufactured after January 1, 1988, shall comply with the requirements of this section.

(Amended 1985)

T.N.8.1.3. Temperature Effect on Zero-Load Balance. – The zero-load indication shall not vary by more than:

- (a) three ~~divisions~~ e per 5 °C (9 °F) change in temperature for Class III L devices; or
- (b) one ~~division~~ e per 5 °C (9 °F) change in temperature for all other devices.

(Amended 1990 **and 20XX**)

T.N.9. Radio Frequency Interference (RFI) and Other Electromagnetic Interference Susceptibility. – The difference between the weight indication due to the disturbance and the weight indication without the disturbance shall not exceed one e ~~scale division (d)~~; or the equipment shall:

- (a) blank the indication; or
- (b) provide an error message; or
- (c) the indication shall be so completely unstable that it cannot be interpreted, or transmitted into memory or to a recording element, as a correct measurement value.

The tolerance in T.N.9. Radio Frequency Interference (RFI) and Other Electromagnetic Interference Susceptibility is to be applied independently of other tolerances. For example, if indications are at allowable basic tolerance error limits when the disturbance occurs, then it is acceptable for the indication to exceed the applicable basic tolerances during the disturbance.

(Amended 1997 **and 20XX**)

T.1. Tolerance Values.

T.1.1. General. – The tolerances applicable to devices not marked with an accuracy class shall have the tolerances applied as specified in Table T.1.1. Tolerances for Unmarked Scales.

~~(Amended 1990)~~

Note: When Table T.1.1. refers to T.N. sections it shall be accepted that the scale division d on the unmarked scale always equals the verification scale division e.

~~(Amended 1990 and 20XX)~~

T.2. Sensitivity Requirement (SR).

T.2.2. General. – Except for scales specified in paragraphs T.2.3. Prescription Scales through T.2.8. Railway Track Scales: 2 (e) ~~ϵ~~, 0.2 % of the scale capacity, or 40 lb, whichever is least.

~~(Amended 20XX)~~

T.2.4. Jewelers' Scales.

T.2.4.2. With More Than One-Half Ounce Capacity. – 1 (e) ~~ϵ~~ or 0.05 % of the scale capacity, whichever is less.

~~(Amended 20XX)~~

T.2.7. Vehicle, Axle-Load, Livestock, and Animal Scales.

T.2.7.1. Equipped With Balance Indicators. – 1 (e) ~~ϵ~~.

~~(Amended 20XX)~~

T.2.7.2. Not Equipped With Balance Indicators. – 2 (e) ~~ϵ~~ or 0.2 % of the scale capacity, whichever is less.

~~(Amended 20XX)~~

T.2.8. Railway Track Scales. – 3 (e) ~~ϵ~~ or 100 lb, whichever is less.

~~(Amended 20XX)~~

S.1.1.1. Digital Indicating Elements.

(a) A digital zero indication shall represent a balance condition that is within $\pm \frac{1}{2}$ the value of the scale division d.

(b) After zero setting (gross zero or net zero after a tare operation) the effect of zero deviation on the result of the weighing shall be not more than $\pm 0.25 e$.

[Nonretroactive as of January 1, 20XX]

~~**(b) (c) A digital indicating device shall either automatically maintain a “center-of-zero” condition to $\pm \frac{1}{4}$ scale division or less, or have an auxiliary or supplemental “center-of-zero” indicator that defines a zero-balance condition to $\pm \frac{1}{4}$ of a scale division or less. A “center-of-zero” indication may operate when zero is indicated for gross and/or net mode(s). A digital indicating device shall have a “center-of-zero” indicator that indicates a zero balance condition when the deviation from zero is not more than $\pm 0.25 e$. A “center-of-zero” indicator may operate when zero is indicated for gross and/or net mode(s). The “center-of-**~~

zero” indicator is not mandatory on a device equipped with an auxiliary indicating device or equipped with a zero tracking mechanism.
[Nonretroactive as of January 1, 1993]

~~(e)~~ **(d)** For electronic cash registers (ECRs) and point-of-sale systems (POS systems) the display of measurement units shall be a minimum of 9.5 mm (3/8 inch) in height.
[Nonretroactive as of January 1, 2021]
(Added 2019)
(Amended 1992, 2008, ~~and 2019,~~ **and 20XX**)

Part 2. Amendment of T.N.1.2. and related sections

T.N.1.2. Accuracy Classes. – Weighing devices are divided into accuracy classes according to the number of verification scale divisions (n) and the value of the **verification** scale division ~~(d)~~ **(e)**.
(Amended 20XX)

Table S.6.3.a. Marking Requirements						
To Be Marked With ↓	Weighing Equipment					
	Weighing, Load-Receiving, and Indicating Element in Same Housing or Covered on the Same CC ¹	Indicating Element not Permanently Attached to Weighing and Load-Receiving Element or Covered by a Separate CC	Weighing and Load-Receiving Element Not Permanently Attached to Indicating Element or Covered by a Separate CC	Load Cell with CC (11)	Other Equipment or Device (10)	
Manufacturer’s ID (1)	X	X	X	X	X	
Model Designation and Prefix (1)	X	X	X	X	X	
Serial Number and Prefix (2)	X	X	X	X	X (16)	
Certificate of Conformance Number (CC) (23)	X	X	X	X	X (23)	
Accuracy Class (17)	X	X (8)	X (19)	X		
Nominal Capacity (3)(18)(20)	X	X	X			
Value of Scale Division, “d” (3) (4)	X	X				
Value of Verification Scale Division , “e” (3) (4)	X	X				
Temperature Limits (5)	X	X	X	X		

Many rows of the table are not included in this proposal for brevity.
(Added 1990) (Amended 1992, 1999, 2000, 2001, 2002, ~~and 2004,~~ **and 20XX**)

Amend Table S.6.3.(b) as follows:

Table S.6.3.b.
Notes for Table S.6.3.a. Marking Requirements

3. The device shall be marked with the nominal capacity. **The nominal capacity may be prefaced by the terms “capacity” or “Max.”**

The For any scale where the value of “e” is equal the value of “d” (see S.1.2.2.), the nominal capacity shall be shown together with the value of the scale division “d” or “e” (e.g., 15×0.005 kg, ~~30×0.01 lb,~~ or capacity = 15 kg; $d = 0.005$ kg, or Max 15 kg $e = 0.005$ kg) in a clear and conspicuous manner and be readily apparent when viewing the reading face of the scale indicator unless already apparent by the design of the device. Each scale division value “d” or “e” ~~or weight unit with its associated nominal capacity~~ shall be marked on multiple range or multi-interval scales. For any scale that has no “d” or any scale where “e” does not equal “d” refer to Note 4.

[Nonretroactive as of January 1, 1983]

(Amended 2005 and 20XX)

4. **Required only if different from “d.” Exceptions to Note 3 regarding marking of “e” and “d.”**
(a) For an ungraduated scale such as an equal arm scale where the scale graduations do not represent a fixed weight quantity, the nominal capacity shall be shown together with the verification scale division “e” (e.g. capacity 1,000 g $e = 0.1$ g, or Max 1,000 g $e = 0.1$ g). These devices have no “d.”

(b) For a scale where e does not equal d , such as a scale equipped with an auxiliary indicating device or a weight classifier marked for special use, the nominal capacity shall be shown together with the scale division “d” and the verification scale division “e,” (e.g., capacity 1,000 g $e = 0.1$ g $d = 0.01$ g, or Max 1,000 g $e = 0.1$ g $d = 0.01$ g).

[Nonretroactive as of January 1, 1986]

(Amended 20XX)

Remainder of the table is omitted for brevity with this proposal.

Appendix D. Definitions

auxiliary indicating device. – a means to increase the display resolution of a weighing device, such as a rider or vernier on an analog device, or a differentiated least significant digit to the right of the decimal point on a digital device. [2.20]

(Added 20XX)

extended displaying device. – a means to temporarily change the scale division (d) to a value less than the verification scale division (e), following a manual command. [2.20]

(Added 20XX)

weight classifier. – A digital scale that rounds weight values up to the next scale division. These scales usually have a verification scale division (e) that is smaller than the displayed scale division (d). [2.20]

(Added 1987) (Amended 20XX)

S.1.2.2. Verification Scale Interval Division “e”.

For scales in classes I, II, III, III L, and IIII, the value of “e” shall equal the value of “d.” On a multi-interval scale or on a multiple range scale, the value of “e” shall be equal to the value of “d” for each partial range or range.

The requirement that $e = d$ does not apply to:

- (a) a scale equipped with an auxiliary indicating device conforming to S.1.2.2.1., or
- (b) a weight classifier marked for special use and complying with S.1.2.2.4., or
- (c) an ungraduated scale, such as an equal arm scale where the scale graduations do not represent a fixed weight quantity. Ungraduated devices are marked with “e” but have no scale divisions “d.”

(Added 20XX)

~~S.1.2.2.1. Class I and II Scales and Dynamic Monorail Scales.— If $e \neq d$, the verification scale interval “e” shall be determined by the expression:~~

$$\del d < e \leq 10 d$$

~~If the displayed division (d) is less than the verification division (e), then the verification division shall less than or equal to 10 times the displayed division.~~

~~The value of e must satisfy the relationship, $e = 10^k$ of the unit of measure, where k is a positive or negative whole number or zero. This requirement does not apply to a Class I device with $d < 1$ mg where $e = 1$ mg. If $e \neq d$, the value of “d” shall be a decimal submultiple of “e,” and the ratio shall not be more than 10:1. If $e \neq d$, and both “e” and “d” are continuously displayed during normal operation, then “d” shall be differentiated from “e” by size, shape, color, etc. throughout the range of weights displayed as “d.”~~

~~(Added 1999)~~

Scales Equipped with an Auxiliary Indicating Device. – Only a Class I or II scale may be equipped with an auxiliary indicating device. A multi-interval scale or a multiple range scale shall not be equipped with an auxiliary indicating device. The auxiliary indicating device may be either a rider or vernier on an analog device, or a scale division “d” to the right of the decimal point on a digital device that is differentiated in size or color.

The verification scale division “e” on a scale equipped with an auxiliary indicating device shall be determined as follows:

- (a) The value of “e” shall be greater than “d” and less than or equal to 10 “d” ($d < e < 10 d$), and
- (b) The value of “e” must satisfy the relationship, $e = 10^k$ of the unit of measure, where k is a positive or negative whole number or zero.

The requirement in subpart (a) does not apply to a Class I device with $e = 1$ mg, where d shall be less than “e” ($d < e$).

Examples: If $e = 1$ g for Class I or II, then “d” may only be 0.5 g, 0.2 g, or 0.1 g
If $e = 1$ mg for Class I, then “d” may be 0.5 mg, 0.2 mg, 0.1 mg, 0.05 mg, 0.02 mg, etc.

(Added 1999) (Amended 20XX)

S.1.2.2.3. Deactivation of a “d” Resolution. – It shall not be possible to deactivate the “d” resolution on a Class I or II scale equipped with an auxiliary indicating device if such action affects the scale’s ability to round digital values to the nearest minimum unit that can be indicated or recorded as required by paragraph G-S.5.2.2. Digital Indication and Representation.

(Added 20XX)

S.1.2.2.4. Weight Classifiers. – On a weight classifier, such as a postal or shipping scale that rounds up and is marked for special use, the value of “e” shall be equal to or less than “d.”

(Added 20XX)

S.1.2.2.5. Extended Displaying Device. – A scale with an auxiliary indicating device shall not be equipped with an extended displaying device. When a scale is equipped with an extended displaying device, displaying an indication with a scale division “d” smaller than “e” shall be possible only:

(a) while pressing a key; or

(b) for a period not exceeding 5 seconds after a manual command.

Printing or transferring data via interface shall not be possible while the extended displaying device is in operation.

(Added 20XX)

<i>Table 3. Parameters for Accuracy Classes</i>			
<i>Class</i>	<i>Value of the Verification Scale Division (d or e¹)</i>	<i>Number of Verification Scale⁴ Divisions (n)</i>	
		<i>Minimum</i>	<i>Maximum</i>
<i>SI Units</i>			
<i>I</i>	<i>equal to or greater than 1 mg</i>	<i>50 000</i>	<i>--</i>
<i>II</i>	<i>1 to 50 mg, inclusive</i>	<i>100</i>	<i>100 000</i>
	<i>equal to or greater than 100 mg</i>	<i>5 000</i>	<i>100 000</i>
<i>III^{2,5}</i>	<i>0.1 to 2 g, inclusive</i>	<i>100</i>	<i>10 000</i>
	<i>equal to or greater than 5 g</i>	<i>500</i>	<i>10 000</i>
<i>III L³</i>	<i>equal to or greater than 2 kg</i>	<i>2 000</i>	<i>10 000</i>
<i>III</i>	<i>equal to or greater than 5 g</i>	<i>100</i>	<i>1 200</i>

The middle section of the table is omitted for brevity.

[Nonretroactive as of January 1, 1986]

(Amended 1986, 1987, 1997, 1998, 1999, 2003, and 2004, **and 20XX**)

Amend Footnotes 1 and 3 to Table 3. As follows:

¹ ~~*For Class I and II devices equipped with auxiliary reading means (i.e., a rider, a vernier, or a least significant decimal differentiated by size, shape, or color), the value of the verification scale division “e” is the value of the scale division immediately preceding the auxiliary means. The verification scale division e does not always equal the displayed scale division d. To ensure the correct value for e is used, refer to required markings on the device (see also notes 3 and 4 in Table S.6.3.b.).*~~

² *A Class III scale marked “For prescription weighing only” may have a verification scale division (e) not less than 0.01 g.*

(Added 1986) (Amended 2003)

³ *The value of a verification scale division (e) for crane and hopper (other than grain hopper) scales shall be not less than 0.2 kg (0.5 lb). The minimum number of verification scale divisions (n) shall be not less than 1000.*

S.5.4. Relationship of Minimum Load Cell Verification Interval Value to the Verification Scale Division. – *The relationship of the value for the minimum load cell verification scale interval, v_{min} , to the verification scale division, d and e , for a specific scale using National Type Evaluation Program (NTEP) certified load cells shall comply with the following formulae where N is the number of load cells in a single independent¹ weighing/load-receiving element (such as hopper, railroad track, or vehicle scale weighing/load-receiving elements):*

(a) $v_{min} \leq \frac{d * e}{\sqrt{N}}$ for scales without lever systems; and

(b) $v_{min} \leq \frac{d * e}{\sqrt{N} \times (\text{scale multiple})}$ for scales with lever systems.

¹”Independent” means with a weighing/load-receiving element not attached to adjacent elements and with its own A/D conversion circuitry and displayed weight.

~~**[*When the value of the scale division, d, is different from the verification scale division, e, for the scale, the value of e must be used in the formulae above.]**~~

This requirement does not apply to complete weighing/load-receiving elements or scales, which satisfy all the following criteria:

- *the complete weighing/load-receiving element or scale has been evaluated for compliance with T.N.8.1. Temperature under the NTEP;*
- *the complete weighing/load-receiving element or scale has received an NTEP Certificate of Conformance; and*
- *the complete weighing/load-receiving element or scale is equipped with an automatic zero-tracking mechanism which cannot be made inoperative in the normal weighing mode. (A test mode which permits the disabling of the automatic zero-tracking mechanism is permissible, provided the scale cannot function normally while in this mode.*

[Nonretroactive as of January 1, 1994]

(Added 1993) (Amended 1996, 2016 **and 20XX**)

UR.3. Use Requirements.

UR.3.1. Recommended Minimum Load. – A recommended minimum load is specified in Table 8 since the use of a device to weigh light loads is likely to result in ~~relatively large~~ **considerable relative** errors.

(Amended 20XX)

Table 8. Recommended Minimum Load		
Class	Value of <u>Verification Scale Division e</u> (d or e*)	Recommended Minimum Load <u>in scale</u> <u>divisions d (See notes) (d or e*)</u>
I	equal to or greater than 0.001 g	100
II	0.001 g to 0.05 g, inclusive	20
III	equal to or greater than 0.1 g	50
III L	All**	20
III	All	50
III	All	10

~~*For Class I and II devices equipped with auxiliary reading means (i.e., a rider, a vernier, or a least significant decimal differentiated by size, shape or color), the value of the verification scale division “e” is the value of the scale division immediately preceding the auxiliary means. For Class III and III devices the value of “e” is specified by the manufacturer as marked on the device; “e” must be less than or equal to “d.”~~

The displayed scale division d is not always equal to the verification scale division e. To ensure the correct values are used, refer to required markings on the device (see also notes 3 and 4 in Table S.6.3.b.).

For an ungraduated device, the scale division d shall be replaced with the verification scale division e in the last column.

~~**A minimum load of **10 d 5 e** is recommended for a weight classifier marked in accordance with a statement identifying its use for special applications.~~

(Amended 1990 **and 20XX**)

Previous Action:

New Item in 2023

Original Justification:

The Verification Scale Division e Task Group has recommended a significant number of changes to the Scale Code. Those changes are reflected below. Before addressing the changes though, it is important to identify the problem that the changes are trying to fix.

The Task Group identified two significant flaws in the current Code after comparison with R76. The changes are proposed to ensure Handbook 44 uses correct measurement principles. They are not proposed for the purpose of harmony with R76. Those two flaws are found in the following paragraphs from the current Scales Code.

T.N.1.2. Accuracy Classes. – Weighing devices are divided into accuracy classes according to the number of scale divisions (n) and the value of the scale division (d).

T.N.1.3. Scale Division. – The tolerance for a weighing device is related to the value of the scale division (d) or the value of the verification scale division (e) and is generally expressed in terms of d or e.

NIST OWM Detailed Technical Analysis:

This item was submitted to the NCWM in November 2022. OWM has not reviewed the proposal in its entirety. For this reason, no technical analysis is being provided at this time.

Regional Association Reporting:

Western Weights and Measures Association

Southern Weights and Measures Association

Northeastern Weights and Measures Association

Central Weights and Measures Association

WIM – Weigh-in-Motion Systems – Tentative Code

WIM-23.1 Remove Tentative Status and Amend Numerous Sections Throughout

Source: New York City DOT, C2SMART, Kistler, and Maryland DOT

Submitter’s Purpose and Justification:

Provide a legal document that can be used by local and State agencies to certify Weigh-In-Motion (WIM) systems used for automated weight enforcement.

1. INTRODUCTION

The Brooklyn-Queens Expressway (BQE) is an aging and deteriorating 6-lane highway which comprises a critical link of I-278 - the sole Interstate highway in Brooklyn, connecting it to Manhattan, Staten Island, and Queens in New York. Constructed in 1954 and comprised of varying and complex structure types, the segment of the BQE between Atlantic Ave. Interchange to the South and Sands St. to the North is nearing the end of its design life. Urgent repairs are underway, while roughly 110 spans may be in need of intervention by 2028, and another 75 spans may be in need of intervention within the next decade. Weigh in Motion (WIM) sensors, installed in October 2019, have revealed overweight vehicles, excessively exceeding FHWA legal load limits, with gross vehicle weights (GVW) that range from just over 80,000 lbs to as high as 200,000. The continued presence of overweight vehicles on the BQE contributes to the continued structural deterioration of this aging piece of infrastructure. The New York State legislature recently authorized the New York City Department of Transportation to conduct automated overweight vehicle enforcement through a WIM demonstration program; however, a universal standard has not yet been established that specifically defines a protocol for calibration and certification by the New York State local Division of Weights and Measures.

In response to this challenge, this proposal seeks an amendment of Section 2.25 of NIST Handbook 44 to allow for Weigh-In-Motion Systems Used for Automated Vehicle Weight Enforcement. The remainder of this proposal lays out the justification for the amendment, using the BQE as an example to establish the urgent need for the amendment, supported by data received from other State programs, including New

Jersey, Maryland, and Indiana. The City of New York is not alone in its struggle to maintain the safety and the structural integrity of its infrastructure. Guarding against violations of vehicle weight restrictions that are enacted to protect critical infrastructure is an issue of national concern.

The combined interstate data presented here stresses the national importance of establishing protocols for automated vehicle weight enforcement using WIM, citing:

- the deleterious effects of overweight vehicles and axles on primary structural components and pavements;
- the difficulty associated with the use of screening combined with stationary weighing stations to enforce vehicle weight regulations;
- the percentages of overweight vehicles on major interstates across the nation; and the proven accuracy of WIM equipment used in several states across the nation.

The submitters requested that this be a Voting item in 2023.

OWM Executive Summary for WIM-23.1 – Remove Tentative Status and Amend Numerous Sections Throughout

OWM Recommendation: The analysis is based on the revised proposal that was posted on the NCWM website on 12/1/2022. NIST OWM is of the opinion that the item currently has merit, but that it is not yet fully developed. NIST OWM recommends making this item Developing to give the submitters the opportunity to address raised concerns.

- The submitter has demonstrated there is a need for permanent and direct enforcement. The proposed code is intended to address this need.
- The proposed tolerances and test procedures are comparable to the OIML recommendation R 134 which is used in multiple countries as the standard for weighing road vehicles in motion (for both direct enforcement and other applications).

However, there are several issues that need to be addressed:

- Since the proposal has a significant impact on the enforcement of vehicle weight limits, it is important that all stakeholders be involved in the development of the code. Not only should be the technical requirements of the system be taken into consideration, but also the practical implementation of field testing after installation. (See the Detailed Technical Analysis below for a list of possible stakeholders).
- Due to the large tolerance of WIM systems, the measured weight value must be corrected for the uncertainty of the measurement, so it is guaranteed that the weight used for the citation never exceeds the actual weight of the vehicle. Although the submitters state that the measured weight value should be corrected, the language in the proposal does not clearly elaborate how or when the measurement value is to be corrected.
- The proposed methods for weighing axle loads are in general considered unsuitable. However, due to the large tolerance, it may be possible that these methods do meet the fundamental considerations.

OWM Executive Summary for WIM-23.1 – Remove Tentative Status and Amend Numerous Sections Throughout
<p>The submitters should investigate whether the proposed methods for determining the axle load, axle-group load and gross vehicle weight of the reference vehicles, are indeed suitable.</p> <ul style="list-style-type: none"> • The proposal should contain provisions to support unattended operation in order to prevent any reasonable doubt about the measurement. The different stakeholders involved in the future development of the proposal should decide on the different provisions that need to be part of the code (e.g., pictures of the vehicle, license plate and its position on the road, and other registrations of the circumstances). • The submitters should provide justification for the proposed vehicle types to be used as reference vehicle. The selected reference vehicles must be representative to the traffic that can be expected traveling over the WIM installation. E.g., vehicles carrying fluids or vehicles with a steel leaf spring suspension. The ultimate criteria for the selection of the reference vehicles must be agreed upon by all stakeholders. • The submitters should demonstrate the acceptable level of performance and reliability of these WIM systems. And demonstrate that the proposed test procedures are effective and sufficient. Any data presented should be complete and traceable to the national standards.

Table 3. Summary of Recommendations							
WIM-23.1 – Remove Tentative Status and Amend Numerous Sections Throughout							
	V	D	W	A	I	Notes*	Comments
Submitter	✓						
OWM		✓					
WWMA		✓					
SWMA		✓					
NEWMA		✓					
CWMA		✓					
NCWM							
	Letters of Support		Letters of Opposition			Notes	
Industry	<ul style="list-style-type: none"> • International Road Dynamics • New York University 					November 15, 2022 November 14, 2022	
Manufacturers							
Retailers and Consumers							
Regulators	<ul style="list-style-type: none"> • Maryland DOT 					November 15, 2022	

Table 3. Summary of Recommendations							
WIM-23.1 – Remove Tentative Status and Amend Numerous Sections Throughout							
	V	D	W	A	I	Notes*	Comments
<p>*Notes Key:</p> <ul style="list-style-type: none"> 1 – Submitted modified language 2 – Item not discussed 3 – No meeting held 4 – Not submitted on agenda 5 – No recommendation or not considered 							

Item Under Consideration (per 12/1/2022):

Amend Handbook 44 Weigh-In-Motions Systems Code as follows:

Table of Contents

Weigh-In-Motions Systems Used for Vehicle Enforcement—~~Tentative Code~~

...

T.2. Tolerance Values for Accuracy Class A and Class E.

...

Additional letters, presentation, and data may have been submitted for consideration with this item. Please refer to <https://www.ncwm.com/publication-15> to review these documents.

Section 2.25. Weigh-In-Motion Systems Used for Vehicle Screening and Enforcement—~~Tentative Code~~

~~This tentative code has a trial or experimental status and is not intended to be enforced. The requirements are designed for study prior to the development and adoption of a final code. Officials wanting to conduct an official examination of a device or system are advised to see paragraph G-A.3. Special and Unclassified Equipment.~~

A. Application

A.1. General. – This code applies to **fixed (not portable)** systems used to weigh vehicles, while in motion, for the purpose of screening and sorting the vehicles based on the vehicle weight to determine if a static weighment is necessary **(Class A), and enforcing the weight limit of road vehicles (Class E)**.

A.2. Exception. – This code does not apply to weighing systems intended for the collection of statistical traffic data.

A.3. Additional Code Requirements. – In addition to the requirements of this code, weigh-in-motion ~~screening~~ systems shall meet the requirements of Section 1.10. General Code.

S. Specifications

S.1. Design of Indicating and Recording Elements and of Recorded Representations.

S.1.1. Ready Indication. – The system shall provide a means of verifying that the system is operational and ready for use.

S.1.2. Value of System Division Units. – The value of a system division “d” expressed in a unit of weight shall be equal to:

- (a) 1, 2, or 5; or
- (b) a decimal multiple or submultiple of 1, 2, or 5.

Examples: divisions may be 10, 20, 50, 100; or 0.01, 0.02, 0.05; or 0.1, 0.2, 0.5, etc.

S.1.2.1. Units of Measure. – The system shall indicate weight values using only a single unit of measure.

S.1.3. Maximum Value of Division. – The value of the system division “d” for a Class A and Class E, weight-in-motion system shall not be greater than 50 kg (100 lb).

S.1.4. Value of Other Units of Measure.

S.1.4.1. Speed. – Vehicle speeds shall be measured in miles per hour or kilometers per hour.

S.1.4.2. Axle-Spacing (Length). – The center-to-center distance between any two successive axles shall be measured in:

- (a) meters and decimal submultiples of a meter;
- (b) feet and inches; or
- (c) feet and decimal submultiples of a foot.

S.1.4.3. Vehicle Length. – If the system is capable of measuring the overall length of the vehicle, the length of the vehicle shall be measured in feet and/or inches, or meters.

S.1.5. Capacity Indication. – An indicating or recording element shall not display nor record any values greater than 105 % of the specified capacity of the load receiving element.

S.1.6. Identification of a Fault. – Fault conditions shall be presented to the operator in a clear and unambiguous means. The following fault conditions shall be identified:

- (a) Vehicle speed is below the minimum or above the maximum speed as specified.
- ~~(b) The maximum number of vehicle axles as specified has been exceeded.~~
- (b) A change in vehicle speed greater than that specified has been detected.
- (c) Imbalanced weight between the left and right wheels has exceeded the specified values.

(d) **The vehicle changes lanes within the sensor locations.**

S.1.7. Recorded Representations.

S.1.7.1. Values to be Recorded. – At a minimum, the following values shall be printed and/or stored electronically for each vehicle weighing. **Consult the specific jurisdictional legislation for additional values that may be required to issue enforcement violations. All gross vehicle, axle, and axle group weights must be printed and/or stored with the corrected values that include any necessary reductions due to the system tolerance and adopted violation thresholds.**

- (a) transaction identification number;
- (b) **station ID;**
- (c) lane identification (required if more than one lane at the site has the ability to weigh a vehicle in motion);
- (d) vehicle speed;
- (e) number of axles;
- (f) weight of each axle;
- (g) **weight of each axle group;**
- (h) identification and weight of axle groups;
- (i) axle spacing;
- (j) total vehicle weight;
- (k) **weight limits as specified in paragraph S.2.1;**
- (l) **total vehicle length;**
- (m) all fault conditions that occurred during the weighing of the vehicle;
- (n) violations, as identified in paragraph S.2.1. Violation Parameters, which occurred during the weighing of the vehicle; and
- (o) time and date.

S.1.8. Value of the Indicated and Recorded System Division. – The value of the system’s division “(d),” as recorded, shall be the same as the division value indicated.

S.2. System Design Requirements.

S.2.1. Violation Parameters. – The instrument shall be capable of accepting user-entered violation parameters for the following items:

- (a) single axle weight limit;

- (b) axle group weight limit;
- (c) gross vehicle weight limit; and
- (d) bridge formula maximum.

The instrument shall display and/or record violation conditions when these parameters have been exceeded.

S.3. Design of Weighing Elements.

S.3.1. Multiple Load-Receiving Elements. – An instrument with a single indicating or recording element, or a combination indicating-recording element, that is coupled to two or more load-receiving elements with independent weighing systems, shall be provided with means to prohibit the activation of any load-receiving element (or elements) not in use, and shall be provided with automatic means to indicate clearly and definitely which load receiving element (or elements) is in use.

S.4. Design of Weighing Devices, Accuracy Class.

S.4.1. Designation of Accuracy. – Weigh-in-motion systems meeting the requirements of this code shall be designated as accuracy Class A **and Class E**.

Note: This does not preclude higher accuracy classes from being proposed and added to this Code in the future when it can be demonstrated that weigh-in-motion systems grouped within those accuracy classes can achieve the higher level of accuracy specified for those devices.

S.5. Marking Requirements. – In addition to the marking requirements in G-S.1. Identification (except G.S.1.(e)), the system shall be marked with the following information:

- (a) accuracy class;
- (b) value of the system division “d”;
- (c) operational temperature limits;
- (d) number of instrumented lanes (not required if only one lane is instrumented);
- (e) minimum and maximum vehicle speed;
- (f) maximum number of axles per vehicle;
- (g) maximum change in vehicle speed during weighment; and
- (h) minimum and maximum load.

S.5.1. Location of Marking Information. – The marking information required in Section 1.10. General Code, G-S.1. Identification and Section 2.25. Weigh-in-Motion Systems, S.5. Marking

Requirements shall be visible after installation. The information shall be marked on the system or recalled from an information screen.

N. Notes

N.1. Test Procedures.

N.1.1. Selection of Test Vehicles. – All dynamic testing associated with the procedures described in each of the subparagraphs of N.1.5 shall be performed ~~with a minimum of two~~ **the following** test vehicles **for each Class A and Class E.**

N.1.1.1. Selection of Test Vehicles for Class A – A minimum of two vehicles below shall be used.

- (a) The first test vehicle may be a two-axle, six-tire, single-unit truck; that is, a vehicle with two axles with the rear axle having dual wheels. The vehicle shall have a maximum gross vehicle weight of 10 000 lb.
- (b) The second test vehicle shall be a five-axle, single-trailer truck with a maximum gross vehicle weight of 80 000 lb.

N.1.1.2. Selection of Test Vehicles for Class E – A minimum of three vehicles below shall be used.

- (a) **The first test vehicle may be a two-axle, six-tire, single-unit truck or Federal Highway Administration (FHWA) Class 5; that is, a vehicle with two axles with the rear axle having dual wheels**
- (b) **The second test vehicle shall be a five-axle, single-trailer truck or FHWA Class 9 3S2 Type.**
- (c) **The third test vehicle shall be a three-axle, single-unit truck or FHWA Class 6.**
- (d) **The gross vehicle weights shall be as stated in N.1.2.3.**

Note: Consideration should be made for testing the systems using vehicles which are typical to the system's daily operation. **Violation thresholds may be dependent on additional items, not specified in this code.**

N.1.1.1.3. Weighing of Test Vehicles. – All test vehicles shall be weighed on a reference scale, **meeting the requirements of Appendix A,** before being used to conduct the dynamic tests.

N.1.1.2.4. Determining Reference Weights for Axle, Axle Groups, and Gross Vehicle Weight. – The reference weights shall be the average weight value of a minimum of three static weighments of all single axles, axle groups, and gross vehicle weight **on a reference scale before being used to conduct the dynamic tests.**

Note: The axles within an axle group are not considered single axles.

N.1.2. Test Loads.

N.1.2.1. Static Test Loads. – All static test loads shall use certified test weights.

N.1.2.2. Dynamic Test Loads for Class A. – Test vehicles used for dynamic testing shall be loaded to 85 % to 95 % of their legal maximum Gross Vehicle Weight **for a minimum of 20 runs per test vehicle type.** The “load” shall be non-shifting and shall be positioned to present as close as possible, an equal side-to-side load.

N.1.2.3. Dynamic Test Loads for Class E. – **Test vehicles used for dynamic testing shall be loaded in two (2) different load conditions. The “load” shall be non-shifting and shall be positioned to present as close as possible, an equal side-to-side load.**

(a) an empty load condition for a minimum of 15 runs per test vehicle type, and

(b) a fully load condition (> 90% of the scale capacity or > 90% of the maximum capacity of the vehicle, whichever is less) for a minimum of 30 runs per test vehicle type

N.1.3. Reference Scale. – Each reference vehicle **for the dynamic test** shall be weighed statically **either** on a multiple platform vehicle scale **or a single platform vehicle scale.**

N.1.3.1. Multiple Platform Vehicle Scale – It is comprised of three individual weighing/load-receiving elements, each an independent scale. The three individual weighing/load receiving elements shall be of such dimension and spacing to facilitate:

the single-draft weighing of all reference test vehicles;

- (a) the simultaneous weighing of each single axle and axle group of the reference test vehicles on different individual elements of the scale; and
- (b) gross vehicle weight determined by summing the values of the different reference axle and reference axle groups of a test vehicle.

N.1.3.2. Single Platform Vehicle Scale – Each individual axle or axle group of the reference test vehicles shall be measured on the single platform vehicle scale. Only the single axle or axle group for measurement shall be on the single platform, while other single axles or axle groups shall be off the platform. The GVW shall be determined by summing all the single axles and axle groups.

The scale shall be tested immediately prior to using it to establish reference test loads and in no case more than 24 hours prior. To qualify for use as a suitable reference scale, it must meet NIST Handbook 44, Class III L maintenance tolerances.

N.1.3.3. Location of a Reference Scale. – The location of the reference scale must be considered since vehicle weights will change due to fuel consumption.

N.1.4. Test Speeds. – All dynamic tests shall be conducted **at the designated speed(s).**

N.1.4.1. Test Speeds for Class A – Speed shall be within 20% below or at the posted speed limit.

N.1.4.2. Test Speeds for Class E – Three speeds shall be used.

(a) high speed – maximum posted speed limit.

(b) low speed – less than 10 mph.

(c) operation speed – average between N.1.4.2.(a) high speed and N.1.4.2.(b) low speed.

N.1.5. Test Procedures.

N.1.5.1. Dynamic Load Test for Class A. – The dynamic test **for Class A** shall be conducted using the test vehicles defined in N.1.1.1. Selection of Test Vehicles **for Class A**. The test shall consist of a minimum of 20 runs for each test vehicle at the speed as stated in N.1.4.1. Test Speeds **for Class A**.

At the conclusion of the dynamic test, there will be a minimum of 20 weight readings for each single axle, axle group, and gross vehicle weight of ~~the~~ **each** test vehicle. The tolerance for each weight reading shall be based on the percentage values specified in Table T.2.2-1 Tolerances for Accuracy Class A.

N.1.5.2. Vehicle Position Test for Class A. – During the conduct of the dynamic testing **for Class A**, ensure the vehicle stays within the defined roadway along the width of the sensor. The test shall be conducted with 10 runs with the vehicle centered along the width of the sensor; 5 runs with the vehicle on the right side along the width of the sensor; and 5 runs with the vehicle on the left side along the width of the sensor. Only gross vehicle weight is used for this test and the tolerance for each weighment shall be based on the tolerance value specified in T.2.3. Tolerance Value for Vehicle Position Test.

N.1.5.3. Dynamic Load Test for Class E. – **The dynamic test for Class E shall be conducted using the test vehicles defined in N.1.1.2. Selection of Test Vehicles for Class E. The test shall consist of a minimum of 45 runs for each test vehicle. A minimum of 15 runs at empty load condition and a minimum of 30 runs at fully load condition.**

At the conclusion of the dynamic test, there will be a minimum of 45 weight readings or 15 weight readings at each speed for each single axle, axle group, and gross vehicle weight. The tolerance for each weight reading shall be based on the percentage values specified in Table T.2.2-2 Tolerances for Accuracy Class E.

N.1.5.4. Vehicle Position Test for Class E. – **During the conduct of the dynamic testing for Class E, ensure the vehicle stays within the defined roadway along the width of the sensor. Only gross vehicle weight is used for this test and the tolerance for each weighment shall be based on the tolerance value specified in T.2.3. Tolerance Value for Vehicle Position Test.**

(a) Empty load condition. – **The test shall be conducted with 15 runs in total or 5 runs at each speed as stated in N.1.4.2. Test Speeds for Class E. The test shall be conducted with 9 runs with the vehicle centered along the width of the sensor (3 runs per speed); 3 runs with the vehicle on the right side along the width of the sensor (1 run per speed); and 1 run with the vehicle on the left side along the width of the sensor (1 run per speed).**

(b) Fully load condition. – **The test shall be conducted with 30 runs in total or 10 runs at each speed as stated in N.1.4.2. Test Speeds for Class E. The test shall be conducted with 18 runs with the vehicle centered along the width of the sensor (6 runs per speed);**

6 runs with the vehicle on the right side along the width of the sensor (2 run per speed); and 6 runs with the vehicle on the left side along the width of the sensor (2 run per speed).

See Table N.1.5. below to summarize all the test runs.

Table N.1.5. Number of Test per Each Test Vehicle for Class E		
<u>Load Condition</u>	<u>Speed</u>	<u>Vehicle Position</u>
<u>Fully Load (30 runs)</u>	<u>High Speed (10 runs)</u>	<u>Left (2 runs), Center (6 runs), Right (2 runs)</u>
	<u>Low Speed (10 runs)</u>	<u>Left (2 runs), Center (6 runs), Right (2 runs)</u>
	<u>Operation Speed (10 runs)</u>	<u>Left (2 runs), Center (6 runs), Right (2 runs)</u>
<u>Empty Load (15 runs)</u>	<u>High Speed (5 runs)</u>	<u>Left (1 run), Center (3 runs), Right (1 run)</u>
	<u>Low Speed (5 runs)</u>	<u>Left (1 run), Center (3 runs), Right (1 run)</u>
	<u>Operation Speed (5 runs)</u>	<u>Left (1 run), Center (3 runs), Right (1 run)</u>
<u>45 runs</u>	<u>15 runs x 3 speeds</u>	<u>9 runs (left) + 27 runs (center) + 9 runs (right)</u>

N.1.5.3-5. Axle Spacing Test. – The axle spacing test is a review of the displayed and/or recorded axle spacing distance of the test vehicles. The tolerance value for each distance shall be based on the tolerance value specified in T.2.4. Tolerance Value for Axle Spacing.

T. Tolerances

T.1. Principles.

T.1.1. Design. – The tolerance for a weigh-in-motion system is a performance requirement independent of the design principle used.

T.2. Tolerance Values for Accuracy Class A and Class E.

T.2.1. Tests Involving Digital Indications or Representations. – To the tolerances that would otherwise be applied in paragraphs T.2.2. Tolerance Value for Dynamic Load Test and T.2.3. Tolerance Value for Vehicle Position Test, there shall be added an amount equal to one-half the value of the scale division to account for the uncertainty of digital rounding.

T.2.2. Tolerance Values for Dynamic Load Test. – The tolerance values applicable during dynamic load testing are as specified in Table T.2.2-1 **for screening and Table T.2.2-2 for enforcement.**

T.2.2.1. Tolerance Value for Class A for Screening Purpose

Table T.2.2-1. Tolerances for Accuracy Class A	
<u>Load Description*</u>	<u>Tolerance as a Percentage of Applied Test Load</u>
Axle Load	± 20 %
Axle Group Load	± 15 %
Gross Vehicle Weight	± 10 %

Table T.2.2-1. Tolerances for Accuracy Class A	
Load Description*	Tolerance as a Percentage of Applied Test Load
* No more than 5 % of the weighments in each of the load description subgroups shown in this table shall exceed the applicable tolerance.	

T.2.2.2. Tolerance Value for Class E for Enforcement Purpose

Table T.2.2-2. Tolerances for Accuracy Class E	
Load Description*	Tolerance as a Percentage of Applied Test Load
<u>Axle Load</u>	<u>± 15 %</u>
<u>Axle Group Load</u>	<u>± 10 %</u>
<u>Gross Vehicle Weight</u>	<u>± 6 %</u>
<u>* No more than 5 % of the weighments in each of the load description subgroups shown in this table shall exceed the applicable tolerance. No single error may exceed a GVW tolerance of ± 10 % (100% compliance).</u>	

T.2.3. Tolerance Value for Vehicle Position Test. – The tolerance value applied to each gross vehicle weighment is ± 10 % of the applied test load.

T.2.4. Tolerance Value for Axle Spacing. – The tolerance value applied to each axle spacing measurement shall be ± 0.15 m (0.5 ft).

T.3. Influence Factors. – The following factor is applicable to tests conducted under controlled conditions only.

T.3.1. Temperature. – Systems shall satisfy the tolerance requirements under all operating temperature unless a limited operating temperature range is specified by the manufacturer.

T.4. Radio Frequency Interference (RFI) and Other Electromagnetic Interference Susceptibility. – The difference between the weight indication due to the disturbance and the weight indication without the disturbance shall not exceed the tolerance value as stated in Table T.2.2 Tolerances for Accuracy ~~Class A~~.

UR. User Requirements

UR.1. Selection Requirements. – Equipment shall be suitable for the service in which it is used with respect to elements of its design, including but not limited to, its capacity, number of scale divisions, value of the scale division, or verification scale division and minimum capacity.

UR.1.1. General. – The typical class or type of device for particular weighing applications is shown in Table 1. Typical Class or Type of Device for Weighing Applications.

Table 1. Typical Class or Type of Device for Weighing Applications	
Class	Weighing Application
A	Screening and sorting of vehicles based on axle, axle group, and gross vehicle weight.

Table 1.	
Typical Class or Type of Device for Weighing Applications	
Class	Weighing Application
<u>E</u>	<u>Enforcing of vehicles based on axle, axle group, and gross vehicle weight</u>
Note: A WIM system with a higher accuracy class than that specified as “typical” may be used.	

UR.2. User Location Conditions and Maintenance. – The system shall be installed and maintained as defined in the manufacturer’s recommendation.

UR.2.1. System Modification. – The dimensions (e.g., length, width, thickness, etc.) of the load receiving element of a system shall not be changed beyond the manufacturer’s specifications, nor shall the capacity of a scale be increased beyond its design capacity by replacing or modifying the original primary indicating or recording element with one of a higher capacity, except when the modification has been approved by a competent engineering authority, preferably that of the engineering department of the manufacturer of the system, and by the weights and measures authority having jurisdiction over the system.

UR.2.2. Foundation, Supports, and Clearance. – The foundation and supports shall be such as to provide strength, rigidity, and permanence of all components.

On load-receiving elements, which use moving parts for determining the load value, clearance shall be provided around all live parts to the extent that no contacts may result when the load-receiving element is empty, nor throughout the weighing range of the system.

UR.2.3. Access to Weighing Elements. – If necessary, adequate provision shall be made for inspection and maintenance of the weighing elements.

UR.3. Maximum Load. – A system shall not be used to weigh a load of more than the marked maximum load of the system.

Appendix D. Definitions

The specific code to which the definition applies is shown in the [brackets] at the end of the definition. Definitions for the General Code [1.10] apply to all codes in NIST Handbook 44.

A

axle. – The axis oriented transversely to the nominal direction of vehicle motion, and extending the full width of the vehicle, about which the wheel(s) at both ends rotate. [2.25]

axle-group load. – The sum of all tire loads of the wheels on a group of adjacent axles; a portion of the gross-vehicle weight. [2.25]

axle load. – The sum of all tire loads of the wheels on an axle; a portion of the gross-vehicle weight. [2.25]

axle spacing. – The distance between the centers of any two axles. When specifying axle spacing, the axles used also need to be identified. [2.25]

S

single-axle load. – The load transmitted to the road surface by the tires lying on the same longitudinal axis (that axis transverse to the movement of the vehicle and about which the wheels rotate). [2.25]

T

tandem-axle load. – The load transmitted to the road surface by the tires of two single-axes lying on the same longitudinal axis (that axis transverse to the movement of the vehicle and about which the wheels rotate). [2.25]

triple-axle load. – The load transmitted to the road surface by the tires of three single-axes lying on the same longitudinal axis (that axis transverse to the movement of the vehicle and about which the wheels rotate). [2.25]

W

weigh-in-motion (WIM). – A process of estimating a moving vehicle's gross weight and the portion of that weight that is carried by each wheel, axle, or axle group, or combination thereof, by measurement and analysis of dynamic vehicle tire forces. [2.25]

weigh-in-motion screening scale. – A weigh-in-motion system used to identify potentially overweight vehicles. [2.25]

wheel weight. – The weight value of any single or set of wheels on one side of a vehicle on a single axle. [2.25]

WIM System. – A set of sensors and supporting instruments that measure the presence of a moving vehicle and the related dynamic tire forces at specified locations with respect to time; estimate tire loads; calculate speed, axle spacing, vehicle class according to axle arrangement, and other parameters concerning the vehicle; and process, display, store, and transmit this information. This standard applies only to highway vehicles. [2.25]

NIST OWM Detailed Technical Analysis:

Permanent installed WIM systems are used in several countries around the world and are generally used for permanent protection of fragile and critical infrastructure. The submitters clearly showed that there is a need for direct and permanent enforcement.

The submitters have requested that the proposal is given a Voting status. However, changing the application of the code from screening to direct enforcement requires a new level of reliability. The submitters have used the existing code, that was adopted by the conference in 2015, as basis for their proposal. The test procedures and tolerances are comparable to internationally used standards which builds confidence. Therefore, it can be assumed that the proposal is a good base to start from. But there are still some concerns to be addressed in order for it to be suitable for direct enforcement application.

These high-speed weigh-in-motion systems generally have a much large error than static scales. That makes them unsuitable for use in commercial applications which are based on a shared risk principle. But for law enforcement applications these systems are suitable provided that the risk is placed on the side of law enforcement. That means that the measured weight value needs to be corrected with the tolerance of the instrument. Although the proposed specification S.1.7.1 contains a sentence that the measurements

must be corrected, the proposal does not clearly state how the correction is implemented (a fixed value or percentage of the measurement), or who corrects the measurement. If the instrument automatically performs the correction, then this must be a specification in the code. If done during the process afterwards, then it must be a user requirement. The conference should decide on the most appropriate way to implement the correction of the measurement value.

The procedures in the proposal should ensure that the test vehicles comply with the fundamental considerations as laid down in appendix A of Handbook 44. Calculations must show that the combined accuracy and uncertainty of the reference scale needs to be better than 1/3 of the applicable tolerance. E.g. Split weighing is considered an inaccurate way to determine the gross vehicle weight for commercial applications. And a single-platform vehicle scale is in general deemed unacceptable for use in determining the individual axle and axle-group loads of vehicles and vehicle combinations that are intended to serve as a standard reference in testing a WIM vehicle scale system. Previous studies conducted by NIST, Measurement Canada, and Kansas have shown very large weighing errors occur when weighing these components (i.e., axle and axle-groups) if the entire vehicle isn't level and in the same plane as the platform when those components are being weighed. Because the approach requirements for single platform vehicle scales do not ensure the level positioning of vehicles during the weight determinations of these components, they should not be used.

That being said, in this case the tolerance of the system is much larger than for static scales, which allows the reference scale also to have a much larger tolerance. This could mean that the proposed method of weighing of a reference vehicle is acceptable. It should be investigated whether the accuracy of weighing methods meet the required 1/3 of the tolerance.

The current code in section 2.25 is meant for screening applications only. That means that for the actual citation another certified scale is being used, not the WIM installation. In case of the proposed code, the citation is based on the output of the WIM installation. Since the weighing process is done without the intervention of a law enforcement officer, the records of the weighment must be unambiguous and beyond reasonable doubt. That means that the records should contain:

- The measured gross weight
- The corrected weight used for the citation (if a correction is applied)
- Proof of the vehicle's identity (e.g., picture of the vehicle including license plate)
- Date and time
- Location
- Any other record that may be necessary to avoid any doubt about the violation (e.g., vehicle speed)

It is unclear whether this kind of supporting evidence should be part of the code. The conference should decide whether to add this to the code or whether this is covered by other legislation.

To build confidence in the proposed WIM, adequate performance and reliability of such system should be demonstrated. Also, the effectiveness and completeness of the proposed test procedures should be demonstrated. Regarding the test procedures, NIST OWM has some concerns:

- One of the most critical vehicle types to be weighed on a weigh in motion system is a vehicle with a shifting load, e.g., a tanker truck carrying fluids. Therefore, these kinds of vehicles should be included in the selection of test vehicles.
- Other vehicles with characteristics that could influence the measurement (e.g., vehicles with conventional steel leaf spring suspension as prescribed by OIML R 134) should be considered too.
- How does the “fully load condition” of a test relate to the specified scale capacity? E.g., is it sufficient to test a 200,000 lb installation with an 80,000 lb test vehicle?
- The objective of the WIM system is to detect and accurately weigh overweighted vehicles. Therefore, correct operation of the scale above the weight limit is essential. The proposal should answer the following questions:
 - Is it the intend to use test vehicles that weigh more than the weight limit of the road the WIM system is supposed to protect? If so, what precautions need to be taken to limit the damage to the road due to testing?
 - If no overweight vehicles are to be used during testing, how is guaranteed that the WIM system is providing an accurate weight within tolerance for loads over the weight limit up to the capacity of the WIM system?

And last but not least, for such a significant change in the code it is important that all stakeholders are heard and consulted. What does this proposal mean for the state inspectors who have to perform regular inspections on these WIM systems? Are there any concerns from the transport sector on having these devices deployed in the field? In order for the proposal to be adopted, it has to be technically sound and supported by a large portion of the legal metrology community. Possible stakeholders are for example other WIM manufacturers, highway weight enforcement regulators (who will be using and possibly testing them), state and local W&M jurisdictions (who may be the ones testing them), truckers association(s), Federal DOT, and perhaps service companies who will be installing and testing the units when they are installed.

Regional Association Reporting:

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received:

Ms. Tanvi Pandya (New York City DOT) – Ms. Pandya stated technologies have moved on. Ms. Pandya noted New York City DOT has data since 2019 showing that accuracy can be met on the devices. Ms. Pandya added the Handbook is outdated and needs to be updated to provide a way to enforce and it cannot be overstated the number of overweight vehicles that need to be regulated. Ms. Pandya recommended a Voting status.

Mr. Chaekuk Na (Rutgers University) stated the submitters of the item tried to meet the standard and got less than 6% error with 100% compliance. Mr. Chaekuk stated Indiana DOT conducted an independent test and received results within 5% error.

Mr. Jess Helmlinger (Kistler Group) clarified Mr. Chaekuk’s comments regarding test loads with testing occurring with both loaded and unloaded vehicles in live traffic and static weights for fairness. Mr.

Helmlinger noted changing the test procedure on live traffic and status weights had no impact. Mr. Helmlinger made reference to the current tentative code for the tolerances are wide and questioned how to test currently – use live trucks and a reference scale. Mr. Helmlinger confirmed this is for law enforcement and not commercial weighing. Mr. Helmlinger stated the submitters have worked with NIST and a multitude of states. Mr. Helmlinger stated the item is intended for states that want to use automated enforcement and would not force any jurisdiction to use it. Mr. Helmlinger recommended a Voting status.

Mr. Matt Douglas (State of California, Division of Measurement Standards on behalf of S&T Committee) sought clarification about the line inside the proposed tolerance table and what the purpose of the second statement. On the last line in the table, it says that the gross vehicle weight shall be +/- 10% but it also says $\pm 6\%$.

Mr. Helmlinger addressed Mr. Douglas comments and clarified the 6% is for gross vehicle weight with a 95% compliance. Mr. Helmlinger referred to the proposed tolerance table and noted the outcome cannot have more than 5% of the values outside the tolerance. Mr. Helmlinger stated if any value is outside of 10% accuracy, then it fails the test. 95% of the values must be within the values.

Mr. Jan Konijnenburg (NIST Associate) confirmed NIST has been involved with this item but has not reviewed the proposal in detail to come to a conclusion. Mr. Konijnenburg made reference the WIM code that currently exists is idle and obsolete. Mr. Konijnenburg acknowledged this is a method of a WIM system enforcement. Mr. Konijnenburg stated he is looking forward to how this will develop. Mr. Konijnenburg made no recommendation at this time for the status of this item.

Mr. Raymond Johnson (Fairbanks Scales, Inc., representing the Scale Manufacturers Association) commented the SMA has not met and has not formulated a position on this item. Mr. Johnson commented the SMA is scheduled to meet in November 2022.

Mr. Douglas commented he believes that there is some merit to some of the item. Mr. Douglas recommended keeping the accuracy class “A” and add accuracy class “E”.

Mr. Kenn Burt (San Luis Obispo County, California on behalf of S&T Committee) sought clarification if industry has seen this proposal and understand what they might be dealing with regard to how the WIM system will be used and applied for enforcement?

Ms. Tanvi Pandya (New York City DOT) addressed Mr. Burt’s question regarding industry reviewing this item. Ms. Pandya commented the submitters have met regularly and developed a task force. Ms. Pandya commented the task force has discussed this for the past several months. Ms. Pandya commented they have not directly engaged with the trucking industry but have spoken with some freight industry in general.

Mr. Helmlinger commented the Commercial Vehicle Safety Alliance (CVSA) has been made aware of this item.

During open hearings there was testimony that neither the SMA nor NIST has evaluated this proposal. The committee looks forward to the analysis of this item by NIST and SMA. The Committee asked the submitters questions about the tolerance table “T.2.2. Tolerances for Accuracy Class E”, specifically the last line in the table. The submitter clarified their statement made during open hearings in the Committee work session. The Committee recommended that the submitter consult the Scales Code for similar applications to expressing tolerances.

The WWMA S&T Committee recommended that this item be assigned a Developing status.

The following comments were received during the 2022 SWMA Annual Meeting:

Dr. Nasif presented a presentation he stated that the device currently operates within 6% of the Type III ASTM Standard. The submitter stated that their intentions is for direct enforcement fines to not apply within 10 % of weight limit based on local enforcement procedures.

Mr. Peter Fedechko (International Road Dynamics) stated that he supports this item.

Mr. Chesser (Arkansas) stated that he liked the language on page 167 lines 25-28. He asked why strike paragraph B. He also cited some errors on page 170.

Mr. Paul Floyd (Louisiana) stated that he has concerns about the accuracy of this system. He stated that he would support this item for screening purposes and recommends it moving forward as Developing.

The SWMA S&T Committee asked about the speed and weight requirements used for testing in the proposal not matching with what the devices will be used to regulate. The Committee also questioned whether these devices would receive a type evaluation from NTEP if specifications were added to the handbook. Additionally, the Committee questioned whether a direct enforcement procedure should be separated from the tentative screening code.

The SWMA S&T Committee recommended this item move forward as a Developing Item.

Northeastern Weights and Measures Association

A presentation was given from the submitters of this item. The submitters reminded the body that this item deals exclusively with law enforcement scales, and not commercial scales.

Mr. John Mcguire (New Jersey) inquired about a 10% leeway in gross weight and believes that if a law enforcement agency is writing summonses, the tolerance should be tighter. He also inquired if the SMA and NIST had a position on this proposal.

Ms. Dawn Harrison (New York City Department of Transportation) indicated that the 10 % leeway was chosen as a local enforcement policy because they believe that percentage on gross vehicle weight falls within tolerances of WIM systems and wants to target heaviest offenders. Any violations written by law enforcement have to be reviewed prior to issuance.

Mr. Helmlinger indicated that the system will be tested to a 6% tolerance and fines would be issued at 10%.

Mr. Jim Willis (New York) stated that his understanding is there is a concern with both axel weights and gross weights of the overweight vehicles.

Ms. Diane Lee (NIST OWM) inquired if this system will be used to provide official weight or estimation, and if weight is not correct are they going to weigh station to get official weight.

Mr. Helmlinger indicated that during testing, they will be tested with a certified field reference scale and vehicles.

Mr. Jason Flint (New Jersey) pointed out that the 10% leeway is a local enforcement decision and will not appear in the handbook as a tolerance.

Mr. Willis has concerns with the number of runs required to test the system.

Mr. Czinku stated that WIM is a mature technology and can provide reliable output and weighments.

Mr. John McGuire (New Jersey) recommended the item as developing so a further look can be taken into the dynamics of WIM.

Mr. Jason Flint (New Jersey) suggested that an on-site demonstration be made available so regulators can view the system being used.

After hearing comments from the floor, the Committee agreed that the item has merit. Considering the underlying questions about tolerances and test procedures, the Committee is recommending a Developing status.

Central Weights and Measures Association

Mr. Nassif stated that overweight percentages of trucks are impacting roadways and bridges. The screening process in the existing tentative code doesn't apply to enforcement of overweight commercial trucks.

Mr. Helmlinger stated that the tentative code has large tolerances and that's why it isn't being used by most states. The technology has improved to 4 % or 5 % tolerance capability since the tentative code was written. The tentative screening code doesn't hold up in court when overweight tickets are challenged. These changes are for law enforcement purposes; not necessarily commercial. The intent is not to require adoption, but to allow the use by states who wish to utilize it.

Mr. Doug Musick (Kansas) stated that testing involves three truck classes, three different loads, and three different speeds. Is the intention that there are different classes of trucks which are all tested at all three different loads and speeds? What does FHWA mean? Spell out the acronym. Is that in a CFR. which can be referenced?

Mr. Loren Minich (Kansas) remarked that page 168, S.1.7.1. is missing the lettering, but it's that way in the tentative code. Formatting needs fixed. Don't get rid of the current screening aspect of the tentative code. He supports this item moving on its own and not take away the ability of jurisdictions to use the tentative code for screening. Maybe add a second class?

The CWMA S&T Committee recommended this as a Developing Item. The Committee would like more input from jurisdictions who would be affected by removing the screening aspect of the tentative code.

SMA

During the 2022 Fall Meeting the SMA supported removing the Tentative status from this code and it to remain used for Vehicle Screening only.

Rationale: This code is not intended to be used in Commercial applications. Commercial weighing applications, including WIM applications, are covered in the Scales code.

LMD – Liquid Measuring Devices

LMD-23.3 Automatic Temperature Compensation Task Group

(This item was numbered as LMD-23.3 on the WWMA, SWMA, and NEWMA Agendas and LMD-23.1 on the CWMA agenda.)

Source: Michael Cleary, Retired State of California

Submitter's Purpose and Justification:

Revisit implementing Temperature Compensation of motor fuel at retail.

Given the skyrocketing price of gasoline and diesel fuel the Conference should study the impact on the American consumer.

OWM Executive Summary for LMD-23.1 – Automatic Temperature Compensation Task Group

OWM Recommendation: This item was withdrawn by all 2023 Fall Regional Weights and Measures Associations prior to the 2023 Interim Meeting as such the item does not appear on the Interim Meeting Agenda.
--

Item Under Consideration:

Form a task group to research the issue of Automatic Temperature Compensation for retail fuels.

NIST OWM Detailed Technical Analysis:

This item was not included on the 2023 NCWM Interim Meeting Agenda; thus, no NIST OWM analysis is provided.

Regional Association Reporting:

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received: Mr. Prentiss Searles (American Petroleum Institute), stated that this is not a complete request; this task was addressed several years ago. There is no change in data or outcome, and we do not need to revisit.

Mr. Scott Simmons (Colorado Division of Oil and Public Safety) agrees with Mr. Searles' comments.

Mr. Kevin Schnepf (California Division of Measurement Standards) stated that California did a study and concluded that the cost far outweighed the benefit. Mr. Schnepf recommended the withdrawal of this item.

During open hearings, comments from the floor supported the withdrawal of this item. The WWMA S&T Committee feels that this item is not a complete proposal, that the proposal does not have merit as the topic has previously been reviewed and recommends that this item be withdrawn.

Southern Weights and Measures Association

At the 2022 SWMA Annual Meeting, Dr. Matt Curran (Florida) stated that NCWM has seen proposals similar to this one in the past. He referenced a study from the California Energy Commission that determined the net cost difference observed before and after adding temperature compensation was very small. He also suggested that, if the item ends up being withdrawn, the submitter may consider sending it to FALS.

Mr. Prentiss Searles (API) stated that he did not support this item, and recommend it be withdrawn. Mr. Chesser (Arkansas) agreed with Mr. Searles. Mr. Ramsburg (Maryland) opposed this item and recommended withdrawal. Mr. Tory Brewer (West Virginia) opposed this item. Mr. Stokes (South Carolina) recommended this item be withdrawn. Mr. Murnane (Seraphin) stated that he totally disagrees with this item and recommends its withdrawal.

The SWMA S&T Committee recommended this item be withdrawn.

Northeastern Weights and Measures Association

At the 2022 Interim Meeting Mr. Searles, Mr. John McGuire (New Jersey), Mr. Jason Flint (New Jersey) requested that the item be withdrawn as no information or direction was given in the proposal. Ms. Diane Lee (NIST OWM) indicated that temperature compensation for retail motor fuel devices had been discussed in 2005 and was not approved by NCWM. Mr. Lou Sakin (Holliston, Massachusetts) and Mr. John Gaccione (Westchester County, New York) referenced a California study which determined cost of retrofitting devices would far outweigh any savings.

After hearing comments from the body, the Committee agreed with the comments that this item does not have merit and is recommending that this item be Withdrawn.

Central Weights and Measures Association

At the 2022 CWMA Interim Meeting, Mr. Loren Minnich (Kansas) stated that he does not support. He also noted that the item be Withdrawn and that it has already been thoroughly studied.

Mr. Michael Keilty (Endress+Hauser) noted that LMD-23.1 (LM-23.1 is also assigned to a separate item Block 1.

Mr. Craig VanBuren (Michigan) requested that the item be withdrawn. Mr. Greg VanderPlaats (Minnesota) requested withdraw. Mr. Searles requested that the item be Withdrawn.

The CWMA S&T Committee recommended this item be withdrawn. The Committee requested that these items be renumbered.

LMD-23.4 N.3.5. Wholesale Devices.

Source: American Petroleum Institute

Submitter's Purpose and Justification:

Clarification that Small Volume Provers are included in N.3.5. Wholesale devices.

The 1996 NCWM agreed that small volume provers (SVP) are suitable as a test standard. The 1996 changes included modifications to paragraph N.3.5. to remove barriers for technology that could achieve the maximum flow rate of the product flowing through the meter.

That said, portions of the text in paragraph N.3.5. have been interpreted to prohibit the use of an SVP because the paragraph states, that the delivered quantity for the meter test (1) “should be equal to at least the amount delivered by the device in one minute at its maximum discharge rate” and (2) “shall in no case be less than 200 L (50 gal).” Given these criteria, an SVP could meet the first requirement, and may not meet the second requirement unless the base prover volume was at least 200 L (50 gal). Research indicates that a reference to a 50 gallon minimum draft has been in the Handbook since 1937. The size of wholesale meter deliveries when the 50 gal minimum was established in paragraph N.3.5. is not reflective of the discharge rates of meters used today in commerce.

Therefore, modifications are warranted to paragraph N.3.5. to clarify that SVP's that are properly sized for the test, which can include having a base prover volume of less than 50 gallons, achieve the accuracy required to meet the original design of N.3.5. The proposed additions clarify that the test device – whether SVP, neck-type prover, or another type of test standard – must be capable of testing the maximum flowrate through the meter being tested. The phrase “and shall in no case be less than 50 gal,” is deleted as SVPs with smaller volumes (e.g., 20-gallon base prover volume) are capable of testing wholesale devices at flowrates exceeding 600 gallons per minute.

In 1996, the weights and measures community gathered data and published a report that recognized the suitability of the SVP as a test standard for liquid measuring devices. Additionally, a 105 series (*Specifications and Tolerances for Reference Standards and Field Standard Weights and Measures*) standard exists for Dynamic SVPs.

Over the last 25 years, SVP technology has improved significantly and API Manual of Petroleum Measurement Standards (MPMS) Chapter 4.6, *Pulse Interpolation*, provides the appropriate standards that ensure the SVP achieves the necessary measurement tolerances. API standards MPMS has 23 chapters with Chapter 4.2, Displacement Provers covering SVPs. The 3rd Edition of the standard was published in 2003, and an Addendum was issued in 2015. The Committee responsible for Chapter 4.2 includes over subject matter experts that assess the data and consider updates and revisions to the standard. The accepted technology of the SVP's achieves an accuracy, at a 95 percent confidence level, that the calculated based prover volume is within plus or minus 0.029% when three consecutive runs agree within 0.02% of one another. In other words, there is only a 5% probability that the true prover base volume lies outside the range of plus or minus 0.029% of the calculated base volume.

The goals for the proposed modification to paragraph N.3.5 are to:

- Reinforce the 1996 goal to remove any test conditions that would prohibit or restrict the use of an SVP or other methodologies
- Establish fair test conditions within the OEM's intended range of the meter's operating conditions
- Specify the minimum test conditions based on the meter's ratings and the key characteristics for the proving device to conduct a test that demonstrates the meter's performance in a commercial application

- Encompass the concept of both the volumetric neck-type prover and small-volume prover (SVP) test or any other methodologies that may be developed in the future
- Eliminate any language that would circumvent or alter the proper use of testing devices or their results
- Provide guidance on test parameters which meet the Fundamental Considerations without the need for a laundry list of possible test methodologies and equipment. The decision of whether or not to accept a given type of test standard still rests with the Director as outlined in the Fundamental Considerations.

In addition to the action taken on the proposed revision to N.3.5., NIST has suggested it may be helpful to review and provide updates or supplements to the NIST Examination Procedure Outline 25 for Loading Rack Meters and possibly suggest modifications to NIST 105-7, “*Specifications and Tolerances for Reference Standards and Field Standard Weights and Measures: Specifications and Tolerances for Dynamic Small Volume Provers,*” 1997, to provide additional guidance on properly sizing and selecting a suitable size small volume prover for a given metering system. Such guidance would require input from SVP manufacturers as well as regulators.

Some may oppose the removal of the 50-gallon test draft. However, research indicates that a reference to a 50-gallon minimum draft has been in the Handbook since 1937. The size of wholesale meter deliveries when the 50 gal minimum was established in paragraph N.3.5. is not reflective of the discharge rates of meters used today in commerce.

Links to NIST OWM newsletter articles written by Diane Lee on SVPs used in testing commercial measuring systems: **Weights and Measures Newsletter Archives - Field Standards | NIST**

- H-003 Part 1 (2005)
- H-004 Part 2
- H-007 Part 3
- H-010 Part 4
- H-012 Part 5

Background Q&A:

1. Can you explain how uncertainty calculations differ between SVP vs can provers?
 - Tank provers provide a cubic inch uncertainty per 1,000 gallon prover by comparing the volume in the tank vs the volume of the computer.
 - SVPs provide a meter factor that is a ratio of the prover vs the meter for a period between detector switches. In addition, calibrations are performed multiple times and a statistical uncertainty of ~0.027% between calibrations is required.
2. What are the pros of SVPs vs cans?

Small Volume Prover	Volumetric (Can) Prover
Prove in actual operating load conditions (flow, pressure, and temperature) by proving into customer loads	Lower cost to operate

Small Volume Prover	Volumetric (Can) Prover
Prove at multiple flow rates	Can visually see the quantity by viewing the neck
Establish multiple factors that can be applied	No moving part
Faster proving runs	
No need to pump back	
Gravimetric water draw more repeatable	
Lower prove uncertainty	
Higher turn down ratio	
Health Safety Security and Environment (HSSE) - reduced risk / impact to environment	
Digital history of meter performance at all flow rates with Meter Factor Control Chart (MFCC) to evaluate the health of each meter	
Help identify rack issues such as control valve issues as well as identify hydraulic issues that have a direct effect on measurements.	
Repeatability issues are easier to identify	
Repeatability is verified by making the comparison over 5 runs	Tank Provers repeatability is verified by one run after the initial meter factor change

3. How are SVPs certified?
 - NIST Traceable cans in a water draw lab, or NIST Traceable weights in a gravimetric lab.
4. How do the computers calculate the final calibration result?
 - Comparing gross standard volume (GSV) of the meter vs the GSV of the prover
5. How are peripheral equipment used in meter proving calibrated /verified (portable electronic thermometer (PET), Pressure Gauge, Transmitters)
 - PET calibrated via NIST certified
 - Pressure gauges NIST certified
 - PET and gauges used to determine if transmitters are in tolerance

The submitter requested that this amendment be retroactive and that the item be a Voting item in 2023.

OWM Executive Summary for LMD-23.4 – N.3.5. Wholesale Devices.
<p>OWM Recommendation: NIST supports these proposed changes to N.3.5 because it helps to broaden the original intent of the paragraph. We believe the requirements for test drafts were written around the most common test methods at that time. Future requirements for test drafts may be better addressed in the General Code with additional guidance in the Fundamental Considerations or another guidance document.</p> <ul style="list-style-type: none"> • There are several items on the 2023 Interim Meeting agenda that propose changes to Test Draft paragraphs in NIST HB 44.

OWM Executive Summary for LMD-23.4 – N.3.5. Wholesale Devices.

- The test draft items included on the 2023 Interim Meeting Agenda are LMD 23.4, LPG-15.1, MFM-15.1, Block 1, and Block 5.
- The purpose stated for Items LPG-15.1, MFM-15.1 and Block 1, “...to allow field standard meters to be used to test and place into service dispensers and delivery system flow meters..” is already addressed in the fundamental considerations section of NIST HB 44, that states the director has the authority to select the standard used to test commercial devices and we believe Item GEN-23.1 and Block 8 on the 2023 Interim Meeting Agenda adds clarity to how the standard should be selected. The Item Under Consideration for these items adds a test draft paragraph that is specific to the use of field standard meters. The paragraph is problematic for some types of test because the language prevents conducting a complete test of a device. See NIST Technical Analysis for these three separate items.
- NIST HB 44 was written to be non-technology specific, but test draft criteria were written around the current technology most common at that time. When testing a positive displacement meter using an open neck prover there are ramp-up and ramp-down errors that are associated with the test. As such, the test draft has to contain enough volume so that these errors do not contribute greatly to the test of the meter. With the use of different test standards, the ramp-up and ramp-down errors may not be factors that will affect the test but there may be other factors that contribute to error in the test that would affect the test draft.
- LMD-23.4 and Block 5 seek to keep the existing N.3.5. paragraph and make it broader to encompass other field standards.
- Over the years some changes have been made to the Test Draft criteria so that the requirement is more inclusive of other technology such as the change that was made to N.3.5 in 1996 to remove “test draft” and replace it with “delivered quantity” to be more inclusive of SVPs for those states using this technology.
- Technology will continue to change and evolve, and we will need to respond to the number of changes, such as the different standards that will be in use, and the factors associated with different technologies. We will need to ensure an appropriate test draft is selected so that the errors of test method and device under test do not contribute greatly to the test of the device. Coupled with what is already in the fundamental considerations for responsibility for selecting a test standard and what is being proposed in Items Gen-23.1 and Block 8, we believe a solution may be to add a general code requirement with additional guidance in the fundamental consideration for Test draft and consider removing Test Draft from the individual codes and addressing it in the general code in test notes as a suitability requirement. Currently with no alternate proposal in place for Test Draft, the changes in both LMD-23.4 and Block 5 would assist with recognizing the test draft of other standards in use.
- We encourage the submitters of these item, LMD-23.4 and Block 5 to work together to combine the changes that are being proposed to the same paragraph, N.3.5. Wholesale Devices. If the submitters are in agreement with combining these changes a proposed change for the combined items LMD-23.4 and B5: LMD lock 5 is provided below:

OWM Executive Summary for LMD-23.4 – N.3.5. Wholesale Devices.
<p>N.3.5. Wholesale Devices – The total delivered quantity for any required accuracy test should shall be equal to, or is recognized as being representative of, a volume equivalent to at least the amount delivered by the device in one minute at its the meter’s maximum discharge rate and shall in no case be less than 200 L (50 gal).</p> <p>(Amended 1987,and 1996, and 2023)</p>

Table 3. Summary of Recommendations							
LMD-23.4 – N.3.5. Wholesale Devices.							
	V	D	W	A	I	Notes*	Comments
Submitter							
OWM							
WWMA		✓					
SWMA	✓						
NEWMA		✓					
CWMA	✓						
NCWM							
	Letters of Support			Letters of Opposition		Notes	
Industry							
Manufacturers							
Retailers and Consumers							
Regulators							
<p>*Notes Key:</p> <ul style="list-style-type: none"> 1 – Submitted modified language 2 – Item not discussed 3 – No meeting held 4 – Not submitted on agenda 5 – No recommendation or not considered 							

Item Under Consideration:

Amend Handbook 44 Liquid Measuring Devices Code as follows:

N.3.5. Wholesale Devices – The **total** delivered quantity **for any required accuracy test** should be equal to, **or is recognized as being representative of, a volume equivalent to** at least the amount delivered by the device in one minute at **its the meter’s** maximum discharge rate **and shall in no case be less than 200 L (50 gal)**.

(Amended 1987,~~and~~ 1996, **and 2023**)

NIST OWM Detailed Technical Analysis:

The proposed changes to LMD-23.5 N.3.5 Wholesale Devices are being made because the base volume of some SVPs are smaller than that which is noted in paragraph N.3.5. Wholesale device. SVPs operate by collecting a smaller volume, using pulse interpolation, and averaging several runs. As such the test draft paragraph N.3.5 in NIST HB 44, LMD code currently in the handbook that states "...shall in no case be less than 50 gal conflicts with the base volume capacity of some SVPs, which can be varying sizes including 20 gal.

NIST HB 44 was written to be non-technology specific, but test draft criteria were written around the current technology that was most common at that time, which were likely positive displacement meters. As such the proposals LMD-23.4 and Block 5 seek to keep the existing paragraph and make it broader to encompass other field standards.

The current test draft criteria gives consideration to the ramp-up and ramp-down errors associated with a positive displacement meter and the test draft criteria was selected based on these and other factors that would affect a fair test. The size of the test draft was selected such that these operational errors do not contribute greatly to the test measurement.

With other technologies these errors may not exist but there may be other factors that contribute to error in the test that would affect the test draft.

Over the years some changes have been made to the Test Draft criteria so that the requirement is more inclusive of other technology such as the change that was made to N.3.5 in 1996 to remove "test draft" and replace it with "delivered quantity" to be more inclusive of SVPs for those states using this technology and this current proposal.

Technology will continue to change and evolve, and we will need to respond to the number of changes, such as the different standards that will be in use, and the factors associated with different technologies. We will need to ensure an appropriate test draft is selected so that the errors of test method and device under test do not contribute greatly to the test of the device. Coupled with what is already in the fundamental considerations for responsibility for selecting a test standard and what is being proposed in Items Gen-23.1 and Block 8, we believe a solution may be to add a general code requirement with additional guidance in the fundamental consideration for Test draft and consider removing Test Draft from the individual codes and addressing it in the general code in test notes as a suitability requirement.

Currently with no alternate proposal in place for Test Draft, we support the proposed changes in both LMD-23.4 and Block 5 that will assist with recognizing the test draft for other standards in use.

We recommend that the submitters of this item, LMD-23.4 and Block 5 work together to combine the changes that are being proposed to the same paragraph, N.3.5. Wholesale Devices. If the submitters are in agreement with combining these changes a proposed change for the combined items LMD-23.4 and Block 5 is provided below:

N.3.5. Wholesale Devices – The total delivered quantity for any required accuracy test should **shall be equal to, or is recognized as being representative of, a volume equivalent to at least the amount delivered by the device in one minute at its **the meter's** maximum discharge rate **and shall in no case be less than 200 L (50 gal).****

(Amended 1987, ~~and~~ 1996, and 2023)

Regional Association Reporting:

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received:

Mr. Prentiss Searles (API) - Wanted to re-enforce the 1996 goal to remove test conditions that restrict the use of small volume provers. The director has the authority to use or not use the device. Spoke about what a captive displacer is. Worked with NIST on this. There was a concern at the Annual conference that someone could take a 100-gallon prover and use multiple drafts to test a meter with a 500 gallon per minute flow rate, so they added language to address that.

They are ANSI accredited. 95% confidence level that you will be within .029%.

Ms. Letitia Arriaga (Marathon Petroleum) - Supports this item. Acknowledges the change from 1996 and removes the restriction that prohibits it.

Mr. Brent Price (Gilbarco) supports this item. He is concerned that this could be restrictive, 50 gallons is a lot for a proving size. He likes the wording as is with 1-minute maximum flow rate. Agrees with the Central Region's edits.

Mr. Searles stated the proposed language from the presentation is ready for a vote.

Mr. Michael Keilty (Endress+Hauser) - Would not disagree with the use of small volume provers. Works on these standards all of the time. As it pertains here in changes to HB 44, he can't support this revision and does not support this moving forward as a Voting item. It doesn't address the issue at hand, which is the small sample size. This only massages the language. He recommends that this item should be a sub-paragraph, as in Block 1. He recommends that this item remain Developing.

Mr. Searles remarked it is not capturing the entire amount that is being delivered, it's 20 gallons. You will recognize a representative sample, that's what the 20-gallon prover does. The captive displacer can test holding 20 gallons with a resolution of 4 digits from the decimal. It is capable of hitting the accuracy that is required. We believe that it is ready for a vote.

Mr. Keilty stated it is because of the math that Prentiss described, if it is a 20-gallon captive displacement prover the flow computer math says that it's 40 gallons. It's double and that's what the volume is.

During open hearings, the submitter provided a presentation (which will be submitted to the NCWM) which contained updated language to the proposal. The WWMA S&T Committee recommended that this item be assigned a Developing status with the further recommendation that the submitter of this item and Block 5 item LMD-23.2 work together to develop language that will support both of their purposes, including taking into consideration the testimony heard during open hearings.

Southern Weights and Measures Association

The following comments were received during the 2022 SWMA Annual Meeting:

Mr. Searles gave a presentation on this item. He stated that the 50-gallon minimum draft size is not relevant to adequate testing and should be removed.

Mr. Chesser (Arkansas) stated that SVP tolerances are much tighter than traditional methods.

Mr. Keilty (Endress+Hauser) stated that he agrees with Mr. Searles and supports this item. He also stated that he believed this item could describe SVPs separately from fixed neck Provers. He recommended this move forward as a Developing Item.

Mr. Nicholas Suemnick (Marathon Petroleum) supports this item.

Mr. Brent Price (Gilbarco) stated that he supports this item with Mr. Searles' changes.

The SWMA S&T Committee recommended this item move forward as a Voting Item.

Northeastern Weights and Measures Association

Mr. Prentiss Searles (API) gave a presentation on this item. Mr. Searles indicated that there has been a language change to the proposed item after hearing comments from CWMA. Mr. John Hathaway (Total Control Systems/Murray Equip) inquired about the use of "should" in the language instead of "shall" or "must". Mr. Keilty commented that he does not challenge the validity of SVPs, but suggested to the submitter that the language is confusing and brought up volume equivalence. Mr. Keilty suggested that this item should be a line item, separate from wholesale, and should be explained explicitly. Mr. Keilty pointed out that there are three different proposals on this subject and recommends developing status. Ms. Tisha Arriaga (Marathon Petroleum) commented that she supports the item as Voting. Ms. Arriaga feels that the change that occurred in the handbook in 1996 has accepted this test measure. Ms. Diane Lee (NIST OWM) appreciated the presentation and stated that NIST has been working with API. Ms. Lee noted that the requirements for provers in the handbook were created in 1937 and this technology did not exist. Mr. Walt Remert (Pennsylvania) commended the outstanding work done by the group and supports the item as developing. Mr. Jim Willis (New York) indicated that this item is going the right direction with addressing to advances in technology and recommended a Developing status.

After hearing comments from the floor, the Committee agreed that this item has merit. The Committee agreed with the commenters and believed that this item should have a Developing status.

Central Weights and Measures Association

Mr. Searles (API) stated the goal is to reinforce that SVPs are allowed, approved, and are recognized. Wants fair test conditions. This change is only an additional allowance, not a requirement. Feels this is developed and ready for Voting. The approach when using a SVP is to start with a primed line, no air is present. After that, it is accurate at both the ramp up and ramp down portion of the meter operation.

Mr. Doug Musick (Kansas) interpretation of maximum discharge rate can change from state to state. Is it the marked rate or the rate of the installation? It needs to be clarified.

Mr. Dmitri Karimov (Liquid Controls) supported "the meter's" is confusing. Should stay at "its". Also, add the word "continuous" may help. As written, it could imply that tests can be performed by starting and stopping.

Mr. Henry Oppermann (WM Consulting in absentia) submitted comments in writing regarding concerns and opposition.

Mr. Matthew Jambor (Marathon) remarked that SVPs are being used in their terminals. They directly communicate with internal software and limits data entry errors associated with using open neck provers.

Bias can be present in any system, not specific to SVPs (response to HO letter). Side by side testing has been performed in Alabama and Minnesota with traditional provers and SVPs and they netted the same results.

Mr. Keilty stated these are used extensively and are of very high precision. Standards and requirements from API are stricter than NIST Handbook 44. Nomenclature LMD-23.2 is also assigned to a separate item in Block 5.

Mr. Musick stated lots of types and names for this kind of equipment. In a lab setting they could be very accurate and repeatable. In the field, there is a difference. Some do not meet the 1/3 requirement from NIST HB44 Fundamental Considerations. These provers don't capture the error from meter ramp up and ramp down. Ramp up and ramp down are where the errors are, not in the middle of a full flow, which is what the SVPs are testing.

Mr. Craig VanBuren (Michigan) stated their office compared a SVP to a 1000 gal prover in 2005. No longer has the data.

The Committee requested that these items be renumbered. The CWMA S&T Committee believes this item is fully developed and recommend Voting status with the following changes:

N.3.5. Wholesale Devices. – The total delivered quantity for any required accuracy test should be equal to, or is recognized as being representative of, a volume equivalent to at least the amount delivered by the device in one minute of continuous flow at its the meter's maximum discharge rate and shall in no case be less than 200 L (50 gal).

(Amended 1987, and 1996, and 2023)

VTM – Vehicle Tank Meters

VTM-18.1 S.3.1 Diversion of Measured Liquid and S.3.1.1. Means for Clearing the Discharge Hose and UR.2.6. Clearing the Discharge on a multiple-product, single discharge hose.

(**Note:** At the 2020 Interim Meeting the Committee agreed to combine both VTM-18.1 and VTM-20.1. Both items are now one item under VTM-18.1.)

(**Note:** At the 2022 Annual Meeting, this item did not receive sufficient votes to pass or to fail and was returned to the Committee.)

Source: New York and NIST OWM (Carryover from 2018, VTM 1-B) and Murray Equipment, Inc., Total Control Systems

Submitter's Purpose and Justification:

Provide specifications and user requirements for manifold flush systems on a multiple-product, single-discharge hose. Recognize that there is a balance between a mechanism that provides an important safety benefit but also, if used incorrectly, facilitates fraud. Ensure that VTM owners understand their responsibilities when installing such a system and ensure uniformity in enforcement throughout the country and clarify the paragraph to protect vehicle motor fuel quality, retain safe operating procedures when handling vehicle motor fuels, and to prevent fraud during delivery of vehicle motor fuels from vehicle tank meters.

OWM Executive Summary for VTM-18.1 – S.3.1 Diversion of Measured Liquid and S.3.1.1. Means for Clearing the Discharge Hose and UR.2.6. Clearing the Discharge on a multiple-product, single discharge hose.

OWM Recommendation: OWM believes the proposed changes represent a reasonable solution that will help minimize the potential for fraud with the use of manifold flush systems while allowing companies access to the safety-related benefits from the use of such systems in distributing products on VTMs. With the most recent version of the Item Under Consideration, OWM believes this item is ready for vote.

- A manifold flush system allows liquid to be diverted from the discharge line on single hose multi-product VTMs so that liquid of one product is not mixed with liquid of another in the discharge line.
- NIST Handbook 44 already includes provisions allowing the use of manifold flush systems.
 - However, without appropriate safeguards, these systems represent a significant potential for fraud.
 - OWM believes the current Item Under Consideration offers additional safeguards that are not present in the current NIST HB 44 language.
 - These changes will reduce the potential for facilitation of fraud with the design and use of these devices.
- When presented for a vote in 2019, this item (though revised multiple times in response to comments) failed to obtain sufficient votes to “pass” or “fail” and was returned to Committee.
 - Several additional variations to address comments and concerns were subsequently considered.
- In January 2020, this item was combined with a related Item VTM-20.1 (which proposed limits on the use of these systems with specific product types) with the goal of having the submitters of both items work together to reach a reasonable compromise between the two proposals.
- Since January 2020, the submitters of both items have worked to find a compromise that best meets the needs of the community.
- In developing the current proposal, the submitters considered concerns raised regarding the use of these systems, including:
 - the potential for facilitation of fraud with the use of these systems;
 - the potential for cross contamination of products in different tank compartments; and

OWM Executive Summary for VTM-18.1 – S.3.1 Diversion of Measured Liquid and S.3.1.1. Means for Clearing the Discharge Hose and UR.2.6. Clearing the Discharge on a multiple-product, single discharge hose.

- the suitability of using a single meter for multiple product types.
- These concerns were balanced against comments indicating:
 - these same product handling practices have occurred for many years without the use of such systems; and
 - manifold flush systems can offer distinct safety advantages for drivers when flushing product.
- OWM continues to have concerns regarding the safety of delivering products such as gasoline and home heating oil through the same meter (and questions whether a single meter is suitable for such purposes)
 - However, OWM recognizes this is already a widespread practice in the industry and placing a blanket limitation in NIST Handbook 44 may not best serve the community.
- OWM acknowledges the safety advantages of such a systems to the drivers since the drivers do not have to climb on top of the VTM truck to flush product from the line before delivering another product.
- OWM notes that such changes do not preclude a jurisdiction from implementing policies regarding the use of a single meter to dispense multiple different product types.

Table 3. Summary of Recommendations

VTM-18.1 - S.3.1 Diversion of Measured Liquid and S.3.1.1. Means for Clearing the Discharge Hose and UR.2.6. Clearing the Discharge on a multiple-product, single discharge hose.

	V	D	W	A	I	Notes*	Comments
Submitter							
OWM							Email comments NIST OWM (01-04-21)
WWMA		✓					
SWMA	✓						
NEWMA	✓						
CWMA	✓						
NCWM							
	Letters of Support		Letters of Opposition		Comments		
Industry							
Manufacturers							
Retailers and Consumers							

Table 3. Summary of Recommendations							
VTM-18.1 - S.3.1 Diversion of Measured Liquid and S.3.1.1. Means for Clearing the Discharge Hose and UR.2.6. Clearing the Discharge <u>on a multiple-product, single discharge hose.</u>							
	V	D	W	A	I	Notes*	Comments
<p>*Notes Key:</p> <ul style="list-style-type: none"> 1 – Submitted modified language 2 – Item not discussed 3 – No meeting held 4 – Not submitted on agenda 5 – No recommendation or not considered 							

Item Under Consideration:

Amend Handbook 44, Vehicle-Tank Meters Code as follows:

S.3.1. Diversion of Measured Liquid. – No means shall be provided by which any measured liquid can be diverted from the measuring chamber of the meter or the discharge line thereof. However, two or more delivery outlets may be installed if means are provided to ensure that:

- (a) liquid can flow from only one such outlet at one time; and
- (b) the direction of flow for which the mechanism may be set at any time is definitely and conspicuously indicated.

This paragraph does not apply to the following:

- (1) Equipment used exclusively for fueling aircraft.
- (2) Multiple-product, single-discharge hose metering systems that are equipped with systems designed to flush the discharge hose, provided the flushing system complies with the provisions of paragraph S.3.1.1. Means for Clearing the Discharge Hose, **Multiple-Product, Single-Discharge Hose Metering Systems.**

(Amended 2018 **and 20XX**)

S.3.1.1. Means for Clearing the Discharge Hose, Multiple-Product, Single-Discharge Hose Metering Systems. - **Multiple-product, single-discharge hose M**metering systems may be equipped with systems specifically designed to facilitate clearing of the discharge hose prior to delivery to avoid product contamination. In such systems. a valve to temporarily divert product from the measuring chamber of the meter to a storage tank, shall be installed only if all the following are met:

- (a) the discharge hose remains of the wet-hose type;
- (b) the valve and associated piping are approved by the weights and measures authority having jurisdiction over the device prior to commercial use;
- (c) the valve is permanently marked with its purpose (e.g., flush valve);
- (d) the valve is installed in a conspicuous manner and as far from the hose reel as practical;

- (e) the system clearly and automatically indicates the direction of product flow during operation of the flush system; and
- (f) clear means, such as an indicator light or audible alarm, is used to identify when the valve is in use on both quantity indications and any associated recorded representations (e.g., using such terms as “flushing mode” or “not for commercial use”);
[Nonretroactive as of January 1, 2024]
- (g) effective, automatic means shall be provided to prevent passage of liquid through any such flush system during normal operation of the measuring system; and
[Nonretroactive as of January 1, 2024]
- (h) no hoses or piping are connected to the inlet when it is not in use.
(Added 2018) (Amended 20XX)

UR.2.6. Clearing the Discharge Hose.

UR.2.6.1. Clearing the Discharge Hose, General. – A manifold flush or similar system designed to accommodate the flushing of product on single-hose, multiple-product systems is not to be used during a commercial transaction. The following restrictions apply:

- (a) The inlet valves for the system are not to be connected to any hose or piping (dust covers are permitted) when not in use.**
- (b) When the flushing system is in operation, the discharge hose is only to be connected to the port for the product type being flushed from the discharge line.**
- (c) Following the flushing process, indications and recording elements must be reset to zero prior to beginning a commercial delivery.**

(Added 20XX)

UR.2.6.2. Minimizing Cross Contamination. – When dissimilar products are dispensed through a single meter, the user shall take steps to ensure the system is properly flushed to minimize the potential for cross contamination of product in receiving tanks on subsequent deliveries. Dispensing products having radically different characteristics (e.g., gasoline and diesel fuel) through a single meter delivery system is not recommended.

(Added 20XX)

UR.2.6.3. Records. Whenever, prior to delivery, a different product is pumped through the discharge hose to avoid contamination, a record including the date, time, original product, new product, and gallons pumped shall be maintained. These records shall be kept for a period of 12 months and available for inspection by the weights and measures authority.

(Added 2018)

NIST OWM Detailed Technical Analysis:

Mrs. Tina Butcher (NIST OWM), Mr. Jim Willis (New York), and Mr. Jim Hathaway (Murray Equipment) met on December 2, 2021 to discuss the proposed changes to VTM-18.1. There were specific concerns raised with VTM-20.1, which was previously included with this proposal that still needed to be addressed

which included concerns with contamination, safety, and fraud. It was agreed that in order to further develop a joint proposal, there was a need to resolve the concerns addressed in VTM-20.1 to the extent possible. Mrs. Tina Butcher (NIST OWM), Ms. Diane Lee (NIST OWM), Mr. Jim Willis (New York), and Mr. John Hathaway (Murray Equipment) met again on January 3, 2021. As a result of this meeting all parties agreed with the existing Item Under Consideration. In addition, the meeting participants agreed with adding a new User Requirement under UR.2.6. Clearing the Discharge Hose to the Item Under Consideration to address the concerns with the use of manifold flush systems with dissimilar fluids a follows:

UR.2.6.2. Minimizing Cross Contamination. – When dissimilar products are dispensed through a single meter, the user shall take steps to ensure the system is properly flushed to minimize the potential for cross contamination of product in receiving tanks on subsequent deliveries. Dispensing products having radically different characteristics (e.g., gasoline and diesel fuel) through a single meter delivery system is not recommended.

UR.2.6.3. Records. – Whenever, prior to delivery, a different product is pumped through the discharge hose to avoid contamination, a record including the date, time, original product, new product, and gallons pumped shall be maintained. These records shall be kept for a period of 12 months and available for inspection by the weights and measures authority.

(Added 2018)

Discuss points during the December 2, 2021, and January 4, 2022 meetings are outlined below:

• **Contamination and Safety:**

- There is no disagreement over concerns about contamination and safety that can come about from inadvertent mixing of products in a storage tank.
- These concerns, however, are not unique to the use of manifold flush systems.
 - Whether product is flushed using a manifold flush system or by flushing into a compartment from the top opening, the risk of contamination is present and is of concern.
- If flushing is to be prohibited and/or the use of single meter/multiple product applications, it should be universally applied and presented as a separate proposed change to NIST Handbook 44, not just to systems equipped with manifold flush systems.
- Establishing minimum flush requirements might also assist with minimizing contamination.
- See recommendations below under “Dissimilar Fluids” and “Minimum Measured Quantity” that might help address these two concerns.
- It might also be acknowledged that the use of manifold flush systems is intended to address a different aspect of safety and that is safety of the driver when conducting a flush operation; the manifold flush system provides a safer way of accomplishing the task than climbing onto the top of a vehicle tank.

Dissimilar Fluids:

- The original proposal in 20.1 (from Murray Equipment) expresses concerns about the use of a single meter to deliver multiple products and suggests language that would limit the use of

manifold flush systems only to those systems which have individual meters dedicated to individual products.

- Such concerns would appear to apply to all systems, not just those equipped with manifold flush systems.
- If a prohibition is to be added to NIST Handbook 44 regarding the use of individual meters for multiple products, this should be done as a separate requirement not included as part of paragraph S.3.1.

Minimum Measured Quantity (MMQ):

- The concept of establishing a minimum delivery size would seem to help minimize concerns over possible contamination however it may be problematic to craft a requirement to adequately cover all applications.

Fraud.

- The concerns about potential fraud are quite valid and have been expressed in OWM's comments from the inception of these requirements.
- The provisions for manifold flush were modified to include various provisions to limit that potential.
- Proposed changes to the existing language in the original Item 18.1 and as shown in the current "Item Under Consideration" include additional recommendations to minimize the potential for fraud when installing and using manifold flush systems. If the additional provisions are adopted, this would help reduce that potential.

Additional Points – Mechanical Metering Systems:

- Some manufacturers raised questions regarding whether communication between the manifold flush system and mechanical metering systems is feasible, raising concerns about the newly proposed changes to S.3.1.1. Means for Clearing the Discharge Hose paragraphs (f) and (g).
- Those manufacturers expressed intent to explore this point more carefully.

NIST OWM provided previous comments to this item. Some oppose modifications that will restrict the use of manifold flush systems with only certain products. Some oppose use of manifold flush systems unless there is a restriction placed on the products with which the system can be used. The submitters (including NIST OWM) will need to work together to find a solution amenable to both views.

- As noted by Mr. Jim Willis (New York) during the NEWMA meeting, New York, Murray Control Systems, and NIST OWM will work together to finalize a recommendation for this item.
- NIST OWM looks forward to working with the other submitters (New York and Murray Equipment) to find a solution that is more widely supported.
- For reference, OWM has retained the technical comments offered in its original analysis below.

Background to Consider:

- Based on comments at the 2019 NCWM Annual Meeting from the submitters of Item VTM-18.1 (New York & NIST OWM) and with support from the Meter Manufacturers Association, the Committee agreed to modify items (f) and (g) in the proposal and to designate part (g) as nonretroactive as of January 2022 to become retroactive January 2025.
 - At the July 2019 meeting, comments from Murray Equipment noted significant problems with fraud in Europe where they are permitted, suggesting the item be withdrawn.
 - Comments from Florida at the July 2019 meeting suggested limiting the application to only certain products. This issue is addressed in the new Item 20.1 from Murray Equipment, which was subsequently withdrawn and is now included in this item (VTM-18.1).
 - When presented for a vote, the revised item failed to obtain sufficient votes to “pass” or “fail” and was returned to Committee.
 - In reviewing the proposals, one needs to recall that a manifold flush system allows liquid to be diverted from the discharge line on single hose multi-product VTMs so that liquid of one product is not mixed with liquid of another in the discharge line.
 - OWM acknowledges the safety advantages of such a system since the operator does not have to climb on top of the VTM truck to flush product from the line before delivering another product.
 - However, without appropriate safeguards, these systems represent a significant potential for fraud. Concerns have been voiced over this potential at multiple national and regional meetings.
- ***OWM offered the following comments on Item 18.1:***
 - At its Fall 2019 meeting, NEWMA recommended changes to extend the *nonretroactive* date. OWM recognizes this extension may help move the item forward and, thus, help reduce the potential for fraud when using these systems. OWM would also like to hear from the Meter Manufacturers Association regarding the difficulty designing communications between the metering system and the flushing system and the feasibility of an earlier nonretroactive date.
 - At its Fall 2019 meeting, NEWMA also recommended eliminating the *retroactive* date. Given the potential to facilitate fraud and a number of comments received to that effect over the past several years, OWM is concerned with the proposed elimination of the retroactive date. However, if this will allow the item to progress it may represent a viable solution. OWM heard from New York regarding the extensive number of systems already in the field, particularly mechanical ones which may not lend themselves to modification. OWM is also interested in how others view the proposal to eliminate the retroactive date.
 - The remaining regional associations recommended the item be given Developing status to permit the submitters to address concerns raised during the Annual Meeting.
 - Comments from the SWMA voice serious concern about the potential for cross contamination of products. The proposal in Item 20.1 may help to address this by including limitations on the type of products with which these systems can be used.

- OWM believes the term “operational” should be deleted from proposed paragraph UR.2.6.1. since the key point is that the system should not be *used* when a commercial transaction is in progress.
- ***OWM offered the following comments to consider in addressing the recommendations originally presented in VTM-20.1 and now included as part of this item (VTM-18.1):***
 - OWM notes that one jurisdiction (New York) in NEWMA specifically opposes the limitation of product types. The S&T Committee will have to consider how to address this.
 - After discussing the proposed limitation of using manifold flush systems to only products other than engine fuels with News York W&M, OWM recognizes there may be instances where a VTM is used to transport only engine fuels of different types and grades. OWM recognizes that a blanket limitation may unintentionally impact applications that may not have been considered under Item 20.1.
 - While OWM continues to have concerns regarding the safety of delivering products such as gasoline and home heating oil through the same meter (and questions whether a single meter is suitable for such purposes), OWM recognizes this is already a widespread practice in the industry and placing a blanket limitation may not best serve the community. OWM suggests working with the submitter of 20.1 to see if there are ways to resolve specific concerns without impacting other applications.
 - In its review of these issues, OWM also noted the need to clarify when paragraph S.3.1.1. applies and suggests the addition of the terms “multiple-product, single discharge hose” to both the title and preamble.

Summary of Discussions and Actions:

Manifold flush systems are typically used on VTM’s with multiple compartments, delivering multiple products through a single hose. The purpose of the system is to allow the driver a means of clearing the hose of product prior to delivery (e.g., clearing the hose of diesel fuel before delivering clear kerosene). These types of systems are often marketed as a safety feature in that it eliminates the need for the driver to climb on top of the truck to clear the hose. Such systems are also useful in helping avoid cross-contamination. Typically, the driver attaches the nozzle to the manifold and pumps product back into the supply tank via the manifold until the previous product is flushed from the hose. There is often a sight gauge which allows the driver to tell when the product is flushed.

The obvious concern is that this makes it very easy for the driver to circulate product through the meter prior to delivery, which goes against S.3.1. It should be noted that it also goes against S.3.1. when the driver climbs on top of the tanker and clears the hose. The submitter has voiced concerns involving the safety of this practice noting that the operator could be subject to falls from the tanker. The distance between the flush system and the hose reel is also a factor in how easy it is for the driver to facilitate fraud.

Manifold flush systems are available from OEMs and can be found in various catalogs. Looking on multiple websites, these systems are being installed across the country and for some manufacturers seem to be standard equipment for new trucks. The submitter of VTM-1 has also seen these systems installed on trucks that are for sale where the seller notes the system as a selling point. He can foresee these systems being mandated in the future as a safety requirement and would like W&Ms to have a clear policy before that happens.

Another concern is with systems fabricated onsite. These systems are often difficult to distinguish and installed in an inconspicuous manner. While the submitter of VTM-1 has ordered many of these systems out-of-service until repaired, it can be frustrating for the owner because the truck was used in another state for years and approved by weights and measures jurisdiction in the other state. This lack of uniformity is problematic for both officials and private industry.

This item was originally submitted by New York Department of Agriculture as a Developing Item. The item was intended to encourage uniformity in how manifold flush systems were being designed, installed, and regulated with the goal of minimizing the facilitation of fraud through the use of these systems while realizing the safety benefits provided by such systems.

This item was one of two separate parts of VTM-1 (previously VTM-1A and VTM-1B) considered by the Committee at the 2018 NCWM Annual Meeting. The item voted on at the 2018 Annual Meeting, VTM-1A was adopted and VTM-1B was assigned an Informational status and carried-over to the next cycle.

In the period between 2018 and 2021, the Item Under Consideration underwent multiple changes based on feedback received at regional and national meetings and, more recently based on collaborations amongst the submitter of this and other related items, which resulted in the current Item Under Consideration. In developing the current proposal, the submitters considered concerns raised regarding the use of these systems, including the potential for facilitation of fraud with the use of these systems; the potential for cross contamination of products in different tank compartments; and the suitability of using a single meter for multiple product types. These concerns were balanced against comments indicating that product handling practices have occurred for many years without the use of such systems and there are distinct safety advantage for drivers when these manifold flush systems are used.

At the 2022 NCWM Interim Meeting, the Committee heard from Mr. Willis and provided an update that contained amended language with modifications to UR.2.6.2 and creating UR.2.6.3. The amendments were agreed upon by the other joint submitters, NIST OWM, and Murray Equipment. Mr. Willis stated that the new proposed language would hold device owners responsible for ensuring there is no cross-contamination of fuels and also allows jurisdictions to prohibit using manifold flush systems or dispensing dissimilar products through a single meter. The Meter Manufacturers Association (MMA), Mr. John Hathaway (Murray Equipment), Ms. Cheryl Ayer (New Hampshire), and Mr. John McGuire (New Jersey) also voiced support for the amended language and urged the item be given a Voting status. Mr. Hal Prince (Florida) opposed the entire item, indicating the use of a single meter to dispense different products is not legal in his state and has concerns of cross-contamination of fuel. During the Committee work session, the Committee assigned this item a Voting status with the amended language seen above as the Item Under Consideration. The item as presented to the 2022 NCWM Interim Meeting can be seen below the Item Under Consideration.

At the 2022 NCWM Annual Meeting, the Committee heard in its open hearings and voting session that some commenters were in favor of making the item retroactive.

Mr. Dmitri Karimov (speaking on behalf of the MMA) commented that the proposed changes are intended to reduce the potential for fraud and increase driver safety and the MMA supports the proposal as written.

Mrs. Tina Butcher (NIST OWM) reiterated comments presented in the OWM's Executive Summary (as shown earlier in this item). She commented that OWM believes the proposed changes are a reasonable solution to incorporate additional provisions that will help further reduce the potential for fraud when these systems are in use and acknowledges the potential benefits to driver safety during a flushing operation. The proposed changes offer additional safeguards to already existing language. She also shared that the three submitters (New York, Murray Equipment, and NIST) have done a lot of work on this item since January

2020 and have strived to balance the concerns and comments expressed over fraud and cross-contamination with those of the distinct safety advantages for the driver. She also observed that the practice of flushing is already a widespread practice, but additional provisions are needed to limit fraud when manifold flush systems are used.

Mr. Willis shared that these manifold flush systems are already in widespread use in New York. Smaller businesses use them and this provides a safer method for the flushing operation. He believes the item is fully developed and ready for a vote.

Mr. Hathaway stated his support for the item and indicated he agrees with most of the changes made and supports the item as a voting item. Contamination is not eliminated entirely with these systems, but is minimized, particularly with the addition of the proposed user requirement UR.2.6.2. Minimizing Cross Contamination. He continues to believe, however, that companies should not dispense dissimilar fuels through a single manifold system. In those cases, there needs to be two sets of meters and two manifold systems.

The Committee also heard comments in opposition to the proposal and original paragraph and also heard questions and concerns regarding the proposed nonretroactive status of some portions of the proposal.

Mr. Hal Prince (Florida) opposed the proposal, noting he cannot endorse a device that can facilitate cross contamination of fuel. He stated that Florida will not allow these systems to be used. His major concern is with systems delivering engine fuels; he believes manifold flush systems should be prohibited on such systems. Mr. Prince also noted the irony of changes made to ASTM standards relative to ensuring high quality fuels and then two weeks later considering the approval of a proposal such as this. He commented that the proposed language in UR.2.6.2. Minimizing Cross Contamination is a bit misleading, noting the act of properly flushing a system can cause contamination.

Mr. Charlie Stutesman (Kansas) observed that product flushing is already being done, but in a less safe manner. He commented that drivers should probably not go to the top of the vehicle tank for safety reasons and, if it's safer to carry out that procedure on the ground, this is the direction to go. Mr. Stutesman also noted his state is starting to see meters equipped with multiple calibration factors and he expects more vehicles will be going to a single meter system so we need something to address this. He questioned whether manifold systems can be retrofitted and asked if the requirements can be made retroactive rather than allowing these systems to operate without the additional safeguards.

Mr. Kevin Schnepf (California) indicated he agrees with the concerns shared by Mr. Prince and Mr. Stutesman. He also opposed the last sentence in the recommended UR.2.6.2. Minimizing Cross Contamination, noting that the word "recommended" is not sufficient for regulatory action. He also observed that the phrase "radically different" is rather subjective making enforcement difficult.

Ms. Angela Godwin (San Bernadino County, California) agreed with the concerns regarding the nonretroactive status of some portions of the proposal and recommends those be made retroactive.

Ms. Ayer supported the item but likes the idea of making the nonretroactive portions of the proposal retroactive.

During the voting session, Mr. Willis suggested some changes that might help address Mr. Prince's concern. He offered a proposed change of adding the phrase "at the discretion of the jurisdiction" to portions of the proposal to make it clear that the use of these systems is up to the jurisdiction with regulatory authority and allow decisions to be made within the jurisdiction regarding their use. However, this suggestion did not appear to satisfy the concerns raised.

In its addendum sheets, the Committee also recognized comments from previous meetings that time may be needed to facilitate the changes required. The Committee recommended no change to the Item Under Consideration in Publication 16 and presented the item for a vote. At the voting session, the Committee again heard comments opposing the non-retroactive status. However, the Committee presented the item as written based on the rationale shared in its addendum sheets.

This item did not receive sufficient votes to pass or to fail and was returned to the Committee. The Committee hopes the submitters will consider the comments heard during the meeting and continue work on the item.

Regional Association Reporting:

Western Weights and Measures Association

During the 2021 Annual Meeting Open Hearing the following comments were heard:

Mr. Matt Douglas (California - DMS) remarked that California supported further development. Has there been any further development since the Annual Meeting?

The WWMA S&T Committee recommended the status remain Developmental. The Committee recommended that the submitters (NIST, New York, and Murray Equipment) continue their work together to further develop the item.

During the WWMA 2022 Annual Meeting the following comments were received:

Mr. Scott Simmons (Colorado Division of Oil and Public Safety) supported this item. Flushing is happening already. It is dangerous to flush into the tank. You can run different products through the electronic meters very easily due to multipoint calibration. They need to be able to flush products through and do so safely. He thinks this is fully developed and it's time for it to pass and be part of the code.

Mr. Michael Keilty (Endress+Hauser and Chair of the NTEP Measuring Sector) stated they talked about test drafts and this item. The Measuring Sector has no recommendations. The absence of the word electronic; how would you do this with an analog system? It was described that you cannot do this with an analog system.

Mr. Kevin Schnepf (California Division of Measurement Standards) stated he did not oppose to this item, wants to bring up that his concerns have not been addressed, "radically different characteristics" and "not recommended" is not an avenue for enforcement. Needs further developing.

Mr. Scott Simmons (Colorado Division of Oil and Public Safety) - it may not be appropriate for older analog devices; however, they have been doing it and will continue to do it on the newer technology. Does not need to be retroactive. Agrees with Mr. Schnepf to a point but doesn't want that to prevent this from going forward.

During open hearings, the Committee heard testimony in support of the item but there are concerns about language contained in UR.2.6.2. including "radically different" and "not recommended" with reference to enforceability. There were also comments regarding applicability to analog devices. The WWMA S&T Committee recommends that this item be assigned a Developing status.

Southern Weights and Measures Association

NIST OWM Analysis
2023 NCWM Interim S&T Agenda Items
1/5/2023

During the 2021 Annual Meeting Open Hearing no comments were received on this item. NIST requests this item remain Developmental.

This Committee recommended the status remain Developing at the request of the submitter.

The following comments were received during the 2022 SWMA Annual Meeting:

Mr. Jason Glass (Kentucky and NCWM S&T Committee member) proposed the following amendment to this proposal:

VTM 18.1

UR 2.6.2.

This system shall not be used for products, that when exposed to one another, will cause either of those products to not meet their respective quality specifications.

Mr. Prince (Florida) stated that he has been concerned with weak language on cross contamination in the past.

Mr. Keilty (Endress+Hauser) stated that “electronic” should be added between hose and metering on page 187 line 10.

The SWMA S&T Committee recommended moving this item forward as a Voting Item with the proposed language from Mr. Glass replacing the current UR 2.6.2. language.

Northeastern Weights and Measures Association

During the 2021 NEWMA Interim Meeting open hearings, comments were heard from Mr. Jim Willis (New York) as submitter of this item. He stated that communication was in process with Murray Controls in regard to changes to this proposal. The flushing “systems” have been around for decades and not just as OEM systems. The driver would climb on top the truck to flush a line. Now they can flush the hose without the danger of falling off the truck. Some suggestions have been made to limit the products carried on the truck to similar products. NYS does not support such language as the flush system actually allows for the safe clearing of the hose and minimizes contamination. A flush manifold enables a truck to carry different products at the same time.

Mr. Willis recommended further development.

Mr. Lou Sakin (Hopkinton/Northbridge, Massachusetts) asked when development may be finished. Mr. Willis responded that hopefully by the NCWM Interim Meeting.

Mr. John McGuire (New Jersey) supported Developing status.

The NEWMA Specifications and Tolerances Committee recommended that this item remain in Developing status and encouraged New York, NIST, and Murray Controls to continue working towards full development.

During the 2022 Interim meeting Mr. Willis recalled a recent incident in New York where a tank-truck that was next to inspectors testing a vehicle tank meter experienced an issue after possible switch loading in which static discharge caused an explosion. An employee of company received burns and a broken leg while the inspectors were knocked to the ground. Mr. Willis urged a Voting status on this item due to safety considerations. Mr. Michael Keilty (Measuring Sector Chairman) commented that this system should be

identified as “electronic” as it will not work with an analog system. Mr Keilty also noted that in UR-2.6.2 “dispensing products with radically different characteristics...not recommended” is vague. Mr. Hathaway commented that he was surprised it was not accepted at NCWM Annual in 2022 and would like to understand what could be changed so that it passed. Mr. Hathaway noted that flush systems are being used, there is code in HB44 that describes them and the language in this item is making it a more controlled system to prevent contamination and fraud. Mr. McGuire, Mr. Willis, Mr. James Cassidy (Massachusetts), Ms. Ayer, and Mr. Marc Paquette (Vermont) all voiced support for a Voting status.

After hearing comments from the floor, the Committee believes this item has merit and is fully developed.

The Committee recommends this item for a Voting status.

Central Weights and Measures Association

During the CWMA 2021 Interim Meeting, the CWMA heard comments from the floor. Ms. Diane Lee (NIST OWM) commented about this item in the NCWM Annual report. Mr. Charles Stutesman (Kansas) asked if the intent of this item was for vehicle motor fuel or for all items such as home heating oil.

CWMA S&T Committee recommended item as a Developing Item.

During the 2022 CWMA Annual Meeting, the CWMA heard no comments from the floor and recommended this item remain a Voting item.

During the 2022 CWMA Interim Meeting Mr. Dmitri Karimov – Liquid Controls noted that some of these systems contain one meter and two hoses. This would not apply to those. Believe the intent was to refer to a single meter instead of a single hose.

The CWMA S&T Committee believes this item is fully developed and recommends Voting status.

VTM-20.2 A Table T.2. Tolerances for Vehicle Mounted Milk Meters.

(Note: This item was revised based on changes that were made by the Committee at the 2021 Interim Meeting.)

(Note: The Item Under Consideration was removed from the voting consent calendar at the 2021 Annual Meeting and the S&T Committee made this a Developing Item.)

Source: POUL TARP A/S

Submitter’s Purpose and Justification:

Change tolerances to accommodate more efficient milk-metering systems.

OWM Executive Summary for VTM-20.2 – Table T.2. Tolerances for Vehicle Mounted Milk Meters.
OWM Recommendation: OWM supports the Assigned status for this item and encourages the task group to continue its review of the proposed OIML tolerances for Vehicle Tank Milk Meters.
<ul style="list-style-type: none">• One of the questions raised concerning the current proposal that includes the OIML tolerances is that the proposal includes tolerances for the system and a separate tolerance for the meter.

- NIST OWM observed that a separate tolerance for the meter would apply during OIML type evaluation. However, NIST HB 44 only includes requirements for the entire measurement system and not separate main elements nor does it have separate tolerances for main elements known to be metrologically significant.
- NIST OWM will look forward to more discussion of this item during task group meetings.

Table 3. Summary of Recommendations							
VTM-20.2 Table T.2. Tolerances for Vehicle Mounted Milk Meters.							
	V	D	W	A	I	Notes*	Comments
Submitter/Task Group							Task Group Documents: <ul style="list-style-type: none"> • Milk Meter Tolerance Spreadsheet (01-14-2021) • Milk Meter Tolerance Report (Task Group, 07-19-21) • Proposed Tolerance Tables (01-10-2022) • Milk Meter NTEP CC Data (01-10-2022)
OWM							
WWMA				✓			
SWMA				✓			
NEWMA				✓			
CWMA				✓			
NCWM							
	Letters of Support			Letters of Opposition		Notes	
Industry				Agri-Mark (01-13-20) Dean Foods (01-14-20) Dairy Farmers of America (01-14-20) Danone North America (01-15-20)			
Manufacturers							
Retailers and Consumers							
*Notes Key: <ul style="list-style-type: none"> 1 – Submitted modified language 2 – Item not discussed 3 – No meeting held 4 – Not submitted on agenda 5 – No recommendation or not considered 							

Item Under Consideration:

Amend Handbook 44, Vehicle-Tank Meters Code as follows:

T.2. Tolerance Values. – Tolerances shall be as shown in Table 1. Accuracy Classes and Tolerances for Vehicle-Tank Meters Other Than Vehicle-Mounted Milk Meters and Table 2. Tolerances for Vehicle-Mounted Milk Meters.

(Amended 1995, ~~20XX~~)

Table 2. Tolerances for Vehicle-Mounted Milk Meters		
Indication (gallons)	Maintenance Tolerance (gallons)	Acceptance Tolerance (gallons)
100	0.5	0.3
200	0.7	0.4
300	0.9	0.5
400	1.1	0.6
500	1.3	0.7
Over 500	Add 0.002 gallon per indicated gallon over 500	Add 0.001 gallon per indicated gallon over 500

(~~Added 1989~~)

Table 2. Tolerances for Vehicle-Mounted Milk Meters		
	Acceptance Tolerance	Maintenance Tolerance
Complete Measuring System	0.5 %	0.5 %
Meter Only	0.3 %	0.3 %

(~~Amended 20XX~~)

NIST OWM Detailed Technical Analysis:

A Milk Meter Task Group Meeting last met on January 3, 2022 to further discussed the proposed tolerances for Milk Meters. This is a proposal to increase the tolerances for vehicle mounted pump metering systems that measure milk and the proposed tolerance are those used in OIML for milk measuring systems.

Collected volume	Proposed Tolerance		Current NIST Tolerance		Proposed Tolerance		Current NIST Tolerance	
	Maintenance		Maintenance		Acceptance		Acceptance	
	Gallon	Percent %	Gallon	Percent %	Gallon	Percent %	Gallon	Percent %
50 Gallon	0.25	0.5 %			0.25	0.5 %		
100 Gallon	0.5	0.5 %	0.5	0.50 %	0.5	0.5 %	0.3	0.30 %

NIST OWM Analysis
 2023 NCWM Interim S&T Agenda Items
 1/5/2023

200 Gallon	1	0.5 %	0.7	0.35 %	1	0.5 %	0.4	0.20 %
300 Gallon	1.5	0.5 %	0.9	0.30 %	1.5	0.5 %	0.5	0.17 %
400 Gallon	2	0.5 %	1.1	0.275 %	2	0.5 %	0.6	0.15 %
500 Gallon	2.5	0.5 %	1.3	0.26 %	2.5	0.5 %	0.7	0.14 %

The submitter (Poul Tarp) explained that use of vehicle mounted pump metering systems to measure milk reduces the amount of time needed to collect and process the milk which reduces the cost and loss of product that would occur with a slower measurement process. But, with the use of vehicle mounted pump measuring systems, entrained air is produced that cannot be removed and this air is measured as product. As such, with the use of a pump metering system there is an inherit loss to the buyer. Although the system has means for air elimination, not all entrained air can be removed and this is the submitter’s reason for requesting that the tolerances currently in the HB be increased.

Poul Tarp also noted that it is recognized by the European Standardization Agencies: Measuring Instrument Directive (MID) and Organization of Legal Metrology (OIML) Recommendation (R) 117 *Dynamic measuring systems for liquids other than water* and the dairy industry in general that it is not possible to remove all the air from milk before measuring it. Poul Tarp notes that the MID and OIML (R) 117 standards specify that measurements of a vehicle mounted milk metering system must not result in inaccuracy of more than 0.5 % at any given amount being collected from a minimum of 50 gallons and up to +500 gallons. NIST HB 44 Section 3.31 has a designated tolerance table in volume for vehicle-mounted milk meters that was added to the code in 1989 with an acceptance tolerance of 0.3 and maintenance tolerance of 0.5 gallons for the first 100 gals and these tolerances decrease in percent tolerance as the indicated volume increases, as was reported in a presentation from Poul Tarp:

NIST OWM’s initial points to consider as the Committee began to deliberate on the proposal were:

- Are there other methods that can be employed to remove entrained air from the milk?
- Can the amount of error introduced from entrained air be determined?
- Should NIST HB 44 tolerances be aligned with OIML R 117 less stringent tolerances, as recommended by the submitter.
- Should there be a separate tolerance table to address vehicle mounted pump metering systems?

During the 2019 Interim Meeting another company stated that they met the current tolerances in HB 44 and were issued an NTEP certificate and believe that the current tolerances are appropriate. Other State regulators commented that the current certificate was limited to testing up to 300 gallons. At that time the S&T Committee assigned a task group to this item and NIST OWM expressed interest in working with the task group.

Mr. Charlie Stutesman (Kansas), Chair of the Task Group, sent an email to the Milk Meter Tolerance Task Group (TG) providing a list of the TG members and the TG’s mission. Mr. Stutesman also informed the Task Group that most communication will be conducted via e-mail and that face-to-face meetings will be planned at Interim and Annual Meetings.

The following list contains the names of members on the Milk Meter Tolerance TG:

- Chair – Mr. Charlie Stutesman (Kansas)
 - NEWMA Representative – Mr. Jim Willis (New York)
 - SWMA Representative – TBD
 - WWMA Representative – Mr. Jeff Cambies (California)
 - NTEP Technical Advisor – Mr. Mike Manheim
 - NIST Technical Advisor – Ms. Diane Lee
 - Measurement Canada Technical Advisor – Mr. Luciano Burtini
 - Industry Representative – Mr. Carey McMahon (Poul Tarp)
 - Industry Representative – Ms. Leigh Hamilton (Piper Systems)
 - Industry Representative – Mr. Brandon Meiwes (Dairy Farmers of America)
 - Industry Representative – Mr. Bob Fradette (Agri-Mark)
- Mr. Mitch Marsalis (Los Angeles County, California) has agreed to be the SWMA representative. I am just waiting on formal assignment by the NCWM Chair for Mitch.

Milk Meter TG Mission:

The mission of the Task Group is to review and possibly recommend changes to the tolerances that apply to milk meters, which may include milk measuring systems, in Sections 3.31. Vehicle Tank Meters, Section 3.35. Milk Meters, Section 3.37. Mass Flow Meters, and Section 4.42. Farm Milk Tanks. This TG will consider the tolerances proposed in S&T item VTM-20.2 and the tolerances in OIML R 117-2 “Dynamic measuring systems for liquids other than water” in their discussion.”

Mr. Stutesman provided the Task Group with milk meter tolerances and requirements from OIML-R117-2: 2007, NIST HB 44 Tolerances for Milk Meters that are located in the VTM Code Section 3.31, the Mass Flow Meter Code Section 3.37, and the Farm Milk Code Section 4.42 and Measurement Canada’s tolerances for milk meters and requested feedback from the task group on appropriate tolerances to apply. A Task Group member from Poul Tarp, the original submitter of the item, recommended that the proposal be changed to align NIST HB 44 with the tolerances for milk meters in OIML R-117-2. Mr. Stutesman circulated a proposal for consideration by the task group that would aligns the tolerances in NIST HB 44 Section 3.31 Table 2 with OIML to tolerances. OIML Tolerances seem to apply two different tolerances. 0.5 % tolerance for milk meters in a system and 0.3 % tolerance for a meter outside of a system that is used to measure milk. The proposed tolerances and changes to NIST HB 44 are provided below:

Table 2. Tolerances for Vehicle-Mounted Milk Meters		
Indication (gallons)	Maintenance Tolerance (gallons)	Acceptance Tolerance (gallons)
100	0.5	0.3
200	0.7	0.4
300	0.9	0.5
400	1.1	0.6
500	1.3	0.7
Over 500	Add 0.002 gallon per indicated gallon over 500	Add 0.001 gallon per indicated gallon over 500

Table 2. Tolerances for Vehicle-Mounted Milk Meters		
Indication (gallons)	Acceptance Tolerance	Maintenance Tolerance
Complete Measuring System	0.5 %	0.5 %
Meter Only	0.3 %	0.3 %

Proposed change to Handbook 44- Simple rewrite of table 2 and paragraph T.4. in 3.31 VTM Code and Table 1 in 3.35 Milk Meter Code.

3.31 Vehicle Tank Meters

T.2. Tolerance Values. – Tolerances shall be as shown in Table 1. Accuracy Classes and Tolerances for Vehicle-Tank Meters Other Than Vehicle-Mounted Milk Meters and Table 2. Tolerances for Vehicle-Mounted Milk Meters.

(Amended 1995, 20XX)

If changes to the product depletion test tolerances in Handbook 44 are made to match OIML R117-1 paragraph 2.10.1:

T.4. Product Depletion Test. – The difference between the test result for any normal test and the product depletion test shall not exceed 0.5 % of the volume delivered in one minute at the maximum flow rate marked on the meter for meters rated higher than 380 Lpm (100 gpm) or 0.6 % of the volume delivered in one minute at the maximum flow rate marked on the meter for meters rated 380 Lpm (100 gpm) or lower. Test drafts shall be of the same size and run at approximately the same flow rate. **For vehicle tank meter measuring systems used to measure milk, the effect due to the influence of the air or gases on the measuring result shall not exceed 1.0 % of the quantity measured.**

Mr. Charlie Stutesman also asked the Task Group if consideration should be given to updating all of the codes pertaining to milk metering devices in NIST HB 44 and if all milk metering requirements should be included in a single code.

The NCWM Milk Meter Tolerance Task Group met virtually on January 7, 2020. During this meeting the Task Group discussed:

- the system of milk collection from farm to processor (seller to buyer),
- the operation of metering systems that measure milk to include discussion of air elimination systems,
- review of the milk measuring tolerances in NIST HB 44 from 1919 to 2020,
- review of the proposal to harmonize the NIST HB 44 VTM code milk metering tolerances with OIML tolerances for single milk meters and milk meter measuring systems, and
- whether or not the task group wanted to consider expanding its scope to include combining all milk metering requirements in NIST HB 44 to a single code.

By consensus the Task Group agreed with harmonizing the VTM milk metering tolerance with OIML R 117 tolerances and that those tolerance be presented during the NCWM 2021 Interim Meeting for discussion. The Task Group also agreed that a request should be made to the S&T Committee to expand the scope of the Task Group to include combining milk meter requirements in NIST HB 44 to a single code.

Mr. Stutesman (TG Chair) proposed the TG visit a location to review Milk Measuring systems in use as its next step. The Task Group last met on July 1, 2021.

NIST OWM is looking forward to gaining additional information on the various systems for milk metering and their capabilities and believes the task groups plans to visit a site will be helpful in determining the best approach for acceptable solution for milk metering systems. In the meantime, harmonizing with OIML tolerances may be an acceptable path forward. OWM reiterates its original questions concerning the operation of milk metering systems. OWM encourages the task group to continue its investigation of these systems.

Summary of Discussions and Actions:

A Milk Meter Tolerance Task Group was formed and assigned to this item. Please contact the Task Group Chair for more information:

Mr. Charlie Stutesman
Kansas Department of Agriculture
(785) 564-6681, charles.stutesman@ks.gov

Existing tolerances are based on the accuracy of the Flow meter itself. The proposed Tolerances are based on Milk Metering Systems where the magnetic flow meter is a part of the Milk Metering system handling milk containing air.

The accuracy of the Flow meter will always be influenced by the way it is used. The only way you can obtain the accuracy described by the manufacture is when the flow meter is operating as a “stand alone” unit and, equally important, only if the product passing through the flow meter is complete air-free.

The submitter provided the following:

During the past 20 years, the need for improved efficiency in the collection of milk has resulted in the use of milk pumping equipment being installed on milk tankers.

One of the most obvious places for a modern Dairy to optimize is the amount of time that the milk tanker uses to make a collection. If you can reduce the collection time at each farmer, the Dairy will be able to get a significant reduction in collection and transport cost for the benefit of the Farmer, Consumer and the Dairy itself. At the same time, you will get an environmental benefit as a result of reduced CO₂ in the milk collection process.

The consequence of introducing pump systems on milk tankers is that it causes air to be mixed with the milk which again will influence the accuracy of the magnetic flow-meter mounted in the system. Milk entrains air unlike petroleum liquids which do not. As you know, the flow meter will count anything that passes through the meter – liquid as well as air – and it is therefore essential that as much air as possible is removed from the milk before it reaches the flow-meter. However, it is widely recognized that it is not possible to remove all the air from the milk, which will result in an inaccuracy.

NIST OWM Analysis
2023 NCWM Interim S&T Agenda Items
1/5/2023

It is therefore essential that the tolerances for vehicle mounted milk pump systems using magnetic flow-meters for determining milk volume reflects today's way of collecting milk. This means that existing Tolerance for milk meters cannot be used when the milk meter is a part of a system where different system parts will influence the accuracy of the count. Such milk metering systems will need to be classified with their own tolerances.

Based on our 25 years of experience as a manufacturer of these systems and more than 3000 installations on milk trucks operating in more than 15 countries, we would like to propose that the Tolerance for Vehicle Mounted Milk Metering Systems is changed from 0.3 % to 0.5 % and that the tolerances will be listed and classified separately and not be associated with products from the oil industry. Our proposal is consistent with Weights & Measures tolerances accepted around the world.



We hope that the NCWM will consider our proposal and we will be more than happy to meet with you and answer any questions you may have. We believe that a change of Tolerance is necessary in order for the Handbook 44 to reflect today's milk collection and the technical progress within milk collection.

Yours sincerely

Poul Tarp
President POUL TARP A/S

The POUL TARP milk pump system holds an MID approval which is recognized and in accordance with guidelines and standards described in the **OIML - INTERNATIONAL ORGANIZATION OF LEGAL METROLOGY**

FLOW COMPUTERS REGULATION IN THE US:

EC-Type Examination Certificate
Measuring Instrument Directive

Certificate number: DK-0200-MI005-006
 Issued by FORCE Certification, Denmark
 EC-notified body number 0200

In accordance with the Directive 2004/22/EC of the European Parliament and Council of March 31st, 2004 on measuring instruments (MID) with later amendments.

Issued to: **Ingeniørfirmaet Poul Tarp A/S**
Jomfruløkken 4
DK - 8930 Randers NØ
Denmark

Reference No.: 115-24938

Type of instrument: Milk Measuring System on road tankers (or stationary)


Type designation: PT LVMS - Poul Tarp Liquid Volume Measuring System


Type variants: type 2, type 3 and type 4

Valid until: August 10, 2025

Number of pages: 38 including appendix

Date of issue: August 10, 2015



Approved by: 
Lone Sølvstrup Kristensen
Certification Manager

Processed by: 
Lars Parmo
Examiner

The conformity markings may only be affixed to the above type approved equipment. The manufacturer's Declaration of Conformity may only be issued and the notified body identification number may only be affixed on the instrument when the production/product assessment module (5 or 6) of the Directive is fully complied with and controlled by a written inspection agreement with a notified body. This EC-type examination certificate may not be reproduced except in full, without written permission by FORCE Certification.

Page 1 of 38

FORCE Certification A/S · Park Allé 345 · 2605 Brøndby · Denmark · Tel +45 43 26 71 77 · Fax +45 43 26 70 11 · cert@force-cert.dk · www.force-cert.dk

Appendix to

EC-Type Examination Certificate
Measuring Instrument Directive

Number: DK-0200-MI005-006
 Issued by FORCE Certification, Denmark
 EC-notified body number 0200

Revision	Issue date	Changes
DK-0200-MI005-006	09-01-2015	First issue
DK-0200-MI005-006	10-08-2015	Second Issue

The measuring system has the following characteristics

Accuracy class	0.5
Mechanical class	M3
Electromagnetic class	E3
Climatic class	Condensing/open location, H3
Ambient temperature	-25 / +55 °C
Liquid temperature	0 / +50 °C
Liquid pressure max	1 bar
Liquid types	Milk (Raw milk)
Liquid density	1,035 Kg/L at 5 °C +/- 0,02 Kg/L
Liquid conductivity	≥ 5 µS/cm

Flow characteristics for Measuring System, including Minimum Measured Quantity (MMQ), depends on actual flow sensor Procecs Data 340 series in combination with Gas Elimination Device (GED) used:

MS/Meter	GED	Qmax	Qmax	Qmin	Qmin	MMQ	Inlet
Type	Type	[m³/h]	[L/m]	[m³/h]	[L/m]	[L]	[mm]
Type2+4/C51	PTø355	22,2	600	4	67	300	51
Type3/C63	PTø506	80	1334	5	84/(250)*	300/(100)*	63,5
Type3/C76	PTø506	90	1500	12	200	300	75
Type3/C102	PTø506	90	1500	18	300	300	102

Note: The ratio between Qmax and Qmin of the measuring system, shall be at least 5 (5:1) within the flow rate range of the actual meter sensor in combination with relevant Gas elimination device.
*) MMQ 100 liter only after first delivery on full system.



Primary display on flow computer S12:

Indication:

Maximum capacity	99999 L	or	99999,9 L
Minimum increment of registration	1 L		0,1 L

Page 2 of 38

FORCE Certification A/S · Park Allé 345 · 2605 Brøndby · Denmark · Tel +45 43 26 71 77 · Fax +45 43 26 70 11 · cert@force-cert.dk · www.force-cert.dk

DK-0200-MI005-006

Applied documents


Recommendations	Guides
OIML R117 (1995)	WELMEC Guide 10.5 Marking of fuel dispensers (2006)
OIML R117-1 (2007)	WELMEC Guide 10.6 Sealing of fuel dispensers (2008)
OIML D11 (2004)	
OIML R117-2 Annex – E (CD2)	

Applied Evaluation Certificates belonging to this Type Examination Certificate:

- Evaluation Certificate Force Certification No. 115-24938.05, issued 10.08.2015
- Evaluation Certificate and Description NMI no. TC7204 rev 6, issued 26 august 2014
- Documentation folder NMI no. TC7204-4

Technical documentation
Reference no.: 114-30557.

The standards related to metrological aspects come from OIML R117-1 for liquids (Dynamic measuring systems for liquids other than water, part 1: Metrological and technical requirements) and documents D11 (General requirements for electronic measuring instruments) and D31 (General requirements for software-controlled measuring instruments) from OIML.



At the NCWM 2020 Interim Meeting Mr. Carey McMahon (Poul Tarp) provided a presentation on his company’s VTM milk metering system advocating for expanding tolerances for these systems.

Ms. Leigh Hamilton (Piper) provided a presentation concerning the piper system and stated in her presentation that piper currently has an approved NTEP certificate for their device that is in service in the U.S. Ms. Leigh opposes this item to increase the tolerances for milk meters and noted in her presentation that there may not be a need to increase the tolerances in order to move forward in allowing innovation in milk measurements.

Mr. Charles Stutesman (Kansas) provided a presentation on research that KDA has done on the history of 3 HB 44 Codes (3.31. VTMs, 3.35. Milk Meters, and 4.42. Farm Milk Tanks) and the issue of Piper’s NTEP Certificate. Mr. Stutesman discussed complications involved in measurement of product using various methods and potential shortcomings of Piper’s NTEP Certificate.

Mr. Doug Musick (Kansas) stated that he does not believe there is enough information presented to change existing tolerances and noted that the Piper system was only evaluated for accuracy up to a measurement of 300 gallons. He also noted that he believes that Piper’s certificate should be amended to qualify the system for draft sizes up to 300 gallons. Mr. Mike Keilty (Endress + Hauser) commented that he had concerns with Piper’s certificate. Ms. Hamilton noted that Piper followed and followed guidelines as

provided during the NTEP evaluation. Ms. Diane Lee (NIST OWM) stated that the Committee may want to consider a Developing status for this item and that more information is needed concerning air elimination methods for milk metering systems.

A representative from the Dairy Farmers of America stated that they oppose the increase in tolerance but supports the use of VTM metering systems. Mr. Carey McMahon (Poul Tarp) pointed out that the Poul Tarp system can be accurate for any size measurement, but the beginning and end of the measurement would not be accurate measures (within tolerance) due to entrained air in the product when the flow is not uniform. Mr. Dmitri Karimov (MMA) stated that the proposal should be further developed and pointed out that due to the tolerance structure becoming more stringent as the volume of the measurement increases, the acceptance tolerance at 500 gallons is unreasonable. Mr. Hal Prince (Florida) stated that he does not agree with expanding the tolerances. Mr. Prince believes that air elimination should be the focus and that the proposal should be assigned to a task group. Mrs. Tina Butcher (NIST OWM) noted that testing should be performed using multiple quantities and flowrates. Mr. Charles Stutesman (Kansas) pointed out that confusion is generated by multiple HB 44 codes addressing the measurement of milk and that the proposal should be assigned to a TG to sort this out. Mr. Stutesman also pointed out there is no requirements in HB 44 for air elimination pertaining to milk metering in these codes. Mrs. Butcher noted that the current HB 44 requirements may not be flexible enough for this new technology and that the existing codes may need to be reviewed and updated.

Ms. Leigh Hamilton (Piper) stated that this is not simply a consideration of only a change in tolerances. There are other requirements (currently in the OIML standard) that should also be considered in making any changes to the existing HB 44 requirements. Mr. Mike Keilty (Endress+Hauser) stated that air elimination is a difficult problem to mitigate and noted that he is not sure if it is necessary to expand the existing tolerances or make other amendments. Mr. Carey McMahon (Poul Tarp) stated that using the existing HB 44 tolerances in the VTM Code, at a draft of 5000 gallons, the tolerance value is highly unreasonable. Mr. Charles Stutesman (Kansas) noted that the type evaluation performed on the Piper system was limited to a draft of 300 gallons. If evaluation had included other draft sizes, the Piper system may have failed the testing.

Mr. Ken Ramsburg (Maryland) stated that the proposal should be given a developing status. Mr. Ramsburg agreed that there is no existing requirement for this type of system addressing air elimination and stated that the flow meter, air eliminator, plumbing, and pumps all need to be considered during evaluation and the evaluation should be conducted on the system.

Mr. Tim Chesser (Arkansas) questioned whether the flow meter used in the system is appropriate and noted that there are many unanswered questions surrounding this issue. Mr. Jim Willis (New York) recommended a Developing status for this item. Mr. Kevin Schnepf (California) stated that although he is opposed to relaxing existing tolerances, he supports the development of this proposal by an assigned task group.

During the Committee's work session, the Committee agreed that this item has merit and should be given an Assigned status. The charge to the assigned task group will be to address three HB 44 codes (VTM, Farm Milk Tanks and Milk meters) to review the requirements and tolerances found in these codes and assess the need for changes.

The NCWM 2020 Annual Meeting, due to the 2020 COVID-19 pandemic, was adjourned to January 2021, at which time it was held as a virtual meeting. Due to constraint of time, only those items designated as 2020 Voting Items were addressed. All other items were addressed in the subsequent 2021 NCWM Interim Meeting.

At the NCWM 2021 Interim Meeting, the Committee heard from Mr. Stutesman (who gave an update on the task group activities. Mr. Stutesman reported that the Milk Meter TG worked via e-mail communication and reviewed and discussed the proposed Milk Meter Tolerances in Agenda item VTM-20.2. The Milk Meter Task Group also discussed the tolerances that are included in NIST HB 44 for Milk meters in various parts of HB 44 which include the VTM, Section 3.31, Farm Milk Tanks, Section 4.42., Mass Flow Meters, Section 3.37, and Milk Meters, Section 3.35. Mr. Stutesman also reported that the TG reviewed OIML tolerances for milk meters. Mr. Stutesman stated that after a review of the various tolerances, the Task Group agreed that the OIML tolerances provide tolerances that encompassed the system of measuring milk and not just a tolerance for the performance of the meter. The Milk Meter TG agreed with proposing the use of the OIML milk meter tolerance as the milk meter tolerances in the VTM code. Mr. Stutesman provided a copy of the proposed changes to VTM-20.2. The proposed tolerances will align the tolerances in the VTM Code for Milk Meters with OIML Milk Meter Tolerances. Mr. Stutesman requested that this item move forward as a Voting item. The Committee also heard from Mr. Clark Cooney who noted that he supported the items as Developing because one company mentioned meeting the existing tolerances. It was mentioned that the company’s testing was only performed over a limited range of volumes.

During the Committee’s work session, the Committee agreed with the proposal from the Milk Meter Task Group to adopt OIML tolerances for milk meters in the VTM code, that this item be given a Voting status, and that the Item Under Consideration be replaced with the work group’s proposal to adopt OIML tolerances. The Committee also agreed with expanding the Task Group to address other milk meter codes in HB 44. The Item Under Consideration above are the tolerances agreed to by the Milk Meter TG and that align with OIML tolerances.

At the NCWM 2021 Annual Meeting Mr. Stutesman provided an update on the Milk Meter Task Group activities. Mr. Stutesman noted that there was a field trip to observe milk metering systems. He noted that the proposed tolerances will align the milk tolerances with the OIML tolerances for milk meters and Mr. Stutesman noted that the OIML tolerances provides one tolerance for the meter and another tolerance for a milk metering system. He also noted that it may be impractical to perform an air eliminator test on these devices due to comingling of product.

During the Committee’s work session, the Committee agreed to a Voting Status for this item and added it to its voting consent calendar.

During the voting session, Mr. Stutesman asked that consideration be given to adding a non-retroactive date to the proposed tolerances. It was questioned during the discussion that if a non-retroactive date was added to the tolerances, then, what tolerances would apply to existing meters that had been manufactured and tested prior to the non-retroactive date. One of the concerns expressed with having a new tolerance table without a nonretroactive date was whether or not existing devices would be required to be reevaluated in the NTEP. The conference voted against adding the nonretroactive requirement to the proposed tolerance table and the Item Under Consideration to change the tolerances failed to receive the 27 votes from the House of State Representatives, so the item failed and went back to the S&T Committee. The S&T Committee agreed to a Developing status for this item.

Note: For reference, the Item Under Consideration that was included in the 2021 NCWM Interim Meeting Agenda is provided below:

Table 2. Tolerances for Vehicle-Mounted Milk Meters		
Indication (gallons)	Maintenance Tolerance (gallons)	Acceptance Tolerance (gallons)

Table 2.		
Tolerances for Vehicle-Mounted Milk Meters		
100	0.5 <u>0.6</u>	0.3 <u>0.5</u>
200	0.7 <u>1.2</u>	0.4 <u>1.0</u>
300	0.9 <u>1.8</u>	0.5 <u>1.5</u>
400	1.1 <u>2.4</u>	0.6 <u>2.0</u>
500	1.3 <u>3.0</u>	0.7 <u>2.5</u>

At the NCWM 2022 Interim Meeting Mr. Stutesman (Kansas) spoke as Chair of the Milk Meter TG. He requested that this item be assigned back to the Task Group for further development. Mr. Stutesman provided an update on the Task Group meeting in January 2022 in which they discussed tolerances in both 3.31 Vehicle Tank Meters and 3.35 Milk Meters and the need to have the tolerance be applied to both vehicle mounted and station meters as the manufacturers are developing meters that will be capable of being installed in either application. The tolerance tables can be found in the supporting documents. Mr. Stutesman also renewed the Task Group’s request to expand its scope to include possibly creating a new code that contains requirements of both vehicle mounted and stationary milk meters and metering systems due to the unique properties of milk as a liquid. Speaking on behalf of himself, Mr. Stutesman (Kansas) stated that he has provided a document in the supporting documents that outlines the four active and five inactive NTEP certified meters and metering systems in terms of test draft size and applicable tolerances. He noted that the active four have a range of 0.12 %-0.6 %. He also noted that milk meters are the only liquid measuring device where the volume tolerance decreases as the draft size increases and suggests percentages more in line with OIML tolerance would be more appropriate. Mr. Ramsburg suggested combining the two tolerances to be used for field evaluations. Ms. Lee commented that the Task Group should work toward making all test methods uniform. Ms. Lee also suggested that the Task Group and Committee look at the comments from various companies concerning different tolerance along the distribution line for milk. Mr. Musick and Mr. Matt Douglas (California) supported assigning this item to the Task Group for further development. During Committee work sessions, the Committee agreed to assign this item back to the Milk Meter TG so they may continue to ascertain data. In addition, the Committee agreed to request that NCWM Chairman Hankins expand the scope of the TG to include all reference to milk meters, meter systems and related test methods, specifications and tolerance in an effort to harmonize the codes.

The Committee agreed to an Assigned status for the item.

At the NCWM 2022 Annual Meeting the Milk Meter TG Chair Stutesman, provided a status update of the milk meter task group activities. He mentioned that the task group continues to support proposed tolerances as provided in the Item Under Consideration. He also noted that the goal is consistency of the tolerances for milk meter measuring. He also noted that another representative from the Western is need on the Milk Meter Task group.

At the Committee’s work session, the Committee agreed to keep an Assign status for this item.

Regional Association Reporting:

Western Weights and Measures Association

During the 2021 Annual Meeting Open Hearings the following comments were heard:

NIST OWM Analysis
2023 NCWM Interim S&T Agenda Items
1/5/2023

Ms. Lee put forth by TG working on milk meters. They are still in process of reviewing. It was put forth to vote but last-minute change to make it non retroactive. This put it back to Developing. What would happen to devices that are currently in the field? During the Annual Meeting this was returned back to Developing and NIST supports Developing.

The WWMA S&T Committee recommended the status remain Developmental. During the 2021 S&T Work Session Ms. Lee was asked for further clarification on her testimony. She provided the following clarification: "During the Annual Meeting a proposal was made to add a non-retroactive date. Because questions were raised as to how this would affect existing devices the item was moved from Voting to Developing." The Committee looks forward to hearing from the working group.

During the WWMA 2022 Annual Meeting the submitter was not present, and no comments were heard.

During open hearings, due to timing constraints, the Committee did not take comments on Assigned Items. The Committee did allow the source to provide updates on these items. No update was provided. The WWMA S&T Committee recommended that this item remain Assigned.

Southern Weights and Measures Association

During the 2021 Annual Meeting Open Hearing no comments were received on this item.

This Committee would like to see more evidence and reasoning on why these devices should not have to meet the existing tolerances, and why the tolerances listed are appropriate.

This Committee recommended the item remain Developing so that the submitters can gather more evidence about the accuracy of these devices.

The following comments were received during the 2022 SWMA Annual Meeting:

Dr. Curran (Florida) stated he was concerned about increasing the tolerance for new technology.

No comments were received from the Milk Meter Tolerance Task Group.

The SWMA S&T Committee recommended this item remain as an Assigned Item.

Northeastern Weights and Measures Association

During the 2021 Interim Meeting Open Hearing the following comments were heard.

Mr. Jim Willis (New York) commented as a member of the Task Group about the field trip that was taken in Rochester New York just prior to the NCWM meeting in July to witness the truck mounted Milk Meters in action. The Task Group is asking for recommendations in regard to a tolerance value that people would be comfortable with. Mr. Willis commented that the tolerance of 0.5 % is considered too large by some, but we have 0.4 % in the handbook now in-regards to checking a milk tank with a meter.

Mr. Jimmy Cassidy (Massachusetts) asked if any systems currently meet the requirements in the handbook and Mr. Willis replied that currently there is one milk meter system on tank trucks that meets the requirements currently in the handbook.

The NEWMA Specifications and Tolerances Committee recommended that this item remain in Developing Status.

During the 2022 Annual Meeting Open Hearing Mr. Willis commented as a member of the Milk Meter Task Group. He indicated that the Task Group has made strides and hopes for ability to perform additional work on the item.

After hearing comments from the floor, the Committee recognized the need for further development of the item and recommended that the item retain an Assigned status. The Committee recommended the NCWM Milk Meter Task Group continue to work with stakeholders to further develop this item.

During the 2022 NEWMA Interim Meeting, no comments were heard from the floor, however the Committee recommended that this item retain an Assigned status with the Milk Meter Tolerance Task Group.

Central Weights and Measures Association

During the 2021 Interim Meeting Open Hearing, the Committee heard comments from the floor. Mr. Charles Stutesman (Kansas) would like to see item be returned to Task Group.

CWMA S&T Committee recommended that the item be assigned to Milk Meter Tolerance Task Group and be an Assigned Item.

During the 2022 Annual Meeting Open Hearing Mr. Stutesman (following 2022 NCWM Interim Meeting, this item was sent back to the MMTTG. Moving forward with staying with original tolerances that were proposed. Request to expand scope has been submitted. There will be a MMTTG meeting prior to the July annual meeting. Hoping to move forward and elevate to Voting status for next cycle.

The CWMA S&T Committee recommended this item to remain an Assigned Item.

During the 2022 CWMA Interim Meeting, no comments were heard from the floor.

The CWMA S&T Committee recommended this item to remain as Assigned status.

LPG – Liquefied Petroleum Gas and Anhydrous Liquid-Measuring Devices

LPG-15.1 D N.3. Test Drafts.

(Note: Previously LPG-4)

(Note: In 2019 this item was combined with Block 1 “Terminology For Testing Standards” and other items that addressed terminology for standards and the use of “master meters.” Based on comments heard during the 2021 Annual Meeting, the S&T Committee recommended that all items that were combined with Block 1 “Terminology For Testing Standards” that originally appeared as a separate item or a separate block of items on the S&T agenda prior to 2019, be removed from Block 1 “Terminology For Testing Standards” and appear as originally presented.

Item LPG-15.1 was removed from Block 1 “Terminology For Testing Standards” and now appears as a separate item on the 2022 Interim Meeting agenda.)

Source: Endress + Hauser Flowtec AG USA

Submitter's Purpose and Justification:

Amend Handbook 44 to allow field reference standards meters to be used to test and place into service dispensers and delivery system flow meters.

This item has been assigned to the submitter for further development. For more information or to provide comment, please contact:

Mr. Michael Keilty
Endress + Hauser Flowtec AG
(970) 586-2122, michael.keilty@us.endress.com

The use of transfer standards is recognized in Code sections 3.34 Cryogenic Liquid-Measuring Devices Code and 3.38 Carbon Dioxide Liquid-Measuring Devices Code and 3.39 Hydrogen Gas-Measuring Devices – Tentative Code. Transfer standard is only defined for testing cryogenic liquid measuring devices. It has been pointed out that the term transfer standard is not correct and that field reference standard meters may be more appropriate. See new the Item Under Consideration, updated on September 8, 2017.

Field evaluation of LPG meters and CNG dispensers and LNG dispensers is very difficult using volumetric and gravimetric field standards and methods. The tolerances for these applications are such that using field reference standard meters are more efficient and safer. With CNG and LNG and LPG applications, the field reference standard meters are placed in-line with the delivery system as it is used to fill tanks and vehicles. The use of field reference standard meters eliminates return to storage issues. The use of field reference standard meters is easier and faster compared to the use of traditional field standards. The cost of using field reference standard meters and transporting them is much less than the cost of traditional field provers and standards.

Recognition in Handbook 44 will enable States to allow field reference standard meters to place systems into service and for field enforcement.

Volumetric field provers and gravimetric field proving are susceptible to environmental influences. The State of Colorado uses a field reference standard meter to test propane delivery truck meters. The State of Nebraska has used a field reference standard meter to test agricultural chemical meters. Other States have asked that there be recognition in HB44 in order for their State to allow the use of field reference standard meters.

In some applications, field reference standard meters are not more accurate than the meters used in the application. For that reason, longer test drafts and possibly more tests may need to be run.

The State of California is purported to have conducted a short study of field reference standard meters in the past. The conclusion did not lead to wide adoption of the practice.

Section 3.37 Mass Flow Meters user requirement U.R.3.8. Return of Product to Storage, Retail Compressed Natural Gas Dispensers requires that the natural gas which is delivered into the test container must be returned to storage. This is difficult and most often not complied with when the test vessel contents are released to atmosphere. States often have difficulties in remote locations finding suitable field reference equipment.

OWM Executive Summary for LPG-15.1 – N.3. Test Drafts.

OWM Recommendation: OWM believes that the purpose for this item, as specified by the submitter, is better addressed from a technical standpoint in Items GEN-23.1 and Block 8.

OWM Executive Summary for LPG-15.1 – N.3. Test Drafts.

- State and industry have a need to use various types of field test standards to evaluate commercial devices installed in the marketplace. NIST OWM recognizes the need to use various standards to test commercial devices and support the use of these standards when test data supports its use.
- NIST OWM is also supporting the use of various types of field test standards through the purchase of several meters and the collection of data throughout the U.S.
- The purpose statement for Items LPG-15.1 (LPG & Anhydrous Ammonia Liquid-Measuring Devices Code) indicates the goal of this items is:

“to amend Handbook 44 to allow field reference standard meters to be used to test and place into service dispensers and delivery system flow meters.”
- The proposed changes in Items LPG-15.1 suggest changes to the *test draft criteria* for devices covered under this code, which is not necessary to allow field reference standard meters to be used to test and place into service dispensers and delivery system flow meters.
- Amongst the concerns raised to the S&T Committee over the proposed changes for LPG-15.1 is that it conflicts with existing test draft criteria and confusion over the application of the proposed requirement.
- As such, given the long debate over multiple iterations of the proposals, OWM proposes that since the purpose of the proposal is to allow field reference standard meters to be used to test and place into service dispensers and delivery system, and the responsibility for allowance of these field test standards are already addressed in the NIST Handbook 44 Fundamental Considerations and Items GEN-23.1 and Block 8 clarifies these responsibilities, that Consideration be given to the proposal in Items GEN-23.1 and Block 8 which clearly states the responsibility for allowance of field standards.
- Block 8 clarifies what has long been recognized in NIST HB 44 concerning the responsibility for acceptance of a standard, making changes to specific codes such as those references in LPG-15.1 unnecessary and confusing.
 - GEN-23.1 provides a requirement for all devices to avoid the need to specifically reference individual test methods in each specific code, it avoids the potential of implying that test methods not specifically referenced in a code would not be appropriate.

Table 3. Summary of Recommendations

LPG-15.1 – N.3. Test Drafts							
	V	D	W	A	I	Notes*	Comments
Submitter							
OWM							
WWMA			✓				

Table 3. Summary of Recommendations							
LPG-15.1 – N.3. Test Drafts							
	V	D	W	A	I	Notes*	Comments
SWMA	✓						
NEWMA			✓				
CWMA	✓						
NCWM							
	Letters of Support			Letters of Opposition			Notes
Industry							
Manufacturers	Endress+Hauser 10-07-2021 Endress+Hauser 01-11-2022 Endress+Hauser 05-12-2022			Seraphin 09-27-2016 Seraphin 06-23-2017 Seraphin 07-02-2018 Seraphin 06-17-2022			
Retailers and Consumers							
*Notes Key: 1 - Submitted modified language 2 - Item not discussed 3 - No meeting held 4 - Not submitted on agenda 5 - No recommendation or not considered							

Item Under Consideration:

Amend Handbook 44, LPG and Anhydrous Ammonia Liquid-Measuring Devices as follows:

N.3. Test Drafts.

N.3.1. Minimum Test - Test drafts should be equal to at least the amount delivered by the device in 1 minute at its normal discharge rate.

(Amended 1982)

N.3.2. Field Reference Standard Meter Test. – **The minimum quantity for any test draft shall be equal to or greater than the amount delivered in one minute at the flow rate being tested.**

(Added 20XX)

NIST OWM Detailed Technical Analysis:

- Although this item has been on the agenda for a number of years, this item was grouped in a block of other similar items then removed from the block and placed back on the NCWM agenda as it originally appeared on the agenda.

- NIST OWM is working with States using Coriolis meters to collect data on the use of these meters as standards to test liquid measuring devices. This data will be shared with all regulatory officials to assist them with their approval of meters as standards.
- This purpose indicates its intent is to permit the use of field reference standard meters in field testing of commercial measuring systems.
- It is not necessary to reference “field reference standards” in a specific NIST HB 44 code in order to permit their use.
- Criteria for assessing the use of a given type of test standard are outlined in NIST HB 44 Appendix A Fundamental Considerations and clarified Items GEN-23.1 and Block 8 and OWM believes that the purpose for this item, as specified by the submitter, is better addressed from a technical standpoint in Items GEN-23.1 and Block 8.
- The decision on whether or not to accept a particular test method for use in testing commercial weighing and measuring equipment ultimately rests with the regulatory authority.
- NIST OWM and Seraphin developed Block 8 items (GEN-19.1 and OTH-22.1) on the 2022 Annual Meeting Report to help clarify and provide additional information on field standard traceability and specifications, and the regulatory authority’s responsibility for approval of field standards.
- Item GEN-23.1 along with Block 8 on the 2023 Interim Meeting agenda clearly references the Director’s authority as outlined in the Fundamental Considerations. This not only avoids the need to specifically reference individual test methods in each specific code, it avoids the potential of implying that test methods not specifically referenced in a code would not be appropriate.
- With regard to the proposed addition of a paragraph N.3.2. Field ~~Reference~~ Standard Meter Test., no information or data has been provided to justify that:
 - a different test draft size than that specified in N.3.1. Test Draft is necessary in order to use a “Field ~~Reference~~ Standard Meter.”
 - the specific criteria of a minimum quantity of “equal to or greater than the amount delivered in one minute at the flow rate being tested” is appropriate.

NIST OWM believes this item is not supported with data, in that it lacks data to show that one minute of flow would be appropriate. We believe that this data can be collected as data is collected across the country to assess field standard meters or the submitter can provide additional data. Also, since the authority to accept or reject a meter as a field standard is the responsibility of the regulatory authority, this item is inappropriate for its purpose.

Summary of Discussions and Actions:

The Committee initially considered a proposal to modify paragraph N.3. Test Drafts and to add a new paragraph N.3.2. Transfer Standard Test as shown below. Note that, in Fall 2016, Mr. Keilty provided an update to this proposal as shown in the Item Under Consideration above.

N.3. Test Drafts. –

N.3.1. Minimum Test - Test drafts should be equal to at least the amount delivered by the device in one minute at its normal discharge rate.

(Amended 1982)

N.3.2. Transfer Standard Test. – When comparing a meter with a calibrated transfer standard, the test draft shall be equal to at least the amount delivered by the device in 2 minutes at its maximum discharge rate.

The submitter recommended that NIST update EPO 28 for CNG dispensers and EPO 26 for LPG Liquid Measuring Systems to include transfer standard meter tests. NIST Handbook 105-4 should also be revised to specifically address the transfer standard meter and the requirements for use.

The S&T Committee might also consider amending Sections 3.30 Liquid-Measuring Devices Code and 3.31 Vehicle-Tank Meters Code to allow transfer standard meters.

The Committee received written comments on all items in Block 4 and Block 5, as well as LPG-4 and MFM-2 emphasizing the need for there to be more study and discussion of the issues to assess the ramifications of all the proposed changes. The Committee also received written comments from the SMA that it looks forward to further information on these items and stating that it is important to be consistent in our use of terms across multiple sections of NIST Handbook 44. The Committee agreed to carryover this group of items on its 2019 agenda to allow for further discussion and development of these proposals.

At the 2019 NCWM Interim Meeting the Committee decided to combine the items on the agenda dealing with the issue of transfer standard (including items already combined into blocks) into one block. Block 1 (New) of the Interim Meeting report now includes Gen-3, Block 1 (original items from the 2019 interim agenda that appeared under Block 1), Block 2, LPG-3 and MFM-5, which were all separate items and blocks of items on the S&T Committee's 2019 Interim Meeting agenda (NCWM Publication 15). Agenda items Gen-3, Block 1, Block 2, LPG-3, and MFM-5 are listed separately on the Interim agenda with a note added beneath each individual item referring the reader to the New B1 items. All items under this New B1 have retained the same numbering system for ease in referring to the appendix for discussion on each item.

At the 2019 NCWM Annual Meeting: Mr. Brett Gurney (NCWM Chair) commented regarding the formation of a Task Group assigned to further develop this block proposal. The TG is charged with providing definitions for various types of standards (transfer, field, reference, etc.) as well as the criteria to be met by these types of standards. The completion date given to the TG is July 2021. The Committee agreed to the Assigned status for this block of items and looks forward to hearing updates from the TG. the Chair of the Task Group was:

Mr. Jason Glass
Kentucky Department of Agriculture
(502) 573-0282, jason.glass@ky.gov

At the 2020 NCWM Interim Meeting the Field Standard TG Chair Glass reported that the Task Group met prior to the Interim Meeting and has begun discussion of the items under Block 1. Mr. Glass stated that bi-weekly teleconference meetings were scheduled and that the group was optimistic but had significant work to accomplish.

Mr. Russ Vires (SMA) supports the Scale item, SCL 18.1; in this block, Mr. Dimitri Karimov (Meter Manufacturers Association) supports the Task Group activities, Mrs. Tina Butcher (NIST OWM) was

encouraged with the progress on terminology and provided an update on the Mass Flow Meter testing reporting that field testing was conducted October 28 to November 1, 2019 and that State and Industry participation included Colorado, Florida, Oregon, Emerson, and Tulsa Gas Technology.

Mr. Kurt Floren (Los Angeles County, California) raised concerns with GEN-19.1. regarding the definition of “Standard, Field” and its reference to “stable” standards and how long a standard is expected to be stable, which is typically 1-year, for which he believes should be longer. Mr. Floren also questioned the statement in the definition “tested over a range of environmental and operational conditions that the measuring devices is used...” Mr. Floren noted that he was unsure if all laboratories will have the capabilities to test over this wide range of conditions. Mr. Floren also expressed concerns with the definition “Standard, Transfer” citing that this standard may not meet the fundamental considerations requirement for standards over a long period of time or wide range of environmental conditions.

Mr. Steve Harrington (Oregon) echoed Mr. Floren’s comments. Field Standard TG Chair Glass responded that these are concerns of the TG and these issues will be discussed and considered as the TG develops these items.

During the Committee’s work session, the Committee agreed that this item should remain an Assigned Item.

At the 2021 NCWM Interim Meeting the NCWM Field Standard TG Chair Glass provided an update on the Task Group activities. Mr. Glass reported that the Field Standard Task Group is following the activities of the NIST Master Meter Project and that the Task Group reviewed API specifications for use of master meters as a standard and a test protocol that will be used to ensure uniformity in collecting data on master meters used as field standards. He also reported that the TG does not have a recommendation for this item. Mr. Glass also reported that he would be stepping down as the TG Chair. Mr. Mike Keilty (Endress+Hauser AG) thanked Chair Glass and the TG for their work and requested that Block 1, LPG-15.1, N.3. and Block 1 MFM-15.1, N.3 be removed from Block 1 items and to allow those items to move forward separate from the other Block 1 Items. Mr. Keilty stated that similar language was added to the Hydrogen code and that the proposed language in LPG-15.1 N.3. and MFM-15.1, N.3 will allow for the recognition of master meters as field standards. Mr. Henry Oppermann (WM-Consulting), stated that data is needed to ensure that master meters can be used over a range of conditions. Mr. Bob Murnane (Seraphin) stated that jurisdictions have the ability to use meters and that Block 1 LPG-15.1, N.3 and Block 1 MM-15.1, N.3 should remain in Block 1 until data is available to support the use of master meters as a standard. Mr. Keilty mentioned that there has been useful dialog regarding master meters in the TG, but that he is concerned that the TG is not close to deciding and he expressed concerns with the TG’s focus on the NIST Master Meter Project. Mrs. Tina Butcher (NIST OWM) provided an update on the NIST Master Meter Project and noted that States have the regulatory powers to accept or reject a standard. She also mentioned that NIST is working with States to collect data needed to assess master meters and preliminary testing was conducted and data was collected on CNG at Tulsa Gas Technology’s facility in fall 2019. Ms. Diane Lee (NIST OWM) noted that NIST OWM feels that it is premature to add more language to the NIST Handbook 44 on master meters without data to support its use.

During the Committee’s work session, the Committee agreed to keeps all items in Block 1 and that this item should remain with an Assigned status.

At the 2021 NCWM Annual Meeting Mr. Glass reported that he would be stepping down as the Field Standard TG Chair. The Committee heard updates from members of the Task Group during open hearings. Mr. Mike Keilty (Endress+Hauser AG) noted that two of the items had been on the agenda since 2015 and requested that they be removed from the block and recommended recognizing the use of master meters. Other comments were to keep the items together until data is analyzed from the NIST Field Reference

Standard Work Group to support the use of master meters but that if some items were removed from the block, all items should be removed from the block. Based on comments heard during the 2021 Annual Meeting, the S&T Committee recommended that all items that were included in Block 1 “Terminology For Testing Standards” that originally appeared as a separate item or a separate block of items on the S&T agenda in and prior to 2019, be removed from Block 1 “Terminology For Testing Standards” and appear as originally presented.

At the 2021 Committee work session, the Committee recognized that the Task Group has accomplished all it is able to at this point and is recommending the Task Group be disbanded and will make said recommendation to the NCWM Chairman. The Committee agreed to break all items in Block 1 into individual items and designate them all as Developing. The Committee thanks the Task Group and its members for their work.

At the 2022 NCWM Interim meeting, the Item Under Consideration is provided below:

N.3. Test Drafts.

N.3.1. Minimum Test - Test drafts should be equal to at least the amount delivered by the device in 1 minute at its normal discharge rate.

(Amended 1982)

N.3.2. Field Reference Standard Meter Test. – The minimum quantity for any test draft shall be equal to or greater than the amount delivered in one minute at the flow rate being tested.

(Added 20XX)

Mr. Keilty shared a presentation on field standard meters during open hearings relevant to both LPG 15.1 and MFM 15.1. The intent of the presentation was to describe initial and ongoing calibration traceability, compare OIML tolerances vs NIST Handbook 44, describe the benefits and show examples of master meters. An abbreviated copy of the presentation is available on the NCWM website in the interim meeting documents archive. Mr. Keilty commented that he believes LPG 15.1 and MFM 15.1 are fully developed and should receive Voting status for the annual meeting. He has updated the proposal to exclude the term “reference” from “field reference standard meter test”, as shown above. He requests that the Committee provide specific guidance if a Developing status is assigned. A comment from industry (Mr. Murnane – Seraphin) stated that N.3.2 in the proposal conflicts with the current code which states normal test drafts must be at least one minute at the maximum discharge flow rate of installation conditions. The current wording allows for a test to be conducted at any flow rate for one minute. There was concern from a regulator (Mr. Charles Stutesman, Kansas) echoing these concerns. Ms. Diane Lee (NIST) requested that more data be made available so that NIST is able to compare worldwide data against test data compiled within the U.S. by NIST. Mr. Mahesh Albuquerque (Colorado) expressed support for this item to receive Voting status. Mr. Marc Butler (Emerson Micro Motion) expressed confusion at the two notes, thinking that perhaps they conflicted with each other; are they both needed or are they independent? Mrs. Tina Butcher (NIST OWM) expressed that she recognizes the use and importance of master meters but is concerned with the purpose of this item. Mrs. Butcher suggested that the statement for use be reworked as test draft criteria is so critical. Mrs. Butcher recommended and offered NIST OWM assistance on this item.

During the S&T Committee work session, the Committee recognized the submitters desire that a Voting status be recommended but determined that there were too many concerns and confusion expressed. The Committee recommends that the submitter develop the item further by aligning language to existing

language in Handbook 44, clarifying the purpose to help avoid confusion of the new code on new equipment, and reaching out to NIST OWM or other industry or regulatory officials for feedback.

During the 2022 Annual Meeting Ms. Tina Butcher provided the NIST OWM Technical Analysis for this item and as addressed in this report she pointed out that a new general code requirement will be proposed for the new 2023 cycle that not only avoids the need to specifically reference individual test methods in each specific code, it avoids the potential of implying that test methods not specifically referenced in a code would not be appropriate.

Further comments were provided that OWM believes the purpose for this item, as specified by the submitter, is better addressed from a technical standpoint in Item Block 8. OWM proposes that since the purpose of the proposal is to allow field standard meters to be used to test and place into service dispensers and delivery systems, and the responsibility for allowance of these field test standards are already addressed in the NIST Handbook 44 Fundamental Considerations, and Item Block 8 clarifies these responsibilities, Consideration be given to the proposal in Item Block 8 which clearly states the responsibility for allowance of field standards along with a 2023 new proposal to add a general code requirement.

Ms. Butcher also noted that State and industry have a need to use various types of field test standards to evaluate commercial devices installed in the marketplace and that NIST OWM recognizes the need to use various standards to test commercial devices and support the use of these standards when test data supports its use. But, the proposed addition of another paragraph N.3.2 in the LPG Code that specifically references test draft for an individual test method (Field Standard Meter Test), potentially implies that test methods not specifically referenced in a code would not be appropriate.

The submitter of the item pointed out that the CWMA recommended that the item move forward as a vote and noted that a presentation was given at the CWMA about using meters to test devices. Also during open hearings a weights and measures official spoke on the ease of use of meters to test device. Although NIST, OWM provided comments in support of the use of various standards to test commercial devices when data supports their use, and that the proposed paragraph N.3.2 in the LPG Code for this item would potentially imply that test methods not specifically referenced in a code would not be appropriate, the submitter of this item noted that he failed to understand why there was opposition the use of meters to test in use commercial meters and asked States to support the item.

During the Committee's work session, the committee agreed to a Developing status for this item based on the comments heard on this item.

Regional Association Reporting:

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received. Mr. Michael Keilty (Endress+Hauser) - Clarified that the Joint source of the item with "Flow USA, Inc." has changed its company name from Flowtec AG USA. An update was provided on this. Mr. Keilty recapped that last year WWMA S&T Committee recommended that these items (LPG-15.1 & MFM-15.1) remain Developing, and this was forwarded to the NCWM. At the Southern, the S&T Committee proposed these items for a vote, both passed at the Southern. The Central heard comments that this should be moved for voting. At the NCWM Interim Meeting Mr. Keilty asked the S&T Committee to revise the titles to provide clarity; that revised language is now before us. Mr. Keilty continued to note that the NCWM Interim & Annual Committee comments are found in the S&T agenda before you. There is an error in the notes for the 2022 NCWM Annual Meeting; Mrs. Tina Butcher (NIST OWM) is not a submitter of this item. I will provide

NIST OWM Analysis
2023 NCWM Interim S&T Agenda Items
1/5/2023

my comments to the Committee by email. In conjunction with this item Mr. Keilty is now proposing to amend LMD-23.1, VTM-23.1 and MLK-23.1 (see Block 1, 2022 WWMA S&T agenda). These field standards will be traceable and will increase productivity. I ask the committee to accept LPG-15.1. Please move these items forward as a Voting Item.

Mr. Robert Murnane (Seraphin Test Measure Company) stated he is not opposed to these meters in any way. Questions for the Committee: the purpose is to amend HB44, what does the language in section N.3.2 have to do with the purpose statement? Will Weights and Measures Officials enforce section N.3 or N.3.2 when testing? How will we know which meters are acceptable and which are not? Request that this item be withdrawn and proposes harmonizing the drafts between the two (N.3.1. & N.3.2.). Change N.3. to read that test drafts should be equal to at least the amount delivered by the device in one minute at the flow rate being tested. Then there is not any need for N.3.2., this is already addressed in the fundamental considerations.

Mr. Matt Douglas (California, Division of Measurement Standards) stated he did not think this language was helpful and that this item has been on the agenda for 8 years. Mr. Douglas recommended this item for withdrawal.

During open hearings, the Committee heard conflicting comments including that the purpose of this item is better addressed in Block 8.

The WWMA S&T Committee recommended this item for withdrawal along with the recommendation that the submitter combine their efforts with the submitters of Block 8.

During the voting session, comments were received from membership. The submitter of LPG-15.1 requested that the Committee reconsider the recommended Withdrawal status and to please leave the item with the current Developing status.

Mr. Brent Ricks (Montana Department of Labor and Industry Weights and Measures) spoke not to a technical comment on this item but to agenda items that may be fully developed could be voted upon and for the committee to consider this when recommending a status for this item.

Based on the comments heard from the body, the Committee entered deliberations. During deliberations, it was determined that the item was fully developed, and the submitter had nothing further to add. The Committee recommended a Voting status for the item.

Upon returning to the voting session, the recommended status was changed from withdrawal to voting. A vote was put forward to the body resulting in no “yea” votes and 1 “nay” vote.

Mr. Kurt Floren (Los Angeles County, California) put forward a motion of reconsideration for the vote due to the lack of response from membership during the vote. The motion passed and the vote for LPG-15.1 was recalled, opening the floor for comments on the item.

Mr. Keilty recommended a Developing status.

Mr. Ed Williams (Ventura County, California) supported the recommendation for a Developing status.

Mr. Austin Shepherd (San Diego County, California) requested clarification on the reasoning for the Committee’s position.

Clarification from the S&T Committee Chair was provided; the Committee recognized that there is language in the history of the item stating that the item may have merit for other jurisdictions.

Mr. Floren recommended that the Committee consider the needs of other regions when recommending a status.

The Committee entered a second deliberation session to assign a status for LPG-15.1. Taking note of the limited participation from the body during the vote to recommend a Voting status and along with the consideration of all the comments heard from the floor during the voting session, and all the previous comments and discussions regarding LPG-15.1, the Committee concluded that the item should return to the originally proposed recommendation of a Withdrawal status.

The S&T Committee returned to the voting session with the Committee's decision to recommend a Withdrawal status, the item was included and presented for a vote in the 2022 WWMA Committee's final report.

Southern Weights and Measures Association

The following comments were received during the 2022 SWMA Annual Meeting:

Mr. Keilty (Endress+Hauser), the submitter of this item, recommended it move forward as a Voting Item with the new language.

The SWMA S&T Committee recommended this item move forward as a Voting Item.

Northeastern Weights and Measures Association

At the 2022 Interim Meeting Mr. Michael Keilty (Endress Hauser) commented that he introduced this item in 2014 and there has been much documentation and discussion. The goal was to introduce field standard meters and small draft size benefit. Mr. Keilty indicated that he polled some states and he believes that having language in HB44 would enable those states to use field standard meters. Mr. Keilty also noted that he has submitted a letter to the NEWAM S&T Chair with changes to the purpose statement and other modifications to the language and recommends a Voting status.

Mr. Bob Murnane (Seraphin Test Measure) asked what changed in the purpose statement and it was shared with the body. Mr. Murnane commented that he believes the Fundamental Considerations already allows State Directors to use field standards and pointed to language in Block 8 that would reinforce that. Mr. Murnane also believes there is an issue with a 1-minute test. Mr. Murnane does not believe this item is needed and urged that submitter to work with submitters of Block 8. Mr. Keilty stated that whenever new technology is available, the conference allows them to be used. He believes the language in this item facilitates the testing of systems already in place and allows 1 minute test to be sufficient. He pointed out that SWMA has voted twice to pass, as has CWMA.

Mr. Henry Opperman (W&M Consulting) commented that the Fundamental Considerations allows recognition of other standards that perform at the level of field standards. He questions how we prove that a field standard meets the requirements in the Fundamental Considerations. Even if used, it is still not clear how the states determined they meet the requirements.

Ms. Diane Lee (NIST OWM) commented that NIST is doing additional research on test draft paragraphs. If the purpose of this item is that master meters can be used, it's always been addressed in Fundamental

NIST OWM Analysis
2023 NCWM Interim S&T Agenda Items
1/5/2023

Considerations that State Directors can accept anything. Ms. Lee noted that Block 8 is just clarifying what I needed for selection of appropriate standards.

Mr. Murnane indicated that he also called states referenced by Keilty and they are using the Fundamental Considerations for field standards.

Mr. Jim Willis (New York) believes this item is redundant, noted that as a Director, he already has the authority through Fundamental Consideration, and recommended withdrawal.

Mr. John Mcguire (New Jersey), Mr. Walt Remert (Pennsylvania), Mr. James Cassidy (Massachusetts) and Mr. Lou Sakin (Holliston, Massachusetts) all recommended withdrawal of this item.

After hearing comments from the body, the Committee agreed with the commenters that this item does not have merit and is redundant in nature. The Committee is recommending that this item be Withdrawn.

Central Weights and Measures Association

At the 2022 Interim Meeting, Michael Keilty recalled that the CWMA recommended this as a Voting Item for the 2022 NCWM. In May CWMA voted and approved this item. Larger drafts than 1 minute can be used.

Mr. Murnane noted that the purpose statement does not align with proposed change to N.3. Numerous meters are already approved under fundamental considerations, i.e.: the authority lies with the Director to approve devices. Why is the test draft being changed? Regulators must be able to choose whatever draft size they want, specifically for Mass Flow Meters.

If the Minimum Measured Quantity is greater than one minute of flow, then some mass flow meters would require larger draft sizes. Several NTEP CCs were referenced in which the MMQ is less than one minute of flow, which would conflict with testing the MMQ.

Craig VanBuren (Michigan): Suggest change in verbiage to address the MMQ/ one minute of flow conflict. The CWMA S&T Committee believes this item is fully developed and recommends Voting status. The Committee also believes this should be added to Block 1.

LPG-22.3 W S.2.5. Zero-Set-Back Interlock., S.2.5.2. Zero -Set-Back Interlock for Stationary Customer -Operated Electronic Retail Motor-Fuel Devices.

(**Note:** The Item Under Consideration has been updated since the 2022 Interim Meeting. The current item is a combined effort of the National Propane Gas Association and U-Haul International, Inc.

Note: At the 2022 Annual Meeting this item was designated as Developing. During the 2022 Fall Regional Meetings, the submitter requested that this item be Withdrawn and that consideration be given to Item LPG-23.)

Source: National Propane Gas Association

Submitter's Purpose and Justification:

The proposal will address practical issues that propane marketers encounter when trying to comply with the zero setback requirements for propane stationary and truck-mounted meters in NIST Handbook 44.

National Propane Gas Association:

This proposal was developed by the National Propane Gas Association's Technology, Standards and Safety Committee, a volunteer organization comprised of 2500+ members, including propane retail marketers and others providing products or services to the propane industry.

In S.2.5, the removal of the vehicle mounted meters from this two-minute requirement is necessary as the initiation of a vehicle mounted meter is performed at the truck prior to moving the delivery hose to the customer tank, sometimes as far as 150 feet from the meter, or in installations with multiple containers that may require continued adjustment of containers or delivery hose to complete a delivery. This configuration can lead to periods of up to 5 minutes between initial meter engagement and first container filling or between containers being filled on a single delivery.

In revised S.2.6, we are proposing that vehicle mounted meters be allowed periods between meter engagement and product flow of greater than 2 minutes prior to automated time out initiation. A five-minute period is more practical as the initiation of a vehicle mounted meter is performed at the truck prior to moving the delivery hose to the customer tank, sometimes as far as 150 feet from the meter, or in installations with multiple containers that may require continued adjustment of containers or delivery hose to complete a delivery. The configuration on a typical bobtail can lead to periods of up to 5 minutes between initial meter engagement and first container filling or additionally periods of greater than two minutes can transpire between containers being filled on a single delivery.

Addressing proposed new S.2.7, motor fuel, within the context of NFPA 58, refers to any container that has the potential to provide propane to fuel an engine. This can include a multitude of DOT cylinders and ASME containers that are not for the propulsion of an automobile. Current mechanical meter technology utilized in a standard propane dispenser for the filling of portable containers, such as those utilized in NFPA 58 for motor fuel applications or those that do power automobiles, are not capable of being equipped with a zero-set-back interlock and the technology will not be potentially available until 2022, per meter manufacturers.

NFPA 58 does not currently explicitly allow the public to refuel its automobiles. All automobiles or other containers must be filled by a specially trained employee. A proposed change has been introduced for consideration in the 2023 edition of NFPA 58 that would permit public refueling of automobiles as long as the dispensing system meets very specific safety requirements, including a specialized nozzle, and is furnished with visible instructions. Upon the acceptance of this new public refueling allowance the propane industry agrees that Zero-Setback-interlocks are needed. These public self-service automotive dispensing systems will be listed to Underwriters Laboratories Standard 495 and will be dedicated to the filling of motor vehicles.

In view of the above information, existing dispenser systems that may only be utilized by qualified trained employees should be permitted to continue operations with the existing meter technology and should not be required to include Zero-Set-Back Interlocks. This should include when the dispenser is removed from one location and installed in another, as long as the original meter remains functional. Existing cabinetry and controls utilized in a standard dispenser cabinet generally include non-digital meters and no electronic controls with the exception of a single switch that operates the pump. These simplistic designs are still effective and should not be prohibited from use in future (new) installations in which the transfer process is attended by trained personnel. Limiting the scope of this section will allow attended dispenser operations

which are primarily utilized for filling of portable containers to remain consistent in design and construction. Current use of this technology has not resulted in any known impact to the consumer or over-charge situations. The term “self-operated” is used in other locations in Handbook 44 and would include electronic dispensing devices and meters, which would then be consistent with the prior two sections that are limited to electronic meters.

It is difficult to counter the arguments above. The sheer difficulties that a service person can encounter when a wet hose must be carried over terrain fairly long distances between receiving containers should be sufficient justification to approve this proposal. The counter argument to new S.2.7 would be that the customer may not be able to view the meter to ensure it is set back to zero. The submitter requested that this be a Voting Item in 2022.

U-Haul International, Inc.

Motor fuel, within the context of NFPA 58, refers to any container that has the potential to provide propane to fuel an engine. This can include a multitude of DOT cylinders and ASME containers that are not for the propulsion of an automobile. Current mechanical meter technology utilized in a standard propane dispenser for the filling of portable containers, such as those utilized in NFPA 58 for motor fuel applications or those that do power automobiles, are not capable of being equipped with a zero-set-back interlock and the technology will not be potentially available until 2022, per meter manufacturers.

NFPA 58 currently does not allow the public to refuel its automobiles. All automobiles or other containers must be filled by a specially trained employee. A proposed change has been introduced for consideration in the 2023 edition of NFPA 58 that would permit public refueling of automobiles as long as the dispensing system meets very specific safety requirements, including a specialized nozzle, and is furnished with visible instructions. Upon the acceptance of this new public refueling allowance the propane industry agrees that Zero-Setback-interlocks are needed. These public self-service automotive dispensing systems will be listed to Underwriters Laboratories Standard 495 and will be dedicated to the filling of motor vehicles.

Most propane dispensed is for purposes other than motor-fuel. Pursuant to NFPA 58, this is accomplished by a trained and certified employee dispensing propane, typically using mechanical meters, into cylinders and tanks. The employee is trained and required to manually reset the meter to zero after each transaction and verify the meter is reset prior to initiating a subsequent transaction. This has been and remains an accepted practice for dispensing propane. This process is the industry standard for approximately 97 % of all propane used in the United States. *See* U.S. Department of Energy, Alternative Fuels Data Center https://afdc.energy.gov/fuels/propane_basics.html.

Unlike traditional motor-fuel, such as gasoline or diesel, customers cannot currently dispense propane into their vehicles. If NFPA 58 is amended to allow customers to dispense their own propane into their vehicles and the demand for propane as motor-fuel increases, the market will drive retailers to provide electronic customer-operated retail motor-fuel devices to meet the demand and customer expectations for efficient and expedient fueling transactions. At that time, the electronic customer-operated motor-fuel devices will certainly need to incorporate an automatic zero-set-back interlock. It is simply too early in the process to effectively force mechanical retail motor-fuel devices out of the market for such a small percentage of the retail propane market (approximately 3 %).

OWM Executive Summary for LPG-22.3 – S.2.5. Zero-Set-Back Interlock., S.2.5.2. Zero -Set-Back Interlock for Stationary Customer -Operated Electronic Retail Motor-Fuel Devices.

OWM Recommendation: This item was withdrawn by the submitter and all regions supported the withdraw of this item. The original OWM comments are maintained in this analysis.

NIST OWM is not in support of this proposal to change S.2.5.2 requirements in the LPG Code and feel that this creates different requirements for retail motor fuel devices used for other products. Also, a proposal is needed for consideration of changes to timeout for LPG. The submitter requested that this item be withdrawn during the 2022 Regional Meetings, and that consideration be given to Item, LPG-23.1. NIST Supports the submitters decision to withdraw this item.

- The submitters explained in their justification that only trained operators can dispense propane into a vehicle and that these propane retail motor fuel dispensers do not meet the requirements for Zero-Set Back Interlock for Stationary Retail Motor-Fuel Devices. As such, the submitters are proposing that since these are not customer operated dispensers, and that the dispensers are operated by trained staff, the requirements in S.2.5.2 Zero-Set-Back Interlock for Stationary Retail Motor Fuel Devices should be revised to only apply to Customer Operated Electronic Retail Motor Fuel Devices. The following are NIST OWM comments to this proposed change.
- If a dispenser is operating as a retail motor fuel device the current requirements for zero-set-back interlock apply whether or not it is operated by the customer or trained staff.
- The purpose of the Zero-Set-back Interlock is to ensure that an automatic interlock prevents subsequent delivery until the indicating element is returned to zero.
- With the changes proposed, any propane retail motor fuel device that is operated by trained staff could possibly not be returned to zero at the start the next transaction.
- Propane retail motor fuel devices, that are not customer operated, would not be required to meet S. 2.5.2. in the LPG Code.

Table 3. Summary of Recommendations

LPG-22.3 – S.2.5. Zero-Set-Back Interlock., S.2.5.2. Zero -Set-Back Interlock for Stationary Customer -Operated Electronic Retail Motor-Fuel Devices.

	V	D	W	A	I	Notes*	Comments
Submitter							
OWM							
WWMA			✓				
SWMA			✓				
NEWMA			✓				
CWMA		✓					
NCWM							
	Letters of Support			Letters of Opposition			Notes

Table 3. Summary of Recommendations							
LPG-22.3 – S.2.5. Zero-Set-Back Interlock., S.2.5.2. Zero -Set-Back Interlock for Stationary Customer -Operated Electronic Retail Motor-Fuel Devices.							
	V	D	W	A	I	Notes*	Comments
Industry							
Manufacturers							
Retailers and Consumers							
*Notes Key: 1 - Submitted modified language 2 - Item not discussed 3 - No meeting held 4 - Not submitted on agenda 5 - No recommendation or not considered							

Item Under Consideration:

Amend Handbook 44, Liquefied Petroleum Gas and Anhydrous Ammonia Liquid-Measuring Devices Cod as follows:

S.2.5. Zero-Set-Back Interlock.

S.2.5.1. Zero-Set-Back Interlock, Electronic Stationary Meters (Other than Stationary Retail Motor-Fuel Dispensers) and Electronic Vehicle-Mounted Meters. – A device shall be constructed so that after an individual delivery or multiple deliveries at one location have been completed, an automatic interlock system shall engage to prevent a subsequent delivery until the indicating element and, if equipped, recording element have been returned to their zero positions.
 [Nonretroactive as January 1, 2021]

(Added 2019)

(Amended 2021)

S.2.5.2. Zero-Set-Back Interlock for Stationary Customer-Operated Electronic Retail Motor-Fuel Devices. – A device shall be constructed so that:

- (a) after a delivery cycle has been completed by moving the starting lever to any position that shuts off the device, an automatic interlock prevents a subsequent delivery until the indicating elements and recording elements, if the device is equipped and activated to record, have been returned to their zero positions;
- (b) the discharge nozzle cannot be returned to its designed hanging position (that is, any position where the tip of the nozzle is placed in its designed receptacle and the lock can be inserted) until the starting lever is in its designed shut-off position and the zero-set-back interlock has been engaged; and

(c) in a system with more than one dispenser supplied by a single pump, an effective automatic control valve in each dispenser prevents product from being delivered until the indicating elements on that dispenser are in a correct zero position.

[Nonretroactive as of January 1, 2017]

(Added 2016)

NIST OWM Detailed Technical Analysis:

A similar proposal LPG-22.2, submitter U-Haul International, Inc. was withdrawn and both U-Haul International, Inc. and National Propane Gas Association collaborated to further develop LPG-22.3. Initially, the proposed changes, were made to an older version of the handbook. The current Item Under Consideration has been edited and changes are being proposed to the current version of NIST HB 44.

Per review of the discussion provided by the submitter, propane dispensed into a vehicle requires a trained operator to dispense the propane. From other proposals on the 2022 Interim Meeting report, it is NIST OWM understanding that some stationary propane dispensers have been retrofitted to dispense propane as fuel for vehicles. As such these dispensers are now retail motor fuel dispensers and must meet the requirements for these devices in the LPG code.

The submitters explained in their justification that only trained operators can dispense propane into a vehicle and that these propane retail motor fuel dispensers do not meet the requirements for Zero-Set Back Interlock for Stationary Retail Motor-Fuel Devices. As such, the submitter is proposing that since these are not customer operated dispensers, and that the dispensers are operated by trained staff, the requirements in S.2.5.2. Zero-Set-Back Interlock for Stationary Retail Motor Fuel Devices should be revised to only apply to Customer Operated Electronic Retail Motor Fuel Devices. The following are NIST OWM comments to this proposed change.

- If a dispenser is operating as a retail motor fuel device the current requirements for zero-set-back interlock apply whether or not it is operated by the customer or trained staff.
- The purpose of the Zero-Set-back Interlock is to ensure that an automatic interlock prevents subsequent delivery until the indicating element is returned to zero.
- With the proposed changes, any propane retail motor fuel device that is operated by trained staff could possibly not be returned to zero at the start the next transaction.
- Retail motor fuel dispenser such as gasoline dispensers are required to meet these requirements in a self-serve (Customer operated) or full Service (Trained staff operated) locations.
- Propane retail motor fuel devices, that are not customer operated, would not be required to meet S. 2.5.2. in the LPG Code.
- The title of the proposal will need to be updated with the current handbook paragraphs.
- In reference to requirements for a 5-minute timeout, the timeout was discussed by the conference in 2021. During those discussions 2, 3 and 5 minutes were discussed. The conference adopted a 3- minute timeout which was added to NIST HB 44 in 2021. Although timeout was discussed in the submitter's justification, the revised Item Under Consideration did not include a proposal for a change to the timeout requirements for LPG.

- NIST OWM is not in support of this proposal to change S.2.5.2 requirements in the LPG Code and feel that this creates different requirements for retail motor fuel devices used for other products. Also, a proposal is needed for consideration of changes to timeout for LPG.

Summary of Discussions and Actions:

During the 2022 NCWM Interim Meeting, Mr. Bruce Swiecicki (National Propane Gas Association), working in collaboration with U-Haul International, requested the Committee replace the proposal in its 2022 Interim Meeting agenda for this item with the following revised version:

Amend Handbook 44, Liquefied Petroleum Gas and Anhydrous Ammonia Liquid-Measuring Devices Code as follows:

S.2.6. Automatic Timeout.

S.2.6.1. Electronic Stationary (Other than Stationary Retail Motor-Fuel Dispensers) and ~~Electronic Vehicle Mounted Meters.~~ – *For individual deliveries, if there is no product flow for three minutes the transaction must be completed before additional product flow is allowed. The three-minute timeout shall be a sealable feature on an indicator.*

[Nonretroactive as of January 1, 2021]

(Added 2021)

S.2.6.2. Zero-Set-Back Interlock, Electronic Vehicle Mounted Meters. - *A device shall be so constructed that after an individual delivery or multiple deliveries at one location have been completed, an automatic interlock system shall engage to prevent a subsequent delivery until the indicating element and, if equipped, recording element have been returned to their zero position. For individual deliveries, if there is no product flow for a maximum of five minutes the transaction must be completed before additional product flow is allowed. The 5-minute timeout shall be a sealable feature on an indicator.*

[Nonretroactive as of January 1, 2021]

During Committee open hearings, Mr. Swiecicki acknowledge the proposal was based on an earlier version of NIST Handbook 44 and the paragraph numbering had changed. Consequently, the proposal needed modification to correspond to the 2022 version of the handbook. Mr. Swiecicki reported a two-minute time out was difficult to accomplish and suggested this be changed to five minutes.

During the Committee's work session, members of the Committee reviewed the revised proposal, which includes updated language and paragraph numbering, however, members of the Committee concluded the proposal was still not fully developed. The Committee agreed to amend the proposal as requested by the submitter. The Committee recommended the submitter of this item work with the submitter of LPG-22.2 (U-Haul International) to harmonize the two proposals.

Two officials supported Mr. Swiecicki's comments and were also in favor of a five-minute time out.

Ms. Diane Lee (NIST OWM) commented the proposal needed to be cleaned up to match the 2022 version of NIST Handbook 44. There was also a suggestion for the submitter to work with NIST OWM to further develop the proposal.

No comments were heard in opposition to the continued development of this item.

Following the 2022 NCWM Interim Meeting, the submitter of this item and Item LPG-22.2 collaborated on a joint proposal as requested and submitted it to the Committee in time that it could be added to the Committee's agenda for the 2022 NCWM Annual Meeting. See the Item Under Consideration for the new joint proposal. Because the submitters combined the two items into one, the Committee was able to withdraw LPG 22.2. from its agenda.

Based on limited notes, during the 2022 NCWM Annual Meeting, comments were heard from the submitters of this item that they opposed the changes as currently written in the Item Under Consideration because when LPG is dispensed it should be dispensed by a trained operator not customer operated. The submitters expressed that they do not believe separate requirements are needed for bottle filling and vehicle fueling. The submitters argued that that LPG dispensed as motor fuel is currently only 3% of the market and that emphasis should be placed on the predominate use of these dispensers. The updated version that appears in the Item Under Consideration is the updated version provided by the submitters to correct the item to the current NIST HB 44 code numbering. The S&T Committee informed the submitters that they can submit updated language to the regions since they have opposed what is currently in the Item Under Consideration.

During the Committee working session the Committee agreed that this item would retain a Developing status.

Editor Note 2: Although the submitter of this item appears to have proposed new language at the 2022 Interim Meeting, the language that appears in Interim Meeting write-up combines automatic timeout and zero setback interlock language under the section for Automatic Timeout. A new proposal was submitted separately for the 2023 NCWM review cycle that is the same proposal with the same structure errors (See the 2023 Interim Meeting agenda LPG-23.2). In addition, another proposal was submitted for the 2023 NCWM review cycle that appears to be a replacement for this item LPG-22.3 (See 2023 Interim Meeting agenda item LPG-23.1). If the submitters intend to withdraw LPG-22.3 and replace it with LPG-23.1 they can request that LPG-22.3 be withdrawn.

Regional Association Reporting:

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received:

Mr. Konrad Philatowicz (U-Haul International, Inc.) – Mr. Philatowicz commented that the submitter intends to withdraw this item in favor of LPG-23.1.

During open hearings, the submitter confirmed their intention to withdraw this item in preference of LPG-23.1.

The WWMA S&T Committee recommended that this item be withdrawn.

Southern Weights and Measures Association

No comments were received on this item during the 2022 SWMA Annual Meeting. This item has been replaced with LPG 23.1.

The SWMA S&T Committee recommended this item be Withdrawn.

Northeastern Weights and Measures Association

During the 2022 Interim Meeting, Mr. Steve Timar (New York), pointed out that the submitter requested to withdraw this item at the WWMA Meeting in favor of LPG-23.1. The Committee did not hear any other comments from the floor, nor the submitter.

The Committee is recommending that this item be Withdrawn.

Central Weights and Measures Association

During the 2022 Interim Meeting there were no comments from the floor.

The CWMA S&T Committee recommended this remain a Developing Item.

LPG-23.1 S.2.5. Zero-Set-Back Interlock

Source: National Propane Gas Association and U-Haul International

Submitter's Purpose and Justification:

Address practical issues that propane retailers encounter when trying to comply with the zero setback requirements for propane stationary meters in Handbook 44.

This proposal reflects the intent of U-Haul International, Inc. and the National Propane Gas Association's Technology, Standards and Safety Committee, a volunteer organization comprised of 2500+ members, including propane retail marketers and others providing products or services to the propane industry.

The intent behind enacting the current version of S.2.5.2 was to create consistency among motor-fuel devices used for all products. This proposal strikes a balance between a consistent standard for retail motor-fuel devices and the diverse applications and industry standard for dispensing LP-Gas. To that end, this proposal addresses only those devices used exclusively for retail motor-fuel transfer. Multi-use LP-Gas devices that are used for the filling motor-fuel and other containers, including grill cylinders, forklift cylinders, cylinders used on recreational vehicles and even motor fuel containers, are covered by S.2.5.1.

Most LP-Gas dispensed is for purposes other than motor-fuel. (Less than 3% of all LP-Gas used in the United States is used for transportation. *See* U.S. Department of Energy, Alternative Fuels Data Center https://afdc.energy.gov/fuels/propane_basics.html.) Pursuant to NFPA 58, this is accomplished by a trained and certified employee dispensing LP-Gas, typically using analog (mechanical) meters, into cylinders and tanks. The analog (mechanical) meters are safe and effective, and most notably exempt from the zero-set-back requirement because S.2.5.1 only applies to electronic devices. Clearly, Handbook 44 recognizes this reality as S.2.5.1 does not require that all LP-Gas dispensers have zero-set-back interlocks, only electronic devices. S.2.5.1 is most appropriate because currently there is no readily available technology that can be used to retrofit an analog device. When looked at from a cost/benefit perspective, one has to question the expense of replacing an analog device with an electronic device at a location that mostly serves portable cylinders and not motor vehicle tanks when LP-Gas's use is so limited in transportation.

Furthermore, NFPA 58 currently does not allow the public to refuel its LP-Gas powered motor vehicles. All motor vehicles or other containers must be filled by a specially trained employee. A proposed change has been introduced for consideration in the 2023 edition of NFPA 58 that would permit public refueling of motor vehicles as long as the dispensing system meets very specific safety requirements, including a

specialized nozzle, and is furnished with visible instructions. Upon the acceptance of this new public refueling allowance, the LP-Gas industry agrees that Zero-Setback-interlocks are needed. These public self-service motor vehicle dispensing systems will be listed to Underwriters Laboratories Standard 495 and will be dedicated to the filling of motor vehicles.

For the minimal amount of retail motor fuel customers that a typical LP-Gas dispenser serves, both U-Haul and NPGA feel that this proposal represents the most equitable approach to date for balancing the need to ensure fair transactions and consistent standards with how the LP-Gas industry currently dispenses LP-Gas and LP-Gas's future transportation applications as envisioned by the proposed changes to NFPA 58 without conducting costly industry-wide retrofits of existing, functioning multi-use equipment. Handbook 44 needs to work with industry to make technical standards economically feasible lest it risk the advancement of LP-Gas as a viable and clean motor-fuel.

One continually occurring objection is that there would be no protection for the consumer without a zero-set-back feature on retail motor fuel devices. That really isn't the case, however, as the customer always has the option to check the dispenser and meter before the filling process begins to verify that it is starting at zero.

The submitter requested that this be a Voting item.

OWM Executive Summary for LPG-23.1 – S.2.5. Zero-Set-Back Interlock

OWM Recommendation: NIST OWM believes additional discussion is need concerning this item and how it will be enforced when other LPG devices are in use that require zero-setback interlock and also the impact of the proposed requirement on other retail motor fuel devices of other products used to fuel vehicles.

- Zero set-back interlock ensures that a device is returned to zero before another customer or services person uses the device for another transaction (to ensure that an automatic interlock prevents subsequent delivery until the indicating element is returned to zero).
- The LPG Code paragraphs S.2.5.1 and S.2.5.2 address electronic stationary and other stationary devices because the process for zero-set-back interlock operates differently for electronic stationary than stationary retail motor fuel device as described in S.2.5.2. but both devices are required to return to zero before another transaction is made.
- The submitter states that only a few transactions for LPG dispenser are for fueling vehicles and they are limited to use by trained staff. Paragraphs S.2.5.1 and S.2.5.2 are not dependent on who is dispensing the product or how often the device is used as a retail motor dispenser; the paragraphs are intended to ensure that the device is so designed that each new transaction starts at zero. What happens when they are used more frequently for use in fueling vehicles?
- Both electronic stationary and stationary retail motor fuel dispensers according to the current requirements must have a zero-setback interlock.
- The proposed language added to both S.1.5.1 and S.1.5.2 is "*Devices Used Exclusively as*" Stationary Retail Motor-Fuel Devices. As such, the zero-setback interlock requirement would only applies to those devices that are used exclusively to fueling vehicles.

OWM Executive Summary for LPG-23.1 – S.2.5. Zero-Set-Back Interlock	
•	Is this equitable to other products dispensed, such as gasoline dispensers. Gasoline dispensers are required to have a zero-setback interlock, and some are used to fill containers used for gasoline-powered equipment. Granted, the majority of gasoline dispensers are used to fill vehicles; but does this create an unfair market situation where some fueling dispensers are required to have zero setback interlock and others are not?
•	The submitter also stated that proposed changes were introduced for consideration in 2023 to allow public refueling of LP Gas with safety precautions and with these new requirements zero-setback interlock is needed. How will LPG devices with and without zero-setback interlock be fairly-regulated?

Table 3. Summary of Recommendations							
LPG-23.1 – S.2.5. Zero-Set-Back Interlock							
	V	D	W	A	I	Notes*	Comments
Submitter							
OWM							
WWMA	✓						
SWMA	✓						
NEWMA						5	
CWMA		✓					
NCWM							
	Letters of Support			Letters of Opposition		Notes	
Industry							
Manufacturers							
Retailers and Consumers							
Regulators							
*Notes Key: 1 – Submitted modified language 2 – Item not discussed 3 – No meeting held 4 – Not submitted on agenda 5 – No recommendation or not considered							

Item Under Consideration:

Amend Handbook 44, Liquefied Petroleum Gas and Anhydrous Ammonia Liquid-Measuring Devices Code as follows:

S.2.5. Zero-Set-Back Interlock.

S.2.5.1. Zero-Set-Back Interlock, Electronic Stationary Meters (Other than Devices used Exclusively as Stationary Retail Motor- Fuel Dispensers) and Electronic Vehicle-Mounted Meters.

– A device shall be constructed so that after an individual delivery or multiple deliveries at one location have been completed, an automatic interlock system shall engage to prevent a subsequent delivery until the indicating element and, if equipped, recording element have been returned to their zero positions.

[Nonretroactive as January 1, 2021]

(Added 2019) (Amended 2021)

S.2.5.2. Zero-Set-Back Interlock for Devices Used Exclusively as Stationary Retail Motor-Fuel Devices. – A device shall be constructed so that:

(a) after a delivery cycle has been completed by moving the starting lever to any position that shuts off the device, an automatic interlock prevents a subsequent delivery until the indicating elements and recording elements, if the device is equipped and activated to record, have been returned to their zero positions;

(b) the discharge nozzle cannot be returned to its designed hanging position (that is, any position where the tip of the nozzle is placed in its designed receptacle and the lock can be inserted) until the starting lever is in its designed shut-off position and the zero-set-back interlock has been engaged; and

(c) in a system with more than one dispenser supplied by a single pump, an effective automatic control valve in each dispenser prevents product from being delivered until the indicating elements on that dispenser are in a correct zero position.

[Nonretroactive as of January 1, 2017]

(Added 2016)

NIST OWM Detailed Technical Analysis:

Zero set-back Interlock ensures that a device is returned to zero before another customer or services person uses the device for another transaction (to ensure that an automatic interlock prevents subsequent delivery until the indicating element is returned to zero). The LPG Code paragraphs S.2.5.1 and S.2.5.2 address electronic stationary and other stationary device because the process for zero-set-back interlock operates differently for electronic stationary than stationary retail motor fuel device as described in S.2.5.2. but both devices are required to return to zero before another transactions is made.

The submitter states that only a few transactions for LPG dispenser are for fueling vehicles and they are limited to use by trained staff. These paragraphs are not dependent on who is dispensing the product or how often the device is used as a retail motor dispenser; the paragraphs are intended to ensure that the device is so designed that each new transaction starts at zero. What happens when they are used more frequently for use in fueling vehicles?

Both electronic stationary and stationary retail motor fuel dispensers according to the current requirements must have a zero-setback interlock. The proposed language added to both S.1.5.1 and S.1.5.2 is “**Devices Used Exclusively as**” Stationary Retail Motor-Fuel Devices. As such the zero-setback interlock requirement would only apply to those devices that are used exclusively to fueling vehicles. Is this equitable to other products dispensed, such as gasoline dispensers. Gasoline dispensers are required to have a zero-setback interlock, and some are used to fill containers used for gasoline-powered equipment. Granted, the

majority of gasoline dispensers are used to fill vehicles, but does this create an unfair market situation where some fueling dispensers are required to have zero set-back interlock and others are not?

The submitter also stated that proposed changes were introduced for consideration in 2023 to allow public refueling of LP Gas with safety precautions and with these new requirements zero setback interlock is needed. How will LPG devices with and without Zero-Setback Interlock be fairly-regulated?

NIST OWM believes additional discussion is need concerning this item and how it will be enforced when other LPG devices are in use that require zero-setback interlock and also the impact of the proposed requirement on other retail motor fuel devices of other products used to fuel vehicles.

Regional Association Reporting:

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received:

Mr. Konrad Philatowicz (U-Haul International, Inc.) stated that Section 2.5.1 gives the general rule regarding the zero set back interlocks and that allows for manual and electronic meters to not meet the same standard which makes perfect sense. Section 2.5.2 refers to motor fuel dispensing devices and the word electronic is missing from the title. The changes address NIST and industry concerns. He asked that this be a voting item at the National meeting.

Mr. Scott Simmons (Colorado Division of Oil and Public Safety) was in support of this item for voting.

During open hearings, comments were heard supporting a Voting status. The WWMA S&T Committee believes that this item has merit, is fully developed, and recommended that this item be assigned a Voting status.

Southern Weights and Measures Association

No comments were received on this item during the 2022 SWMA Annual Meeting.

The SWMA S&T Committee recommended this item move forward as a Voting Item.

Northeastern Weights and Measures Association

No comments. No comments were heard from the floor. The Committee does not have a recommendation as to the status of this item.

Central Weights and Measures Association

No comments were heard from the floor.

The CWMA S&T Committee recommended this as a Developing Item. The Committee has concerns regarding a consumer/customer starting a delivery when the device is not on zero.

LPG-23.2 S.2.6. Automatic Timeout.

Source: National Propane Gas Association

Submitter's Purpose and Justification:

Address practical issues that propane marketers encounter when trying to comply with the zero setback requirements for propane stationary and truck-mounted meters in Handbook 44.

This proposal was developed by the National Propane Gas Association's Technology, Standards and Safety Committee, a volunteer organization comprised of 2500+ members, including propane retail marketers and others providing products or services to the propane industry.

In S.2.6.1, the removal of the vehicle mounted meters from this three-minute requirement is necessary as the initiation of a vehicle mounted meter is performed at the truck prior to moving the delivery hose to the customer tank, sometimes as far as 150 feet from the meter, or in installations with multiple containers that may require continued adjustment of containers or delivery hose to complete a delivery. This configuration can lead to periods of up to 5 minutes between initial meter engagement and first container filling or between containers being filled on a single delivery.

In revised S.2.6, we are proposing that vehicle mounted meters be allowed periods between meter engagement and product flow of greater than 2 minutes prior to automated time out initiation. A five-minute period is more practical as the initiation of a vehicle mounted meter is performed at the truck prior to moving the delivery hose to the customer tank, sometimes as far as 150 feet from the meter, or in installations with multiple containers that may require continued adjustments of containers or delivery hose to complete a delivery. The configuration on a typical bobtail can lead to periods of up to 5 minutes between initial meter engagement and first container filling or additionally periods of greater than two minutes can transpire between containers being filled on a single delivery.

The submitter acknowledged that the opposition may feel that the change enacted from two to three minutes for the timeout is sufficient. However, it is not. Some sources say the average age of drivers in the propane industry is mid-50's. Those folks do not move as quickly or nimbly as much younger drivers.

The submitter requested that this be a Voting Item.

OWM Executive Summary for LPG-23.2 – S.2.6. Automatic Timeout.
<p>OWM Recommendation: Different device types may require varying timeouts; as such, if 5 minutes is deemed appropriate for electronic vehicle tank meters NIST OWM supports this change.</p> <ul style="list-style-type: none">• The Automatic time-out feature helps to prevent the use of the device by another customer when the preceding customer completes the transaction. This is achieved by requiring that the device automatically time-out after a specified time.• The submitter is requesting that the automatic time out that is currently specified as 3 minutes for electronic vehicle mounted meters in the LPG code be removed from S.2.6.1 in the LPG code and another paragraph be created, S.2.6.3 for electronic vehicle tank meters and,• The submitter is requesting that the automatic time out be extended to 5 minutes for electronic vehicle tank meters to account for the initiation time at the truck and moving the discharge hose to the customer tank which can exceed 150 feet.• Discussion may be needed to determine how this will impact the VTM code requirements with Timeout requirements of three-minutes.

OWM Executive Summary for LPG-23.2 – S.2.6. Automatic Timeout.	
<ul style="list-style-type: none"> Different device types will require varying timeout. As such, if the 5 minutes suggested is the appropriate industry standard for this device, NIST OWM supports this change. 	

Table 3. Summary of Recommendations							
LPG-23.2 – S.2.6. Automatic Timeout.							
	V	D	W	A	I	Notes*	Comments
Submitter							
OWM							
WWMA	✓						
SWMA	✓						
NEWMA						5	
CWMA			✓				
NCWM							
	Letters of Support			Letters of Opposition		Notes	
Industry							
Manufacturers							
Retailers and Consumers							
Regulators							
*Notes Key:							
1 – Submitted modified language							
2 – Item not discussed							
3 – No meeting held							
4 – Not submitted on agenda							
5 – No recommendation or not considered							

Item Under Consideration:

Amend Handbook 44, LPG and Anhydrous Ammonia Liquid-Measuring Devices as follows:

S.2.6. Automatic Timeout.

S.2.6.1. Electronic Stationary (Other than Stationary Retail Motor-Fuel Dispensers) and Electronic Vehicle-Mounted Meters. – For individual deliveries, if there is no product flow for three minutes the transaction must be completed before additional product flow is allowed. The three-minute timeout shall be a sealable feature on an indicator.
 [Nonretroactive as of January 1, 2021]

(Added 2021) (**Amended 20XX**)

S.2.6.2. Automatic Timeout Pay-at-Pump Retail Motor-Fuel Devices – Once a device has been authorized, it must deauthorize within three minutes if not activated. Reauthorization of the

*device must be performed before any product can be dispensed. If the time limit to deauthorize the device is programmable, it shall not accept an entry greater than three minutes.
[Nonretroactive as of January 1, 2022]*

(Added 2021)

S.2.6.3. Electronic Vehicle-Mounted Meters. – For individual deliveries, if there is no product flow for five minutes the transaction must be completed before additional product flow is allowed. The five-minute timeout shall be a sealable feature on an indicator.

(Added 20XX)

NIST OWM Detailed Technical Analysis:

The Automatic time-out feature helps to prevent the use of the device by another customer, when the preceding customer completes the transaction. This is achieved by requiring that the device automatically time-out after a specified time. The submitter is requesting that the automatic time out that is currently specified as 3 minutes for electronic vehicle mounted meters in the LPG code be removed from S.2.6.1 in the LPG code and another paragraph be created, S.2.6.3 for electronic vehicle tank meters and, the submitter is requesting that the automatic time out be extended to 5 minutes for electronic vehicle tank meters to account for the initiation time at the truck and moving the discharge hose to the customer tank which can exceed 150 feet.

Discussion may be needed to determine how this will impact the VTM code requirements with Timeout requirements of three-minutes, but different device types will require varying timeout. As such, if the 5 minutes suggested is the appropriate industry standard for this device, NIST OWM supports this change.

Regional Association Reporting:

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received:

Mr. Scott Simmons (Colorado Division of Oil and Public Safety) was in support of this item for voting. From the bobtail delivery driver perspective this makes sense. The automatic timeout will be beneficial. He did not see any detriment.

Mr. Kevin Schnepf (California Division of Measurement Standards) agreed with Mr. Simmons' comments.

During open hearings, comments were heard supporting a Voting status. The WWMA S&T Committee believes that this item has merit, is fully developed, and recommended that this item be assigned a Voting status.

Southern Weights and Measures Association

No comments were received on this item during the 2022 SWMA Annual Meeting.

The SWMA S&T Committee recommended this item move forward as a Voting Item.

Northeastern Weights and Measures Association

At the 2022 Interim Meeting no comments were heard from the floor. The Committee does not have a recommendation as to the status of this item.

Central Weights and Measures Association

At the 2022 Interim Meeting, there were no comments from the floor. The CWMA S&T Committee recommends this item be withdrawn.

MLK – Milk Meters

MLK-23.2 Table T.1. Tolerances for Milk Meters

Source: Milk Meter Tolerances Task Group

Submitter’s Purpose and Justification:

Eliminate the current tolerance structure of a decreasing permissible tolerance allowance as the size of the test draft increases.

This is a companion item to VTM-20.2 [Vehicle Mounted Milk Meters] currently being considered. It would be logical to block these two items as the data and discussion for changes to both Handbook 44 sections will be identical. This proposal is being made to eliminate the current tolerance structure of a decreasing permissible tolerance allowance as the size of the test draft increases. The proposed changes are identical to the current tolerance structure in the international community that follow OIML R-117. Without the changes to the tolerances, it would be possible for a device to be within tolerance at small test drafts and be out of tolerance for larger test drafts that are more representative of a typical delivery.

If OIML tolerances are adopted, the tolerances that are currently in place may increase at larger test drafts.

The Submitter requested a Voting status for this Item.

OWM Executive Summary for MLK-23.2 – Table T.1. Tolerances for Milk Meters
<p>OWM Recommendation: A review of this item by the Milk Meter Task Group when a new chair is appointed may be useful. We agree with other regionals that this item be assigned to the Milk Meter Task Group.</p> <ul style="list-style-type: none">• The Milk Meter Task Group reviewed all the varying tolerances in HB 44 for Milk meters. Instead of keeping a decreasing tolerance as the test draft increases, as the tolerance in the Milk meters code, the Task Group is proposing that the tolerances as included in the 2023 interim Meeting Agenda for VTM-20.2 for milk meter also be adopted in the Milk Meter code.• With the Task Group Chair currently not assigned since Mr. Charlie Stutesman no longer works with Kansas Weights and Measures and is no longer Chair of the Milk Meter Task Group, a review of the item by the Task Group when a new chair is appointed may be useful. We agree with other regionals that this item be assigned to the Milk Meter Task Group when a new task group chair is assigned.

Table 3. Summary of Recommendations							
MLK-23.2 – Table T.1. Tolerances for Milk Meters							
	V	D	W	A	I	Notes*	Comments
Submitter							
OWM							
WWMA				✓			
SWMA				✓			
NEWMA						5	
CWMA	✓						
NCWM							
	Letters of Support			Letters of Opposition		Notes	
Industry							
Manufacturers							
Retailers and Consumers							
Regulators							
<p>*Notes Key:</p> <ul style="list-style-type: none"> 1 – Submitted modified language 2 – Item not discussed 3 – No meeting held 4 – Not submitted on agenda 5 – No recommendation or not considered 							

Item Under Consideration:

Amend Handbook 44, Milk Meters Code, as follows:

T.2. Tolerance Values. – Tolerances shall be as shown in Table 1. Tolerances for Milk Meters.
 (Amended 1989, ~~20XX~~)

Table 1. Tolerances for Milk Meters		
Indication (gallons)	Maintenance Tolerance (gallons)	Acceptance Tolerance (gallons)
100	0.5	0.3
200	0.7	0.4
300	0.9	0.5
400	1.1	0.6
500	1.3	0.7
Over 500	Add 0.002 gallon per indicated gallon over 500	Add 0.001 gallon per indicated gallon over 500

(Added 1989)

Table 1. Tolerances for Milk Meters		
	Acceptance Tolerance	Maintenance Tolerance
<u>Complete Measuring System</u>	<u>0.5%</u>	<u>0.5%</u>
<u>Meter Only</u>	<u>0.3%</u>	<u>0.3%</u>

(Amended 20XX)

NIST OWM Detailed Technical Analysis:

The Milk Meter Task Group reviewed all the varying tolerances in HB 44 for Milk meters. Instead of keeping a decreasing tolerance as the test draft increases, as the tolerance in the Milk meters code, the Task Group is proposing that the tolerances as included in the 2023 Interim Meeting Agenda for VTM-20.2 for milk meter also be adopted in the Milk Meter code.

With the Task Group Chair currently not assigned since Mr. Stutesman no longer works with Kansas Weights and Measures and is no longer Chair of the Milk Meter Task Group, a review of the item by the Task Group when a new chair is appointed may be useful. We agree with other regionals that this item be assigned to the Milk Meter Task Group when a new Task Group Chair is assigned.

Regional Association Reporting:

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received: Mr. Michael Keilty (Endress+Hauser) alerted the Committee that the Chairman of the Task Group no longer works for the State of Kansas, leaving a vacancy for the Chair position. Mr. Matt Douglas (California Division of Measurement Standards) recommended that this be combined with VTM-20.2 and recommended assignment to the Milk Meter Tolerance Task Group. In the original justification, the submitter recommended that this item be blocked with VTM-20.2. The WWMA S&T Committee recommended that this item be assigned to the Milk Meter Tolerance Task Group and that this item be blocked with VTM-20.2.

Southern Weights and Measures Association

The following comments were received during the 2022 SWMA Annual Meeting: Dr. Curran (Florida) stated that he opposed raising the tolerances to accommodate this new device. No comments were received from the Milk Meter Tolerance Task Group.

The SWMA S&T Committee recommended this item be Assigned to the Milk Meter Tolerance Task Group.

Northeastern Weights and Measures Association

At the 2022 Interim Meeting, no comments were heard from the floor. The Committee does not have a recommendation as to the status of this item.

Central Weights and Measures Association

At the 2022 Interim Meeting, Mr. Doug Musick (Kansas) stated the current tolerance table has a specified tolerance for a specified draft size. The percentage calculations for them do not match. The percentage tolerance changes for the same meter based on draft size. Updating the tolerance will make it uniform with other liquid tolerance tables.

Mr. Michael Keilty (Endress+Hauser) stated that the sizes of provers for this testing are not common. They are difficult to find.

The CWMA S&T Committee believes this item is fully developed and recommends Voting status.

MFM – Mass Flow Meters

MFM-15.1 D N.3. Test Drafts.

Previously MFM-2

(**Note:** In 2019 this item was combined with Block 1 “Terminology For Testing Standards” and other items that addressed terminology for standards and the use of “master meters.” Based on comments heard during the 2021 Annual Meeting, the S&T Committee recommended that all items that were combined with Block 1 “Terminology For Testing Standards” that originally appeared as a separate item or a separate block of items on the S&T agenda prior to 2019, be removed from Block 1 “Terminology For Testing Standards” and appear as originally presented.

Item MFM-15.1 was removed from Block 1 “Terminology For Testing Standards” and now appears as a separate item on the 2022 Interim Meeting agenda.)

Source: Endress + Hauser Flowtec AG USA

Submitter’s Purpose and Justification:

Amend Handbook 44 to allow field reference standard meters to be used to test and place into service dispensers and delivery system flow meters. This item has been assigned to the submitter for further development. For more information or to provide comment, please contact:

Mr. Michael Keilty
Endress + Hauser Flowtec AG USA

The use of transfer standards is recognized in Code sections 3.34 Cryogenic Liquid-Measuring Devices Code and 3.38 Carbon Dioxide Liquid-Measuring Devices Code and 3.39 Hydrogen Gas-Measuring Devices – Tentative Code. Transfer standard is only defined for testing cryogenic liquid measuring devices. It has been pointed out that the term transfer standard is not correct and that field reference standard meters may be more appropriate. See new the Item Under Consideration, updated on September 8, 2017.

Field evaluation of LPG meters and CNG dispensers and LNG dispensers is very difficult using volumetric and gravimetric field standards and methods. The tolerances for these applications are such that using field reference standard meters are more efficient and safer. With CNG and LNG and LPG applications, the field reference standard meters are placed in-line with the delivery system as it is used to fill tanks and vehicles. The use of field reference standard meters eliminates return to storage issues. The use of field reference standard meters is easier and faster compared to the use of traditional field standards. The cost of using field reference standard meters and transporting them is much less than the cost of traditional field provers and standards.

Recognition in Handbook 44 will enable States to allow field reference standard meters to place systems into service and for field enforcement.

Volumetric field provers and gravimetric field proving are susceptible to environmental influences. The State of Colorado uses a field reference standard meter to test propane delivery truck meters. The State of Nebraska has used a field reference standard meter to test agricultural chemical meters. Other States have asked that there be recognition in HB 44 in order for their State to allow the use of field reference standard meters.

In some applications, field reference standard meters are not more accurate than the meters used in the application. For that reason, longer test drafts and possibly more tests may need to be run.

The State of California is purported to have conducted a short study of field reference standard meters in the past. The conclusion did not lead to wide adoption of the practice.

Section 3.37 Mass Flow Meters user requirement U.R.3.8. Return of Product to Storage, Retail Compressed Natural Gas Dispensers requires that the natural gas which is delivered into the test container must be returned to storage. This is difficult and most often not complied with when the test vessel contents are released to atmosphere. States often have difficulties in remote locations finding suitable field reference equipment.

OWM Executive Summary for MFM-15.1 – N.3. Test Drafts.

OWM Recommendation: OWM believes that the purpose for this item, as specified by the submitter, is better addressed from a technical standpoint in Items GEN-23.1 and Block 8.

- State and industry have a need to use various types of field test standards to evaluate commercial devices installed in the marketplace. NIST OWM recognizes the need to use various standards to test commercial devices and support the use of these standards when test data supports its use.
- The NIST OWM is also supporting the use of field test standards through the purchase of several meters and the collection of data throughout the U.S.

OWM Executive Summary for MFM-15.1 – N.3. Test Drafts.

- The purpose statement for Item MFM-15.1 (Mass Flow Meters Code) indicates the goal of this item is:

“to amend Handbook 44 to allow field reference standard meters to be used to test and place into service dispensers and delivery system flow meters.”

- The proposed changes in Items MFM-15.1 suggest changes to the *test draft criteria* for devices covered under this code, which is not necessary to allow field reference standard meters to be used to test and place into service dispensers and delivery system flow meters.
- Amongst the concerns raised to the S&T Committee over the proposed changes for MFM-15.1, is the inability for an inspector or service company to test devices under their conditions of use and as required elsewhere in the MFM code.
 - Specifically, with the proposed addition of a paragraph N.3.2. Field Reference Standard Meter Test., no information or data has been provided to justify that:
 - a different test draft size than that specified in N.3.1. or the current Mass Flow Meter, NIST HB 44 paragraph N.3 Test Draft is necessary in order to use a “Field Reference Standard Meter.”
 - the current requirements for test draft “one test draft at the maximum flow rate of the installation and one test draft at the minimum flow rate” is appropriate for use when testing with a meter or volume prover.
 - This proposal creates two test draft paragraphs in NIST HB 44. It retains the existing criteria for the test draft and adds a proposal for a second test draft paragraph that states “the test draft shall be equal to or greater than the amount delivered in one minute”
 - It has been observed when testing CNG that some draft will take far less time than one minute. If the proposed test draft paragraph is added the test draft will not be achievable and as stated unable to test under conditions of use.
 - Since this proposal adds another test draft paragraph with the existing paragraph for test draft it also creates confusion as to what paragraph the inspector should apply.

As such, given the long debate over multiple iterations of the proposals, OWM proposes that since the purpose of the proposal is to allow field reference standard meters to be used to test and place into service dispensers and delivery system, and the responsibility for allowance of these field test standards are already addressed in the NIST Handbook 44 Fundamental Considerations and Item Block 8 clarifies these responsibilities, that Consideration be given to the proposal in Item Block 8 which clearly states the responsibility for allowance of field standards along with a new proposal to add a general code requirement.

- Note that GEN-23.1 and Block 8 items clarify what has long been recognized in NIST HB 44 concerning the responsibility for acceptance of a standard making changes to specific codes such as those references in MFM-15.1 and is better addressed in GEN-23.1 and Block 8.

OWM Executive Summary for MFM-15.1 – N.3. Test Drafts.
<ul style="list-style-type: none"> • GEN-23.1 not only avoids the need to specifically reference individual test methods in each specific code, it avoids the potential of implying that test methods not specifically referenced in a code would not be appropriate.

Table 3. Summary of Recommendations							
MFM-15.1 – N.3. Test Drafts							
	V	D	W	A	I	Notes*	Comments
Submitter							
OWM							
WWMA			✓				
SWMA	✓						
NEWMA			✓				
CWMA	✓						
NCWM							
	Letters of Support			Letters of Opposition			Notes
Industry	<ul style="list-style-type: none"> • Letter from Endress+Hauser (10-07-2021) • Endress+Hauser Slides (01-11-2022) • Endress+Hauser Letter to CWMA (05-12-2022) 			<ul style="list-style-type: none"> • Comments from Seraphin (09-27-2016) • Comments from Seraphin (06-23-2017) • Comments from Seraphin (07-02-2018) • Comments from Seraphin Test Measure Co. (06-17-2022) 			
Manufacturers							
Retailers and Consumers							
*Notes Key: 1 – Submitted modified language 2 – Item not discussed 3 - No meeting held 4 - Not submitted on agenda 5 - No recommendation or not considered							

Item Under Consideration:

Amend Handbook 44, Mass Flow Meters Code as follows:

N.3. Test Drafts.

N.3.1. Minimum Test - The minimum test shall be one test draft at the maximum flow rate of the installation and one test draft at the minimum flow rate. More tests may be performed at these or other flow rates. (See T.3. Repeatability.)

(Amended 1982 **and 20XX**)

N.3.2. Field Reference Standard Meter Test. – The minimum quantity for any test draft shall be equal to or greater than the amount delivered in one minute at the flow rate being tested.

(Added 20XX)

NIST OWM Detailed Technical Analysis:

- Although this item has been on the agenda for a number of years, this item was group in a block of other similar items then removed from the block and placed back on the NCWM agenda as it originally appeared on the agenda.
- NIST OWM is working with States using Coriolis meters to collect data on the use of these meters as standards to test liquid measuring devices. This data will be shared with all regulatory officials to assist them with their approval of meters as standards.
- This purpose indicates its intent is to permit the use of field reference standard meters in field testing of commercial measuring systems.
- It is not necessary to reference “field reference standards” in a specific NIST HB 44 code in order to permit their use.
- Criteria for assessing the use of a given type of test standard are outlined in NIST HB 44 Appendix A Fundamental Considerations.
- The decision on whether or not to accept a particular test method for use in testing commercial weighing and measuring equipment ultimately rests with the regulatory authority.
- NIST OWM and Seraphin developed Block 8 items (GEN-19.1 and OTH-22.1) on the 2022 Annual Meeting Report to help clarify and provide additional information on field standard traceability and specifications, and the regulatory authority’s responsibility for approval of field standards.
- Specifically, with regard to the proposed addition of a paragraph N.3.2. Field Reference Standard Meter Test, no information or data has been provided to justify that:
 - a different test draft size than that specified in N.3.1. or the current Mass Flow Meter, NIST HB 44 paragraph N.3 Test Draft is necessary in order to use a “Field Reference Standard Meter.”
 - The current requirements for test draft “one test draft at the maximum flow rate of the installation and one test draft at the minimum flow rate” is appropriate is for use when testing with a meter or volume prover.
- This proposal creates two test draft paragraphs in NIST HB 44. It retains the existing criteria for the test draft and adds a proposal for a second test draft paragraph that states “the test draft shall be equal to or greater than the amount delivered in one minute”.
- It has been observed when testing CNG that some draft will take far less time than one minute. If the proposed test draft paragraph is added the test draft will not be achievable.

- Since this proposal adds another test draft paragraph with the existing paragraph for test draft it also creates confusion as to what paragraph the inspector should apply.

As such, given the long debate over multiple iterations of the proposals, OWM proposes that since the purpose of the proposal is to allow field reference standard meters to be used to test and place into service dispensers and delivery system, and the responsibility for allowance of these field test standards are already addressed in the NIST Handbook 44 Fundamental Considerations and Items GEN-23.1 and Block 8 clarifies these responsibilities, that Consideration be given to the proposal in Items GEN-23.1 and Block 8 which clearly states the responsibility for allowance of field standards along with the proposal to add a general code requirement.

Summary of Discussions and Actions:

In the fall of 2016, Mr. Keilty provided an update to the Item Under Consideration. That update appears in the agenda. The previous proposed Item Under Consideration was as follows:

N.3. Test Drafts. –

N.3.1. Minimum Test - Test drafts should be equal to at least the amount delivered by the device in one minute at its normal discharge rate.

(Amended 1982)

N.3.2. Transfer Standard Test. – When comparing a meter with a calibrated transfer standard, the test draft shall be equal to at least the amount delivered by the device in 2 minutes at its maximum discharge rate.

The submitter recommends that NIST update EPO 28 for CNG dispensers and EPO 26 for LPG Liquid Measuring Systems to include transfer standard meter tests. NIST Publication R 105-4 should also be revised to specifically address the transfer standard meter and the requirements for use.

The S&T Committee might also consider amending Sections 3.30 Liquid-Measuring Devices Code and 3.31 Vehicle-Tank Meters Code to allow transfer standard meters.

The Committee received written comments on all items in Block 4 and Block 5, as well as LPG-4 and MFM-2 emphasizing the need for there to be more study and discussion of the issues to assess the ramifications of all the proposed changes. The Committee also received written comments from the SMA that it looks forward to further information on these items and stating that it is important to be consistent in our use of terms across multiple sections of Handbook 44. The Committee agreed to carryover this group of items on its 2019 agenda to allow for further discussion and development of these proposals.

At the 2019 NCWM Interim Meeting, the S&T Committee decided to combine the items on the agenda dealing with the issue of transfer standard (including items already combined into blocks) into one block. Block 1 (New) of the Interim Meeting report now includes GEN-3, Block 1 (original items from the 2019 interim agenda that appeared under Block 1), Block 2, LPG-3, and MFM-5, which were all separate items and blocks of items on the S&T Committee's 2019 Interim Meeting agenda (NCWM Publication 15). Agenda items GEN-3, Block 1, Block 2, LPG-3, and MFM-5 are listed separately on the Interim agenda with a note added beneath each individual item referring the reader to the New B1 items. All items under this New B1 have retained the same numbering system for ease in referring to the appendix for discussion on each item.

At the 2019 NCWM Annual Meeting, Mr. Brett Gurney (NCWM Chair) commented regarding the formation of a Task Group assigned to further develop this block proposal. The TG is charged with providing definitions for various types of standards (transfer, field, reference, etc.) as well as the criteria to be met by these types of standards. The completion date given to the TG is July 2021. The Committee agreed to the Assigned status for this block of items and looks forward to hearing updates from the TG. The Chair of the Task Group was:

Mr. Jason Glass
Kentucky Department of Agriculture
(502) 573-0282, jason.glass@ky.gov

At the 2020 NCWM Interim Meeting Field Standard TG Chair Glass reported that the TG met prior to the NCWM Interim Meeting and has begun discussion of the items under Block 1. Mr. Glass stated that bi-weekly teleconference meetings were scheduled and that the group was optimistic but had significant work to accomplish.

Mr. Russ Vires (SMA) supports the Scale item, SCL 18.1; in this block, Mr. Dimitri Karimov (Meter Manufacturers Association) supports the Task Group activities, Mrs. Tina Butcher (NIST OWM) was encouraged with the progress on terminology and provided an update on the Mass Flow Meter testing reporting that field testing was conducted October 28 to November 1, 2019, and that State and Industry participation included Colorado, Florida, Oregon, Emerson, and Tulsa Gas Technology.

Mr. Kurt Floren (Los Angeles County, California) raised concerns with GEN-19.1 regarding the definition of “Standard, Field” and its reference to “stable” standards and how long a standard is expected to be stable, which is typically 1-year, for which he believes should be longer. Mr. Floren also questioned the statement in the definition “tested over a range of environmental and operational conditions that the measuring devices is used...”. Mr. Floren noted that he was unsure if all laboratories will have the capabilities to test over this wide range of conditions. Mr. Floren also expressed concerns with the definition “Standard, Transfer” citing that this standard may not meet the fundamental considerations requirement for standards over a long period of time or wide range of environmental conditions.

Mr. Steve Harrington (Oregon) echoed Mr. Floren’s comments. Field Standard TG Chair Glass responded that these are concerns of the TG and these issues will be discussed and considered as the TG develops these items.

During the Committee’s work session, the Committee agreed that this item should remain an Assigned Item.

At the 2021 NCWM Interim Meeting, the NCWM Field Standard TG Chair Glass provided an update on the Task Group activities. Mr. Glass reported that the field standard Task Group is following the activities of the NIST Master Meter Project and that the Task Group reviewed API specifications for use of master meters as a standard and a test protocol that will be used to ensure uniformity in collecting data on master meters used as field standards. Mr. Glass also reported that the TG does not have a recommendation for this item. Mr. Glass also reported that he would be stepping down as the TG Chair. Mr. Mike Keilty (Endress+Hauser AG) thanked Chair Glass and the TG for their work and requested that Block 1, LPG-15.1, N.3. and Block 1 MFM-15.1, N.3 be removed from Block 1 items and to allow those items to move forward separate from the other Block 1 Items. Mr. Keilty stated that similar language was added to the Hydrogen code and that the proposed language in LPG-15.1 N.3. and MFM-15.1, N.3 will allow for the recognition of master meters as field standards. Mr. Henry Oppermann (W&M Consulting) stated that data is needed to ensure that master meters can be used over a range of conditions. Mr. Bob Murnane (Seraphin) stated that jurisdictions have the ability to use meters and that Block 1 LPG-15.1, N.3 and Block 1 MM-

15.1, N.3 should remain in Block 1 until data is available to support the use of master meters as a standard. Mr. Keilty mentioned that there has been useful dialog regarding master meters in the TG, but that he is concerned that the TG is not close to deciding and he expressed concerns with the TG's focus on the NIST Master Meter Project. Mrs. Tina Butcher (NIST OWM) provided an update on the NIST Master Meter Project and noted that States have the regulatory powers to accept or reject a standard. She also mentioned that NIST is working with States to collect data needed to assess master meters and preliminary testing was conducted and data was collected on CNG at Tulsa Gas Technology's facility in fall 2019. Ms. Diane Lee (NIST OWM) noted that NIST OWM feels that it is premature to add more language to the NIST Handbook 44 on master meters without data to support its use.

During the Committee's work session, the Committee agreed to keeps all items in Block 1 and that this item should remain with an Assigned status.

At the 2021 NCWM Annual Meeting, Mr. Glass reported that he would be stepping down as the Field Standard TG Chair. The Committee heard updates from members of the Task Group during open hearings. Mr. Keilty noted that two of the items had been on the agenda since 2015 and requested that they be removed from the block and recommended recognizing the use of master meters. Other comments were to keep the items together until data is analyzed from the NIST Field Reference Standard Work Group to support the use of master meters but that if some items were removed from the block, all items should be removed from the block. Based on comments heard during the 2021 Annual Meeting, the S&T Committee recommended that all items that were included in Block 1 "Terminology For Testing Standards" that originally appeared as a separate item or a separate block of items on the S&T agenda in and prior to 2019, be removed from Block 1 "Terminology For Testing Standards" and appear as originally presented.

During the 2021 Committee work session the Committee recognized that the Task Group has accomplished all it is able to at this point and is recommending the Task Group be disbanded and will make said recommendation to the NCWM Chair. The Committee agreed to break all items in Block 1 into individual items and designate them all as Developing. The Committee thanks the Task Group and its members for their work.

At the 2022 NCWM Interim Meeting the Item Under Consideration presented at this meeting is provided below.

N.3. Test Drafts.

N.3.1. Minimum Test - The minimum test shall be one test draft at the maximum flow rate of the installation and one test draft at the minimum flow rate. More tests may be performed at these or other flow rates. (See T.3. Repeatability.)

(Amended 1982 **and 20XX**)

N.3.2. Field Reference Standard Meter Test. – The minimum quantity for any test draft shall be equal to or greater than the amount delivered in one minute at the flow rate being tested.

(Added 20XX)

Mr. Keilty shared a presentation on field standard meters during open hearings relevant to both MFM 15.1 and LPG 15.1. The intent of the presentation was to describe initial and ongoing calibration traceability, compare OIML tolerances vs NIST Handbook 44, describe the benefits and show example. An abbreviated copy of the presentation is available on the NCWM website in the interim meeting documents archive. Mr. Keilty commented that he believes MFM 15.1 and LPG 15.1 are fully developed and should receive Voting status for the annual meeting. He has updated the proposal to exclude the term "reference" from "field

reference standard meter test”, as shown above. He requested that the Committee provide specific guidance if a Developing status is assigned. A comment from industry (Mr. Bob Murnane [Seraphin]) stated that N.3.2 in the proposal conflicts with the current code which states normal test drafts must be at least one minute at the maximum discharge flow rate of installation conditions. The current wording allows for a test to be conducted at any flow rate for one minute. There was concern from a regulator (Mr. Charles Stutesman, Kansas) echoing these concerns. Ms. Diane Lee (NIST OWM) requested that more data be made available so that NIST is able to compare worldwide data against test data compiled within the U.S. by NIST. Mr. Mahesh Albuquerque (Colorado) expressed support for this item to receive Voting status. Mr. Marc Butler (Emerson Micro Motion) expressed confusion at the two notes, thinking that perhaps they conflicted with each other; are they both needed or are they independent? Mrs. Tina Butcher (NIST OWM) expressed that she recognizes the use and importance of master meters, but is concerned with the purpose of this item. Mrs. Butcher suggested that the statement for use be reworked as test draft criteria is so critical. Mrs. Butcher recommended and offered NIST OWM assistance on this item.

During the S&T Committee work session, the Committee recognized the submitters desire that a Voting status be recommended but determined that there were too many concerns and confusion expressed. The Committee recommended that the submitter develop the item further by aligning language to existing language in Handbook 44, clarifying the purpose to help avoid confusion of the new code on new equipment, and reaching out to NIST OWM or other industry or regulatory officials for feedback.

During the 2022 Annual Meeting, S&T Committee open hearings Mrs. Tina Butcher provided the NIST OWM technical analysis for this items when she address NIST OWM comments to LPG-15.1 and as addressed in this report she pointed out that a new general code requirement will be proposed for the new 2023 cycle that would not only avoid the need to specifically reference individual test methods in each specific code, it avoids the potential of implying that test methods not specifically referenced in a code would not be appropriate.

Further comments were provided that OWM believes that the purpose for this item, as specified by the submitter, is better addressed from a technical standpoint in Item Block 8 and that OWM proposes that since the purpose of the proposal is to allow field standard meters to be used to test and place into service dispensers and delivery systems, and the responsibility for allowance of these field test standards are already addressed in the NIST Handbook 44 Fundamental Considerations and Item Block 8 clarifies these responsibilities, that Consideration be given to the proposal in Item Block 8 which clearly states the responsibility for allowance of field standards along with a 2023 new proposal to add a general code requirement.

Mrs. Butcher also noted that State and industry have a need to use various types of field test standards to evaluate commercial devices installed in the marketplace and that NIST OWM recognizes the need to use various standards to test commercial devices and support the use of these standards when test data supports its use. But the proposed addition of another paragraph N.3.2 in the MFM Code that specifically references test draft for an individual test method (Field Standard Meter Test), potentially implies that test methods not specifically referenced in a code would not be appropriate.

The submitter of the item pointed out that the Central Weights and Measures Association recommended that the item move forward as a vote and noted that a presentation was given at the CWMA about using meters to test devices. Also, during open hearings, a weights and measures official spoke on the ease of use of meters to test device. Although NIST, OWM provided comments in support of the use of various standards to test commercial devices when data supports their use, and that the proposed paragraph N.3.2 in the MFM Code for this item would potentially imply that test methods not specifically referenced in a code would not be appropriate, the submitter of this item noted that he failed to understand why there was in opposition and asked States to support the item.

During the 2022 Annual Meeting, Committee work session, the Committee agreed to a Developing status for this item based on the comments heard on this item.

Regional Association Reporting:

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received:

Mr. Robert Murnane (Seraphin Test Measure Company) - asked what does adding the language do? What data has been provided to support the change to 1 minute? Is it acceptable for Weights and Measures Officials to be prohibited from testing mass flow meters using any draft size equal to or greater than the MMQ over the range of flow rates? Currently code allows for conducting tests specified by the manufacture of the meter. This proposal would increase the size of the drafts. Will HB44 have to be changed every time a new field standard is introduced? The proposed item is not necessary and requests that this item be withdrawn from consideration.

Mr. Jan Konijnenburg (NIST Associate) stated the position of NIST OWM: the purpose of this item (and LPG-15.1) is better addressed in Block 8 and opposes this item as it is written.

Mr. Michael Keilty (Endress+Hauser) commented on Mr. Murnane's comments. Mr. Murnane has submitted comments in June and Mr. Keilty wants to respond to those comments. Whenever there is a new technology, we must write codes. It is appropriate to make changes to HB44. You have to refer to HB44 to see if a meter is acceptable. These devices will be traceable and vetted by the director or meteorologist. The MMQ test is not done normally. I looked at the certificates that were issued and three of the certificates are for the same meter, used by two companies in the U.S. it is impractical and unsafe to try to collect an MMQ sample at the maximum flow rate. I will forward my comments to the committee in an email. Recommends that this item move forward as a Voting Item.

Mr. Scott Wagner (State of Colorado) commented on Section N.3.2. transfer test, the concern is that the 2-minute test draft might affect the EPO for testing CNG meters and would make it restrictive.

Mr. Murnane stated: how does the item support the purpose? An MMQ test would be prohibited by this code amendment. The test equipment available will change the volume of the test draft.

Mr. Matt Douglas (California Division of Measurement Standards) stated, "I do not think this language is helpful. This item has been on the agenda for 8 years and recommends this item be withdrawn."

During open hearings, the Committee heard conflicting comments including that the purpose of this item is better addressed in Block 8. WWMA S&T Committee recommended this item for withdrawal, along with the recommendation that the submitter combine their efforts with the submitters of Block 8.

During the voting session comments were received from membership. The submitter requested that the committee reconsider the recommended Withdrawal status and to please leave the item with the current Developing status.

Based on the comments heard, the Committee entered deliberations. During deliberations, it was determined that the item was fully developed, and the submitter had nothing further to add. The Committee concluded that the item should remain with the recommendation for withdrawal.

Southern Weights and Measures Association

The following comments were received during the 2022 SWMA Annual Meeting:

Mr. Keilty stated that the purpose statement was left out of the proposal when it moved from Block 8. It has now been added. He also submitted new language for N.3.2.

N.3.2. Field Standard Meter Test.-The minimum quantity for any test draft shall be equal to or greater than the amount delivered in one minute at the flow rate being tested except for tests of the minimum measured quantity specified for the meter.

The SWMA S&T Committee recommended this item move forward as a Voting Item with the language above included.

Northeastern Weights and Measures Association

At the 2022 Interim Meeting Mr. Keilty commented that he introduced this item in 2014 and there has been much documentation and discussion. The goal was to introduce field standard meters and small draft size benefit. Mr. Keilty indicated that he polled some states and he believes that having language in HB44 would enable those states to use field standard meters. Mr. Keilty also noted that he has submitted a letter to the NEWAM S&T Chair with changes to the purpose statement and other modifications to the language and recommends a Voting status. Mr. Murnane asked what changed in the purpose statement and it was shared with the body. Mr. Murnane commented that he believes the Fundamental Considerations already allows State Directors to use field standards and pointed to language in Block 8 that would reinforce that. Mr. Murnane also believes there is an issue with a 1-minute test. Mr. Murnane does not believe this item is needed and urged that submitter to work with submitters of Block 8. Mr. Keilty stated that whenever new technology is available, the conference allows them to be used. He believes the language in this item facilitates the testing of systems already in place and allows 1 minute test to be sufficient. He pointed out that SWMA has voted twice to pass, as has CWMA. Mr. Henry Opperman (W&M Consulting) commented that the Fundamental Considerations allows recognition of other standards that perform at the level of field standards. He questions how we prove that a field standard meets the requirements in the Fundamental Considerations. Even if used, it is still not clear how the states determined they meet the requirements. Ms. Diane Lee (NIST OWM) commented that NIST is doing additional research on test draft paragraphs. If the purpose of this item is that master meters can be used, it's always been addressed in Fundamental Considerations that State Directors can accept anything. Ms. Lee noted that Block 8 is just clarifying what is needed for selection of appropriate standards. Mr. Murnane indicated that he also called states referenced by Keilty and they are using the Fundamental Considerations for field standards. Mr. Jim Willis (New York) believes this item is redundant, noted that as a Director, he already has the authority through Fundamental Consideration, and recommends withdrawal. Mr. John Mcguire (New Jersey), Mr. Walt Remert (Pennsylvania), Mr. James Cassidy (Massachusetts) and Mr. Lou Sakin (Holliston, Massachusetts) all recommended withdrawal of this item.

After hearing comments from the body, the Committee agreed with the commenters that this item does not have merit and is redundant in nature. The Committee is recommending that this item be Withdrawn.

Central Weights and Measures Association

At the 2022 Interim Meeting Mr. Keilty recalled that the CWMA recommended this as a Voting Item for the 2022 NCWM. In May CWMA voted and approved this item. Larger drafts than 1 minute can be used.

Mr. Murnane stated that the purpose statement does not align with proposed change to N.3. Numerous meters are already approved under fundamental considerations, i.e.: the authority lies with the Director to

approve devices. Why is the test draft being changed? Regulators must be able to choose whatever draft size they want, specifically for Mass Flow Meters.

If the Minimum Measured Quantity is greater than one minute of flow, then some mass flow meters would require larger draft sizes. Several NTEP CCs were referenced in which the MMQ is less than one minute of flow, which would conflict with testing the MMQ.

Mr. Craig VanBuren (Michigan) suggested changes in verbiage to address the MMQ / one minute of flow conflict.

The CWMA S&T Committee believes this item is fully developed and recommends Voting status. The Committee also believes this should be added to Block 1.

HGM – Hydrogen Gas-Measuring Devices

HGM-23.1 UR.3.8. Safety Requirement

Source: Quong and Associates, Inc.

Submitter's Purpose and Justification:

Add safety requirement for hydrogen gas measuring devices. The proper fueling of hydrogen vehicles is critical to ensure that the vehicle and high-pressure tank is not damaged. Unlike other gases, such as compressed natural gas, hydrogen heats as a vehicle is fueled due to the reverse Joule-Thompson effect. This means that the fueling rate and temperature of the hydrogen must be carefully controlled, or damage can occur to the vehicle hydrogen tanks. The hydrogen industry has done considerable work in developing standard fueling protocols in SAE.

J2601 (https://www.sae.org/standards/content/j2601_202005/) and validation methods in ANSI/CSA HGV 4.3 (<https://www.csagroup.org/store/product/CSA%25100ANSI%20HGV%204.3%3A22/>) to ensure that the vehicles are fueled correctly and safely.

The validation of SAE J2601 using ANSI/CSA HGV 4.3 has been performed on the 50+ hydrogen stations in California by the Air Resources Board (ARB) (<https://ww2.arb.ca.gov/resources/documents/annual-hydrogen-evaluation>). The proposed requirement provides assurances that dispensers have been verified to the proper fueling protocol which will protect the dispenser, vehicle, and consumer.

While the California Department of Food and Agriculture is discussing submitting the same language for the California Code of Regulations, adding the same language of Handbook 44 would allow other states to understand and adopt the key hydrogen fueling protocol standards, thereby expanding the use of hydrogen throughout the United States.

The submitter acknowledged that some may argue that the equipment to validate stations is not available except in California.

The submitter's response would be that, first, there are other private companies who have the equipment to test dispensers outside of California, including stations in the northeast US. Second, HGV 4.3 allows for factory acceptance testing of dispensers prior to installation and an abbreviated Site Acceptance Test. This approach shortens the time and equipment necessary to verify a station meets SAE J2601. Third,

the design and software of the Hydrogen Station Equipment Performance (HyStEP) Device used by ARB is publicly available. (<https://h2tools.org/hystep-hydrogen-station-equipment-performance-device>)

The submitter provided the following links:

- SAE J2601: https://www.sae.org/standards/content/j2601_202005/ (copyrighted)
- ANSI/CSA HGV 4.3
(<https://www.csagroup.org/store/product/CSA%25100ANSI%20HGV%204.3%3A22/>)
(copyrighted)
- California Air Resources Board: Annual Evaluation of Fuel Cell Electric Vehicle Deployment & Hydrogen Fuel Station Network Development
- <https://ww2.arb.ca.gov/resources/documents/annual-hydrogen-evaluation> (many reports available, latest is too large to attach)
- EVSE Pre_Rule Wkshop Shared Deck.pdf

The submitter requested that this be a Voting Item in 2023.

OWM Executive Summary for HGM-23.1 – UR.3.8. Safety Requirement
<p>OWM Recommendation:</p> <ul style="list-style-type: none"> • It has not been part of the weights and measures standards development process to include prescriptive safety requirements into handbook legal metrology standards. • The dispenser’s design features regardless of their function should not affect the metrological integrity of the equipment. • Traditional fueling applications have established mechanisms to address the safety features of dispenser installations not typically within in the scope of the weights and measures authority. • Groundwork not outlined in the proposal must be laid to establish an SAE J2601 verification program.

Table 3. Summary of Recommendations							
HGM-23.1 – UR.3.8. Safety Requirement							
	V	D	W	A	I	Notes*	Comments
Submitter	✓						
OWM							5
WWMA		✓					
SWMA		✓					
NEWMA		✓					
CWMA		✓					

Table 3. Summary of Recommendations							
HGM-23.1 – UR.3.8. Safety Requirement							
	V	D	W	A	I	Notes*	Comments
NCWM							
	Letters of Support		Letters of Opposition		Notes		
Industry							
Manufacturers							
Retailers and Consumers							
Regulators							
*Notes Key: 1 - Submitted modified language 2 - Item not discussed 3 - No meeting held 4 - Not submitted on agenda 5 - No recommendation or not considered							

Item Under Consideration:

Amend Handbook 44 Hydrogen Gas-Metering Devices Code as follows:

UR 3.8. Safety Requirement –All hydrogen gas-measuring devices subject to this code shall maintain verification of testingdemonstrating conformance with the latest version of SAE J2601 Fuel Protocols for Light Duty Gaseous Hydrogen Surface Vehicles, as determined by the latest version of ANSI/CSA HGV 4.3 “Test Methods for Hydrogen Fueling Parameter Evaluation. (Nonretroactive as of January 1, 10XX)

NIST OWM Detailed Technical Analysis:

The proposal will essentially require weights and measures officials to assess compliance with an SAE and ANSI standards. The official will be required to verify the owner is operating dispensing equipment that holds fueling safety protocol certification to SAE J2601 which can involve the performance of the dispenser, its programming, communications capability, and the station’s hydrogen storage system as well as a suitable test apparatus for use in the verification procedure. It has not been part of the weights and measures standards development process to include prescriptive safety requirements into handbook legal metrology standards. The dispenser’s design features regardless of their function should not affect the metrological integrity of the equipment.

If it is just an inspection for possession of current documentation, that may be more palatable; however, that is not really clear from the proposal and weights and measures programs do not typically enforce safety standards. Will compliance with safety standards keep coming up as an issue with alternative fuel vehicle refueling applications? This is unlike traditional fueling applications which have established mechanisms to address the safety features of dispenser installations. How does each jurisdiction ensure that equipment has met safety standards without putting weights and measures programs in the position of having to verify

the equipment complies with standards other than HB44, since that's not typically within the scope of their authority (other than a limited number of programs which do regulate safety requirements)?

Safety is always first priority; however, has the groundwork been laid to provide all the key components to weights and measures jurisdictions to properly address existing and new installations of equipment. The safety community should be approached on lessons learned in similar applications and to determine all other options and possible opportunities to make stakeholders in the up-and-coming hydrogen marketplace aware of recommended practices for safe fueling protocols.

Regional Association Reporting:

Central Weights and Measures Association

No comments from the floor. The CWMA S&T Committee recommended this as a Developing Item. Clarification regarding the term "verification" is needed.

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received:

Mr. Kevin Schnepf (California Division of Measurement Standards) stated that he has worked with the submitter. J-2601 is a requirement for operating in the state of California. This is a safety protocol. This is both a standard and a test method. The design parameters for the equipment meet the standard. This is not a type evaluation requirement; it is a user requirement. He supported this item.

The WWMA S&T Committee feels that this item has merit and recommended that this item be assigned a Developing status with consideration to the concerns identified during open hearings.

Southern Weights and Measures Association

The following comments were received during the 2022 SWMA Annual Meeting:

Dr. Curran (Florida) questioned whether this was the proper venue for this item. Mr. Floyd (Louisiana) also commented that this was not the proper venue for this item. This Committee would like the NCWM S&T Committee to consider whether this type of item is within the scope of weights and measures.

The SWMA S&T Committee recommended this item move forward as a Developing Item.

Northeastern Weights and Measures Association

Mr. Spencer Quong (Quong and Associates representing Toyota Motors North America) explained the requirements for validation of fueling protocol through SAE. Mr. Quong indicated that if hydrogen vehicles filled too quickly, it will overheat and if the fueling protocol is performed significantly different, it may affect accuracy. Ms. Juana Williams (NIST OWM) noted that safety is first and foremost however, this proposal would require that the owner of the device be trained in fueling safety, which is not typical to put in HB44. Mr. Jason Flint (New Jersey) commented that the language in this item may be more suited for other standard setting organizations such as NFPA.

After hearing comments from the floor, the Committee recommended that this item be given a Developing status.

EVF – Electric Vehicle Fueling Systems

EVF-21.1 D A.1. General

Source: ABB, BTCPower, Electrify America, Edison Electric Institute, EVConnect, EVgo, Greenlots, Rivian, Siemens, Tesla, Tritium

Submitter's Purpose and Justification:

To provide clarity on how Handbook 44, Sec. 3.4 tentative code will apply to existing EVSE that are in the ground before it becomes effective by identifying which elements are non-retroactive.

While it is important to ensure that consumers are receiving accurate and transparent information regarding the accuracy of EV charging stations, the cost to retrofit existing stations that often do not include an integrated meter, especially DCFC where commercial DC metering technology is not readily available today, will be cost prohibitive. In California Initial Statement of Reasons (ISOR) for adopting specifications and tolerances requirement for commercial EVSE, California estimated that it costs approximately \$4,500 to upgrade existing Level 2 stations and \$20,000 to upgrade existing DCFC. To put this into context, California DMS utilized 2015 DOE data stating that the average commercial Level 2 EVSE costs between \$3,000-\$6,000 and the average DCFC up to \$40,000 or more. The retrofit costs would represent a significant investment amount that does not seem warranted. The ISOR is available here: https://www.cdfa.ca.gov/dms/pdfs/regulations/EVSE_ISOR.pdf. According to DOE AFDC station locator there are 23,000 level 2 station with 66,000 connectors in the U.S. and 3,700 DCFC stations with 14,000 connectors. Being conservative and utilizing just the number of stations, it would cost \$92M to upgrade the existing Level 2 station in the U.S. today and \$74M to upgrade the existing DCFC stations, a number that is expected to grow as more stations are deployed. Placing this excessive upgrade burden on manufacturers and network operators is not feasible and an alternative pathway needs to be explored to ensure consumer transparency and EVSE accuracy for existing stations without requiring extensive retrofits. This number also does not include the amount of public funding across various states that has been invested in these EVSE that would prematurely potentially be ripped out and replaced. It could also have the unintended consequence that the EV industry stops charging for charging services at existing sites or shut them down if the investment in retrofits is greater than the benefit of continuing to operate. Stranded assets across the country are a valid concern and should not be taken lightly. It is important to not prematurely replace EVSE in the field until the useful life of the system has been obtained. Spending a significant amount of capital to upgrade existing stations rather than investing in new infrastructure does not appear aligned with EV deployment goals. Therefore, it is recommended that there is consideration for making sure requirements are non-retroactive and there is a phase in timeline for existing stations. The language utilized above is similar to what CA DMS implemented, which was the first state to adopt a version of Handbook 44 Sec 3.4 for EVSE. The date for DC EVSE is set at January 1, 2023 to match California's timeline but also because this is when DC metering technology is expected to be commercially available in the market and integrated into DC EVSE by most EVSE manufacturers that are either working on their own product or with third party meter manufacturers.

In general, it appears that there is some openness to considering how legacy EVSE that are in the ground today should be treated when considering that DC metering technology integrated into the EVSE was not commercially available when many of these stations were developed. The main concern that has been raised is regarding whether there should be an overall exemption for existing EVSE to the measurement provisions in HB 44 Sec 3.4 or whether existing EVSE should be exempt from certain requirements in the subsections of Sec 3.4 that are not feasible to attain. In reviewing the subsections of Sec 3.4, the proposal submitters determined that it would not be feasible to meet most subsections of Sec 3.4 with equipment that is in the ground with the exception of S.5 Marking (except S.5.2) and S.6 printing requirements. To ensure

there is not confusion between which stations were in the ground prior to dates referenced above, EVSE owners and operators will need to work with local weights and measures officials on a self-reporting mechanisms or some other mechanism for tracking station service dates. California will be the first state that will need to determine how this process will operate in the field given it has already adopted the exemption noted above and compliance for new AC stations is effective January 1, 2021. On the consumer side, EVSE operators and owners today can provide certain provisions to ensure the accuracy of the commercial transaction that can be facilitated outside of having a meter integrated into the EVSE. For instance, some owners and operators may be able to utilize the accuracy that is traceable via the measurement technology in the EV that accounts for any losses and ensure the consumer is being accurately and fairly billed for what he or she is receiving.

The submitter requested Voting status for this item in 2021.

OWM Executive Summary for EVF-21.1 – A.1. General

OWM Recommendation:

- OWM believes this item should not be revisited because as written in the Item Under Consideration it requires considerable further development. Rather than proposing an exemption from all requirements in Section 3.40, OWM recommends the submitters not revisit this proposal and for those problematic areas of compliance they should propose modifications to specific requirements that result in a suitable alternative means to achieve conformity.
- OWM acknowledges the submitters have been diligently working with the NIST USNWG EVFE Subgroup. The EVFE Subgroup has held 16 meetings since 2020 where the submitters presented possible alternatives for the group to review prior to presenting those alternatives to the community for consideration. The EVFE Subgroup only reached a consensus in June 2022 for a proposal that does not delay fundamental requirements for accuracy of commercial systems. The EVFE Subgroup’s proposal recommends a wider DC tolerance (5 percent) for EVSEs installed prior to 2024 and specifies that must include accuracy markings for transparency to the EV driver about the conditions for the sale of electrical energy and in fairness to competing businesses. The EVFE Subgroup offers that proposal for consideration as an alternative to Agenda Items EVF-23.5 and EVF-23.6 with notable differences.
- NIST OWM is aware of the submitters’ November 15, 2022 email sent to the Committee where the submitters recommend withdrawing EVF 21.1 and EVF-21.5 given new proposal EVF-23.6 reflects feedback on these 2021 proposals and the significant changes to the proposals since August 2020 (as well as the EVSE code becoming permanent). The submitters are also supportive of designating EVF-23.6 as a Voting Item.
- The proposal, if adopted as written, would mean an entire generation of devices will be permitted to operate for a 10-year period without having to comply with any HB 44 Section 3.40 requirements for indications, receipts, accuracy, security for metrological features, specific code markings, etc. for what may well be the lifetime of the device.
- To allow such a blanket exemption does a disservice to the electric vehicle refueling industry and would be viewed as competitively unfair to traditional and other alternative vehicle fueling applications which are required to comply with similar requirements or EVSE manufacturers who are spending money to comply with current requirements. The fairness issue has surfaced in several 2023 proposals.

OWM Executive Summary for EVF-21.1 – A.1. General	
<ul style="list-style-type: none"> • The submitters need to consider that, even if an effective date is added to a device-specific code, Section 1.10 General Code requirements will still apply. • The submitters made alternate proposals available to the EVFE Subgroup for their review in January 2022 and April 2022. These alternate proposals do not include any modifications to paragraph A.1. General as shown in the Item Under Consideration. • The EVFE Subgroup’s discussions have been ongoing in their review of the submitters latest proposals which are intended to replace S&T Agenda Items EVF-21.1 and EVF-21.5. The EVFE Subgroup has not reached a consensus on the submitters’ latest proposals which were revised to address specific features such as the indicating element, identification/marketing information, as well as general and type evaluation tolerances. 	

Table 3. Summary of Recommendations							
EVF-21.1 – A.1. General							
	V	D	W	A	I	Notes*	Comments
Submitter							See 9/28/20 industry presentation of the original proposal at WWMA. See also letters of 7/12/21 and 10/6/21 regarding proposed modifications to the original proposal.
OWM			✓				See also OWM’s letter of 9/28/20 summarizing key points to consider.
WWMA			✓				
SWMA			✓				
NEWMA			✓				
CWMA		✓					
NCWM							
	Letters of Support			Letters of Opposition			Notes
Industry	1						In addition to submitters’ letters noted above.
Manufacturers							
Retailers and Consumers							
*Notes Key: 1 – Submitted modified language 2 – Item not discussed 3 – No meeting held 4 – Not submitted on agenda 5 – No recommendation or not considered							

Item Under Consideration:

A.1. General – This code applies to devices, accessories, and systems used for the measurement of electricity dispensed in vehicle fuel applications wherein a quantity determination or statement of measure is used wholly or partially as a basis for sale or upon which a charge for service is based.

A.1.1. Effective Dates for DC EVSE – All DC EVSE used for commercial purposes and put into service on or before January 1, 2023 are exempt from this standard for a period of 10 years from the date put into service. comply

A.1.2. Effective Dates for AC EVSE – All AC EVSE used for commercial purposes and put into service on or before January 1, 2022 are exempt from this standard for a period of 10 years from the date put into service.

NIST OWM Detailed Technical Analysis:

As the weights and measures community continues to consider proposed new paragraphs A.1.1 and A.1.2 which would exempt EVSEs from all NIST HB 44 Section 3.40 requirements based on the dates these systems were placed into commercial use, NIST OWM would like to note the following concerns:

As worded the proposal is: (1) unclear on the exact type of use that entitles an EVSE to an exemption from all code requirements and also (2) in conflict with General Code paragraph G-A.6. Nonretroactive Requirements.

The proposal, if adopted, would mean an entire generation of devices will be permitted to operate for a 10-year period without having to comply with any HB 44 Section 3.40 requirements for indications, receipts, accuracy, security for metrological features, specific code markings, etc. for what may well be the lifetime of the device.

To allow such a blanket exemption does a disservice to the electric vehicle refueling industry and would be viewed as competitively unfair to traditional and other alternative vehicle fueling applications which are required to comply with similar requirements or EVSE manufacturers who are spending money to comply with current requirements.

The submitter needs to consider that, even if an effective date is added to an entire device-specific code, Section 1.10. General Code requirements will still apply.

For jurisdictions that don't automatically adopt the current version on NIST Handbook 44, this window of time during which noncompliant devices can continue to be installed will be even longer.

The USNWG EVF&S that developed the EVFS Code and modified the Timing Device Code (to recognize EVSEs) has been widely advertised and all stakeholders (including EVFS OEMs) encouraged to join. Many companies have been an integral part of the development of these requirements and have expended considerable funds to bring their equipment into compliance at a competitive disadvantage if a large group of competing devices were to be exempted from the requirements.

The proposal describes the marketplace as having “existing stations that often do not include an integrated meter” which might be an indication that available EVSEs placed into commercial use before the proposed enforcement date will have limited or no legal metrology components. In this case a notice is necessary for

consumers that purchasing electricity from one site does not provide the same assurance of accuracy that is provided at another site.

If there are concerns about specific provisions in the code, these need to be addressed by making specific sections “nonretroactive” with sunset dates, not by exempting the device from the requirements of the specific code in entirety. Factored into any enforcement dates should be the fact that the EVFS codes have been available for over seven years (and was under development by regulators and industry for three years prior to that).

Throughout 2021 up through June 2022 NIST OWM has recommended the submitters revise their 2021 proposals to address concerns previously expressed by the USNWG EVF&S’s EVFE Subgroup and weights and measures community prior to submission of any alternate proposals for a review of the EVFE Subgroup.

The submitters provided updates to the community in July 2021 about their work to revise the proposals in NCWM S&T Committee Agenda Items EVF-21.1 A.1. General and EVF-21.5 T.2. Load Test Tolerances. Their work was completed in early November 2021.

On November 20, 2021, NIST OWM provided input on the submitter’s alternate proposal. This revised proposal modifies five NIST Handbook 44 Section 3.40 EVFS requirements (that address indicating elements, sealing, identification/marketing, and tolerances). The submitters and NIST OWM met on December 7, 2021 to discuss NIST OWM’s preliminary review and adjustments suggested for the alternate proposal. Subsequent revisions by the submitters of their alternate proposals were also made available to the EVFE Subgroup in January 2022 and April 2022. These alternate proposals do not include any modifications to paragraph A.1. General. The EVFE Subgroup’s discussions have been ongoing in their review of the submitters latest proposals which are intended to replace S&T Agenda Items EVF-21.1 and EVF-21.5. The EVFE has not reached a consensus on the submitters’ latest proposals.

NIST OWM is aware of the submitters’ November 15, 2022 email sent to the Committee where the submitters recommend withdrawing EVF 21.1 and EVF-21.5 given new proposal EVF-23.6 reflects feedback on these 2021 proposals and the significant changes to the proposals since August 2020 (as well as the EVSE code becoming permanent). The submitters are also supportive of designating EVF-23.6 as a voting item. At this stage, given the lengthy deliberations over the course of the past three years by the EVFE Subgroup on EVF-21.1 and other alternative proposals developed by the submitters, as well as the significant differences between the enforcement dates and conditions applicable to DC Systems in EVF-23.6 in contrast to and the Subgroup’s June 2022 alternate proposal for DC tolerances and corresponding marking requirements to be applicable based simply on a 2024 installation date; nor the proposed conditions in EVF-21.1 for a blanket exemption from the entire code for ten years being replaced by EVF-23.6 where DC system’s compliance involves certification/installation/multiple enforcement dates would any of these options be conducive to a straightforward and orderly implementation of the EVFS Code. Possibly the EVFE Subgroup’s alternate proposal with some refinement is the most viable option.

Summary of Discussions and Actions:

During the NCWM 2021 Interim Meeting the Committee assigned Developing status for this item. For more information or to provide comment, please contact:

Ms. Francesca Wahl
Tesla
(650) 435-0422, fwahl@tesla.com

NCWM 2022 Annual Meeting

Ms. Francesca Wahl (Tesla) representing the submitters of this proposal indicated the developers of the agenda item are working to address problems encountered with the requirements by the upcoming standards development cycle and before the code gains permanent status. Mr. Kurt Floren (Los Angeles County, California) had a question regarding whether amendments to the code would be entertained prior to the code becoming permanent. A priority item (EVF-22.1) recommending the EVFS Code be upgraded to permanent status was approved late June 2022 and included as a Voting Item on the July 2022 S&T Committee's Agenda. There is already a Voting Item (EVF-20.1), this proposal (EVF-21.1), and a second unresolved proposal (EVF-21.5) as well as ongoing work and deliberations in the community to further refine specific tentative EVFS code requirements. The July 2022 adoption of the priority item resulted in amending NIST Handbook 44 Section 3.40 Electric Vehicle Fueling Systems – Tentative Code to: (1) change the code's status to permanent effective January 1, 2023 and (2) modify paragraphs S.2.7. Indications of Delivery, N.5.2.(b) Accuracy Testing; For DC systems, and T.2.1. EVSE Load Test Tolerances to include a statement that makes these three requirements applicable to DC systems on or after January 1, 2028. This agenda item (EVF-21.1) remained unchanged and carried over to the 2023 standards develop cycle under the development of the submitters.

Submitter's Update: The 11 Submitters' sent a November 15, 2022 email to the NCWM S&T Committee outlining their history with EVF-21.1 (a proposal for a 10 year EVSE code exemption) and EVF-21.5 (a proposal for DC systems installed before 2033 to be permitted 2.5 times wider tolerances and after 2033 a 1 percent/2 percent tolerance already applied to AC systems applies to all EVSEs), the items introduction into the 2021 cycle and the proposals achieving Developmental status and subsequent work to address input on these items. The submitters noted their unanticipated July 2022 change in the code's status to become enforceable in 2023 and acknowledged at that same time the NCWM also modified the code to make certain elements not enforceable until 2028 implying it was not possible today to enforce these elements. For the submitters these actions accelerated the need to incorporate the concepts in the proposals and other handbook modifications to ensure the EVFS code is ready for implementation. However, a new 2023 proposal EVF 23.6 (for DC systems installed prior to 2024 when bearing accuracy markings are permitted a 5 percent tolerance which sunsets in 2034 although all DC tolerances don't apply until 2028) replaces the need to continue maintaining EVF-21.1 and EVF-21.5 as Developing Items.

The submitters noted their diligence in their work and are appreciative of the feedback and guidance from the community. The submitters recommend withdrawing EVF 21.1 and EVF-21.5 given new proposal EVF-23.6 reflects feedback on these 2021 proposals and the significant changes to the proposals since August 2020 (to include the EVSE code becoming permanent). The submitters are also supportive of designating EVF-23.6 as a voting item. The submitters plan to speak to both recommendations during the January 2023 NCWM Interim Meeting and are happy to answer questions.

Regional Association Reporting:

Central Weights and Measures Association

Francesca Wahl (Tesla): EVF-23.6 is a resubmittal of this item. Request this remains Developing.

The CWMA S&T Committee recommended this item remains as Developing.

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received:

Ms. Francesca Wahl (TESLA) – Ms. Wahl commented the USNWG has been making progress on the subject. She noted the group has made some significant modifications along with submitting item EVF-23.6. A formal vote on the item was not taken by the workgroup. Ms. Wahl noted the comments expressed apply to both EVF 21.1 and EVF-21.5. A recommendation for items EVF-21.1 and EVF-21.5 to remain developing was made by the Ms. Wahl.

Mr. Kurt Floren (County of Los Angeles, California) questioned the justification of this item, including the 10-year exemption. He opposed the item and encouraged the Committee to propose nothing more than to keep it developmental.

Mr. Kevin Schnepf (California Division of Measurement Standards) recommended the item be withdrawn for the reasons mentioned. He further commented that a 10-year exemption is not warranted, is not applicable for these devices, and does not belong in the handbook.

Southern Weights and Measures Association

The following comments were received during the 2022 SWMA Annual Meeting:

Ms. Scheleese Goudy (Electrify America and submitter) requested that it be withdrawn.

The SWMA S&T Committee recommended this item be Withdrawn.

Northeastern Weights and Measures Association

Ms. Wahl commented that there is no status update from the group of submitters and requested to keep the item as developing. Ms. Juana Williams (NIST OWM) pointed out that this proposal as worded grants a 10-year exemption for both AC and DC systems. The EVSE Subgroup is aware there are multiple alternate proposals addressing this item. Ms. Williams asks submitters to work with the EVSE Subgroup. Mr. John McGuire (New Jersey) stated that a 10-year exemption is too long and unnecessary and recommend withdrawal or developing. Mr. Jim Willis (New York) requested that this item be withdrawn.

After hearing comments from the floor, the Committee does not believe this item has merit. The Committee agreed that a blanket 10-year exemption for devices is not appropriate and recommended that this item be Withdrawn.

EVF-21.5 D T.2. Load Test Tolerances.

Source: ABB, BTCPower, Electrify America, Edison Electric Institute, EVConnect, EVgo, Greenlots, Rivian, Siemens, Tesla, Tritium

Submitter's Purpose and Justification:

To create separate metering requirements for DC EVSE due to significant technology differences and challenges between AC and DC systems.

Proposed changes to the text to differentiate alternating current (AC) EVSE from direct current (DC) EVSE. Metering for DC architected systems is considerably more complicated and in ways that the original drafting of this provision never contemplated. For example, the tentative code when initially written never contemplated 350kW EVSE or liquid cooled cabling from the charging post to the connector. As such, it is necessary to separate the implementation dates of some of the specifications, tolerances, and other technical requirements. DC metering solutions are still being researched and developed and are not yet commercially available to be integrated into DC chargers at scale and at reasonable cost. While the supply chain for the physical meters themselves is slowly catching up, the metering system in a DC EVSE, particularly high-power DC EVSE that utilize liquid-cooled cables, goes beyond the physical meter itself which is incorporated in the main housing of the EVSE. For example, measurements may also need to be taken at the connector end of the dispenser and software and algorithms must be developed, validated, and integrated into the EVSE system to allow for accurate metering of kWh delivered to the vehicle. Implementing more complex metering systems needed for DCFC requires significant design and manufacturing changes to DC EVSE.

The proposed tolerances account for the fact that these systems are still in development and are untested. The proposed timeline provides the industry with enough time to develop, test, validate, and deploy reliable DC metering system technology. This timeline is also consistent with the timeline approved by the State of California which accounts for the vast majority of the EVSE market. EVSE manufacturers are working diligently to meet the California timeline and are confident that it can be met.

While it is important to ensure that consumers are receiving accurate and transparent information regarding the accuracy of EV charging stations, it is also important that the technology to deliver high accuracy is available and reliable.

There is concern about both the proposed timeline and the accuracy requirement. Some are concerned that the accuracy specification of 2.5% acceptance and 5% maintenance is too high and does not provide sufficient consumer confidence that all charge sessions are equal regardless of provider and station. The proposers would note that this is a new and evolving technology where charging providers place a premium on customer experience as they compete for this growing market. Thus far, customers have not registered complaints about lack of transparency. Some are concerned that the timeline for instituting a metering regime is too far into the future. The proposers acknowledge the few years it will take to have reliable DC metering systems commercially available at scale but are working as quickly as possible to develop and integrate these systems into their chargers. Some are also concerned that the metering requirements have been in a place for several years already and therefore the EVSE community should not need more years to develop solutions. The proposers note that current DC EVSE technology was never contemplated by the existing metering regime and DC technology, particularly high-power DC EVSE, were not in existence at the time the original specifications were set. For example, the first 350kWh EVSE with liquid cooled cables weren't deployed in the US until 2018.

The submitter requested Voting status for this item in 2021.

OWM Executive Summary for EVF-21.5 – T.2. Load Test Tolerances

OWM Recommendation: OWM believes this item requires further development.

- The submitters made alternate proposals available to the EVFE Subgroup for their review in January 2022 and April 2022. These alternate proposals did include modifications to paragraph T.2. Load Test Tolerance to become a nonretroactive requirement enforceable in 2024 initially with a 4 percent overregistration/6 percent underregistration tolerance which then became 5 percent for DC systems that would also require accuracy markings if the device “is not subject to 1 percent Acceptance/2 percent Maintenance tolerance.”
- The EVFE Subgroup’s discussions have been ongoing in their review of the submitters 2022 proposals which are intended to replace S&T Agenda Items EVF-21.1 and EVF-21.5. The EVFE Subgroup did not reach a consensus on the submitters' latest proposals which were revised to address specific features such as the indicating element, identification/marketing information, as well as general and type evaluation tolerances.
- The EVFE Subgroup was balloted June 17, 2022 on its proposal to recognize a separate new 5 % tolerance for DC EVSEs installed prior to 2024 and a corresponding new requirement for marking the accuracy of pre-2024 equipment.
 - The final outcome of this ballot resulted in the EVFE Subgroup being in favor of the proposal. The results were provided to the submitters in October 2022 to enable them to assess how and if to modify their original proposal to the S&T Committee.
- OWM notes that a sunset date (retroactive enforcement date) ending a dual tolerance structure would encourage uniformity in equipment performance in the marketplace; facilitate value comparisons by consumers; and phase out less accurate equipment.
- According to information provided to the USNWG by the submitters, not all DC chargers (including those manufactured in recent years) manufactured prior to 2024 can be readily or inexpensively upgraded to meet the existing (1 % and 2 %) tolerances.
 - Of the DC chargers manufactured prior to 2024, including those manufactured in recent years, some are capable of being upgraded to meet the existing (1 % and 2 % tolerances) and some are not.
 - Of those DC chargers that can be upgraded, the cost for such upgrades can vary across a rather wide spectrum.
 - While some estimates of impact have been provided, the details seem to represent the broad spectrum of capabilities and cost, making it difficult to assess the impact on manufacturers, businesses, and consumers as a whole.
 - Details regarding the percentage of equipment that falls into these categories would be helpful to the community in assessing the need for a sunset date and, if a sunset date is deemed appropriate, what represents a reasonable time frame for phasing out the less accurate equipment.

OWM Executive Summary for EVF-21.5 – T.2. Load Test Tolerances

- Information has also been provided to suggest that newer DC devices being manufactured (including those manufactured today) are more robust than older equipment, extending the lifespan beyond that originally reported in past discussions.
- OWM acknowledges the submitters have been diligently working with the NIST USNWG EVFE Subgroup. The EVFE Subgroup has held 16 meetings since 2020 where the submitters presented possible alternatives for the group to review prior to presenting those alternatives to the community for consideration. The EVFE Subgroup reached a consensus the group’s June 2022 proposal. The EVFE Subgroup proposal does not delay fundamental requirements for accuracy of commercial systems. The EVFE Subgroup’s proposal recommends a wider DC tolerance (5 percent) for EVSEs installed prior to 2024 and specifies that must include accuracy markings for transparency to the EV driver about the conditions for the sale of electrical energy and in fairness to competing businesses. NIST OWM notes that the group’s proposal does require additional editing for clarity about the application of the marking requirement. The EVFE Subgroup offers that proposal for consideration as an alternative to Agenda Items EVF-23.5 and EVF-23.6. NIST OWM finds there are notable differences in the EVFE Subgroup proposal and EVF-23.6 proposal for DC systems installed prior to 2024 when bearing accuracy markings are permitted a 5 percent tolerance which sunsets in 2034 although all DC tolerances don’t apply until 2028.
- NIST OWM is aware of the submitters’ November 15, 2022 email sent to the Committee where the submitters recommend withdrawing EVF 21.1 and EVF-21.5 given new proposal EVF-23.6 reflects feedback on these 2021 proposals and the significant changes to the proposals since August 2020 (as well as the EVSE code becoming permanent). The submitters also indicated they are supportive of designating EVF-23.6 as a Voting Item.
- The submitters need to consider that, even if an effective date is added to a device-specific code, Section 1.10 General Code requirements will still apply.

Table 3. Summary of Recommendations

EVF-21.5 – T.2. Load Test Tolerances.							
	V	D	W	A	I	Notes*	Comments
Submitter							See also letters of 7/12/21 and 10/6/21 regarding proposed modifications to the original proposal. See 11/15/22 email asking Committee to withdraw as submitters move to endorse EVF-23.6.
OWM			✓				See also OWM’s letter of 9/28/20 summarizing key points to consider.
WWMA			✓				
SWMA			✓				
NEWMA			✓				
CWMA		✓					
NCWM							

Table 3. Summary of Recommendations							
EVF-21.5 – T.2. Load Test Tolerances.							
	V	D	W	A	I	Notes*	Comments
	Letters of Support		Letters of Opposition		Notes		
Industry	1				In addition to submitters' letters noted above.		
Manufacturers							
Retailers and Consumers							
*Notes Key: 1 - Submitted modified language 2 - Item not discussed 3 - No meeting held 4 - Not submitted on agenda 5 - No recommendation or not considered							

Item Under Consideration:

T.2. Load Test Tolerances.

T.2.1. AC EVSE Load Test Tolerances. – The tolerances for **AC** EVSE load tests are:

- (a) Acceptance Tolerance: 1.0 %; and
- (b) Maintenance Tolerance: 2.0 %.

T.2.2. DC EVSE Load Test Tolerances. – **The tolerances for DC EVSE load tests:**

(a) Devices installed prior to January 1, 2033

- (1) Acceptance Tolerance: 2.5 %; and**
- (2) Maintenance Tolerance: 5.0 %**

(b) Devices installed January 1, 2033 or later

- (1) Acceptance Tolerance: 1.0 %; and**
- (2) Maintenance Tolerance: 2.0 %**

NIST OWM Detailed Technical Analysis:

Should the weights and measures community continue to consider proposed new paragraph T.2.2 which would widen the tolerances for DC systems “installed” prior to January 1, 2033, NIST OWM asks are there existing devices that can meet the current requirements? Justifications for proposing the relaxing of the tolerances to this degree, particularly without a sunset date (i.e., a retroactive date) are not being received from all manufacturers?

From a technical standpoint accuracy is fundamental to determining a basic property of a measuring system in its use to establish a fee. Manufacturers and at least one jurisdiction are evaluating the performance of DC equipment as of December 2022. If the existing HB 44 requirement for a 1 percent Acceptance and 2 percent Maintenance Tolerances for *all* systems are modified then OWM would be less reluctant to seeing the adoption of a phase-in date to meet the tighter tolerances that includes an accompanying sunset date (i.e., a retroactive date). Those dates should be established from multiple factors looking at the overall impact which may not be well understood by many members of the community. OWM asks what concrete issues can be cited by the submitters to counter any opposing arguments for a phase in period for DC systems? It would be important to have statistics on the population of devices not in compliance with requirements as discussion moves forward on this proposal.

This is not a typical practice to be done on an unlimited basis. This would be more palatable from both a competitive and enforcement standpoint if there are specific technical issues, that necessitate and justify relaxing equipment tolerances on an industrywide basis. An additional concern is that companies are spending money to comply with the existing NIST HB section 3.40 tentative code yet are competing with a population of existing equipment. An additional question is: how big is that population exactly?

NIST OWM also would ask how many devices are out there that would be put into use and competing with AC devices, thus creating a competitive advantage for DC devices?

Lately multiple stakeholders in the community have either brought forward or indicated less reluctance in opposing a dual tolerance structure. There will be concerns about a dual tolerance structure if this proposal moves forward since it still does not include a corresponding marking or some other type of information requirement to alert consumers that purchasing electricity from one fueling device does not provide the same accuracy assurance as it does from another fueling device. Bottom line multiple tolerance tiers frustrate value comparisons. There is not a lot of data being made available on the accuracy of DC devices. Comments from the EVFE Subgroup representatives from industry and national laboratory indicate the current 1 % acceptance and 2 % maintenance tolerances are achievable by existing DC systems. NIST OWM was made aware in June 2022 that at least one jurisdiction is in possession of a DC test standard that has traceability, but that date has been extended several times. Several EVFE Subgroup members indicate there is a confidentiality issue that prevents release of any data.

Throughout 2021 up through mid-2022 NIST OWM has recommended the submitters revise their 2021 proposals to address concerns previously expressed by the USNWG EVF&S's EVFE Subgroup and weights and measures community prior to submission of any alternate proposals for a review of the EVFE Subgroup.

The submitters provided updates to the community in July 2021 about their work to revise the proposals in NCWM S&T Committee Agenda Items EVF-21.1 A.1. General and EVF-21.5 T.2. Load Test Tolerances. Their work was completed in early November 2021.

On November 20, 2021, NIST OWM provided input on the submitter's alternate proposal. This revised proposal modified five NIST Handbook 44 Section 3.40 EVFS requirements (that address indicating elements, sealing, identification/markings, and tolerances). The submitters and NIST OWM met on December 7, 2021 to discuss NIST OWM's preliminary review and adjustments suggested for the alternate proposal. Subsequent revisions by the submitters of their alternate proposals were also made available to the EVFE Subgroup in January 2022 and April 2022. The EVFE Subgroup's discussions have been ongoing in their review of the submitters proposals for expanding tolerances to 5 % for older equipment in commercial operation and EVSE marking requirements if a dual tier tolerance structure exists. The EVFE Subgroup was balloted June 17, 2022 on a proposed new 5 % tolerance for DC EVSEs installed prior to 2024 and a corresponding new requirement for marking the accuracy of pre-2024 equipment. The EVFE

Subgroup will offer this proposal as an alternative to two new 2023 proposals (EVF-23.5 and EVF-23.6 both are proposals to require new accuracy markings and widen DC systems tolerances but warrant careful review of the conditions and enforcement dates in these proposals).

NIST OWM is aware of the submitters' November 15, 2022 email sent to the Committee where the submitters recommend withdrawing EVF 21.1 and EVF-21.5 given new proposal EVF-23.6 reflects feedback on these 2021 proposals and the significant changes to the proposals since August 2020 (as well as the EVSE code becoming permanent). The submitters are also supportive of designating EVF-23.6 as a voting item. At this stage, given the lengthy deliberations over the course of the past three years by the EVFE Subgroup on EVF-21.1 and other alternative proposals developed by the submitters, as well as the significant differences between the enforcement dates and conditions applicable to DC Systems in EVF-23.6 in contrast to and the Subgroup's June 2022 alternate proposal for DC tolerances and corresponding marking requirements to be applicable based simply on a 2024 installation date; nor the proposed conditions in EVF-21.1 for a blanket exemption from the entire code for ten years being replaced by EVF-23.6 where DC system's compliance involves certification/installation/multiple enforcement dates would any of these options be conducive to a straightforward and orderly implementation of the EVFS Code. Possibly the EVFE Subgroup's alternate proposal with some refinement is the most viable option.

Summary of Discussions and Actions:

During the NCWM 2021 Interim Meeting the Committee assigned Developing status for this item. For more information or to provide comment, please contact:

Mr. Asaf Nagler
ABB
202-639-4075, asaf.nagler@us.abb.com

At the NCWM 2022 Annual Meeting a priority item (EVF-22.1) recommending the EVFS Code be upgraded to permanent status was approved late June 2022 to be included as a voting item on the July 2022 S&T Committee's Agenda. There was already a voting item (EVF-20.1), this proposal (EVF-21.5) and a second unresolved proposal (EVF-21.1) as well as work and deliberations in the community to further refine specific tentative EVFS code requirements. Adoption of the priority item did occur resulting in amendments to the NIST Handbook 44 Section 3.40 Electric Vehicle Fueling Systems – Tentative Code to: (1) change the code's status to permanent effective January 1, 2023 and (2) modify paragraphs S.2.7. Indications of Delivery, N.5.2.(b) Accuracy Testing; For DC systems, and T.2.1. EVSE Load Test Tolerances to include a statement that makes these three requirements applicable to DC systems on or after January 1, 2028. This agenda item (EVF-21.5) remained unchanged and carried over to the 2023 standards develop cycle under the development of the submitters. This item should be updated to include the new statement that passed adoption July 2022 to reflect the retroactive enforcement date of January 1, 2028 for paragraph T.2.1, that will be applicable to DC systems.

Submitter's Update: the 11 Submitters' sent a November 15, 2022 email to the NCWM S&T Committee outlining their history with EVF-21.1 (a proposal for a 10 year EVSE code exemption) and EVF-21.5 (a proposal for DC systems installed before 2033 to be permitted 2.5 times wider tolerances and after 2033 a 1 percent/2 percent tolerance already applied to AC systems applies to all EVSEs), the items introduction into the 2021 cycle and the proposals achieving Developmental status and subsequent work to address input on these items. The submitters noted their unanticipated July 2022 change in the code's status to become enforceable in 2023 and acknowledged at that same time the NCWM also modified the code to make certain elements not enforceable until 2028 implying it was not possible today to enforce these elements. For the submitters these actions accelerated the need to incorporate the concepts in the proposals and other

handbook modifications to ensure the EVFS code is ready for implementation. However, a new 2023 proposal EVF 23.6 (for DC systems installed prior to 2024 when bearing accuracy markings are permitted a 5 percent tolerance which sunsets in 2034 although all DC tolerances don't apply until 2028) replaces the need to continue maintaining EVF-21.1 and EVF-21.5 as Developing Items.

The submitters noted their diligence in their work and are appreciative of the feedback and guidance from the community. The submitters recommended withdrawing EVF 21.1 and EVF-21.5 given new proposal EVF-23.6 reflects feedback on these 2021 proposals and the significant changes to the proposals since August 2020 (to include the EVSE code becoming permanent). The submitters are also supportive of designating EVF-23.6 as a voting item. The submitters plan to speak to both recommendations during the January 2023 NCWM Interim Meeting and are happy to answer questions.

Regional Association Reporting:

Central Weights and Measures Association

Ms. Francesca Wahl (Tesla): EVF-23.6 is a resubmittal of this item. Requested this remain Developing.

The CWMA S&T Committee recommended this item remains as Developing.

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received:

Ms. Francesca Wahl (TESLA): Ms. Wahl commented the USNWG has been making progress on the subject. She noted the group has made some significant modifications along with submitting EVF-23.6. A formal vote on the item was not taken by the workgroup. Ms. Wahl noted the comments expressed apply to both EVF-21.1 and EVF-21.5. A recommendation for items EVF-21.1 and EVF-21.5 to remain developing was made by Ms. Wahl.

Mr. Kevin Schnepf (California Division of Measurement Standards): Mr. Schnepf commented the item does not have merit, given the state of current technology. Mr. Schnepf recommended the item be withdrawn.

Mr. Kurt Floren (County of Los Angeles, California): Mr. Floren agreed with Mr. Schnepf's comments.

During open hearings comments were heard the item was outdated and not applicable given the state of current technology. The WWMA S&T Committee recommended that this item be withdrawn.

Southern Weights and Measures Association

The following comments were received during the 2022 SWMA Annual Meeting:

Ms. Scheleese Goudy (Electrify America), the submitter of this item, requested that it be withdrawn.

The SWMA S&T Committee recommended this item be withdrawn.

Northeastern Weights and Measures Association

Ms. Francesca Wahl (Tesla), on behalf of the submitters, indicated there has been no movement on this item and noted there are new proposals as part of the EVSE Subgroup. Mr. Keith Bradley (Electrify

America) recommended this item be withdrawn. Ms. Juana Williams (NIST OWM) indicated that devices already can meet requirements in this paragraph, but EVSE Subgroup has reviewed proposal and did not reach a consensus. Mr. Jason Flint (New Jersey) and Mr. Jim Willis (New York) recommended that the item be withdrawn.

After hearing comments from the floor, the Committee does not believe this item has merit and there are other proposals that deal with this subject. The Committee is requesting that this item be withdrawn.

EVF-23.1 S.2.5.1. Money-Value Divisions Digital, S.8.(a) Minimum Measured Quantity, S.5.3.(d) Abbreviations and Symbols; Joule, N.1. No Load Test, T.5. No Load Test, N.2. Starting Load Test, T.6. Starting Load, Appendix D–megajoule

Source: NIST USNWG EVF&S-EVFE Subgroup

Submitter’s Purpose and Justification:

Further refine electrical vehicle fueling systems code requirements in NIST Handbook 44 *Specifications, Tolerances, and Other Technical Requirements for Weighing and Measuring Devices* Section 3.40 Electric Vehicle Fueling Systems Code to: (1) remove the “megajoule” unit of measurement definition and all references to the term cited in the design specifications; (2) base the computation of the total sales price on a more appropriate quantity interval that does not exceed 0.01 kWh rather than a 0.1 kWh; (3) decrease the permissible sizes of the minimum measured quantity (MMQ) to those that are more appropriate quantities for AC and DC systems deliveries and result in a shorter duration for the light load test procedure; and (4) no longer require an accuracy test and the applicable test tolerances at no load and at starting load.

The EVFE Subgroup proposes deleting all references to the “megajoule” unit of measurement in the method of sale regulation for retail sales of electrical energy as a vehicle fuel. This modification will align the unit of measurement recognized for electrical energy vehicle fueling equipment (i.e., the kilowatt-hour) in corresponding legal metrology requirements in NIST Handbook 44 *Specifications, Tolerances, and Other Technical Requirements for Weighing and Measuring Devices* Section 3.40 Electric Vehicle Fueling Systems Code and corresponding international documentary standards.

While objections to the proposed modifications may surface the group is not currently aware of any and these matters would be brought to light during the August through October 2022 comment period. The EVFE Subgroup also notes that the additional paragraphs it has recommended for modification are not recent developments but are the result of information gathered through testing carried out over the past six years and input from OEMs on EVSEs and from jurisdictions conducting tests and type evaluation of devices in field installations and laboratory environments; therefore, this proposal is the result of advances in the operating capacity of EVSEs which indicate that modifications to multiple paragraphs are warranted. Removing the “megajoule (MJ)” unit of measurement from the handbook does not conform to the practice in place for applying the concept of primary use of SI (metric) measurements recommended in the Omnibus Trade and Competitiveness Act of 1988. Although it appears that trade practice is limited to use of the kilowatt-hour unit of measurement for electrical energy deliveries to an EV battery; if that practice were to change the “joule” could be placed back into the handbook.

The submitter requested that this be a Voting Item in 2023.

OWM Executive Summary for EVF-23.1 – S.2.5.1., S.8., S.5.3.(d), N.1., T.5., N.2., T.6., Appendix D – Definitions; megajoule (MJ)							
<p>OWM Recommendation:</p> <ul style="list-style-type: none"> • NIST OWM agrees with this EVFE Subgroup’s proposal that further refines the electrical vehicle fueling systems code requirements in NIST HB 44. • NIST OWM also notes there is a related method of sale proposal on the L&R Committee Agenda (MOS-23.4) that updates the unit of measurement terminology for the EVSE application in NIST HB 130. • NIST OWM concurs with the EVFE Subgroup’s late fall 2022 proposed changes to the EVFS Code in S&T Agenda Item 23.1 to include: <ul style="list-style-type: none"> ○ further modification to paragraph S.2.5.1. Money-Value Divisions Digital to clarify that it is at the “end of the transaction when mathematical agreement shall occur. ○ proposed new modifications to: <ul style="list-style-type: none"> - paragraph S.5.2. EVSE Identification and Marking Information to ensure continuity across the EVFS Code in all references to the EVSE’s current level; and - further amending paragraph S.5.3. Abbreviations and Symbols to recognize the term “kilowatt-hour” <p>The additional modifications would read:</p> <p>S.2.5.1. Money-Value Divisions Digital. – An EVSE with digital indications shall comply with the requirements of paragraph G-S.5.5. Money-Values, Mathematical Agreement, and the total price computation <u>at the end of a transaction</u> shall be based on quantities not exceeding 0.5 MJ or 0.01 kWh.”</p> <p>S.5.2. EVSE Identification and Marking Information.</p> <p>(b) maximum current-deliverable <u>amperes</u>;</p> <p>S.5.3. Abbreviations and Symbols.</p> <p>(d) JkWh = <u>joulekilowatt hour</u>.</p>							

Table 3. Summary of Recommendations							
EVF-23.1 – S.2.5.1., S.8., S.5.3.(d), N.1., T.5., N.2., T.6., Appendix D – Definitions; megajoule (MJ)							
	V	D	W	A	I	Notes*	Comments
Submitter	✓						

Table 3. Summary of Recommendations							
EVF-23.1 – S.2.5.1., S.8., S.5.3.(d), N.1., T.5., N.2., T.6., Appendix D – Definitions; megajoule (MJ)							
	V	D	W	A	I	Notes*	Comments
OWM	✓						
WWMA	✓						
SWMA	✓						
NEWMA		✓					
CWMA	✓						
NCWM							
	Letters of Support		Letters of Opposition		Notes		
Industry			1		26AUG2022 input on S.2.5.1.		
Manufacturers							
Retailers and Consumers							
Regulators							
*Notes Key: 1 - Submitted modified language 2 - Item not discussed 3 - No meeting held 4 - Not submitted on agenda 5 - No recommendation or not considered							

Item Under Consideration:

Amend Handbook 44, Electric Vehicle Fueling Systems Code Sections as follows:

The EVFE Subgroup developed recommendations for modifying the code by removing the definition of the unit of measurement for the “megajoule” from the handbook:

megajoule (MJ). — An SI unit of energy equal to 1 000 000 joules (J). [3.40]

The computed total price for the sale of electrical energy shall be based on an EVSE using a quantity interval that does not exceed 0.01 kWh rather than 0.1 kWh or in units of the megajoule. The EVFE Subgroup also recommends removing the megajoule unit of measurement from paragraph S.2.5.1. Money-Value Divisions Digital. During its December 8, 2022 meeting the group agreed to further amend the requirement in response industry concerns about systems’ delays in relaying transaction information and for clarify that it is at the “end of the transaction” when mathematical agreement shall occur as shown below:

S.2.5.1. Money-Value Divisions Digital. – An EVSE with digital indications shall comply with the requirements of paragraph G-S.5.5. Money-Values, Mathematical Agreement, and the total price computation **at the end of a transaction** shall be based on quantities not exceeding ~~0.5 MJ~~ or 0.01 kWh.

(Amended 202X)

The EVFE Subgroup recommends modifying paragraph S.8. Minimum Measured Quantity (MMQ) to recognize an MMQ of 0.1 kWh which is very common among EVSE that have already been type approved. For ANSI C12 American National Standard for Electricity Meters—0.1, 0.2, and 0.5 Accuracy Classes compliant meters meter constants of 0.001 kWh are common. In these meters the meter is expected to be fully accurate at deliveries of only a single watt-hour (i.e., 0.001 kWh). Dispensing a larger amount of energy to determine accuracy is not needed. Additionally, the EVFE Subgroup recommends paragraph S.8 specify an MMQ not to exceed 1.0 kWh as a more appropriate quantity for DC systems and include a new note to encourage a smaller MMQ for EVSEs which in the case of AC systems will result in a shorter time to conduct a test by a factor of five.

S.8. Minimum Measured Quantity (MMQ). – The minimum measured quantity shall satisfy the conditions of use of the measuring system as follows:

(a) Measuring systems shall have a minimum measured quantity not exceeding ~~2.5 MJ or:~~

(1) 0.5 kWh for AC EVSE; and

(2) 1.0 kWh for DC EVSE.

Note: To minimize the duration of required testing, manufacturers may want to consider limiting the declared MMQ to the level of 0.1 kWh for AC EVSE.

(Amended 202X)

The EVFE Subgroup also recommends removing the term and abbreviation for the “joule” unit of measurement, the No Load Test and Starting Load Test notes and their corresponding tolerances from the code requirements because these conditions are never encountered by a customer. An EVSE never operates at no load for any significant time. The Starting Load Test should not be required because the EVSE never operates at 0.5A. Also, during its December 8, 2022 meeting the group agreed to amend paragraph S.5.2. EVSE Identification and Marking Information to ensure continuity across the EVFS Code in all references to the EVSE’s current level and further amend paragraph S.5.3. Abbreviations and Symbols to recognize the term “kilowatt-hour” and its corresponding abbreviation and after reviewing a similar proposal in Agenda Item EVF-23.4. Consequently, also modify the relevant handbook requirements as follows:

S.5.2. EVSE Identification and Marking Information.

(b) maximum ~~current~~-deliverable **amperes**;

S.5.3. Abbreviations and Symbols.

~~(d) J=joule.~~

~~**N.1. No Load Test.**—A no load test may be conducted on an EVSE measuring system by applying rated voltage to the system under test and no load applied.~~

~~**T.5. No Load Test.**—An EVSE measuring system shall not register when no load is applied.~~

~~**N.2. Starting Load Test.**—A system starting load test may be conducted by applying rated voltage and 0.5 ampere load.~~

~~**T.6. Starting Load.**—An EVSE measuring system shall register a starting load test at a 0.5 ampere (A) load.~~

Re-number paragraph N.3. Minimum Test Draft (Size) through N.6. Repeatability Tests to become N.1. through N.4., respectively.

NIST OWM Detailed Technical Analysis:

NIST OWM acknowledges the EVFE Subgroup’s proposal was developed to further refine the electrical vehicle fueling systems code requirements in NIST Handbook 44 *Specifications, Tolerances, and Other Technical Requirements for Weighing and Measuring Devices* Section 3.40 Electric Vehicle Fueling Systems Code and agrees with the proposal. NIST OWM also notes there is a related method of sale proposal on the L&R Committee Agenda (MOS-23.4) that updates the unit of measurement terminology for the EVSE application in NIST HB 130 *Uniform Laws and Regulations in the Areas of Legal Metrology and Fuel Quality*.

NIST OWM concurs with the EVFE Subgroup’s late fall 2022 proposed changes to the EVFS Code in S&T Agenda Item 23.1 to include the alternate proposed modifications to paragraph S.2.5.1. Money-Value Divisions Digital. The EVFE Subgroup agreed at its December 8, 2022 meeting that further modification to paragraph S.2.5.1. was appropriate to clarify that it is at the “end of the transaction when mathematical agreement shall occur. NIST OWM agrees with the proposed new modifications to paragraph S.5.2. EVSE Identification and Marking Information to ensure continuity across the EVFS Code in all references to the EVSE’s current level and further amending paragraph S.5.3. Abbreviations and Symbols to recognize the term “kilowatt-hour” and its corresponding abbreviation which the EVFE Subgroup recommended after reviewing similar proposals in Agenda Item EVF-23.4. These additional modifications are shown below:

S.2.5.1. Money-Value Divisions Digital. – An EVSE with digital indications shall comply with the requirements of paragraph G-S.5.5. Money-Values, Mathematical Agreement, and the total price computation **at the end of a transaction** shall be based on quantities not exceeding ~~0.5 MJ~~ or 0.01 kWh.”

S.5.2. EVSE Identification and Marking Information.

(b) maximum ~~current~~-deliverable **amperes**;

S.5.3. Abbreviations and Symbols.

(d) ~~JkWh~~ = **joulekilowatt hour**.

U.S. National Work Group’s Electric Vehicle Fueling Equipment Subgroup (EVFE SG)

- The SG asks the S&T Committee to replace its recommended changes to paragraph S.2.5.1. Money-Value Divisions Digital to further clarify the point in the process when mathematical agreement occurs with the following:

S.2.5.1. Money-Value Divisions Digital. – An EVSE with digital indications shall comply with the requirements of paragraph G-S.5.5. Money-Values, Mathematical Agreement, and the total price computation **at the end of the transaction** shall be based on quantities not exceeding ~~0.5 MJ~~ or 0.01 kWh.

(Amended 202X)

- The SG considered recommending a definition for the term “transaction” that would be specifically applicable to Section 3.40 possibly based on the definition published September 2022 in OIML G

22 the corresponding international EVSE guide. The SG did not reach a conclusion on a proposed definition; however, the SG may come back with a recommendation at some point in the future as part of a separate proposal. Two points to consider should the SG revisit the proposed definition is whether the term should apply to the 14 other NIST HB 44 codes where the term is also cited and further clarify whether it is the customer, the electric vehicle fueling system, or some other intelligence that provides acknowledgement of receipt of information relevant to the transaction process.

- The SG agrees with the proposed changes in S&T Agenda Item 23.4 to: (1) paragraph S.5.2.(b) EVSE Identification and Marking Requirements for clarity and consistency in the expression of current values across the EVFS Code and to properly identify the highest current value or level at which the manufacturer has specified for the operation of the EVSE, the EVFE SG supports identifying this marking information as the “maximum deliverable ampere” rather than the currently stated “maximum current deliverable”, and (2) paragraph S.5.3.(d) Abbreviations and Symbols which removes the “joule” unit of measurement and its corresponding abbreviation and further modifies that subparagraph to include the “kilowatt-hour” as well as recognize that unit’s abbreviation “kWh”.

The EVFE SG believes it has addressed all questions about the interpretation and applicability of code requirements in this proposal and is not aware of any further requests that the group revisit requirements or definitions in Agenda Item EVF-23.1.

Summary of Discussions and Actions:

A letter dated August 26, 2022 from industry representing Electrify America was sent to the NCWM S&T Committee. Electrify America “offered a revision to this proposal that is narrowly tailored and necessary to avoid significant interference with the ordinary operation of electric vehicle chargers. Electrify America, LLC, is the country’s largest open network of fast DC electric vehicle chargers operating over 3,000 chargers in most states. Electrify America has a serious concern about the proposed revision to paragraph S.2.5.1, “Money-Value Divisions Digital,” where the total price computation must be based on quantities not exceeding 0.01 kWh. Measurements of energy delivery are carried out locally, but the price calculation is carried out by the centralized server and reported back, repeatedly through the transaction, for display to the customer. For a charger operating at 350 kW (a capability that is now quite common) to ensure that the total cost is updated with each 0.01 kWh would require an update every 50 milliseconds. Lags in communications (Internet service to the device) for fast chargers will be not uncommon to be more than 0.01 kWh late in updating the rolling cost display, even after operators incur the heavy bandwidth penalty to even attempt these updates. It would be impossible for even the swiftest humans to make a choice, and stop a charging session, based on a change in information occurring in 100 milliseconds. The system in which cost information is calculated and communicated by a central server uses the Open Charge Point Protocol (OCPP) the emerging industry standard. These central server calculations are important for chargers to be able to operate flexibly with multiple pricing structures.

Electrify America asks why this requirement should be imposed and was not aware that this 0.01-kWh issue was brought up and deliberated in the EVFE Subgroup promptly alerting NIST. As Electrify America understands the code, the obligation to present a running, continually-updated cost would come from the reference to paragraph G-S.5.5. Money-Values, Mathematical Agreement. So, proposal EVF-23.1 could be revised to separate the 0.01-kWh requirement, as follows:

S.2.5.1. Money-Value Divisions Digital. – An EVSE with digital indications shall comply with the requirements of paragraph G-S.5.5. Money-Values, Mathematical Agreement, and

the total **computed** price **of the energy sale, presented at the completion of a transaction**, computation **presented** shall be based on quantities not exceeding 0.5 MJ or 0.01 kWh.

In this proposed revision, Electrify America used the term “total computed price” instead of “price computation” to remain consistent with existing paragraph S.2.6. EVSE Recorded Representation, which describes the information that must be provided at the end of the transaction. “The completion of a transaction” is also the same term that is used in paragraph S.2.6.

Electrify America asks the Committee to recommend this change. The remainder of EVF-23.1 is sensible and appropriate.”

The following background information was excerpted from the abbreviated summary on Agenda Item 3.a of the EVFE Subgroup’s October 6, 2022 virtual meeting. The following discussion by the EVFE Subgroup in an effort to address Electrify America’s concerns regarding the group’s proposed modification to paragraph S.2.5.1. Money-Value Divisions.

The group identified S&T Agenda Item EVF 23.1 as needing further modification to its proposed changes to paragraph S.2.5.1. Money-Value Divisions Digital to specify at what point in the delivery to apply this requirement. The EVFE Subgroup also agreed to recommend a new definition of “transaction” drawn from OIML Guide 22 Electrical Vehicle Supply Equipment be included in NIST Handbook 44 Appendix D – Definitions to further clarify what constitutes the purchase or transaction process.

The proposal to modify paragraph S.2.5.1. to no longer include the megajoule unit of measurement when expressing the electrical energy quantity value that is used to calculate the total price for refueling was developed in May 2022 by the EVFE Subgroup. An industry representative who agrees with the group’s recommendation cautions the group on the second part of its proposal to reduce the maximum interval value permissible for quantities expressed in the kilowatt-hour (kWh) from 0.1 to 0.01. The proposed change was made in anticipation that the unit price of electrical energy for vehicle refueling would reach \$1.00 per kWh or more. The group acknowledges that the maximum quantity value should be revisited to keep pace with the average national price per kilowatt hour for an EV charging session.

One industry member has concern that the recommended modification of the kWh value would result in the relay (“pinging”) of information would result in a delay in the device’s processing transaction information from what currently takes place in the system. Several in the group indicated that some delay might occur (e.g., a minimal number of milliseconds); however, with digital indications the consumer most likely would not detect the lag during refueling. Additionally, paragraph S.1.2. EVSE Indicating Elements specifies that an EVSE shall include an indicating element that continuously accumulates transaction information. During the processing of that information a very minimal lag might occur while the electrical energy delivery is taking place, but at the conclusion of the delivery there would be agreement between indications. Therefore, the EVSE Subgroup agreed further modification is necessary to paragraph S.2.5.1. Money-Value Divisions Digital for clarity and to specify this requirement applies “at the end of a transaction.”

The EVFE Subgroup concluded that the interpretation of what process occurs to constitute a “transaction” is not defined in the handbook and therefore, a new definition of “transaction” which will be drawn from OIML Guide 22 Electrical Vehicle Supply Equipment should be included in NIST Handbook 44 Appendix D – Definitions. These latest alternate modification to the code and proposed new definition for Appendix D were distributed to the Subgroup membership on October 7th for input at the upcoming meeting on October 18th. At this time the group is not recommending other than the EVFS Code [3.40] be referenced in the proposed new definition.

Regional Association Reporting:

Central Weights and Measures Association

Ms. Scheleese Goudy (Electrify America) opposed to the 0.01 kWh statement of S.2.5.1. This is unreasonable for the communication network system which would have to work in the background to “ping” at this rate.

Ms. Francesca Wahl (Tesla) requested to remove the 0.01 kWh change and move everything else forward as Voting.

Mr. Craig VanBuren (Michigan) stated the difference between 0.1 kWh and 0.01 kWh is not significant: approximately 0.4 cents. Supports moving forward with that change.

The CWMA S&T Committee believes this item is fully developed and recommended Voting status with the following changes:

S.2.5.1. Money-Value Divisions Digital. – An EVSE with digital indications shall comply with the requirements of paragraph G-S.5.5. Money-Values, Mathematical Agreement, and the total price computation shall be based on quantities not exceeding ~~0.5 MJ~~ or 0.1 kWh.

(Amended 202X)

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received:

Ms. Goudy stated: generally okay with this item. She doesn’t recall if there was a consensus on the 0.01 kWh. The pinging of the back-end system could go past the capabilities of the charger and there is no added benefit to the customer. We suggest that the 0.01-kilowatt hour be removed.

Mr. Kevin Schnepf (California Division of Measurement Standards) commented: DMS can stand in support of the item and recommended that the 0.01 kWh issue be addressed.

Ms. Wahl seconded the comments regarding the 0.01 recommendation.

Mr. Chris King (Siemens) agreed with TESLA.

During open hearings, comments were heard supporting a Voting status with exception of the “0.01 kWh” edit in the section S.2.5.1. portion of the proposal. The WWMA S&T Committee believes that this item has merit, and recommends that this item be assigned a Voting status with the following edit:

S.2.5.1. Money-Value Divisions Digital. – An EVSE with digital indications shall comply with the requirements of paragraph G-S.5.5. Money-Values, Mathematical Agreement, and the total price computation shall be based on quantities not exceeding ~~0.5 MJ~~ or ~~0.01 kWh~~ 0.1 kWh.

(Amended 202X)

The WWMA S&T Committee requested the submitter address the formatting of their proposal to meet NCWM standard editing requirements.

The following comments were received during the 2022 SWMA Annual Meeting:

Ms. Goudy submitted the updated wording, which is newly adopted by the NIST workgroup as of October 2022. She recommended moving this item forward as a Voting Item with the following wording:

S.2.5.1. Money-Value Divisions Digital. – An EVSE with digital indications shall comply with the requirements of paragraph G-S.5.5. Money-Values, Mathematical Agreement, and the total price computation at the end of a transaction shall be based on quantities not exceeding ~~0.5 MJ~~ or 0.01 kWh.

The SWMA S&T Committee recommended this item move forward as a Voting Item with the above wording.

Northeastern Weights and Measures Association

Mr. Keith Bradley (Electrify America) explained that 0.1kWh for DC could be an issue due to communication speeds. Mr. Bradley suggested modifying the language to "...total price computation at the end of the transaction". Ms. Juana Williams (NIST OWM) indicated that the EVSE Subgroup is making further modifications to this item. Ms. Wahl agreed with the language modification suggested by Mr. Bradley. Mr. Lou Sakin (Holliston, Massachusetts) recommended that this item be Developing.

After hearing comments from the floor, the Committee believes the item has merit. The Committee recommended that the item be given a Developing status.

EVF-23.2 S.2.7. Indication of Delivery

Source: Siemens Industry Inc., Smart Infrastructure eMobility

Submitter's Purpose and Justification:

Provide consistent treatment of AC and DC chargers on the topic of Indication of Delivery.

People have argued that retrofitting DC EVSE with displays would be extremely expensive. First manufacturers have had seven years to comply with the display requirement. All but one have complied. Non-compliance was a conscious business decision to ignore the requirement. Second, Tesla generally places multiple chargers at each location and at each location has a data/control device for the entire installation. Since HB44 allows a single information kiosk for multiple EVSE it would be quite economical to put in a single display pedestal for all EVSE installed at a single location.

Tesla has an elegant customer experience where the charging transaction is authorized and all of the information desired by the customer is displayed on the vehicle's display. That provides a good driver experience but does not allow testing of the EVSE as per the Handbook. Tesla has recently announced that it intends to begin offering charging to non-Tesla EVSE. Those vehicles will not have access to the data provided on a Tesla display.

The submitter requested that this be a Voting item in 2023.

OWM Executive Summary for EVF-23.2 – S.2.7. Indication of Delivery

OWM Recommendation:

- The effective date was placed under this specific paragraph that addresses indications and therefore applies only to this paragraph while there are multiple other code paragraphs that include requirements for indication of that same transaction information throughout the charging session.
- An important question for the community is that as the enforcement date draws closer will compliance be delayed further by extending the effective date or granting a permanent exemption to equipment.
- An EVFS may have its own integral display indication or multiple devices being interfaced to a single display capable of clearly providing each device’s associated information. NIST Handbook 44 Section 1.10 General Code requirements under G.S.5. Indicating and Recording Elements and where applicable Section 5.55 Timing Devices Code also include indication requirements that apply to EVFSs.
- The proposal should be analyzed from the standpoint of its effect on the consumer, operator, competing businesses, and regulatory authority. One thing that is missing from that part of the argument is that simply eliminating the indications requirement doesn’t ensure that all vehicle displays provide the same clear and understandable alternative in the vehicle, nor explain how W&M officials will regulate/ensure that clear and legible indication for all vehicle types.
- The State of California has type approved AC systems based on their meeting indication requirement in the Electric Vehicle Fueling Systems Code.
- This is a continuance of the case where consideration has not been given to similar work by multiple stakeholders from the weights and measures and electrical energy community on the USN WG EVFE SG over the past three years to reach a consensus that is clear, comprehensive, fair from a competitive standpoint, and takes place before submitting a proposal that effects the fundamental weights and measures component of transparency.

Table 3. Summary of Recommendations

EVF-23.2 – S.2.7. Indication of Delivery							
	V	D	W	A	I	Notes*	Comments
Submitter	✓						
OWM			✓				
WWMA			✓				
SWMA			✓				
NEWMA		✓					
CWMA		✓					
NCWM							
	Letters of Support			Letters of Opposition		Notes	

Table 3. Summary of Recommendations							
EVF-23.2 – S.2.7. Indication of Delivery							
	V	D	W	A	I	Notes*	Comments
NO LETTERS/NOTES AS OF 13:30 09NOV2022,jw							
Industry							
Manufacturers							
Retailers and Consumers							
Regulators							
*Notes Key: 1 – Submitted modified language 2 – Item not discussed 3 – No meeting held 4 – Not submitted on agenda 5 – No recommendation or not considered							

Item Under Consideration:

Amend Handbook 44, Electric Vehicle Fueling Systems as follows:

S.2.7. Indication of Delivery. – The EVSE shall automatically show on its face the initial zero condition and the quantity delivered (up to the capacity of the indicating elements). All AC and DC EVSE are exempt from this requirement until January 1, 2028.

NIST OWM Detailed Technical Analysis:

The effective date was placed under this specific paragraph that addresses indications and therefore applies only to this paragraph while there are multiple other code paragraphs that include requirements for indication of that same transaction information throughout the charging session. An important question for the community is that as the enforcement date draws closer will compliance be delayed further by extending the effective date or granting a permanent exemption to equipment.

Indications are the means by which transaction and other related information is read from the device itself, although a device may have additional auxiliary indicating elements for the convenience of the owner/operator as long as they are not confusing or misleading. Electric Vehicle Fueling Systems have the option of each device having its own integral display indication or multiple devices being interfaced to a single display capable of clearly providing each device’s associated information. NIST Handbook 44 Section 1.10 General Code requirements under G.S.5. Indicating and Recording Elements and where applicable Section 5.55 Timing Devices Code also include indication requirements that apply to EVFSs.

Proposals which alter, further delay the enforcement date, or eliminate any requirement for making basic transaction information available should be analyzed from the standpoint of their effect on the consumer, operator, competing businesses, and regulatory authority. Consideration should be given to transparency, value comparison across competing installations, confidence in the marketplace, etc., given the projected expansion of commercial devices also competing with traditional and other alternative fueling applications in the marketplace. What if other vehicle refueling industries request a similar exemption?

It should be noted that the State of California has type approved AC systems based on their meeting indication requirement in the Electric Vehicle Fueling Systems Code.

There is limited justification for this proposal, and it appears that it follows on the heels of the NCWM's actions in July 2022 to delay the application for DC systems until 2028. This is a continuance of the case where consideration has not been given to similar work by multiple stakeholders from the weights and measures and electrical energy community on the USNWG EVFE SG over the past three years to reach a consensus that is clear, comprehensive, fair from a competitive standpoint, and takes place before submitting a proposal that effects the fundamental component of transparency, knowing what has been transacted whether buying or selling and being able to make value comparisons in the marketplace. Given that the earliest this proposal could become effective is 2024, and the rapidly expanding marketplace it is uncertain what point there is to implementing the latest proposed modifications for AC systems in the paragraph. It's likely that once a device has been "approved" without an indication, there will be argument that it should then be grandfathered.

Regional Association Reporting:

Central Weights and Measures Association

Ms. Francesca Wahl (Tesla) indicated no direct position. Generally supportive of the consistency. The justification section for this item in the agenda is not accurate. The current version is online.

Mr. Craig VanBuren (Michigan) recommended Developing status.

The CWMA S&T Committee recommended this as a Developing Item.

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received. Mr. Chris King (Siemens) stated the voting item was approved at the NCWM. It all comes down to customer choice as well as cost. Most models do not have this indicator. All of them provide the info to the customer through an app and it has worked well for years. We support extending this exemption to the face of all AC and DC EVSE. The models that do have this are 2 to 3 times more expensive. Allowing this change would reduce costs for customers buying this EVSE. Ms. Wahl agreed with Siemens.

Mr. Kevin Schnepf (California Division of Measurement Standards) stated California already has this requirement for AC EVSE's. Mr. Schnepf cautioned the body; they are proposing a device that puts the onus on the customer. This is wrong. There are 16 devices already approved that meet the requirements. I recommend withdrawal.

During open hearings, comments were heard that there are AC EVSE devices approved and in use that meet the current requirement. The WWMA S&T Committee recommended withdrawal of this item.

Southern Weights and Measures Association

The following comments were received during the 2022 SWMA Annual Meeting. Mr. Prince (Florida) stated that this has been addressed and the item should be withdrawn. Ms. Goudy (Electrify America) stated that this would modify a brand-new proposal and should be withdrawn. The SWMA S&T Committee recommended this item be Withdrawn.

Northeastern Weights and Measures Association

Ms. Francesca Wahl (Tesla) stated that she believes there is merit for discussion, but additional details would be helpful. Ms. Juana Williams (NIST OWM) pointed out there are AC systems that meet this requirement and are already type-approved in California. Mr. Jason Flint (New Jersey) and Mr. Jim Willis (New York) suggested that this item be given a Developing status.

After hearing comments from the floor, the Committee believes that this item has merit. The Committee recommended that this item be given a Developing status.

EVF-23.3 S.2.7. Indication of Delivery

Source: Power Measurements LLC

Submitter’s Purpose and Justification:

Reduce the exemption for DC EVSE from 2028 to 2025.

The requirement for a display has been in the code since its inception in 2016. On December 31, 2015 (just before HB44 3.4 was published with tentative status) there were only 2,377 DC EVSE installed. Of these 1,790 were from a single provider, Tesla. By December 31, 2017 (two years after the code was published) there were only 3,708 DC EVSE of which 2,883 were Tesla. At that point in time the only manufacturer not producing EVSE which complied with the display requirement in S.2.7 was Tesla. They remain the only noncompliant supplier today, seven years after the code was initially published. There is no technological reason for Tesla not to provide a display on their EVSE.

People have argued that retrofitting DC EVSE with displays would be extremely expensive. First manufacturers have had seven years to comply with the display requirement. All but one have complied. Non-compliance was a conscious business decision to ignore the requirement. Second, Tesla generally places multiple chargers at each location and at each location has a data/control device for the entire installation. Since HB44 allows a single information kiosk for multiple EVSE it would be quite economical to put in a single display pedestal for all EVSE installed at a single location.

Tesla has an elegant customer experience where the charging transaction is authorized, and all of the information desired by the customer is displayed on the vehicle’s display. That provides a good driver experience but does not allow testing of the EVSE as per the Handbook. Tesla has recently announced that it intends to begin offering charging to non-Tesla EVSE. Those vehicles will not have access to the data provided on a Tesla display.

The submitter requested that this be a Voting item in 2023.

OWM Executive Summary for EVF-23.3 – S.2.7. Indication of Delivery
<p>OWM Recommendation:</p> <ul style="list-style-type: none">• The effective date was placed under this specific paragraph that addresses indications and therefore applies only to this paragraph while there are multiple other code paragraphs that include requirements for indication of that same transaction information throughout the charging session.

OWM Executive Summary for EVF-23.3 – S.2.7. Indication of Delivery
<ul style="list-style-type: none"> • An important question for the community is that as the enforcement date draws closer will compliance be delayed further by extending the effective date or granting a permanent exemption to equipment. • An EVFS may have its own integral display indication or multiple devices being interfaced to a single display capable of clearly providing each device’s associated information. NIST Handbook 44 Section 1.10 General Code requirements under G.S.5. Indicating and Recording Elements and where applicable Section 5.55. Timing Devices Code also include indication requirements that apply to EVFSs. • The proposal should be analyzed from the standpoint of its effect on the equipment manufacturer, consumer, operator, competing businesses, and regulatory authority as to how it will be interpreted, applied, and enforced because of other indication requirements across the codes. • The State of California has type approved AC systems based on their meeting indication requirement in the Electric Vehicle Fueling Systems Code.

Table 3. Summary of Recommendations							
EVF-23.3 – S.2.7. Indication of Delivery							
	V	D	W	A	I	Notes*	Comments
Submitter							
OWM							
WWMA	✓						
SWMA			✓				
NEWMA			✓				
CWMA			✓				
NCWM							
	Letters of Support			Letters of Opposition		Notes	
Industry							
Manufacturers							
Retailers and Consumers							
Regulators							
*Notes Key:							
1 – Submitted modified language							
2 – Item not discussed							
3 – No meeting held							
4 – Not submitted on agenda							
5 – No recommendation or not considered							

Item Under Consideration:

Amend Handbook 44, Electric Vehicle Fueling Systems as follows:

S.2.7. Indication of Delivery. – The EVSE shall automatically show on its face the initial zero condition and the quantity delivered (up to the capacity of the indicating elements). All DC EVSE are exempt from this requirement until January 1, ~~2028~~2025.

NIST OWM Detailed Technical Analysis:

Although the proposal modifies the 2028 effective date to become 2025, that effective date was placed under this specific paragraph that addresses indications and therefore applies only to this paragraph. There are multiple other code paragraphs that include requirements for indication of that same transaction information throughout the charging session. An important question for the community is that as the enforcement date draws closer will compliance be delayed further by extending the effective date or granting a permanent exemption to equipment.

Indications are the means by which transaction and other related information is read from the device itself, although a device may have additional auxiliary indicating elements for the convenience of the owner/operator as long as they are not confusing or misleading. Electric Vehicle Fueling Systems have the option of each device having its own integral display indication or multiple devices being interfaced to a single display capable of clearly providing each device's associated information. NIST Handbook 44 Section 1.10 General Code requirements under G.S.5. Indicating and Recording Elements and where applicable Section 5.55 Timing Devices Code also include indication requirements that apply to EVFSs.

Proposals which alter, further delay the enforcement date, or eliminate any requirement for making basic transaction information available should be analyzed from the standpoint of their effect on the consumer, operator, competing businesses, and regulatory authority. Consideration should be given to transparency, value comparison across competing installations, confidence in the marketplace, etc., given the projected expansion of commercial devices also competing with traditional and other alternative fueling applications in the marketplace. What if other vehicle refueling industries request a similar exemption?

Regional Association Reporting:

Central Weights and Measures Association

Ms. Francesca Wahl (Tesla) requested this be Withdrawn. No additional justification as to why the date should be changed. No supporting data.

Mr. Craig VanBuren (Michigan) also requested this be Withdrawn. Both industry and regulators worked in good faith to come to this consensus of a 5-year time allowance. Federal administration has indicated that this would be contended if it passed.

Ms. Scheleese Goudy (Electrify America) requested this be Withdrawn.

The CWMA S&T Committee recommended this item be Withdrawn.

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received:

Ms. Wahl commented, we believe this item should be withdrawn. Two months ago, the 2028 date was adopted. There is no real merit in moving up to the 2025 date.

Ms. Goudy agreed with TESLA.

Mr. Kevin Schnepf (California Division of Measurement Standards) stood to support this item. DMS thinks that 2028 exemption is too long, technology can already meet the requirements and supports a Voting status.

Mr. Chris King (Siemens) supported the comments of TESLA.

During open hearings comments were heard that there are already devices which meet the current requirement. The WWMA S&T Committee believes that this item has merit, is fully developed, and recommended that this item be assigned a Voting status.

Southern Weights and Measures Association

The following comments were received during the 2022 SWMA Annual Meeting:

Mr. Prince (Florida) stated that this has been addressed and the item should be withdrawn.

Ms. Goudy stated that this item would modify a brand-new proposal and it should be withdrawn.

The SWMA S&T Committee recommended this item be withdrawn.

Northeastern Weights and Measures Association

Ms. Juana Williams (NIST OWM) stated that the EVSE Subgroup has no recommendation at this time. Ms. Wahl recommends withdrawal. She noted that at the 2022 NCWM Annual Meeting, the EVSE code was fully adopted as enforceable, and no justification was made within this proposal to roll back the date to 2025. Mr. Keith Bradley (Electrify America), Marc Paquette (Vermont), Mr. James Cassidy (Massachusetts), and Mr. Jim Willis (New York) all agreed with the statements of Ms. Wahl and agree with a Withdrawal status.

After hearing comments from the floor, the Committee does not believe this item has merit. The submitter did not provide reasoning to roll back the date to 2025. The Committee is recommending that this item be withdrawn.

EVF-23.4 S.5. Markings, and N.5. Test of an EVSE System.

Source: Power Measurements LLC

Submitter's Purpose and Justification:

Update the details of the recommended tests in HB44 3.40 to better conform to current practice and Pub 14 instructions.

- Change (b) to maximum deliverable amperes because that is the term to be used throughout the document. Previously both terms had been used interchangeably.

S.5.3

- Joule is no longer used in the document. Replace with the abbreviation for kilowatt hours.

N.5

- When the HB44 code was originally written there had been no real experience in EVSE testing. Additionally, DC EVSE were quite new and power levels were low (typically 50kW) by today's standards where 350 kW systems are already deployed, and megawatt systems are in discussion. The test points chosen at that time have been proven to be less than optimum to verify performance of the EVSE. Publication 14, which was developed later than HB44 adopted a set of test points similar to those proposed here. The tests proposed here have been extensively discussed in the NIST EVSE Working Group. However, that Work Group ran out of time for a formal vote to approve these proposals.

As background, the NIST WG is submitting Form 15s to start the restructuring of the test process. In those Form 15s the No Load and Starting load tests are removed from Section 3.4. This proposal completes the restructuring of the EVSE testing.

Detailed review of proposed changes:

Logically Section 5.2.1 should follow Section 5.2.2 so both sections have been renumbered.

New 5.2.1

In the new 5.2.1 (formerly 5.2.2) the word Laboratory was added to the title. As the power of both AC and DC EVSE has grown rapidly the equipment to test them at full power has become both large and expensive. It is perfectly reasonable for NTEP or a manufacturer to have this type of equipment but not reasonable for the average Weights and Measures inspector to have it available in the field. For that reason, this proposal breaks testing into two types: (1) testing for type verification done in a laboratory or at a manufacturer and (2) testing in the field for verification.

For testing AC systems in the laboratory three test points are proposed:

- (i) A point between 10 % and 20 % of the maximum deliverable amperes, but not exceeding 8A,
- (ii) A point between 45 % and 55 % of the maximum deliverable amperes,
- (iii) A point between 70 % and 100 % of the maximum deliverable amperes.

All test points are expressed in terms of a percent of the maximum deliverable amperes of the EVSE. For point (i) of the test a restriction has been added to ensure that high current chargers are tested near the nominal 6 A load that is the minimum charging current for most vehicles.

Today AC Level 2 chargers typically have maximum currents of 30 A to 80 A. Chargers with currents above 32 A were generally unavailable at the time HB44 3.4 was written. Several vehicles have recently

been introduced that charge at 48 A. There is only one vehicle currently available that charges at 80 A. This test regime can be performed quickly. It can be performed on any AC Level 2 EVSE with test equipment commercially available and in the hands of multiple Weights and Measures authorities.

New 5.2.2

Since HB44 3.40 was initially written a whole new generation of DC chargers have been developed. At that time the maximum power delivery was approximately 100 kW at 400 VDC. Today we have 350 kW systems operating at both 400 VDC and 800 VDC. The CCS EVSE standards have already been updated to allow chargers up to 1000 VDC and 800 A (800 kW). Because there are now two broad classes of DC EVSE; 400 VDC and 800VDC two voltage test points are included. Both voltage classes are capable of charging at 400V so a point between 350 VDC and 400VDC is required for both. For systems that can also operate at 800VDC a second point between 700 VDC and 800 VDC is required. Current points are to be tested at both voltages if they are appropriate for the EVSE.

For DC systems three test points are proposed:

- (i) A point at less than 30 A
- (ii) A point between 45 % and 55 % of the maximum deliverable amperes
- (iii) A point between 70 % and 100 % of the maximum deliverable amperes

This approach provides a test point at the lower end of the power transfer range where older vehicles may charge or where more modern EVs charge when topping off. The other two points are intended to bracket the power levels where most EV transfer most of their energy.

The power levels of DC EVSE are rapidly evolving to ever higher levels. For that reason, this change provides for flexibility in field testing of DC EVSE at the high power point. The high current point is revised to 20% to 100% of the maximum deliverable current **with guidance to test at the maximum power level that is possible using the test equipment available. The new code also provides for using a vehicle as the test load providing it meets the 20% of maximum deliverable current requirement.**

One objection might be the creation of a field testing regime for DC EVSE that is less rigorous than that applied in the laboratory. For many decades ANSI C12 meter testing has applied testing over the full range of voltage and current for meters during type testing but only done validation testing at two current values. For example, class 320 meters (320 A maximum current) are tested for accuracy at 11 points between 3 A and 320 A during type evaluation. However, for verification typically only two current points are used 5 A and 50 A.

Another objection might be the requirement to test 800 VDC EVSE at both 400 VDC and 800 VDC. Only a very few electric vehicles (three at this time) are capable of using 800 VDC charging. Therefore, even though an EVSE may be capable of 800 VDC operation because most EV operate at 400 VDC testing at 400 VDC on an 800 VDC capable system is appropriate.

The submitter requested that this be a Voting Item in 2023.

OWM Executive Summary for EVF-23.4 S.5. – Markings and N.5. Test of an EVSE System.	
OWM Recommendation:	
<ul style="list-style-type: none"> • The proposed modifications to subparagraph S.5.2. (b) to specify EVSEs must be marked with the “maximum deliverable amperes” will clarify the appropriate terminology for specifying the amperage load rating for the equipment’s operation and to be marked on the device. • At this time the “joule” unit of measurement is not used for expressing electrical energy quantity values in commercial EVSE applications. For continuity across EVSE NIST Handbook codes and regulations the term and its abbreviation (J) should also be removed from subparagraph S.5.3.(d). The kilowatt-hour unit of measurement and its corresponding abbreviation should be recognized in the EVFS Code. • There does not seem to be a general consensus on the minimum test criteria to apply to AC and DC systems. There may be test criteria that cannot be applied in both the laboratory and in the field because there are factors the examiner cannot control or adequately correct for. Tests should be conducted over the range of operating conditions for which the device is designed. • The 2023 proposal creates a new separate test requirement specifically for laboratory evaluations; therefore a 2028 exemption would also be new text that requires being underscored to clearly designate the 2028 effective date as new language. • The 2028 effective date is confusing, is the intent that no testing at an approved brick and motor facility nor type evaluations can be carried out until January 1, 2028? • A slight change is recommended for the agenda item’s title to include missing paragraphs <u>S.5.2.(b) EVSE Identification and Marking Requirements</u> and <u>S.5.3.(d) Abbreviations and Symbols; joule</u> and striking <u>S.5. Markings</u> to clarify these units of measurement are a part of this proposal. This would also assist the community in distinguishing this item from multiple others 2023 proposals that address EVFS marking requirements. 	

Table 3. Summary of Recommendations							
EVF-23.4 – S.5. Markings and N.5. Test of an EVSE System.							
	V	D	W	A	I	Notes*	Comments
Submitter	✓						
OWM							
WWMA		✓					
SWMA			✓				
NEWMA		✓					
CWMA							No recommendation for this item.
NCWM							
	Letters of Support			Letters of Opposition			Notes
Industry							

Table 3. Summary of Recommendations							
EVF-23.4 – S.5. Markings and N.5. Test of an EVSE System.							
	V	D	W	A	I	Notes*	Comments
Manufacturers							
Retailers and Consumers							
Regulators							
*Notes Key: 1 - Submitted modified language 2 - Item not discussed 3 - No meeting held 4 - Not submitted on agenda 5 - No recommendation or not considered							

Item Under Consideration:

Amend Handbook 44, Electric Vehicle Fueling Systems as follows:

S.5. Markings. – The following identification and marking requirements are in addition to the requirements of Section 1.10. General Code, paragraph G-S.1. Identification.

S.5.1. Location of Marking Information; EVSE. – The marking information required in General Code, paragraph G-S.1. Identification shall appear as follows:

- (a) within 60 cm (24 in) to 150 cm (60 in) from ground level; and
- (b) on a portion of the EVSE that cannot be readily removed or interchanged (e.g., not on a service access panel).

S.5.2. EVSE Identification and Marking Requirements. – In addition to all the marking requirements of Section 1.10. General Code, paragraph G-S.1. Identification, each EVSE shall have the following information conspicuously, legibly, and indelibly marked:

- (a) voltage rating;
- (b) maximum-~~current~~ deliverable amperes;
- (c) type of current (AC or DC or, if capable of both, both shall be listed);
- (d) minimum measured quantity (MMQ); and
- (e) temperature limits, if narrower than and within – 40 °C to + 85 °C (– 40 °F to + 185 °F).
(Amended 2021)

S.5.3. Abbreviations and Symbols. – The following abbreviations or symbols may appear on an EVSE system.

- (a) VAC = volts alternating current;

- (b) VDC = volts direct current;
- (c) MDA = maximum deliverable amperes;
- (d) ~~J=joule~~Wh – kilowatt hours.

And

N.5. Test of an EVSE System.

N.5.12. Performance Verification in the Field. – Testing in the field is intended to validate the transactional accuracy of the EVSE system. Provided the EVSE under test has a valid type approval certificate, then tThe following testing is deemed sufficient for a field validation.

(a) For AC EVSE

- (1) A point between 10 % and 20 % of the maximum deliverable amperes, but not exceeding 8 A;
- (2) A point between 45 % and 55 % of the maximum deliverable amperes; and
- (3) A point between 70 % and 100 % of the maximum deliverable amperes.

(b) For DC EVSE

- (1) A point at less than 30 A
- (2) A point between 20 % and 100 % of the maximum deliverable amperes with guidance to test at the maximum power level that is possible using the test equipment available.

For DC systems it is anticipated that an electric vehicle may be used as the test load. Under that circumstance, testing at the load presented by the vehicle shall be sufficient provided that it is greater than 20 % of the maximum deliverable amperes.

All DC EVSE are exempt from this requirement until January 1, 2028.

(Amended 2023)

N.5.21. Laboratory Accuracy Testing. – The testing methodology compares the total energy delivered in a transaction and the total cost charged as displayed/reported by the EVSE with that measured by the measurement standard. Each test shall be performed for at least the minimum measured quantity (MMQ).

(a) For AC systems:

- (1) ~~Accuracy tests of the EVSE system at a load of not less than 85 % of the maximum deliverable amperes (expressed as MDA) as determined from the pilot signal for a total energy delivered of at least twice the minimum measured quantity (MMQ). If the MDA would result in maximum deliverable power of greater than 7.2 kW, then the test may be performed at 7.2 kW.~~ Shall be performed at the following current levels:

- (i) A point between 10 % and 20 % of the maximum deliverable amperes, but not exceeding 8A;
 - (ii) A point between 45 % and 55 % of the maximum deliverable amperes; and
 - (iii) A point between 70 % and 100 % of the maximum deliverable amperes.
- ~~(2) Accuracy test of the EVSE system at a load of not greater than 10 % of the maximum deliverable amperes (expressed as MDA) as determined from the pilot signal for a total energy delivered of at least the minimum measured quantity (MMQ).~~
- (b) For DC systems (see note) tests shall be performed at two voltage points one between 350 VDC and 400 VDC and if supported by the EVSE a second at between 700 VDC and 800 VDC:
- (1) Accuracy tests of the EVSE system at a load of not less than 85 % of the maximum deliverable amperes current (expressed as MDA) as determined from the digital communication message from the DC EVSE to the test standard for a total energy delivered of at least twice the minimum measured quantity (MMQ), shall be performed at the following current levels:
 - (i) A point at less than 30A;
 - (ii) A point between 45 % and 55 % of the maximum deliverable amperes; and
 - (iii) A point between 70 % and 100 % of the maximum deliverable amperes.
 - (2) ~~Accuracy test of the EVSE system at a load of not more than 10 % of the maximum deliverable amperes (expressed as MDA) as determined from the digital communication message from the DC EVSE to the test standard for a total energy delivered of at least the minimum measured quantity (MMQ).~~ ~~(2) Accuracy test of the EVSE system at a load of not more than 10 % of the maximum deliverable amperes (expressed as MDA) as determined from the digital communication message from the DC EVSE to the test standard for a total energy delivered of at least the minimum measured quantity (MMQ).~~

All DC EVSE are exempt from this requirement until January 1, 2028.

(Amended 2022 and 2023)

~~Note: For DC systems it is anticipated that an electric vehicle may be used as the test load. Under that circumstance, testing at the load presented by the vehicle shall be sufficient. Circumstance, testing at the load presented by the vehicle shall be sufficient~~

NIST OWM Detailed Technical Analysis:

The submitter's proposed modifications to subparagraph S.5.2. (b) EVSE Identification and Marking Requirements will clarify throughout the EVFS code the appropriate terminology for specifying the amperage load the EVSE's manufacturer has rated the equipment at for its operation and as a required marking on the device.

The unit of measurement “joule” is not presently in use for expressing electrical energy quantity values in commercial EVSE applications. Therefore, to ensure continuity across all relevant EVSE NIST Handbook codes and regulations the term “joule,” to include its abbreviation (J), should *not* be included in subparagraph S.5.3.(d) or any other legal metrology requirements at this time. The kilowatt-hour unit of measurement and its corresponding abbreviation should be recognized in the EVFS Code.

Although the community has more knowledge on the operations of EVFSs, test equipment, and installation sites there does not seem to be a general consensus on the minimum test criteria to apply to AC and DC systems. Variability in test processes and procedures arise from factors that are inherent in the device under test, in the test itself, or in test equipment. There may be test criteria that cannot be applied in both the laboratory and in the field because there are factors the examiner cannot control or adequately correct for. Tests should be conducted over the range of operating conditions for which the device is designed.

The 2028 exemption included in the DC system test procedure as part of the July 2022 priority item amended paragraph N.5.2 a general set of test procedures. S&T Agenda Item EVF-23.4, a 2023 proposal, adds a separate set of test procedures for type evaluation that did not previously exist and would be a substantive change to the 2023 edition of the handbook. The 2023 proposal creates a new separate test requirement specifically for laboratory evaluations; therefore a 2028 exemption, if appropriate, would also be new text that requires being underscored to clearly designate the 2028 effective date as new language.

The 2028 effective date is confusing, is the intent that no testing at an approved brick and motor facility nor type evaluations can be carried out until January 1, 2028?

A slight change is recommended for the agenda item’s title to include missing paragraphs **S.5.2.(b) EVSE Identification and Marking Requirements and S.5.3.(d) Abbreviations and Symbols** and striking **S.5. Markings** to clarify the appropriate terminology for the EVSE current level and unit of measurement are also under consideration in this proposal. This would also assist the community in distinguishing this item from multiple other 2023 proposals that address other types of EVFS marking information.

U.S. National Work Group’s Electric Vehicle Fueling Equipment Subgroup (EVFE SG)

- The SG agrees with the proposed changes to: (1) paragraph S.5.2.(b) EVSE Identification and Marking Requirements for clarity and consistency in the expression of current values across the EVFS Code and to properly identify the highest current value or level at which the manufacturer has specified for the operation of the EVSE, the EVFE SG supports identifying this marking information as the “maximum deliverable ampere” rather than the currently stated “maximum current deliverable”, and (2) paragraph S.5.3.(d) Abbreviations and Symbols which removes the “joule” unit of measurement and its corresponding abbreviation and further modifies that subparagraph to include the “kilowatt-hour” as well as recognize that unit’s abbreviation “kWh”.
- The SG agrees with the proposed changes to N.5.1. Performance Verification in the Field and N.5.2. Accuracy Testing in concept, but the SG is not in concurrence with specific recommendations in the proposal. The SG would like to share the following points from its discussions of these items.
 - Some members of the SG would like to take a closer look at the test points.
 - The SG would like to ask the SG’s Test Procedures Subcommittee to take a look at the criteria and provide feedback to the SG and the S&T Committee before the item moves ahead.

- There are concerns about the limitations of available test standards and how the proposed test criteria might impact this.
- Regarding N.5.2. Accuracy Testing (Field) subparagraph (2)(i), the SG has concerns about testing to less than 10% of maximum current or maximum deliverable amperes which could be significantly below typical levels of operation.
- There were some questions about whether type evaluation criteria should be included in Handbook 44.
- Specifying field test criteria that only apply if a device holds type evaluation certification. Exactly what test criteria apply to devices that do not have a certificate? Must those devices first undergo the proposed more stringent test criteria specified to be performed under laboratory conditions?

Regional Association Reporting:

Central Weights and Measures Association

Ms. Scheleese Goudy (Electrify America): Ms. Goudy stated the NIST USNWG discussed this and had consensus of doing the opposite of this proposal. This makes it unnecessarily difficult for testing.

Ms. Francesca Wahl (Tesla): Opposes. The high-end testing as written may be challenging for systems with higher power levels such as heavy-duty trucks and other high-power systems.

CWMA S&T 2022 Interim Meeting Report

Mr. Craig VanBuren (Michigan): Requested developing. Send to the NIST USNWG for consideration.

The CWMA S&T Committee has no recommendation for this item.

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received:

Ms. Scheleese Goudy (Electrify America): Ms. Goudy stated Electrify America opposes this proposal. Ms. Goudy suggested the 30 amps is too small and too low for the 10% accuracy testing. Ms. Goudy recommended a Withdrawal status.

Mr. Chris King (Siemens) stated Siemens supports and agrees with Electrify America's comments. Mr. King proposed this item would add significantly to the expense of setting up and running an operation. Mr. King recommended a Withdrawal status.

Ms. Francesca Wahl (TESLA) stated TESLA supports the previous comments by Electrify America and Siemens. Ms. Wahl proposed the item can be developed, that there is merit, but is not consistent with the working group. Ms. Wahl suggested the item is not fully developed.

Mr. Kevin Schnepf (California Division of Measurement Standards) commented there is some concern about the language for specifications and tolerances. Mr. Schnepf recommended this item be assigned to a work group. Mr. Schnepf recommended a Developing status.

During open hearings, comments were heard that contents in this item were previously discussed in the USN WG, but no official position has been taken by the USN WG. There were also comments during open hearing taking the position the item is not fully developed. The WWMA S&T Committee recommended the submitters work with USN WG to address the comments heard during open hearings and that they work to develop one proposal by combining language from EVF-23.7.

The WWMA S&T Committee recommended that this item be blocked with item EVF-23.7. The WWMA S&T Committee recommended the new blocked items be assigned a Developing status.

Southern Weights and Measures Association

The following comments were received during the 2022 SWMA Annual Meeting:

Ms. Goudy stated that the test current is too low and recommended withdrawal.

Dr. Curran (Florida) stated that line 17 on page 238 should read N.5.1.

The SWMA S&T Committee recommended that this item be withdrawn.

Northeastern Weights and Measures Association

Mr. Keith Bradley (Electrify America) addressed challenges in testing DC meters in that low current is the hardest and perhaps the least important thing to test in the system.

After hearing comments from the floor, the Committee believes this item has merit and requests that the EVSE Subgroup continue work on this item. The Committee recommended this item be given a Developing status.

EVF-23.5 S.5.2. EVSE Identifications and Marking Requirements and T.2. Load Accuracy Test tolerances

Source: Power Measurements LLC

Submitter's Purpose and Justification:

Update the tolerances for DC EVSE and change the effective date to January 1, 2024. Make the new tolerance retroactive effective January 1, 2025.

This topic has been discussed in the NIST Working Group numerous times. Most recently it appeared that the group was obtaining consensus on the language presented here. Industry has reported that their testing of existing systems suggests that they would comply with the proposed error limits of +/- 5% without requiring any infield upgrades. Since thousands of new DC EVSE are planned under current Federal programs it is very important to have some known level of accuracy for all EVSE in the field. The 5% level for all systems installed prior to January 1, 2025 is a reasonable approach that should have no negative effects on the industry. Delaying a specified accuracy to 2028 opens the market up to inequities and fraud.

This proposal has significant financial advantage to industry. Under it all systems installed before January 1, 2025 would be permanently grandfathered in at the +/- 5% tolerance levels until they were retired or had a repair which required recertification.

The time frame discussed most recently in the NIST WG was for this change to be effective January 2024. That was to some extent predicated on getting this change into the code in 2023. In this submission the date has been delayed to January 1, 2025 to allow everyone to be fully prepared for its implementation.

The principal argument made against this requirement has been that systems cannot be made to comply in a reasonable time or for a reasonable amount of investment. More recent testing of existing systems has shown that with the relaxed tolerance of +/- 5% the vast majority of systems already installed would qualify.

The submitter requested that this be a Voting Item in 2023.

OWM Executive Summary for EVF-23.5 – S.5.2. EVSE Identifications and Marking Requirements and T.2. Load Accuracy Test Tolerances

OWM Recommendation:

- Items EVF-23.5 and EVF-23.6 both propose changes to marking and accuracy requirements in NIST Handbook 44.
- OWM has given thought to how we might assist the Committee and the Community in addressing these items and arriving at a single proposal that would meet the needs of the submitters of both items and other stakeholders.
- OWM believes this proposal (Item EVF-23.5) and the alternative recommended in Item EVF 23.6 both require more work and vetting as suggested by two of the four regional associations.
 - We believe this work would most appropriately be done in the USNWSG SG as recommended during the WWMA meeting and recommend the Committee designate these items as Developing and ask the SG for assistance in vetting the proposals.
- Should the Committee believe there is an urgent need to move one of these proposals forward, we encourage the Committee to use the proposed language in Item EVF-23.5 as a starting point to ensure clarity and understanding of the final language.
 - Having well-defined tolerances with clear and understandable effective dates is essential.
 - Defining tolerances in the specific device codes is also preferable to the alternative of having jurisdictions use the provisions of the General Code to implement tolerances suitable for the application since this has the potential for non-uniform application across the country.
- OWM has included comments on Item EVF-23.6 as part of its analysis of that item.
- Regarding Item EVF-23.5, OWM is mindful of the comments made in some of the regions and by other stakeholders through written comments submitted to the Committee that the specifics of this proposal (Item EVF-23.5) may not meet the needs of all stakeholders.
 - See the letter on the Committee’s website in opposition to EVF-23.5 (Colorado, Michigan, Florida, Vermont and Electrify America, Tesla, and EVGo) and recommends the community work to modify the code to appropriately address the marketplace and provide a comprehensive uniform set of requirements needed by regulators and equipment manufacturers (EVSE and

OWM Executive Summary for EVF-23.5 – S.5.2. EVSE Identifications and Marking Requirements and T.2. Load Accuracy Test Tolerances

test apparatus). What has been done in the development stage and over the last seven years to verify EVSEs in commercial (for fee) applications.

- However, the proposed changes in Item EVF-23.5 are much clearer in language, format, and application and are closer to language agreed to by the USNWG SG in June 2022 than are the proposed changes in Item EVF-23.6.
 - The NIST USNWG EVFE Subgroup reached a consensus through a June 2022 ballot in which the group agreed to move forward to recommend a wider tolerance of 5 percent only for DC systems installed before 2024 that must bear accuracy markings while maintaining for AC systems a 1 percent Acceptance Tolerance/2 percent Maintenance Tolerance and the tighter tolerance would also apply to post 2024 DC systems.
 - The language from that June 2022 ballot is included in OWM’s detailed analysis below and in Item EVF-23.6.
 - OWM has included specific comments regarding changes needed to the proposed language in Item EVF-23.6 as part of OWM’s analysis of that item.
- Below are some additional comments for the Committee and other stakeholders to consider in reviewing Items EVF-23.5 and EVF-23.6.
- Proposed accuracy markings need to be separate from the markings of electrical energy levels and required temperature ranges, therefore OWM recommends the “Notice” be included as a separate, new subparagraph S.5.2.1.
- Adoption should occur only after fully vetting proposals to modify fundamental requirements such as those that impact accuracy, transparency, or that ensure fair competition to:
 - avoid unforeseen consequences;
 - ensure stakeholders have the tools needed for this new device application;
 - discourage nonuniformity which can have a disruptive impact on the marketplace; and
 - take corrective action on discovering any gaps/oversight in modifications to the seven-year-old legal metrology requirements.
- NIST OWM encourages the community's participation in the USNWG EVFE Subgroup which began its work in 2012 and whose work resulted in NIST HB 44 3.40. EVFS Code's adoption in 2015. The Subgroup is reviewing the four paragraphs that appear in multiple 2023 proposals that address: (1) dual EVSE tolerances (2.0 percent or 5.0 percent [DC EVSEs]); (2) new EVSE markings required for the wider tolerance in the marketplace; and (3) corresponding accuracy test procedures.
- The EVFE Subgroup last met on December 8, 2022, to address proposals under consideration for the 2023 cycle and will provide a clear statement in writing of its exact position on agenda items.

Table 3. Summary of Recommendations							
EVF-23.5 – S.5.2. EVSE Identifications and Marking Requirements, and T.2. Load Accuracy Test tolerances.							
	V	D	W	A	I	Notes*	Comments
Submitter	✓						
OWM							USNWG EVFE SG's position is available.
WWMA		✓					
SWMA			✓				
NEWMA		✓					
CWMA			✓				
NCWM							
	Letters of Support		Letters of Opposition		Notes		
Industry			✓		Co-authors and sent October 18, 2022.		
Manufacturers							
Retailers and Consumers							
Regulators			✓		Co-authors and sent October 18, 2022.		
*Notes Key: 1 - Submitted modified language 2 - Item not discussed 3 - No meeting held 4 - Not submitted on agenda 5 - No recommendation or not considered							

Item Under Consideration:

Amend Handbook 44, Electric Vehicle Fueling Systems as follows:

S.5.1. EVSE Identification and Marking Requirements. – In addition to all the marking requirements of Section 1.10. General Code, paragraph G-S.1. Identification, each EVSE shall have the following information conspicuously, legibly, and indelibly marked:

- (a) voltage rating;
- (b) maximum current deliverable;
- (c) type of current (AC or DC or, if capable of both, both shall be listed);
- (d) minimum measured quantity (MMQ); and

- (e) temperature limits, if narrower than and within – 40 °C to + 85 °C (– 40 °F to + 185 °F). (Amended 2021)

(f) For EVSEs subject to a tolerance of 5% (see paragraph T.2.1.) a notice shall be conspicuously, legibly, and indelibly displayed, in a position plainly visible to a person accessing a charging port of the EVSE which states:

NOTICE:

“This charger operates at a tolerance of 5 percent versus chargers which operate at a tolerance of 2 percent.”

EVSEs subject to a tolerance of 1 % Acceptance and 2% Maintenance Tolerance are not required to be marked with such a statement.

And

N.5.2. Accuracy Testing. – The testing methodology compares the total energy delivered in a transaction and the total cost charged as displayed/reported by the EVSE with that measured by the measurement standard.

- (b) For DC systems (see note):

- (1) Accuracy test of the EVSE system at a load of not less than 85 % of the maximum deliverable amperes current (expressed as MDA) as determined from the digital communication message from the DC EVSE to the test standard for a total energy delivered of at least twice the minimum measured quantity (MMQ).
- (2) Accuracy test of the EVSE system at a load of not more than 10 % of the maximum deliverable amperes (expressed as MDA) as determined from the digital communication message from the DC EVSE to the test standard for a total energy delivered of at least the minimum measured quantity (MMQ).

~~All DC EVSE are exempt from this requirement until January 1, 2028.~~

And

T.2. ~~Load Accuracy~~ Test Tolerances.

T.2.1. EVSE ~~Load Accuracy~~ Test Tolerances. – The tolerances for EVSE ~~load accuracy tests~~ **for all AC EVSE and for DC EVSE installed on or after January 1, 2025** are:

- (a) Acceptance Tolerance: 1.0 %; and
- (b) Maintenance Tolerance: 2.0 %.

For DC EVSE installed prior to January 1, 2025 tolerances for the accuracy tests are:

- (a) Acceptance Tolerance: 5.0 %; and**
- (b) Maintenance Tolerance: 5.0 %.**

~~All DC EVSE are exempt from this requirement until January 1, 2028.~~

(Amended 2022)

NIST OWM Detailed Technical Analysis:

Moving forward with adoption before fully vetting proposals to modify fundamental requirements such as accuracy, transparency, or that ensure fair competition which are the foundation of every weighing and measuring device code can have unforeseen consequences. To delay or eliminate these basic guidelines (tools needed for this new device application) encourages nonuniformity (from state to state) which can be disruptive and impact the level of confidence in the marketplace. Proposals should be evaluated based on their impact on all stakeholders in the community. Time and again the community has moved to take corrective action on discovering an oversight that resulted from either the modification of existing or adoption of a new legal metrology requirement. In the interim prior to a code's publication or the first type evaluation, jurisdictions maintain their regulatory authority over new commercial device applications and emerging technological advances in weighing and measuring equipment through provisions offer alternative means of achieving a provisional status of compliance that encourages commerce is not overburdensome while still allowing for their program's oversight. Some do admit this path can be a more complex process but when well thought out it works. So, there are options such as General Code provisions, the Fundamental Considerations, and provisional status for devices for stakeholders during that interim period until all components of the weights and measures infrastructure are in place.

The proposal outlined in agenda item EVF-23.5 is not exactly the same as an alternative proposal agreed to in a June 2022 ballot of the EVFE Subgroup. In the case of the EVFE Subgroup, the wider tolerance of 5 % for DC systems installed before 2024 was identified by several OEMs as achievable, and the less than ideal existence of dual tolerances in the marketplace would be addressed by marking the accuracy achievable by devices which met only the wider tolerance. Granted some refining of the requirement text would be necessary the group's alternate proposal addressed many concerns expressed by both OEMs and regulators when the Subgroup's discussions on this topic first began in 2020.

NIST OWM is aware of a letter from the State Weights and Measures Directors of Colorado, Michigan, Florida, Vermont and industry representative from Electrify America, Tesla, and EVGo. If as the co-authors of the letter indicate that jurisdictions have not up through October 2022 regulated these systems, then all work to modify the code to appropriately address the marketplace and provide a comprehensive uniform set of tools/requirements needed by regulators and equipment manufacturers (EVSE and test apparatus) can be accomplished. And this includes expediting changes to any oversights or other gaps in the requirements.

Since the proposed accuracy marking applies only to systems capable of meeting the wider 5 percent tolerance, thus not applicable to all systems, and is separate information from the required marking of electrical energy levels and temperature range for the operation of the equipment, we therefore recommend the "Notice" be included as a separate new subparagraph S.5.2.1.

NIST OWM encourages the community's participation in the USNWG which began work in 2012 as a forum for stakeholders and other interested parties in establishing legal metrology standards (also the weights and measures infrastructure) for electrical energy measurements. That effort resulted in NIST HB 44 3.40 EVFS Code's adoption in 2015. The four paragraphs that appear in multiple 2023 proposals address (1) dual EVSE tolerances (2.0 percent or 5.0 percent [DC EVSEs]); (2) new EVSE markings required for the wider tolerance in the marketplace (proposed new 5.0 percent accuracy for DC systems); and (3) corresponding accuracy test procedures are part of the EVFE SG's meeting discussions. The EVFE Subgroup's work continues up through today having met October 6, 18, and December 8, 2022 to address

proposals under consideration for the 2023 cycle. It should be noted that the EVFE SG has worked to further refine the code as more is learned about these systems and since January 2020 met 16 times to consider the proposals the group submitted to the S&T Committee as well as those developed or under development outside of its forum to provide their input. The EVFE SG will provide a clear statement of its exact position on agenda proposals when it reaches a consensus and provides this information in writing (as shown below). The EVFE SG reached a consensus in July 2022 which the group agreed to move forward to recommend a wider tolerance of 5 percent only for DC systems installed before 2024 that must bear accuracy markings while maintaining for AC systems a 1 percent Acceptance Tolerance/2 percent Maintenance Tolerance and the tighter tolerance would also apply to post 2024 DC systems.

U.S. National Work Group's Electric Vehicle Fueling Equipment Subgroup (EVFE SG)

- The SG agreed to forward the results of its June 2022 ballot (in which it proposed changes to the tolerances and the addition of marking requirements) to the S&T Committee and recommended the Committee consider these recommendations as it considers Items EVF-23.5 and EVF-23.6.
- In a June 2022 ballot, the SG agreed to recommend the following changes to the tolerances and marking requirements in Section 3.40. The SG asks that the Committee consider the SG's recommendations presented below as it deliberates on S&T Agenda Items EVF-23.5 and EVF-23.6 which include proposed changes to these same handbook code paragraphs. The changes agreed to by the SG in its June 2022 ballot are shown below.
 - Additionally, some device users on the SG indicated that there remains a desire to recognize and then maintain a 5% tolerance for DC legacy (i.e., installed prior to 2024) equipment.

T.2. ~~Load Accuracy~~ Test Tolerances.

T.2.1. EVSE ~~Load Accuracy~~ Test Tolerances for AC Systems. – The tolerances for EVSE load tests for AC systems ~~are~~ shall be as follows:

- (a) Acceptance Tolerance: 1.0 %; and
- (b) Maintenance Tolerance: 2.0 %.

(Amended 202X)

T.2.2. EVSE Accuracy Test Tolerances for DC Systems. – **The tolerances for EVSE load tests on DC systems shall be as follows:**

- (a) For DC systems installed prior to 2024 and that bear the notice specified in paragraph S.5.2.1. Marking of Accuracy Limits, DC EVSEs Installed Prior to 2024, acceptance and maintenance tolerances are: 5.0 %.**
- (b) For DC systems installed on or after January 1, 2024 or that do not bear the notice specified in paragraph S.5.2.1. Marking of Accuracy Limits, DC EVSEs Installed Prior to 2024 tolerances are:**

(1) Acceptance Tolerance: 1.0 %; and

(2) Maintenance Tolerance: 2.0 %.

(Added 202X)

S.5.2. EVSE Identification and Marking Requirements. – In addition to all the marking requirements of Section 1.10. General Code, paragraph G-S.1. Identification, each EVSE shall have the following information conspicuously, legibly, and indelibly marked:

- (a) voltage rating;
- (b) maximum current deliverable;
- (c) type of current (AC or DC or, if capable of both, both shall be listed);
- (d) minimum measured quantity (MMQ); and
- (e) temperature limits, if narrower than and within – 40 °C to + 85 °C (– 40 °F to + 185 °F).

S.5.2.1. Marking of Accuracy Limits, DC EVSEs Installed Prior to 2024. - DC EVSEs installed prior to 2024 shall be marked with the following:

NOTICE:

“This charger operates at a tolerance of ± 5 percent versus newer chargers which operate at a maximum tolerance of ± 2 percent.”

This marking shall be conspicuously, legibly, and indelibly marked, in a position plainly visible to a person accessing a charging port of the EVSE.

This marking requirement does not apply to DC EVSEs that are capable of meeting an acceptance tolerance of 1 % and a maintenance tolerance of 2 %.

(Added 202X)

(Amended 2021)

Summary of Discussions and Actions:

A letter dated October 18, 2022 from the State Weights and Measures Directors of Colorado, Michigan, Florida, Vermont, and industry representatives from Electrify America, Tesla, and EVGo was sent to the NCWM S&T Committee. The co-authors of the letter remind the Committee that it accepted their July 2022 recommendations for exempting DC systems from “accuracy tolerances and testing until 2028” citing this as a “solution that enables regulators to inspect and test to the accuracy of chargers for which appropriate testing equipment is available.” Further indicating that an “inspector or service agent cannot certify a DC fast charger because what is needed is equipment that they can bring to a site of a range up to 350 kW and 600 amps or more and that has NIST-traceable calibration for the energy delivered.” Also, the letter states the “NCWM should not reduce the exemption that it adopted in July 2022 until the Committee has evidence test equipment is reasonably available.”

Regional Association Reporting:

Central Weights and Measures Association

Ms. Francesca Wahl (Tesla) requested it be Withdrawn. This is already covered in EVF-23.6. The NIST USNWG does not agree with this. This is another proposal to try to move up the already agreed upon 2028 date.

Mr. Craig VanBuren (Michigan) and Ms. Scheleese Goudy (Electrify America) requested it be Withdrawn.

The CWMA S&T Committee recommended this item be Withdrawn.

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received:

Ms. Wahl commented TESLA opposes this item and proposed this item looks to moving up the date that was recently adopted at the July 2022 NCWM, from 2028 to 2025. Ms. Wahl proposed this item be combined and harmonized with EVF-23.6. Ms. Wahl recommended a Withdrawal status.

Ms. Goudy commented Electrify America agrees with TESLA's comments.

Mr. Chris King (Siemens) commented Siemens agrees with TESLA's comments.

During open hearings, comments were heard that contents in this item were previously discussed in the USNWG, but no official position has been taken by the USNWG. There were also comments during open hearing taking the position the item is not fully developed. The WWMA S&T Committee recommended the submitters work with the USNWG to develop one proposal by combining language from EVF-23.6.

The WWMA S&T Committee recommended that this item be blocked with item EVF-23.6. The WWMA S&T Committee recommended the new blocked items be assigned a Developing status.

Southern Weights and Measures Association

The following comments were received during the 2022 SWMA Annual Meeting:

Mr. Prince (Florida) stated that this issue has been addressed and that this item should be withdrawn.

Ms. Goudy stated that this item should be withdrawn.

The SWMA S&T Committee recommended that this item be withdrawn.

Northeastern Weights and Measures Association

Mr. Bradley and Ms. Wahl requested that this item be withdrawn. Ms. Juana Williams (NIST OWM) commented that the EVFE Subgroup has not had the time to vet this item and requested that it be developing. Mr. Marc Paquette (Vermont) noted that there are currently no traceable standards to test DC devices and requested a developing status. Mr. Lou Sakin (Holliston, Massachusetts), Mr. John McGuire (New Jersey), and Mr. Walt Remert (Pennsylvania) agreed with Mr. Paquette's comments and also requested that the item have a Developing status.

After hearing comments from the floor, the Committee believes that this item has merit. The Committee recognizes the current limitations in testing DC devices. The Committee is recommending that this item be assigned a Developing status.

EVF-23.6 S.5.2. EVSE Identification and Marking Requirements and T.2. Tolerances

Source: Florida Department of Agriculture and Consumer Services; Electrify America; Tesla; EVGo, Siemens

Submitter's Purpose and Justification:

The revised proposal would amend Handbook 44, Section 3.40 Tentative Code in the following ways:

1. Paragraph T.2.1. would be revised for DC chargers. The 1 % (acceptance) / 2 % (maintenance) tolerances would apply to devices installed after January 1, 2024. For devices installed before that date, the tolerances would be 5% (acceptance and maintenance).
2. For the sake of clarity and transparency for customers and inspectors, a device subject to the 5 % tolerance would have to be marked as such. The proposal would require specific language for the marking.
3. If a manufacturer has achieved 1 %-capable chargers earlier than the January 2024 timeframe, users of those chargers might prefer not to mark the chargers as 5% chargers; and then those chargers would be subject to the 1 %/2 % tolerance. The proposal includes language to establish this treatment.

The 5 % tolerance for pre-2024 chargers would end on January 1, 2034. After that date, all DC chargers would be subject to the 1 % (acceptance) / 2 % (maintenance) tolerance.

A. The effect of the proposed revisions

The changes we propose would work as follows: all DC chargers would remain exempt from the accuracy tolerances until January 1, 2028, as NCWM adopted at the 2022 Annual Meeting. When accuracy tolerances come into force, a DC charger installed after January 1, 2024, would have to satisfy the 1% (acceptance) / 2 % (maintenance) tolerance, the same levels as for AC chargers. But a DC charger installed before January 1, 2024, would have to meet only a 5% accuracy tolerance. That 5% accuracy tolerance would expire on January 1, 2034, at which point all the legacy chargers will have to have been retrofitted or replaced.

The proposal would require a charger that is subject to the 5 % tolerance to display a marking, with specified language, informing customers and inspectors of that fact. But the proposal leaves open the possibility that a given manufacturer might achieve the 1 %/2 % tolerance earlier, and then would specify that capability for a given model. Devices in that model would not have to be marked as 5 % devices; but if they are not marked that way, they would of course be subject to the 1 %/2 % level as for new chargers.

B. The basic justification

DC and AC chargers are fundamentally different—in technology, in customer use, and in metering capabilities. AC charging technology, the older form, delivers energy in the same form—voltages and currents oscillating at 60 Hertz (in the United States) as utilities have provided it for a century. Because a vehicle has to convert AC energy to DC for charging the battery, AC charging stations operate

at no more than 19.7 kW, and most no more than 6-7 kW. These charging rates will add 24-80 miles of range in an hour of charging a typical car, and consequently AC charging involves extended sessions—the median time that a customer uses an AC station is 22 hours.¹ The voltages delivered are no more than 480 volts ac, and the current is no more than 50 amps ac (and more typically 30 amps ac). By contrast, DC chargers deliver energy in the same form that a battery ultimately needs it. Using voltages of 400 to 950 volts dc and currents up to 500 amps dc (higher levels are coming in the future for applications like charging heavy trucks), they are able to deliver 50kW, 150 kW, 350 kW, or higher charging rates. These stations will add 200-1400 miles of range in an hour of charging, or, more meaningfully, 400 miles of range in as little as 20 minutes. A customer at a DC station will arrive, charge briefly, and then depart. Customers incorporate AC chargers into their regular routines, such as by driving to work and charging there. DC chargers are more commonly used to support long-distance trips.²

For AC charging, manufacturers have been able to utilize metering technology that has been developed over a century for electric utilities. When Handbook 44, section 3.40 was developed in 2015, that AC metering technology was well understood. There have been long-established standards for AC revenue meters—though those standards, in the utility sector, are not necessarily the same in every respect as how a weights and measures standard would work. One indication of the relatively mature state of AC metering is that NIST has long provided ordinary-course calibration services for AC watt-hour meters that operate at 60 Hertz, within ranges of 69 to 480 volts and 0.5 to 30 amps (sufficient to cover typical AC chargers).³ DC metering technology, by contrast, has been “in research and development.”⁴ When section 3.40 was adopted, the accuracy tolerances of 1.0% (acceptance) and 2.0% (maintenance) were predictive and aspirational for DC chargers. As of November 2019, when California adopted its own regulation based on section 3.40, meters and chargers meeting that standard were not yet generally commercially available.⁵ Meanwhile, NIST calibration services for DC watt-hour meters are non-standard, and are available only up to 240 volts and 5 amps⁶—far below the levels needed for testing DC chargers.

Argonne National Lab has studied the availability of DC metering technology. Our understanding is that its draft report (not yet finalized, so far as we are aware) concludes that there are now on the market (at least in principle) meters for use in DC chargers that can meet a 1% acceptance / 2% maintenance tolerance. It is reasonable to conclude that the 1% / 2% tolerance will be achievable in general. The current proposal is focused on how to handle the chargers that are installed before that point. Previously installed chargers will not in general be able to satisfy a 1% / 2% accuracy tolerance. To be clear, we do not suggest that every existing charger would be more than 2% inaccurate. Indeed, it would not genuinely be possible to make that assessment, given the lack of NIST-traceable measurement apparatus to test fast DC chargers in the field.

There is presumably a distribution of potential deviations among devices in the field. Given what metering technology has been commercially available, a 2 % maintenance accuracy would lead to inspection problems for a high proportion of devices.

¹ Idaho National Laboratory, “Plugged In: How Americans Charge Their Electric Vehicles,” p.14, <https://avt.inl.gov/sites/default/files/pdf/arra/PluggedInSummaryReport.pdf>.

² As the California Energy Commission has explained, “it is therefore useful to treat infrastructure for interregional travel (predominantly DCFCs) differently from infrastructure for intraregional travel (predominantly Level 1 and Level 2 chargers).” <https://efiling.energy.ca.gov/GetDocument.aspx?tn=233986&DocumentContentId=66805> at page 14.

³ https://shop.nist.gov/ccrz/ProductDetails?sku=56200C&cclcl=en_US.

⁴ Cal. Dep’t of Food & Agriculture, Final Statement of Reasons on Electric Vehicle Fueling Systems, p.23 (Nov. 1, 2019).

⁵ *Id.*

⁶ https://shop.nist.gov/ccrz/ProductDetails?sku=56110S&cclcl=en_US.

The proposal would establish a tolerance of 5% for devices installed before January 1, 2024. The justification for this particular choice of tolerance and timeline is as follows:

1. In 2019, California adopted a regulation that put a modified version of section 3.40 into force for new devices. DC chargers installed before January 2023 are subject to no weights and measures standards at all until 2033. DC chargers installed after January 2023 (and before January 2033) are subject to a maintenance tolerance of 5.0% (and acceptance tolerance of 2.5%). Consequently, in California, which represents roughly 30% of the currently-existing base of DC chargers, the maintenance tolerance will be 5.0% for the coming decade. A maintenance tolerance of 5.0% for legacy chargers in section 3.40 will be stricter overall than the California regulation (because it will apply to all legacy chargers, whereas the California standard applies only to post-2023 chargers) but will align with the numerical tolerance used in California. Although a 5.0% tolerance is among the larger tolerances used in Handbook 44, it is not unprecedented. And the fact that newchargers in California will be subject to that standard will mean EV charging customers have substantial experience with that chargers at that tolerance, and the 5.0% tolerance we propose would be the same transactional experience as customers in California (the largest EV charging market in the country) receive. It bears mention, too, that as Measurement Canada prepares to implement standards for AC chargers, the tolerance (acceptance and maintenance) will be 3.0%, not the 1% acceptance in Handbook 44. The cost of a typical charging session is \$15 to \$20. A 5.0% maintenance standard would mean a variation, beyond that, of an additional plus *or minus* 40 cents. As with any tolerance, that variation could at any given charger be for or against either side to the transaction.
2. The industry submitters have studied carefully their existing chargers, measurement devices and existing models now available. They believe the 5% maintenance tolerance is achievable at a manageable cost in the future, because it will generally not require extensive reconfiguring of cabinets and the installation of four-wire cables.
3. The cost of bringing legacy chargers into line with the 1 %/2 % standard would be extreme. Although equipment is not available to test DC fast chargers in the field, some operators have found in tests of existing devices that they can be brought to a 5% tolerance but cannot meet the 1 %/2 % standard without replacing the meters or implementing an entirely new measurement system, which means a physical reconfiguration at each station and/or replacing the cables for delivering the energy to vehicles. Section 3.40. standards are based on the energy delivered at the connector to the car; in other words, a charger must account for losses in the cables. The most straightforward way to account for losses is to measure the voltage at the vehicle connector; that means the cable must have two additional high-voltage leads, to carry that voltage back to the meter⁷. In California's Initial Statement of Reasons (ISOR) for adopting specifications and tolerances requirement for commercial EVSE, California estimated that it costs approximately \$20,000 to retrofit an existing DC charger.⁸ We understand that cost to represent the cost (parts and labor) to replace the charging cable, and possibly to replace the meter if that task is simple. This cost may be a significant underestimate for some models of charger, because replacing the meter may not always be possible without physical reconfiguration of the space within the charger. Which charger models would require that sort of reconfiguration, and what proportion of the installed base they represent, is impossible to know without a detailed model-by-model study and detailed model-by-model installation data across manufacturers. The upper end of cost would be simply the cost of

⁷ Charging cables are themselves complex objects, with liquid coolant and high-voltage insulation. Cables for fast DC chargers that include additional high-voltage sensing leads were not available in 2015.

⁸ https://www.cdfa.ca.gov/dms/pdfs/regulations/EVSE_ISOR.pdf.

replacing a charger, which many operators would find preferable to physical reconfiguration of charger internals anyway. The International Council on Clean Transportation (“ICCT”) reported in 2019 that fast DC chargers cost between \$75,000 and \$140,000 per charger, for the charger itself.⁹ Installation costs range from \$18,000 per charger (for six 150 kW chargers⁹ Michael Nicholas, “Estimating electric vehicle charging infrastructure costs across major U.S. metropolitan areas,” ICCT Working Paper 2019-14, p.2 tab. 2 (Aug. 2019, at a site) to \$65,000 per charger (for one 350 kW charger at a site).¹⁰ The total cost (installation and equipment) for a 4-charger site would be roughly \$720,000. That said, some amount of the installation cost represents upgrades to electrical supply lines and basic site construction, costs that would not be incurred anew to replace equipment. So, for a rough estimate, it is appropriate to use the lowest cost estimate from the ICCT, which is \$17,692 (the cost per charger for a large site of 50 kW chargers). With that figure, replacing a 4-charger site of 350 kW chargers would cost roughly \$630,000, or \$157,000 per charger.

4. Based on data on the existing charge base from the National Renewable Energy Laboratory’s Alternative Fuels Data Center (“AFDC”), we can assume there will be about 36,000 “pre-2024” DCchargers.¹¹ These are only a fraction of the overall chargers that will be installed nationwide over the coming decade but bringing them into compliance with a 1%/2% tolerance will be highly costly. Taking out the 30% that are in California (which already has regulations with a 5.0% maintenance tolerance, for all post-2023 DC chargers), retrofitting all of those at the \$20,000 cost would total \$720 million. If meter replacement is not possible and those chargers must all be replaced, the total would be \$5.6 billion. The actual cost of bringing the pre-2024 chargers to compliance with a 2.0% maintenance tolerance would be somewhere between these numbers.¹²
5. The January 2024 date moves faster than the California regulation. Under the California regulation, the 1% / 2% tolerance would not come into force until 2033. It appears that meters capable of that tolerance are now available on the market. The submitters propose January 2024 as the date for distinguishing “legacy” from “new” chargers, because the existence of these meters on the market is not all that is needed. Manufacturers have to access the meters, design products incorporating them; revise production lines; test the new products to ensure they are safe and reliable; and obtain third-party certifications (such as from Underwriters Laboratory) of the revisedproducts. After those steps, a manufacturer can begin delivering a revised product to operators. Installation of a charger is not simply a matter of placing it on a counter; charging sites involve construction work, leading to the secure attachment of a charger to a specially built concrete pad. In other words, from the first delivery of a new model of charger to the first installations of thosechargers also takes time. The January 2024 date is appropriate for expecting new chargers to incorporate meters that were available a few years before that date.

⁹ Michael Nicholas, “Estimating electric vehicle charging infrastructure costs across major U.S. metropolitan areas,” ICCT Working Paper 2019-14, p.2 tab. 2 (Aug. 2019), https://theicct.org/sites/default/files/publications/ICCT_EV_Charging_Cost_20190813.pdf.

¹⁰ *Id.* at 4 tab. 4.

¹¹ According to the AFDC’s station locator database, there are 6,580 DC stations with 22,767 chargers. The AFDC also reports that the number of DC ports grew 29% year-on-year to the second quarter of 2021. https://afdc.energy.gov/files/u/publication/electric_vehicle_charging_infrastructure_trends_second_quarter_2021.pdf. With growth at this rate, about 6,600 additional DCFC stations will be installed in 2022 and 2023, leading to a total of about 36,000 DC chargers that would be “pre-2024” chargers under the proposal.

¹² A charger that is not qualified for a given tolerance level may well be within the bounds of the tolerance, because there is some distribution in metering performance. Even if devices are replaced only after inspection, a significant fraction would need replacement, thus incurring this scale of cost. Moreover, it might be most sensible for an operator to ensure all its devices are qualified, rather than waiting to see what the results of inspection might be for a given charger.

6. The proposal focuses on installation before January 2024, rather than using the concept of retroactive/non-retroactive that is more common in Handbook 44, because non-retroactive is ordinarily based on when a device is placed in service. Many states do not yet regulate EV chargers and consequently have no placed-in-service process. In these states, “placed in service” would not be a well-defined concept, and regulators might not have good ways to determine when a device was placed in service. Installation is a reasonably well-defined process, and it should be possible to identify when a given charger was installed. California’s regulation has differing status for pre-2023 and post-2023 chargers, and it bases that line on installation.
7. The proposal also specifies 5.0% as the acceptance tolerance, not just the maintenance tolerance. As a practical matter in field inspections, the acceptance tolerance for pre-2024 chargers will not be important. Section 3.40 (as amended at the 2022 NCWM meeting) exempts DC chargers from the accuracy tolerance until 2028. When they become subject to accuracy tolerances, no pre-2024 charger will be at the point of acceptance. The proposal specifies an acceptance tolerance for clarity in type evaluations, which ordinarily evaluate device models against the applicable acceptance tolerance.
8. The exemption until 2028 adopted at the 2022 meeting does not eliminate the need for this proposal. When DC chargers are subject to accuracy tolerance requirements, pre-2024 chargers will still need to meet the applicable tolerance or be retrofitted or replaced. The 2028 time frame is unreasonably soon to do that, given the cost estimates above. California estimated that chargers have an effective 10-year lifespan.¹³ This estimate is highly uncertain, in part because it was based in part on older AC chargers. Newer DC chargers, using more advanced technology for significantly more expensive equipment, are likely to have usable lifetimes greater than 10 years. The proposal recognizes that, nonetheless, there is a tradeoff between the cost of retrofitting or replacing devices, and the value of tighter tolerances. Some number of chargers will fail and need replacement earlier than 10 years, thus reducing the number that eventually need to be retrofitted or replaced to comply with tighter accuracy tolerances. Overall, the proposal uses the same 10-year period that several states have already adopted.¹⁴ Notably, the effect is significantly more stringent than in the California regulation. Under California’s rule, a charger installed before 2023 is subject to no standards for 10 years, and then becomes subject to standards in 2033; a replacement of the charger in 2032 would be subject to the 5.0% maintenance tolerance. A charger installed in 2023 (and that hypothetical 2032 installation) would be subject to the 5.0% tolerance indefinitely, with no end point. Our proposal, by contrast, would make a pre-2024 charger subject to the 5.0% tolerance once the 2028 compliance dates kicks in but only until 2034, at which point the charger would have to be retrofitted, replaced, or otherwise brought to the 1%/2% tolerance.

C. Potential objections

In response to the industry’s original proposal, some people commented that AC and DC chargers should be treated the same. As explained above, they are not the same, not only because of technology differences but also because customers use them and view them differently. California and NTEP have distinguished AC and DC chargers since at least 2021, and NCWM has already recognized important differences between them, in Handbook 44.

Some have also commented that there should not be parallel accuracy classes for a given application. But this approach is not unprecedented. In 1986, NCWM required new scales to be marked with an accuracy class. Pre-1986 scales could remain unmarked, and those unmarked scales were subject to various

¹³ Cal. Dep’t of Food & Agriculture, Final Statement of Reasons, p.6.

¹⁴ 4 Cal. Code of Regulations § 4002.11; Rev. Code Wash. § 19.94.190(6).

accuracy tolerances (depending on application) that ranged up to 5.0 %, compared to the largest tolerance for any marked scale at 2.0 %. For grain moisture meters, Handbook 44 has completely separate sections for pre-1998 and post-1998 devices, with some different tolerance specifications for older and newer devices. For both scales and grain moisture meters, there was no sunset date; the older devices have been allowed to continue in use for as long as they operated. We do not suggest that the circumstances with EV chargers are the same. Each of those past examples was based on justifications particular to that situation. Nonetheless, these examples show that it has been done to maintain parallel tolerances for a given application. In addition, there are already parallel, differing tolerances for EV chargers. If the proposal is not adopted, pre-2023 chargers in California will have no tolerance at all until 2033; post-2023 chargers will have a 5.0% maintenance tolerance for the indefinite future; and chargers elsewhere in the country, including in states neighboring California, will have the existing Handbook 44 tolerances. The proposal shifts the line between differing tolerances, but the situation of differing tolerances for the same application is already in place without the proposal.

There have been claims that some manufacturers may be able to achieve 1% devices (DC chargers) before January 2024, and one or more may already have done so. Even so, the proposal is still warranted. Operators of EV chargers should not be forced to replace their existing chargers simply because they could not get access to chargers made by a given manufacturer. It is generally agreed that when section 3.40 was adopted, the equipment to satisfy it did not exist for DC chargers. Reaching that point has required research and development by meter manufacturers and charger manufacturers. The goal of regulation should be to handle the technology transition in a reasonable, fair manner, without prejudice to operators that have made diligent efforts in procurement and operation of their chargers.

This proposal arrives without the formal approval of the U.S. National Work Group subgroup on EV charging. But a similar proposal did have general consensus at the Work Group. NIST personnel solicited views on the proposal through an email ballot at the end of June 2022. The resulting votes were 11 in favor, and 1 opposed. As of this filing, NIST has not provided information on whether this vote was sufficient for the subgroup to formally endorse the proposal. The one person voting “no” said that the person would have voted yes if the proposal included a 10-year end date for the 5% tolerance. The current proposal has that feature and thus addresses the only concern expressed by the sole “no” vote. The current proposal has that feature and thus addresses the only concern expressed by the sole “no” vote.

OWM Executive Summary for EVF-23.6 – S.5.2. EVSE Identification and Marking Requirements., and T.2. Tolerances.

OWM Recommendation:

- Items EVF-23.5 and EVF-23.6 both propose changes to marking and accuracy requirements in NIST Handbook 44.
- OWM has given thought to how we might assist the Committee and the Community in addressing these items and arriving at a single proposal that would meet the needs of the submitters of both items and other stakeholders.
- OWM believes this proposal (Item EVF-23.6) and the alternative recommended in Item EVF 23.5 both require more work and vetting as suggested by two of the four regional associations.
- We believe this work would most appropriately be done in the USNWG SG as recommended during the WWMA meeting and recommend the Committee designate these items as Developing and ask the SG for assistance in vetting the proposals.

**OWM Executive Summary for EVF-23.6 – S.5.2. EVSE Identification and Marking Requirements.,
and T.2. Tolerances.**

- Should the Committee believe there is an urgent need to move one of these proposals forward, OWM encourages the Committee to use the proposed language in Item EVF-23.5 as a starting point to ensure clarity and understanding of the final language.
 - Having well-defined tolerances with clear and understandable effective dates is essential.
 - Defining tolerances in the specific device codes is also preferable to the alternative of having jurisdictions use the provisions of the General Code to implement tolerances suitable for the application since this has the potential for non-uniform application across the country.
- Regarding Item EVF-23.6, OWM offers the following specific technical concerns and comments.
- OWM questions the reference to the phrase “certified to....” In the proposed EVF-23.6 paragraph S.2.5.1. Marking.
 - If the intent is to note the marking is not required for devices capable of meeting the 1 % Acceptance and 2% Maintenance tolerance, then the language should clearly state this.
- OWM concurs that the markings need to be “conspicuously and legibly displayed.” Prior versions of similar language considered by the EVFE Subgroup also included the term “indelible” in recognition that the General Code requires all markings to be of a permanent nature. OWM recommends including the term “permanent” to align with the language used in the General Code.
- There are several dates referenced in proposed EVF-23.6 paragraph T.2.2. Tolerances that conflict and OWM believes will create confusion for those implementing the proposed requirements.
- The statement adopted by the NCWM in July 2022 exempting DC devices from any tolerance requirements until 2028 remains in the proposal, yet there is a date of 2024 in both the proposed paragraph T.2.2.(a) and paragraph T.2.2.(b) which specifies requirements for DC devices installed prior to 2024. This is confusing.
- Proposed paragraph T.2.2.(a) references a sunset date of 2034, yet there is still a statement referring to a 2028 date, creating a conflict. Additionally, the 2034 date is 6 years after the 2028 date that was adopted by the NCWM in July 2022. The rationale for extending the sunset date is not clear. OWM also notes that a date of 2034 is eighteen years after the tentative code was first adopted by the NCWM.
- The rationale for the following statement in paragraph T.2.2.(b) is not clear and OWM believes this statement needs to be struck from the proposed new paragraph T.2.2.(b):

OWM Executive Summary for EVF-23.6 – S.5.2. EVSE Identification and Marking Requirements, and T.2. Tolerances.

- “or that do not bear the notice specified in paragraph S.5.2.1. Marking of Accuracy Limits, DC EVSEs Installed Prior to 2024 tolerances are”
- Proposed accuracy markings need to be separate from the markings of electrical energy levels and required temperature ranges, therefore OWM agrees the “Notice” be included as a separate, new subparagraph S.5.2.1.
- As shared in its comments in Item EVF-23.5, OWM believes the proposed changes in Item EVF-23.5 are much clearer in language, format, and application and are closer to language agreed to by the USN WG SG in June 2022 than are the proposed changes in Item EVF-23.6.
 - The NIST USN WG EVFE Subgroup reached a consensus through a June 2022 ballot in which the group agreed to move forward to recommend a wider tolerance of 5 percent only for DC systems installed before 2024 that must bear accuracy markings while maintaining for AC systems a 1 percent Acceptance Tolerance/2 percent Maintenance Tolerance and the tighter tolerance would also apply to post 2024 DC systems.
 - The language from the June 2022 ballot is included in OWM’s detailed analysis below and in Item EVF-23.5.
 - As noted in its comments on Item EVF-23.5, OWM is aware of comments indicating EVF-23.5 may not meet the needs of all stakeholders as presently written and OWM believes additional changes would be needed to that item. However, the proposed changes in Item EVF-23.5 are much clearer in language, format, and application and are closer to language previously agreed to by the USN WG SG in June 2022 than are the proposed changes in Item EVF-23.6.
- There are differences between the language recommended in that June 2022 SG ballot and that proposed in Item EVF-23.6. The language adopted in the June 2022 ballot:
 - Permits DC devices installed before 2024 to have a wider tolerance if they were clearly marked to designate their accuracy.
 - Includes a wider tolerance of 5 % for DC systems installed before 2024 when accuracy is marked, which several OEMs identified as achievable. Note: The SG’s language does not include an exemption for DC systems from accuracy tolerances up through 2028 to sunset in 2034.
 - Acknowledges the less-than-ideal existence of dual tolerances in the marketplace would be addressed by marking systems to indicate when 5 percent is their achievable accuracy; and
 - Recognizes the EVFE Subgroup would further refine the requirement’s text.
- OWM is also aware of a Florida, Electrify America, Tesla, EVGo, and Siemens’ October 15, 2022, letter sent to the S&T Committee regarding EVF-23.6 and a June balloted proposal of the

**OWM Executive Summary for EVF-23.6 – S.5.2. EVSE Identification and Marking Requirements.,
and T.2. Tolerances.**

USNWG EVFE Subgroup (SG). OWM submitted the following clarifications regarding this letter to the S&T Committee.

- NIST OWM, as convenors of the EVFE SG, sent a response to the Committee indicating that although the results of the Subgroup’s June 2022 ballot indicate the group’s support for modifications to tolerances and marking requirements this should not be construed as supporting the specific changes proposed in EVF-23.6.
- There are some key differences between the Subgroup’s June balloted proposal and EVF-23.6. Specifically, the Subgroup’s proposal does not include two different retroactive dates and differs in the magnitude of the tolerances and specific conditions under which they would apply, the permissible format required for markings (which are not indelible, do the submitters have a label or electronic only in mind?) and reference to certification. The convenors of the Subgroup will continue to provide written and verbal input as explicitly directed by the group.
- Below are some additional comments for the Committee and other stakeholders to consider in reviewing Items EVF-23.5 and EVF-23.6.
- Adoption should occur only after fully vetting proposals to modify fundamental requirements such as those that impact accuracy, transparency, or that ensure fair competition to:
 - avoid unforeseen consequences;
 - ensure stakeholders have the tools needed for this new device application;
 - discourage nonuniformity which can have a disruptive influence on the marketplace; and
 - take corrective action on discovering any gaps/oversight in modifications to the seven-year-old legal metrology requirements.
- NIST OWM encourages the community's participation in the USNWG EVFE Subgroup which began its work in 2012 and whose work resulted in NIST HB 44 3.40. EVFS Code's adoption in 2015. The Subgroup is reviewing the four paragraphs that appear in multiple 2023 proposals that address: (1) dual EVSE tolerances (2.0 percent or 5.0 percent [DC EVSEs]); (2) new EVSE markings required for the wider tolerance in the marketplace; and (3) corresponding accuracy test procedures.
- The EVFE Subgroup last met on December 8, 2022, to address proposals under consideration for the 2023 cycle and will provide a clear statement in writing of its exact position on agenda items.

Table 3. Summary of Recommendations							
EVF-23.6 – S.5.2. EVSE Identification and Marking Requirements., and T.2. Tolerances.							
	V	D	W	A	I	Notes*	Comments
Submitter							
OWM							
WWMA		✓					
SWMA	✓						
NEWMA		✓					
CWMA	✓						
NCWM							
	Letters of Support		Letters of Opposition		Notes		
Industry	✓				October 15, 2022 letter.		
Manufacturers	✓				October 15, 2022 letter.		
OWM					Clarification on the June and December 2022 findings of the USNWG EVFE Subgroup.		
Retailers and Consumers							
Regulators	✓				October 15, 2022 letter.		
*Notes Key: 1 - Submitted modified language 2 - Item not discussed 3 - No meeting held 4 - Not submitted on agenda 5 - No recommendation or not considered							

Item Under Consideration:

Amend Handbook 44, Electric Vehicle Fueling Systems as follows:

S.5.2. EVSE Identification and Marking Requirements. – In addition to all the marking requirements of Section 1.10. General Code, paragraph G-S.1. Identification, each EVSE shall have the following information conspicuously, legibly, and indelibly marked:

- (a) voltage rating;
- (b) maximum current deliverable;
- (c) type of current (AC or DC or, if capable of both, both shall be listed);
- (d) minimum measured quantity (MMQ); and
- (e) temperature limits, if narrower than and within – 40 °C to + 85 °C (40 °F to + 185 °F).

S.5.2.1. Marking of Accuracy Limits, DC EVSEs Installed Prior to 2024. - A DC EVSE installed prior to 2024 shall be marked with the following unless it is certified to the tolerances of T.2.2(b):

NOTICE:

“This charger operates at a tolerance of up to ± 5 percent versus other chargers which operate at a tolerance of up to ± 2 percent.”

This marking shall be conspicuously and legibly displayed in a position plainly visible to a person accessing a charging port of the EVSE.

(Added 202X)

T.2. Test Tolerances

T.2.1. EVSE Load Accuracy Test Tolerances for AC Systems. – The tolerances for EVSE load tests for AC systems are:

- (a) Acceptance Tolerance: 1.0 %; and
- (b) Maintenance Tolerance: 2.0 %.

T.2.2. EVSE Load Accuracy Test Tolerances for DC Systems. -- The tolerances for EVSE load test on DC systems shall be as follows:

(a) For DC systems installed prior to January 1, 2024, and that bear the notice specified in paragraph S.5.2.1. Marking of Accuracy Limits, DC EVSEs Installed Prior to 2024, acceptance and maintenance tolerances are: 5.0 %. This paragraph T.2.2(a) shall expire on January 1, 2034; after that date, all DC EVSEs shall be subject to the tolerances of paragraph T.2.2(b).

(b) For DC systems installed on or after January 1, 2024, or that do not bear the notice specified in paragraph S.5.2.1. Marking of Accuracy Limits, DC EVSEs Installed Prior to 2024 tolerances are:

- (1) Acceptance Tolerance: 1.0 %; and**
- (2) Maintenance Tolerance: 2.0 %.**

All DC EVSE are exempt from ~~this requirement~~ **paragraph T.2.2** until January 1, 2028.

NIST OWM Detailed Technical Analysis:

The proposal outlined in agenda item EVF-23.6 is not exactly the same as an alternative proposal agreed to in a June 2022 ballot of the EVFE Subgroup. In the case of the EVFE Subgroup, the wider tolerance of 5 % for DC systems installed before 2024 was identified by several OEMs as achievable, and the less than ideal existence of dual tolerances in the marketplace would be addressed by marking the accuracy achievable by devices which met only the wider tolerance. Granted some refining of the requirement text would be necessary the group’s alternate proposal addressed many concerns expressed by both OEMs and regulators when the Subgroup’s discussions on this topic first began in 2020.

NIST OWM is aware of an October 15, 2022 letter from Florida and industry representatives from Electrify America, Tesla, EVGo, and Siemens sent to the NCWM S&T Committee. The co-authors of the letter summarized the EVF-23.6 proposal recommendations. The co-authors stated their beliefs about their comparison of EVF-23.6 to the Subgroup membership's June 2022 balloted proposal and the subgroup's position on EVF-23.6. On October 20th NIST OWM as convenors of the USNWG EVFE Subgroup sent to the NCWM S&T Committee a written response to the October 15th letter to clarify references made that imply the EVFE Subgroup's approval or support of S&T Agenda Item EVF-23.6. Though the results of the Subgroup's June 2022 ballot indicate the group's support for modifications to tolerances and marking requirements this should not be construed as supporting the specific changes proposed in EVF-23.6. There are some key differences between the Subgroup's June balloted proposal and EVF-23.6. Specifically, the Subgroup's proposal does *not* include two different retroactive dates and differs in the magnitude of the tolerances and specific conditions under which they would apply, the permissible format required for markings, and reference to certification. The convenors also clarified that the Subgroup will provide written and verbal input as explicitly directed by the group (shown below under the subgroup heading).

The proposal in EVF-23.6 to include a new paragraph T.2.2. to address DC systems tolerances as worded permits a 5 percent tolerance for EVSEs installed pre- or post- 2024 on the condition this accuracy is declared in a "NOTICE"; however, if not bearing a notice then the expectation is that regardless of the installation date a DC system will still be permitted 5 percent accuracy. Device tolerances should not hinge on the presence of a temporary label (i.e., the "Notice" for accuracy does not have to be indelible). Equipment has been permitted multiple accuracy classes; however, those devices bear an accuracy class marking permanently at all times and that determination is made during type evaluation of the device. In many device codes there is only a single accuracy class.

Newly proposed subparagraph T.2.2.(a) specifies a 2034 sunset date for equipment with a 5 percent accuracy this is almost two decades after the EVFS Code was published and becomes the second enforcement date included in the tolerance specification. The DC tolerance requirement also includes a 2028 enforcement date proposed in July 2022 and then adopted in July 2022 as part of a priority item. That 2028 date appears as the current handbook edition as an applicable enforcement date in Agenda Item EVF-23.6. This proposal attempts to address DC systems tolerances when they are exempt from handbook test tolerances until 2028.

Agenda Item EVF-23.6 proposed new paragraph S.5.2.1., an accuracy marking requirement for DC systems installed before 2024, is not applicable if the EVSE is "certified." Typically, references in the code to "certified" equipment are there to address requirements applicable to either test standards such as certified test weights or a reference scale, which are typically verified just prior to use and meet a performance level higher than that of the commercial device under test, or the device has undergone type evaluation and been issued a certificate. What would be the instructions for achieving this status given DC systems are not certified?

Moving forward with adoption before fully vetting proposals to modify fundamental requirements such as accuracy, transparency, or that ensure fair competition which are the foundation of every weighing and measuring device code can have unforeseen consequences. To delay or eliminate these basic guidelines (tools needed for this new device application) encourages nonuniformity (from state to state) which can be disruptive and impact the level of confidence in the marketplace. Proposals should be evaluated based on their impact on all stakeholders in the community. Time and again the community has moved to take corrective action on discovering an oversight that resulted from either the modification of existing or adoption of a new legal metrology requirement.

NIST OWM encourages the community's participation in the USNWG which began work in 2012 as a forum for stakeholders and other interested parties in establishing legal metrology standards (also the

weights and measures infrastructure) for electrical energy measurements. That effort resulted in NIST HB 44 3.40 EVFS Code's adoption in 2015. The four paragraphs that appear in multiple 2023 proposals address (1) dual EVSE tolerances (2.0 percent or 5.0 percent [DC EVSEs]); (2) new EVSE markings required for the wider tolerance in the marketplace (proposed new 5.0 percent accuracy for DC systems); and (3) corresponding accuracy test procedures are part of the EVFE SG's meeting discussions. The EVFE Subgroup's work continues up through today having met October 6, 18, and December 8, 2022 to address proposals under consideration for the 2023 cycle. It should be noted that the EVFE SG has worked to further refine the code as more is learned about these systems and since January 2020 met 16 times to consider the proposals the group submitted to the S&T Committee as well as those developed or under development outside of its forum to provide the group's input. The EVFE SG will provide a clear statement of its exact position on agenda proposals when it reaches a consensus and provides this information in writing (as shown below). The EVFE SG reached a consensus in July 2022 which the group agreed to move forward to recommend a wider tolerance of 5 percent only for DC systems installed before 2024 that must bear accuracy markings while maintaining for AC systems a 1 percent Acceptance Tolerance/2 percent Maintenance Tolerance and the tighter tolerance would also apply to post 2024 DC systems.

U.S. National Work Group's Electric Vehicle Fueling Equipment Subgroup (EVFE SG)

- The SG agreed to forward the results of its June 2022 ballot (in which it proposed changes to the tolerances and the addition of marking requirements) to the S&T Committee and recommend the Committee consider these recommendations as it considers Items EVF-23.5 and EVF-23.6.
- In a June 2022 ballot, the SG agreed to recommend the following changes to the tolerances and marking requirements in Section 3.40. The SG asks that the Committee consider the SG's recommendations presented below as it deliberates on S&T Agenda Items EVF-23.5 and EVF-23.6 which include proposed changes to these same handbook code paragraphs. The changes agreed to by the SG in its June 2022 ballot are shown below.
 - Additionally, some device users on the SG indicated that there remains a desire to recognize and then maintain a 5% tolerance for DC legacy (i.e., installed prior to 2024) equipment.

T.2. ~~Load~~ Accuracy Test Tolerances.

T.2.1. ~~EVSE Load~~ EVSE Accuracy Test Tolerances for AC Systems. – The tolerances for EVSE load tests for AC systems shall be as follows:

- (a) Acceptance Tolerance: 1.0 %; and
- (b) Maintenance Tolerance: 2.0 %.

(Amended 202X)

T.2.2. EVSE Accuracy Test Tolerances for DC Systems. – **The tolerances for EVSE load tests on DC systems shall be as follows:**

- (a) For DC systems installed prior to 2024 and that bear the notice specified in paragraph S.5.2.1. Marking of Accuracy Limits, DC EVSEs Installed Prior to 2024, acceptance and maintenance tolerances are: 5.0 %.**

(b) For DC systems installed on or after January 1, 2024 or that do not bear the notice specified in paragraph S.5.2.1. Marking of Accuracy Limits, DC EVSEs Installed Prior to 2024 tolerances are:

(1) Acceptance Tolerance: 1.0 %; and

(2) Maintenance Tolerance: 2.0 %.

(Added 202X)

S.5.2. EVSE Identification and Marking Requirements. – In addition to all the marking requirements of Section 1.10. General Code, paragraph G-S.1. Identification, each EVSE shall have the following information conspicuously, legibly, and indelibly marked:

- (a) voltage rating;
- (b) maximum current deliverable;
- (c) type of current (AC or DC or, if capable of both, both shall be listed);
- (d) minimum measured quantity (MMQ); and
- (e) temperature limits, if narrower than and within – 40 °C to + 85 °C (– 40 °F to + 185 °F).

S.5.2.1. Marking of Accuracy Limits, DC EVSEs Installed Prior to 2024. - DC EVSEs installed prior to 2024 shall be marked with the following:

NOTICE:

“This charger operates at a tolerance of +/- 5 percent versus newer chargers which operate at a maximum tolerance of +/- 2 percent.”

This marking shall be conspicuously, legibly, and indelibly marked, in a position plainly visible to a person accessing a charging port of the EVSE.

This marking requirement does not apply to DC EVSEs that are capable of meeting an acceptance tolerance of 1 % and a maintenance tolerance of 2 %.

(Added 202X)

(Amended 2021)

Summary of Discussions and Actions:

A letter dated October 15, 2022 from the State Weights and Measures Director of Florida and industry representatives from Electrify America, Tesla, EVGo, and Siemens was sent to the NCWM S&T Committee. The co-authors of the letter summarized the EVF-23.6 proposal recommendation for a 5 percent tolerance for DC systems installed before 2024 when so marked, if installed after 2024 or lacking the 5 percent DC systems are subject to 1 percent/2 percent tolerance. The co-authors noted the October

4th announcement by NIST of a general consensus on a June 2022 balloted proposal of the USNWG EVFE Subgroup (attached to the co-authors October 15th letter). The co-authors response to the Subgroup member opposing the June 2022 proposal was to include a new 2034 expiration on the 5 percent tolerance as part of the proposal in item EVF-23.6. The co-authors stated their beliefs about their comparison of EVF-23.6 to the Subgroup membership's June 2022 balloted proposal and the subgroup's position on EVF-23.6.

A letter dated October 20, 2022 from the NIST OWM as convenors of the USNWG EVFE Subgroup was sent to the NCWM S&T Committee in response to an October 15th letter co-authored by Florida, Electrify America, Tesla, EVGo, and Siemens. The letter was sent to clarify references made in the October 15th letter that imply the EVFE Subgroup's approval or support of S&T Agenda Item EVF-23.6. Though the results of the Subgroup's June 2022 ballot indicate the group's support for modifications to tolerances and marking requirements this should not be construed as supporting the specific changes proposed in EVF-23.6. There are some key differences between the Subgroup's June balloted proposal and EVF-23.6. Specifically, the Subgroup's proposal does *not* include two different retroactive dates and differs in the magnitude of the tolerances and specific conditions under which they would apply, the permissible format required for markings, and reference to certification. The convenors of the Subgroup will continue to provide written and verbal input as explicitly directed by the group.

NOTE: The EVFE Subgroup met on December 8, 2022, input based on the group's discussions of S&T Item EVF-23.6 are provided above in the section of this analysis under the heading U.S. National Work Group's Electric Vehicle Fueling Equipment Subgroup (EVFE SG).

Regional Association Reporting:

Central Weights and Measures Association

Ms. Scheleese Goudy (Electrify America): DC EVSE installed before 2024 will have 5 % accuracy until 2034. When the tentative code was written in 2015, historical data for AC measurements were readily available. DC metering technology was still in R&D. Tolerances could not be formulated. Legacy devices could reasonably meet 5 %, but not 1%/2 %. This could require complete replacement of many legacy devices.

Ms. Francesca Wahl (Tesla): Rework of two above. Does not modify the 2028 date but provides a pathway forward. This proposal represents informal consensus of the NIST USNWG.

Mr. Craig VanBuren (Michigan): Move forward as Voting. Possible change: P 244, line 39. which "may" operate.

The CWMA S&T Committee believes this item is fully developed and recommend Voting status with the following changes:

S.5.2. EVSE Identification and Marking Requirements. – In addition to all the marking requirements of Section 1.10. General Code, paragraph G-S.1. Identification, each EVSE shall have the following information conspicuously, legibly, and indelibly marked:

- (a) voltage rating;
- (b) maximum current deliverable;
- (c) type of current (AC or DC or, if capable of both, both shall be listed);

- (d) minimum measured quantity (MMQ); and
- (e) temperature limits, if narrower than and within – 40 C to + 85 C (40 F to + 185 F).

S.5.2.1. Marking of Accuracy Limits, DC EVSEs Installed Prior to 2024. - A DC EVSE installed prior to 2024 shall be marked with the following unless it is certified to the tolerances of T.2.2(b):

NOTICE:

“This charger operates at a tolerance of up to ± 5 percent versus other chargers which may operate at a tolerance of up to ± 2 percent.”

This marking shall be conspicuously and legibly displayed in a position plainly visible to a person accessing a charging port of the EVSE.

(Added 202X)

T.2. Test Tolerances.

T.2.1. EVSE Load Accuracy Test Tolerances for AC Systems. – The tolerances for EVSE load tests for AC systems are:

- (a) Acceptance Tolerance: 1.0 %; and
- (b) Maintenance Tolerance: 2.0 %.

T.2.2. EVSE Load Accuracy Test Tolerances for DC Systems. -- The tolerances for EVSE load tests on DC systems shall be as follows:

(a) For DC systems installed prior to January 1, 2024, and that bear the notice specified in paragraph S.5.2.1. Marking of Accuracy Limits, DC EVSEs Installed Prior to 2024, acceptance and maintenance tolerances are: 5.0 %. This paragraph T.2.2(a) shall expire on January 1, 2034; after that date, all DC EVSEs shall be subject to the tolerances of paragraph T.2.2(b).

(b) For DC systems installed on or after January 1, 2024, or that do not bear the notice specified in paragraph S.5.2.1. Marking of Accuracy Limits, DC EVSEs Installed Prior to 2024 tolerances are:

(1) Acceptance Tolerance: 1.0 %; and

(2) Maintenance Tolerance: 2.0 %.

All DC EVSE are exempt from ~~this requirement~~ **paragraph T.2.2** until January 1, 2028.

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received:

Ms. Scheleese Goudy (Electrify America): Ms. Goudy commented on the metering technology for DC chargers are now becoming available as technology develops. Ms. Goudy proposed previously installed

devices will not be able to meet the 1 and 2% tolerances. Ms. Goudy commented the tolerances are being developed with separate tolerances for legacy devices that can't meet the proposed requirements. Ms. Goudy stated there was a vote of 11-1 in favor of the item in the assigned work group. The 1 no vote said that it would have been a yes if there was a 10-year sunset. Ms. Goudy stated the changes to the item incorporated the change to include a 10-year sunset of legacy devices. Ms. Goudy commented devices would be marked for the public and inspectors with the required tolerances. Ms. Goudy recommended Voting status.

Mr. Kevin Schnepf (California Division of Measurement Standards) commented this was discussed in the national workgroup. Mr. Schnepf recommended that a task group be assigned to verify which items were in a consensus and which were not. Mr. Schnepf proposed a hard stop date for legacy devices is necessary and that there isn't one with the current language. Mr. Schnepf commented on his disagreement with the "or" statement in the current language.

Ms. Francesca Wahl (TESLA) commented TESLA agrees with the comments made by Electrify America. Ms. Wahl commented the language is to include a hard stop date of legacy devices supports the removal of "or" from the language.

Mr. Chris King (Siemens) commented Siemens agrees with TESLA's comments.

During open hearings, comments were heard that contents in this item were previously discussed in the USNWG, but no official position has been taken by the USNWG. There were also comments during open hearing taking the position the item is not fully developed. The WWMA S&T Committee recommended the submitters work with the USNWG to develop one proposal by combining language from EVF -23.5.

The WWMA S&T Committee recommended that this item be blocked with item EVF-23.5. The WWMA S&T Committee recommended the new blocked items be assigned a Developing status.

Southern Weights and Measures Association

The following comments were received during the 2022 SWMA Annual Meeting:

Mr. Prince (Florida) spoke in favor of this item being a satisfactory compromise.

Mr. Floyd (Louisiana) stated that he would rather not have devices with warning labels for accuracy.

Ms. Goudy (Electrify America) the submitter of this item, recommended this move forward as a Voting Item.

Mr. Stokes (South Carolina) stated that he supported the use of warning labels for these devices and supported this item.

The SWMA S&T Committee recommended this item move forward as a Voting Item.

Northeastern Weights and Measures Association

Mr. Keith Bradley (Electrify America) recognizes that when the code was originally adopted there was questions about DC meters being able to meet a 1% and 2% tolerance. This item is to make sure devices are properly marked for the consumer as installed before 2024 and 5% tolerance. If devices are not marked this way, the 1% and 2% tolerances would apply. Installed devices would have the larger tolerance until 2034, then revert. Ms. Francesca Wahl (Tesla) recommends Voting status. Ms. Juana Williams (NIST

OWM) noted that there is a letter from NIST to indicate that a status update on this item is forthcoming and has info to address marking and tolerances for DC systems. In a June meeting by the EVSE Subgroup, there was no 2028 retroactive date being considered and the proposal they reviewed included different sets of tolerances and marking requirements based on install date. Mr. Jason Flint (New Jersey) requested that this item be given a Developing status as there is too much debate and too many questions. Mr. Flint suggested that the submitters of EVF-23.5 and EVF-23.6 work together to develop further.

After hearing comments from the floor, the Committee believes the item is not fully developed and several questions need to be answered. The Committee is recommending that this item be given a Developing status.

EVF-23.7 N.1. No Load Test, N.2. Starting Load Test, N.5.2. Accuracy Testing, and Appendix D: maximum deliverable amperes

Source: Electrify America

Submitter's Purpose and Justification:

The proposal would have the testing conducted at the contemplated 10%. Because it is unlikely that tests would actually be at precisely 10%, the proposal would allow testing in a small range slightly above 10%.

The accuracy tests in section 3.40 contemplate testing an EV charger at two points, one at relatively low current and power, and the other at relatively high current and power. The low point was evidently intended to be at 10% of a charger's maximum current. It is likely that charger manufacturers have designed chargers with that 10% in mind as the "low" point of accuracy tests. But the code does not actually state that testing should be *at* 10%. It says testing can be at a current *less than* 10%. This formulation is problematic because it encompasses any current less than 10%. Zero is less than 10%, and 0.1 A is less than 10% even though it is less than the amount at which the code requires a charger to first register a load. Even currents larger than these, but less than 10%, would be unnecessarily difficult for an accuracy test. The problem is that low currents are an area where accuracy is particularly difficult. For example, one common metering configuration is to measure the current being delivered by means of a shunt resistor, which generates a voltage from the high current passing through it. These resistors necessarily have very low resistances because they are necessarily dissipating power in accordance with the resistance. A typical resistor in an EV charger metering setup might be 100 micro-ohms. For a 500 amps full-scale current in a DC charger, that resistor would be dissipating 25 watts of power - thus, a much larger resistor is not a practical option. At, say, 10 amps of delivered current, the voltage generated across the resistor would be 1 millivolt. A 1% measurement of that 1 millivolt would be 10 microvolts. At that level, a range of noise sources become quite significant, such as thermal EMF in the resistor itself and induced EMFs from the presence within the charger cabinet of voltages up to 480 volts ac or 950 volts dc, as well as any offsets or noise in the circuitry measuring the transduced voltage. The net result is that it is very challenging to achieve high accuracy at low currents in a device designed to handle and measure high currents. For reasons like these, the draft international (OIML) standard specifies that an accuracy test should be conducted *at* a given minimum current, rather than (like current Handbook 44) at any current *up to* that minimum.

Meanwhile, low currents are the levels least significant for transactional accuracy. At low current, a charger is delivering energy at a relatively low rate. As a practical matter, an EV will charge at the maximum rate possible in the circumstances. As the battery reaches a higher state of charge, it will draw less power from the EV, but only a small proportion of the overall energy will be delivered at low rates, precisely because the rates are low. Suppose as a simplified example, an EV charges for 30 minutes at 300 amps and 30 minutes at 15 amps (at a voltage of 400 volts). The EV will have received 60 kWh in the first part of the

session, and only 3 kWh in the second part. The low-current period of charging contributes relatively little to the accuracy/inaccuracy of the overall transaction.

Thus, it is important for Handbook 44 to set a minimum current for accuracy tests. Because the point of 10% of the maximum deliverable amperes is already in the code and has probably been used as a design basis for chargers, the proposal would keep that as the low-current point. The overall concept would be for testing to occur *at* 10% of maximum deliverable amperes, rather than *up to* 10%. But it is impractical to specify a single point. An inspection that does not achieve a test at precisely the 10% should not, as a consequence, be an invalid inspection. To make this practical, the proposal would have the low-end test occur in a range of currents, namely 10% to 20% of the charger's maximum.

The code presents a similar problem for DC chargers tested using EVs as loads. The code allows an EV to be used as the load, rather than using a controlled load that draws the loads specified in the code. But the code provides no specifications about how to use an EV in this sort of test. So, it is possible that a tester could use an EV that is, say, at 95% state of charge in the battery, and that would arrive at the charger and draw very low levels of current (sometimes called a "trickle charge"). For the reasons discussed above, that sort of test would not be a productive test of the meaningful accuracy of the charger. The code should set a minimum current for an EV-based test to be usable. The proposal would have that minimum be 30% of the charger's maximum. It is set at more than 10% because the EV-based test uses a single test point, which should therefore be somewhere in the middle of the charger's range.

The proposal would also add a definition of "maximum deliverable amperes." This quantity is the same as used in the existing code as the basis for the 10% figure, but it is not currently defined. The definition would state that maximum deliverable amperes means the amount marked on the charger. (The code already requires that amount to be marked.) This amount might be less than the manufacturer's specification for the potential maximum of the device, if for example the installation limits the charger to a particular amount, or the installer has selected a configuration with a lower maximum. But the maximum deliverable amount is a quantity that is fixed at installation and marked on the charger. The current code suggests that maximum deliverable amperes is the amount that the charger communicates to a vehicle or test apparatus. That approach is confusingly ambiguous, because the charger might for various reasons sometimes communicate a lower available current than its marked maximum. The proposal clarifies that for accuracy tests based on a percentage of maximum current, the "maximum" being used is the maximum marked on the device.

These concepts have been discussed in the U.S. National Work Group's subgroup on EV charging. There is general consensus in favor of the proposal, but there has not been a quorum to vote formally in favor of it.

Finally, the proposal would eliminate the no-load and starting-load tests. These tests take unnecessary time, because an inspector has to wait to verify that a load of zero genuinely produces no response and a starting load of just 0.5 amps produces a response. Meanwhile, these tests are not meaningful for the transactional accuracy of an EV charger. In the process of establishing a handshake that the EV charger is connected to a vehicle, the charger might provide minute test amounts of current, so that a truly zero load is not pertinent to any real transaction; and these minute test currents may well be above 0.5 amps, so that this threshold is also not pertinent to transactions. It would be possible to verify that a charger does not register an energy delivery when no transaction is started, but that test would be redundant of verifying that the charger starts at zero. Meanwhile, 0.001 kWh (the minimum resolution under Handbook 44) corresponds to roughly 3 to 5 hundredths of a cent, so that verifying the registration of such tiny amounts given a tiny current is not helpful for the overall transactional accuracy.

The submitter is not aware of objections that would be raised to this proposal. The concept is consistent with the discussions at the U.S. National Work Group based on information from testing over the past six years, and input from regulators and industry.

The submitter requested that this be a Voting Item in 2023.

OWM Executive Summary for EVF-23.7 – N.1. No Load Test, N.2. Starting Load Test N.5.2. Accuracy Testing, and Appendix D: maximum deliverable amperes

OWM Recommendation:

- Test procedures are not solely written to the operational characteristics or particular design of one test apparatus. Test procedures should encompass operational conditions over the course of the entire transactions in the marketplace. Test points should fall within the rated minimum up through the maximum operational ranges specified by the manufacturer for the EVFS under normal conditions of commercial use.
- Observe this proposal removes any reference to the feature used to determine the MDA percentage level achieved during accuracy tests and establishes a new MDA range for performing the light load test and when a vehicle is the test load for verifying EVFSs; whereas other proposals recommend the establishment of a new laboratory test in addition to field test procedures.
- The EVFS test standard must be fit for purpose or appropriate and suitable (this might be demonstrated by data) in its design, capacity, and accuracy; and would allow for replication of the manner in which the EVSE is used in commerce. The test standard used to verify an EVSE must also meet the NIST HB 44 Appendix A Fundamental Considerations for a test apparatus.
- Therefore, with a decade of experience with EVFSs having gone through type evaluation (i.e., CADMS) and test equipment designed to verify both AC and DC systems and the laboratory community closing in on filling the last gaps in the weights and measures infrastructure for EVFSs; it is important and necessary that all stakeholders (EVSE/test equipment manufacturers, type examiners, and regulators) reach a consensus on test procedures.
- Is this a proposal to renumber paragraph N.5. Accuracy Testing to become N.5.2.1.? The proposal does not show paragraph N.5.2 in entirety, is the submitter proposing to remove the 2028 enforcement date?
- For clarity the “meaning portion” of a definition should not include the term or parts of the term it is defining nor cite one of the many code paragraphs where the term is used because the appearance can be the term is unique to that sole paragraph. Therefore, the term’s definition should include reference to the EVFS Code in brackets (i.e., [3.40] at the end of the definition rather cite a single code requirement or paragraph. The EVFS is a permanent code and definitions applicable to the code should be included in Appendix D—Definitions.
- The proposal removes the No Load Test and Starting Load Test but does not do the same for the tolerances applicable to these tests in paragraphs T.5. and T.6, respectively.

Table 3. Summary of Recommendations							
EVF-23.7 – N.1. No Load Test, N.2. Starting Load Test, N.5.2. Accuracy Testing, and Appendix D: maximum deliverable amperes							
	V	D	W	A	I	Notes*	Comments
Submitter	✓						
OWM							Work necessary to refine tests.
WWMA		✓					Block with Item EVF-23.4.
SWMA	✓						
NEWMA		✓					
CWMA	✓						
NCWM							
	Letters of Support			Letters of Opposition		Notes	
Industry							
Manufacturers							
Retailers and Consumers							
Regulators							
*Notes Key: 1 - Submitted modified language 2 - Item not discussed 3 - No meeting held 4 - Not submitted on agenda 5 - No recommendation or not considered							

Item Under Consideration:

Amend Handbook 44 Electric Vehicle Fueling Systems Code as follows:

~~**N.1. No Load Test. A no load test may be conducted on an EVSE measuring system by applying rated voltage to the system under test and no load applied.**~~

~~**N.2. Starting Load Test. A system starting load test may be conducted by applying rated voltage and 0.5-ampere load.**~~

...

N.5.2.1. Accuracy Testing. – The testing methodology compares the total energy delivered in a transaction and the total cost charged as displayed/reported by the EVSE with that measured by the measurement standard.

(a) For AC systems:

- (1) Accuracy test of the EVSE system at a load of not less than 85 % of the maximum deliverable amperes (~~expressed as MDA~~) ~~as determined from the pilot signal~~ for a

total energy delivered of at least twice the minimum measured quantity (MMQ). If the MDA would result in maximum deliverable power of greater than 7.2 kW, then the test may be performed at 7.2 kW.

- (2) Accuracy test of the EVSE system at a load of ~~not greater than~~ between 10 % and 20% of the maximum deliverable amperes ~~(expressed as MDA) as determined from the pilot signal~~ for a total energy delivered of at least the minimum measured quantity (MMQ).
- (b) For DC systems (see note):
- (1) Accuracy test of the EVSE system at a load of not less than 85 % of the maximum deliverable amperes ~~current (expressed as MDA) as determined from the digital communication message from the DC EVSE to the test standard~~ for a total energy delivered of at least twice the minimum measured quantity (MMQ).
 - (2) Accuracy test of the EVSE system at a load of ~~not more than~~ 10 % and 20% of the maximum deliverable amperes ~~(expressed as MDA) as determined from the digital communication message from the DC EVSE to the test standard~~ for a total energy delivered of at least the minimum measured quantity (MMQ).

Note: For DC systems it is anticipated that an electric vehicle may be used as the test load. Under that circumstance, testing at the load presented by the vehicle shall be sufficient provided that it is greater than 30% of the maximum deliverable amperes of the EVSE system.

And

Appendix D:

maximum deliverable amperes. - The value in amperes, marked on an EVSE pursuant to paragraph S.5.2, EVSE Identification and Marking Requirements, of the maximum current that the EVSE can provide.

NIST OWM Detailed Technical Analysis:

There are other proposals on the S&T Committee agenda to modify the minimum light load and full load test procedures for AC and DC systems addressed in paragraph N.5.2. Accuracy Testing under consideration in the 2023 cycle. One reoccurring recommendation is for a separate new set of test procedures for type evaluation performed under laboratory conditions that did not previously exist and would be a substantive change to the 2023 edition of the HB 44. However, this proposal removes any reference to the feature used to determine the MDA percentage level achieved during accuracy tests and establishes a new MDA range for performing the light load test and when a vehicle is the test load for verifying EVFSs.

Test procedures are not solely written to the operational characteristics or particular design of one test apparatus. Test procedures should encompass operational conditions over the course of the entire transactions in the marketplace. Test points should fall within the rated minimum up through the maximum operational ranges specified by the manufacturer for the EVFS under normal conditions of commercial use. The USNWG developed the handbook AC and DC systems' light load test and full load test procedures in part because they appeared to be the most likely conditions under which equipment would be used during

a charging session and based on existing test procedures and knowledge about watt-hour type electric meters. Watthour type electric meters were the only electrical energy device regulated by a U.S. weights and measures in the 2012 timeframe. For each gap in the EVSE infrastructure there have been stakeholders indicating a solution is possible. The community was advised to wait for completion of performance criteria for DC meters which became available in March 2021 in ANSI C 12.32-2021 American National Standard for Electricity Meters for the Measurement of DC Energy and would be an important reference document for DC type electricity metering in EVFSs. Therefore, with a decade of experience with EVFSs having gone through type evaluation (i.e., CADMS) and test equipment designed to verify both AC and DC systems and the laboratory community closing in on filling the last gaps in the weights and measures infrastructure for EVFSs it is important and necessary that all stakeholders (EVSE/test equipment manufacturers, type examiners, and regulators) reach a consensus on test procedures.

The EVFS test standard must be fit for purpose or appropriate and suitable (this might be demonstrated by data) in its design, capacity, and accuracy; and would allow for replication of the manner in which the EVSE is used in commerce. The test standard used to verify an EVSE must also meet the NIST HB 44 Appendix A Fundamental Considerations for a test apparatus.

The term “maximum deliverable amperes” or abbreviated as “MDA” would be defined as “the highest current value or highest level of current or highest total current capacity at which the manufacturer has designed the EVFS to operate and meet accuracy.” Note: choose one of the three lead statements as the most appropriate description of the current level in the beginning of this alternative new definition. The current level at the installation site and for test equipment shall be suitable for the MDA rating of the EVFS. The term “maximum deliverable amperes” is cited in multiple requirements in the EVFS Code and is relevant to test conditions and is also required marking information on the EVFS. For clarity the “meaning portion” of a definition should not include the term or parts of the term it is defining nor cite one of the many code paragraphs where the term is used because the appearance can be the term is unique to that sole paragraph. Therefore, the term’s definition should include reference to the EVFS Code in brackets (i.e., [3.40] at the end of the definition rather cite a single code requirement or paragraph. The EVFS is a permanent code and definitions applicable to the code should be included in Appendix D—Definitions.

Is this a proposal to renumber paragraph N.5. Accuracy Testing to become N.5.2.1.? The proposal does not show paragraph N.5.2 in entirety, is the submitter proposing to remove the 2028 enforcement date?

Regional Association Reporting:

Central Weights and Measures Association

Ms. Scheleese Goudy (Electrify America) remarked that the low end test was meant to be at 10% but as written would allow anything less than 10 %. Less than 10 % is unnecessarily difficult. Little energy will be delivered at these low rates. Greater inaccuracies below 10 %. Move forward as voting. Note the change on N.5.2.1.(b)(2) to “between 10 % and 20%”.

Ms. Francesca Wahl (Tesla) recommended this move forward as voting.

Mr. Loren Minich (Kansas) stated that page 252 Line 10, remove the “of” before the range.

Mr. Craig VanBuren (Michigan) agreed and remarked this is rReady for voting with recommended changes.

The CWMA S&T Committee believes this item is fully developed and recommended Voting status with the following changes:

~~N.1. No Load Test. A no load test may be conducted on an EVSE measuring system by applying rated voltage to the system under test and no load applied.~~

~~N.2. Starting Load Test. A system starting load test may be conducted by applying rated voltage and 0.5 ampere load.~~

N.5.2.1. Accuracy Testing. – The testing methodology compares the total energy delivered in a transaction and the total cost charged as displayed/reported by the EVSE with that measured by the measurement standard.

(a) For AC systems:

- (1) Accuracy test of the EVSE system at a load of not less than 85 % of the maximum deliverable amperes ~~(expressed as MDA) as determined from the pilot signal~~ for a total energy delivered of at least twice the minimum measured quantity (MMQ). If the MDA would result in maximum deliverable power of greater than 7.2 kW, then the test may be performed at 7.2 kW.
- (2) Accuracy test of the EVSE system at a load ~~of not greater than~~ between 10 % and 20% of the maximum deliverable amperes ~~(expressed as MDA) as determined from the pilot signal~~ for a total energy delivered of at least the minimum measured quantity (MMQ).

(b) For DC systems (see note):

- (1) Accuracy test of the EVSE system at a load of not less than 85 % of the maximum deliverable amperes ~~current (expressed as MDA) as determined from the digital communication message from the DC EVSE to the test standard~~ for a total energy delivered of at least twice the minimum measured quantity (MMQ).
- (2) Accuracy test of the EVSE system at a load ~~of not more than~~ between 10 % and 20% and 20 % of the maximum deliverable amperes ~~(expressed as MDA) as determined from the digital communication message from the DC EVSE to the test standard~~ for a total energy delivered of at least the minimum measured quantity (MMQ).

Note: For DC systems it is anticipated that an electric vehicle may be used as the test load. Under that circumstance, testing at the load presented by the vehicle shall be sufficient provided that it is greater than 30% of the maximum deliverable amperes of the EVSE system.

And

Appendix D:

maximum deliverable amperes. - The value in amperes, marked on an EVSE pursuant to paragraph S.5.2. EVSE Identification and Marking Requirements, of the maximum current that the EVSE can provide.

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received:

Ms. Scheleese Goudy (Electrify America) commented the item is written to allow testing at any current and the rate to charge is very low compared to the 10% accuracy. Ms. Goudy commented these tests make inspectors wait and are not meaningful for the accuracy of an EV charger. Ms. Goudy commented there was a broad consensus at the USNWG but no official vote was taken by the Work Group. Ms. Goudy recommended a Voting status.

Mr. King commented Siemens targets a 10% accuracy test. Mr. King commented Siemens is in favor of the change.

Ms. Wahl second the comments by Electrify America and Siemens. Ms. Wahl recommended a Voting status.

Mr. Kevin Schnepf (California Division of Measurement Standards commented in full support of recommendations to strike the no load and starting load tests. Mr. Schnepf commented he doesn't think there is consensus from the Work Group. Mr. Schnepf recommended that this item be discussed with the U.S. National Working Group to make sure that it is highly agreed upon. Mr. Schnepf proposed if two vehicles are charging at once it cuts the 10% in half. Mr. Schnepf commented in favor the range between 10 and 20%. Mr. Schnepf recommended a Developing status.

During open hearings, comments were heard that contents in this item were previously discussed in the USNWG, but no official position has been taken by the USNWG. There were also comments during open hearing taking the position the item is not fully developed. The WWMA S&T Committee recommended the submitters work with the USNWG to develop one proposal by combining language from EVF-23.4.

The WWMA S&T Committee recommended that this item be blocked with item EVF-23.4. The WWMA S&T Committee recommended the new blocked items be assigned a Developing status.

Southern Weights and Measures Association

The following comments were received during the 2022 SWMA Annual Meeting:

Mr. Prince (Florida) supports this as a Voting Item.

Ms. Goudy (Electrify America) recommended this item move forward as a Voting Item.

The SWMA S&T Committee recommended this item move forward as a Voting Item.

Northeastern Weights and Measures Association

Mr. Keith Bradley (Electrify America) stated that the core problem is testing at low currents. Mr. Bradley believes that "10%-20%" is better than "up to 10%" as no currently installed charger will be able to do less than 10%. Currently, the HB doesn't qualify what the test procedure is for testing device using an EV. Ms. Juana Williams (NIST OWM) indicated that the removal of "no load test" and "starting load test" is consistent with other proposals viewed by the EVFE Subgroup. Ms. Williams also questioned how an inspector will know they reached 10% and 85% if there is no pilot signal or information coming from digital communications with the system. Ms. Williams also noted that a definition being tied to marking requirement is not typically done. Mr. Keith Bradley (Electrify America) explained that an inspector would know max deliverable amps as it should be marked on the device, know the current as displayed by the testing apparatus, then compare. Mr. Jason Flint (New Jersey) recommended that the item be Developing.

After hearing comments from the floor, the Committee believes the item has merit. The Committee is recommending a Developing status.

GMA – Grain Moisture Meters 5.56 (A)

GMA-19.1 D Table T.2.1. Acceptance and Maintenance Tolerances Air Oven Method for All Grains and Oil Seeds.

Source: NTEP Grain Analyzer Sector

Submitter's Purpose and Justification:

Reduce the tolerances for the air oven reference method.

This item has been assigned to the submitter for further development. For more information or to provide comment, please contact:

Mr. Karl Cunningham
Illinois Department of Agriculture
217-785-8301, karl.cunningham@illinois.gov

AMS, FGIS request samples and list of grains from states to include in their ongoing calibration program. States and other interested parties wanted to verify that corn samples from their state were included in the calibration data for NTEP meters because of variations states reported between UGMA meter and other meter technologies on corn samples.

During the 2016 Grain Analyzer Sector Meeting, numerous instances of inconsistent moisture meter measurements involving grain shipments from U.S. interior facilities to U.S. export port facilities were reported. The Sector received a suggestion that if the UGMA can make better measurements, then the Sector should consider reducing the applicable tolerances in HB 44. At the 2016 and 2017 Grain Analyzer Sector meetings Mr. Charlie Hurburgh (Iowa State University) agreed to chair a GA Sector Task Group to review the current HB 44 tolerance with both UGMA meters and Non-UGMA meters. During the 2018 meeting Mr. Hurburgh reported that based on data he analyzed from Iowa State Weights and Measures Grain Inspection reports, UGMA meters read closer to the reference air oven moisture results than non-UGMA meters.

It was also noted during the 2018 NTEP Grain Analyzer Sector meeting that the current tolerances were developed in 1991 and have not been changed to coincide with the change in technology for these devices; and this action is needed for grain industry risk management.

Prior to the 2019 NCWM Interim Meeting, all four regional weights and measures associations agreed to forward the proposal as a voting item on the Interim Agenda. However, following the regional meetings, additional data was submitted to the Sector which indicates a need to consider developing different tolerance for some grain types. Through a subsequent ballot, and a majority vote, the Sector agreed to recommend changing the status of the item to developing to provide the Sector time to consider additional data and changes to its original proposal.

**OWM Executive Summary for GMA-19.1 – Table T.2.1. Acceptance and Maintenance Tolerances
Air Oven Method for All Grains and Oil Seeds.**

OWM Recommendation: NIST OWM supports the collection of data to verify that the proposed reduction in tolerances is appropriate for all grains.

- During the NTEP Grain Analyzer (GA) Sector 2019 meeting, the Sector reviewed data from Arkansas for Long Grain Rough Rice (LGRR) and other grains. The data showed that the proposal to tighten the acceptance and maintenance tolerance may not be appropriate for all grain types. The original data presented and used as a basis for the proposal applied to corn and soybeans. After reviewing the data, the Sector decided to collect inspection data from across the country. An industry representative offered to assist with data analysis and along with the NIST representative will work in producing the inspection data needed for the analysis. A request for State participation will be sent to State weight and measures. The Sector requests that this remain a Developing Item as they move forward in evaluating additional data.
- North Carolina submitted the requested grain data for review. Field meter inspection data from the state of North Carolina for years 2017 to 2019 was examined and comprised over 3300 records each usually averaged 3 commodity drops on UGMA and Non-UGMA meter types. While only one state’s data cannot be considered representative of all the other states, the results provide indications of trouble with decreased tolerances on both UGMA and Non-UGMA meter types.
- Additional data is expected from other States participating in the grain data submission.

Table 3. Summary of Recommendations

Item GMA-19.1–Table T.2.1. Acceptance and Maintenance Tolerances Air Oven Method for All Grains and Oil Seeds.

	V	D	W	A	I	Notes*	Comments
Submitter							
OWM							
WWMA			✓				
SWMA		✓					
NEWMA		✓					
CWMA		✓					
NCWM							
	Letters of Support			Letters of Opposition			Notes
Industry							
Manufacturers							
Retailers and Consumers							

Table 3. Summary of Recommendations							
Item GMA-19.1–Table T.2.1. Acceptance and Maintenance Tolerances Air Oven Method for All Grains and Oil Seeds.							
	V	D	W	A	I	Notes*	Comments
*Notes Key: 1 - Submitted modified language 2 - Item not discussed 3 - No meeting held 4 - Not submitted on agenda 5 - No recommendation or not considered							

Item Under Consideration:

Amend Handbook 44, Grain Moisture Meter Code 5.56 (a) as follows:

T.2.1. Air Oven Reference Method. – Maintenance and acceptance tolerances shall be as shown in Table T.2.1. Acceptance and Maintenance Tolerances Air Oven Reference Method. Tolerances are expressed as a fraction of the percent moisture content of the official grain sample, together with a minimum tolerance.

(Amended 2001)

Table T.2.1. Acceptance and Maintenance Tolerances Air Oven Reference Method		
Type of Grain, Class, or Seed	Tolerance	Minimum Tolerance
Corn, oats, rice, sorghum, sunflower	0.05 of the percent moisture content	0.8 % in moisture content
All other cereal grains and oil seeds	0.04 of the percent moisture content	0.7 % in moisture content

Table T.2.1. Acceptance and Maintenance Tolerances Air Oven Reference Method for All Grains and Oil Seeds	
<u>Tolerance</u>	<u>Minimum Tolerance</u>
<u>0.03 of the percent moisture content</u>	<u>0.5 % in moisture content</u>

(Amended 2001 and 20XX)

NIST OWM Detailed Technical Analysis:

During the NTEP Grain Analyzer (GA) Sector 2019 meeting, the Sector reviewed data from Arkansas for Long Grain Rough Rice (LGRR) and other grains. The data showed that the proposal to tighten the acceptance and maintenance tolerance may not be appropriate for all grain types. The original data

presented and used as a basis for the proposal applied to corn and soybeans. After reviewing the data, the Sector decided to collect inspection data from across the country. An industry representative offered to assist with data analysis and along with the NIST representative will work in producing the inspection data needed for the analysis. A request for State participation will be sent to State weight and measures. The Sector requests that this remain a Developing Item as they move forward in evaluating additional data.

At the 2020 Interim Meeting the S&T Committee agreed to retain this item as Developing in anticipation of additional data that is being collected to assess the proposed tolerances and the appropriateness of the change to tolerances for other grain types. The NIST Technical Advisor is working with the Grain Analyzer Sector and States to collect additional data on the proposed changes to the tolerances with plans to present data at the next NTEP GA Sector Meeting in August 2021. NIST OWM agrees with the S&T Committee that this item should be given a Developing status until additional data is examined.

Ms. Diane Lee (NIST) is working with the Sector to collect data on Unified Grain Moisture Algorithm (UGMA) grain moisture meters and non-UGMA grain moisture meters. North Carolina, Arizona, Illinois, and Iowa agreed to provide 2017-2019 inspection data on field meters. The participating States were requested to submit data by December 1, 2021. One state will be unable to participate, and North Carolina has submitted their data.

During the 2022 Grain Analyzer Sector Meeting the Sector reviewed data from North Carolina. Regarding potential changes to “Handbook 44” tolerances for Grain Moisture Meters, field meter inspection data from the state of North Carolina for years 2017 to 2019 was examined. Only the one state provided data, but that comprised over 3300 records each usually averaging 3 commodity drops on UGMA and Non-UGMA meter types. While only one state’s data cannot be considered representative of all the other states, the results here provide indications of trouble with decreased tolerances on both UGMA and Non-UGMA meter types. The following provide a percentage of device that exceeded the current tolerance compared to the percentage of meters that would exceed the proposed tolerance.

	Exceed current tolerance (UGMA)	Exceed current tolerance (Non-UGMA)	Exceed proposed tolerance (UGMA)	Exceed proposed tolerance (Non-UGMA)
Count	10	18	54	263
Records	1146	2208	1146	2208
Fraction	0.87%	0.82%	4.71%	11.91%

The Sector has requested additional data from other States to gain a better perspective on the impact of lowering the tolerances for grain moisture meters.

History

The GA Sector originally forwarded this proposal to the regional weights and measures associations with a proposed Voting status. All regional weights and measures associations agreed to forward the proposal as a voting item on the 2019 NCWM Interim Agenda and the Sector appreciates their review and support. However, following the regional meetings additional data was submitted to the sector which indicates a need to consider developing different tolerance for some grain types. Through a subsequent ballot, and a majority vote, the sector agreed to recommend changing the status of the item to developing to provide the Sector time to consider additional data and changes to its original proposal. OWM agrees with the Grain Analyzer (GA) Sector’s revised decision to change the status of this item to Developing.

This proposal to change the air-oven method tolerances was developed during the 2018 GA Sector meeting. During the 2018 GA Sector Meeting, Dr. Charlie Hurburgh provided the Sector with an analysis of data for 2-corn and 1-soybeans samples which included the average error for UGMA grain moisture meter

technology and the average error of 2 MHz grain moisture meter technology from Iowa State weights and measures inspection data for years 2014-2017. Based on the Sectors review of the data, discussion of new tolerances, and the ability of the technologies to meet the new tolerances the Sector agreed to change the tolerances based on the data provided.

During additional discussion of what tolerances to apply to other grains, it was proposed that the same tolerances could apply to all grains, because corn is one of the more difficult grains to test and would likely have one of the largest variations when testing. No objections from States or meter manufacturers were provided during the discussion and voting to forward the item to the State regional weights and measures associations. Following the Sector meeting one State noted that there may be an issue with applying the tolerance to some grain types, specifically long grain rough rice. The GA Sector's technical advisor requested that the State forward field data to review the grain moisture meter results for LGRR and other grains. After review of the data with the proposed tolerances it was determined that a high meter failure rate could result with a change to the tolerances for some grain types.

After the Sector's Technical Advisor discussed the findings with the NTEP laboratory and the Sector members that originally proposed the tolerance change, they agreed with proposing a Developing status for this item, the Sector was officially balloted and also agreed to change the originally proposed Voting status to Developing to allow the Sector time to review additional data and make changes to its original proposal.

Summary of Discussions and Actions:

At the NCWM 2022 Interim Meeting, the Committee heard comments from Ms. Diane Lee (NIST OWM) who noted that additional data is needed to assess the proposed tolerances. Ms. Lee added that states would be submitting more data. Ms. Lee requested that this item remain Developing. During the Committee's work session, the Committee agreed to a Developing status for this item.

At the NCWM 2022 Annual Meeting open hearings Mrs. Tina Butcher (NIST OWM) provided updates on the Grain Analyzer Sector's proposal to reduce the tolerance for grain moisture meters. She informed the S&T Committee that the Grain Analyzer Sector had originally reviewed data for corn and soybeans. After the proposal for changes to the tolerances were submitted to the NCWM, information was received that reducing the tolerance may be problematic for other grains. As such the Grain Analyzer Sector is collecting additional data on other grain types and request a Developing status and additional time to collect the data.

At the NCWM 2022 Annual Meeting Committee meeting, the Committee agreed to a Developing status for this item.

Regional Association Reporting:

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting no comments were heard on this item:

No additional data or update was received by the Committee. The WWMA S&T Committee recommended withdrawal and encouraged the submitter to reintroduce the item when sufficient data is available.

Southern Weights and Measures Association

During the 2022 SWMA Annual Meeting open hearing the Committee heard no comments.

The SWMA S&T Committee recommended this item remain as a Developing Item.

Northeastern Weights and Measures Association

During the 2022 Interim Meeting, Ms. Diane Lee (NIST OWM) indicated the need for more data on more grains. This proposal is seeking to lower tolerances due to better technologies of UGMA meters. However, according to data submitted by North Carolina, grains are failing at the proposed tolerances. Ms. Lee requests more time so more states can submit data.

The Committee is recommending that this item retain a Developing status.

Central Weights and Measures Association

During the 2022 Interim Meeting Open Hearing Doug Musick, Kansas, recommended that item remain developing, while waiting on additional data. Mr. Ivan Hankins (Iowa) stated that 0.5% tolerance is fair and should move forward to Voting.

The CWMA S&T Committee recommended this remains a Developing Item to allow time to collect additional data.

GMA-23.1 N.1.3. Meter to Like-Type Meter Method Transfer Standards and Table T.2.2. Acceptance and Maintenance Tolerances Meter to Like-Type Meter Method

Source: NTEP Grain Analyzer Sector

Submitter's Purpose and Justification:

Clarify what is meant by the term Meter to Like-Type Meter in the Grain Moisture Meter Code 5.56(a).

During the 2017 Grain Analyzer Sector meeting there was a discussion on Meter to like-type meter testing and the definition of a like-type meter. There was discussion on test procedures for meter to like-type meter testing. It was noted that there may be only about two states using this type of test method and that it may be due to the cost of obtaining like-type meters to perform the test. A question was raised as to what is considered a like-type meter and it was explained that like-type meant that the make and model were the same. Suggestions were made to include a definition for like-type in NIST HB 44 and to consider documenting test procedures for meter to like-type meter testing.

During the 2018 grain analyzer sector meeting, the sector discussed industry and State weights and measures programs that used meter to like-type meter testing and master meter test methods. Kansas reported that reference meters are used to collect moisture results on samples. The samples are then taken to the field to compare to commercial field moisture meters. It was also reported that most State weights and Measures that use a meter-to-meter test method for testing field meters do not use a meter to like-type meter testing program which is specified in NIST HB44. The Perten representative reported that Perten uses three layers of master meters when calibrating their devices. It was noted that an analysis of the failure rate for meter-to-meter test methods should be investigated and an analysis of all the issues for meter-to-meter test methods is needed along with test methods for this type of field testing.

During the 2022 grain analyzer sector meeting the GA sector reviewed data from States and the NTEP laboratory and discussed what was considered like-type for this test method. Data collected in the NTEP program shows a bias between meters of different type, therefore adding an error to the test results when a

meter of unlike type is used to test another meter. The GA sector agreed that like-type based on the current data available must be interpreted as the same model family, as defined by the National Type Evaluation Program Certificate of Conformance. As such the Sector agreed to add language to Section 5.56(a) paragraphs N.1.3 and T.2.2. to clarify the definition of like type.

The submitter acknowledged that some states may be using a meter-to-meter test method that is not a meter to like-type meter method.

The submitter requested Voting status.

OWM Executive Summary for GMA-23.1 – N.1.3. Meter to Like-Type Meter Method Transfer Standards and Table T.2.2. Acceptance and Maintenance Tolerances Meter to Like-Type Meter Method
<p>OWM Recommendation: NIST supports with the proposed changes with suggestions for editorial changes to the proposal.</p> <ul style="list-style-type: none"> The title of the item should include the word "type" to be consistent with the term used in NIST HB 44. Thus, the title and references in the item should include the phrase "Meter to Like-Type Meter" rather than "Meter to Like-Meter." The title in our technical analysis and references in the body of the proposed item have been corrected to include the term "Like-Type." We suggest modifications to the changes made to the note in T.2.2. as follows: <p><u>NOTE: Like-type as described in paragraph N.1.3. See definition for like-type meter in N.1.3. (Added 20XX)</u></p>

Table 3. Summary of Recommendations							
GMA-23.1 N.1.3. Meter to Like-Type Meter Method Transfer Standards and Table T.2.2. Acceptance and Maintenance Tolerances Meter to Like-Type Meter Method							
	V	D	W	A	I	Notes*	Comments
Submitter							
OWM							
WWMA		✓					
SWMA	✓						
NEWMA		✓					
CWMA	✓						
NCWM							
	Letters of Support			Letters of Opposition		Notes	
Industry							
Manufacturers							
Retailers and Consumers							
Regulators							

Table 3. Summary of Recommendations							
GMA-23.1 N.1.3. Meter to Like-Type Meter Method Transfer Standards and Table T.2.2. Acceptance and Maintenance Tolerances Meter to Like-Type Meter Method							
	V	D	W	A	I	Notes*	Comments
<p>*Notes Key:</p> <ul style="list-style-type: none"> 1 – Submitted modified language 2 – Item not discussed 3 – No meeting held 4 – Not submitted on agenda 5 – No recommendation or not considered 							

Item Under Consideration:

Amend NIST Handbook 44 Grain Moisture Meters Code as follows:

N.1.3. Meter to Like-Type Meter Method Transfer Standards. – Properly standardized reference meters using National Type Evaluation Program approved calibrations shall be used as transfer standards. A reference meter shall be of the same type model family, as defined by the National Type Evaluation Program Certificate of Conformance, as the meter under test. Tests shall be conducted side-by-side using, as a comparison medium, grain samples that are clean and naturally moist, but not tempered (i.e., water not added).

(Added 2001) (Amended 20XX)

And

T.2.2. Meter to Like-Type Meter Method. – Maintenance and acceptance tolerances shall be as shown in Table T.2.2. Acceptance and Maintenance Tolerances Meter to Like-Type Meter Method. The tolerances shall apply to all types of grain and seed.

(Added 2001)

Table T.2.2. Acceptance and Maintenance Tolerances Meter to Like-Type Meter Method	
Sample Reference Moisture	Tolerance
Up to 22 %	0.5 % in moisture content

(Added 2001)

NOTE: See definition for like-type meter in N.1.3.

(Added 20XX)

NIST OWM Detailed Technical Analysis:

NIST supports with the proposed changes with suggestions for editorial changes to the proposal. These changes are provided below:

- The title of the item should include the word "type" to be consistent with the term used in NIST HB 44. Thus, the title and references in the item should include the phrase "Meter to Like-Type Meter" rather than "Meter to Like-Meter." The title in our technical analysis and references in the body of the proposed item have been corrected to include the term "Like-Type."
- We suggest modifications to the changes made to the note in T.2.2. as follows:

NOTE: Like-type as described in paragraph N.1.3. See definition for like-type meter in N.1.3.
(Added 20XX)

Regional Association Reporting:

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting no comments were heard on this item. The WWMA S&T Committee believes that this item has merit and recommended this item remain Developing to allow for input and adjustments. The WWMA S&T Committee also requested the submitter address the formatting of their proposal to meet NCWM standard editing requirements.

Southern Weights and Measures Association

No comments were received on this item during the 2022 SWMA Annual Meeting. The SWMA S&T Committee recommended this item move forward as a Voting Item.

Northeastern Weights and Measures Association

Ms. Diane Lee (NIST OWM) noted that questions came up as to what is considered "like-type" and if inspectors could use any and all models of a device listed on a Certificate of Conformance. In this situation "like-type" would mean model family. NIST has not made a full assessment on this item.

The Committee is recommending that this item be given a Developing status.

Central Weights and Measures Association

Mr. Loren Minnich (Kansas) stated that this clarifies which meter can be used in this application. He supports this item as Voting. Mr. Ivan Hankins (Iowa) supported as Voting.

The CWMA S&T Committee believes this item is fully developed and recommended Voting status.

MULTIPLE DIMENSION MEASURING DEVICES

MDM-22.1 D S.1.7. Minimum Measurement.

Source: Parceltool P/L

Submitter's Purpose and Justification:

Exempt mobile tape based MDMD devices from the 12D minimum measurement.

The 12 d minimum measurement is designed for instruments that use an internal rounding function to round the actual measurement up or down to the nearest value of d before being displayed. For measurement of 12 d, or less, the potential error in the measurement is considered too large and therefore the specification of the 12 d minimum measurement is in place.

Measurements below 12 d are commonplace when using a mobile tape (tape measure) type of device for determining measurements. An accepted practice for this type of device is for the Measurement to be rounded up to the nearest whole unit of measurement (e.g., 1 inch) before being used to calculate any charges.

The submitter requested that this be a Voting Item in 2022.

OWM Executive Summary for MDM-22.1 – S.1.7. Minimum Measurement.
<p>OWM Recommendation: Unless additional information to justify the proposed changes to the MDMD Code is provided to the Committee by the submitter (or submitter’s consultant), OWM recommends this item be withdrawn.</p> <ul style="list-style-type: none"> • This is the identical proposal that appeared in the S&T Committee’s 2019 agenda (as S&T Item MDM-2) and was withdrawn by the Committee in 2019. • The NCWM MDMD Work Group also reviewed the MDM-2 proposal during its spring 2019 meeting and recommended the item be withdrawn. • We have reviewed our comments and recommendations provided to the 2019 S&T Committee for S&T Item MDM-2 and still find them relevant today. Consequently, we provide them again with only few minor changes in our detailed analysis of this item included below. • There is no additional information provided in the justification section of this item in the Committee’s current agenda to explain the reason for resubmission or why the Committee should reconsider its earlier action to withdraw the item in 2019. • We raised all of the above points during the 2022 NCWM Interim Meeting and recommended the Committee withdraw this item. During that same meeting, however, Mr. Darrell Flocken (NCWM) requested the Committee maintain a Developing status based upon a request he had received from the submitter’s consultant who indicated the submitter wished to resurrect the item.

Table 3. Summary of Recommendations							
MDM-22.1 – S.1.7. Minimum Measurement.							
	V	D	W	A	I	Notes*	Comments
Submitter	✓						
OWM			✓				
WWMA			✓				
SWMA			✓				
NEWMA			✓				

Table 3. Summary of Recommendations							
MDM-22.1 – S.1.7. Minimum Measurement.							
	V	D	W	A	I	Notes*	Comments
CWMA			✓				
NCWM		✓					
	Letters of Support			Letters of Opposition			Notes
Industry	• Letter from CubeTape (08-10-2021)			• Letter from Mr. Suiter (06-27-2022)			
Manufacturers				• Letter from Mettler-Toledo (10-18-2022)			
Retailers and Consumers							
*Notes Key: 1 - Submitted modified language 2 - Item not discussed 3 - No meeting held 4 - Not submitted on agenda 5 - No recommendation or not considered							

Item Under Consideration:

Amend Handbook 44, Multiple Dimension Measuring Devices Code as follows:

S.1.7. Minimum Measurement. – Except for entries of tare **and mobile tape based MDMD devices**, the minimum measurement by a device is 12 d. The manufacturer may specify a longer minimum measurement. For multi-interval devices, this applies only to the first measuring range (or segment) of each measurement axis (length, width, and height).

(Amended 2017 **and 20XX**)

NIST OWM Detailed Technical Analysis:

The following was copied from OWM’s 2022 NCWM Annual Meeting analysis and remains unchanged for the 2023 NCWM Interim Meeting:

This very same proposal appeared in the S&T Committee’s 2019 agenda (as S&T Item MDM-2) and was withdrawn by the Committee in 2019. Additionally, the first two paragraphs included in the Committee’s current agenda beneath the heading “Original Justification,” are the very same two paragraphs contained in the Committee’s 2019 Interim Meeting Agenda in the Background Discussion section of the item. That is, there is no additional information provided in the justification section of this item in the Committee’s current agenda to explain the reason for resubmission or why the Committee should reconsider its earlier action to withdraw the item in 2019. OWM notes too that the NCWM MDMD work group also reviewed the MDM-2 proposal during its spring 2019 meeting and recommended the item be withdrawn.

We have reviewed our comments and recommendations provided to the 2019 S&T Committee for S&T Item MDM2 and still find them relevant today. Consequently, we submit them again (shown in the box

below to include a few minor changes that we've made) to the Committee as our analysis for the item "MDM-22.1" in the Committee's current agenda.

OWM recognizes there is a potential for introducing excessive error in measurements when they are performed using a process or instrument that does not provide a sufficient level of resolution in the measurement. Minimum measurement requirements are established in NIST Handbook 44 device codes based on the premise, "rounding of digital values and the allowable error in a device from the application of tolerance creates the potential for large errors at small measurements." This effect decreases proportionately as the measurement size is increased along with the number of increments used in the measurement. To put this principle into perspective as it relates to multiple dimension measuring devices (MDMDs), NIST Handbook 44 maintenance and acceptance tolerances applicable to MDMDs are plus or minus 1 division (See paragraph T.3. Tolerance Values). Considering this tolerance in perspective with this proposal, a 1-division error within a 12-division measurement (i.e., the minimum measurement currently permitted in accordance with paragraph S.1.7.) represents over 8 percent of the measurement value ($1 \div 12 = 0.083 \approx 8.3 \%$). If the measurement were to include 50 divisions (or increments), that same 1-division error represents only 2 percent of the measurement value ($1 \div 50 = 0.020$ or 2 %).

Compounding the potential for even greater error is the fact that MDMDs are generally used to measure hexahedron-shaped objects by determining values for length, width, and height, and then multiplying these values together to determine the cubic volume occupied by the object. Since there are three measurements needed to determine the volume, the error effect of using a device to make small measurements is multiplied threefold. For example, a 1-division plus error at a 12-division measurement of length, width, and height would result in over a 27 percent error in the volume measurement of the object being measured as illustrated in the table below.

Axis	Measurement (+ 1 d error)	Actual
Length	13 d	12 d
Width	13 d	12 d
Height	13 d	12 d
Volume	2197 x-unit ³	1728 x-unit ³
Difference:	$2197 \text{ x-unit}^3 - 1728 \text{ x-unit}^3 = 469 \text{ x-unit}^3$	
Measurement minus Actual		
Percent error calculation	$(469 \text{ x-unit}^3 \div 1728 \text{ x-unit}^3) \times 100 = 27.1 \%$	

Thus, given the potential that this proposal has for creating such very large measurement errors and the monetary impact those errors can have on commercial transactions, OWM does not believe this item should be advanced.

In addition, OWM also points out the following concerns relating to this item:

- A guiding principle in the development of HB 44 requirements is that the same requirements should apply to devices used in the same application, regardless of technology or design. The proposed change in this item violates the principle by proposing there be an exemption to one of the requirements in the MDMD code for a particular type of MDMD.
- The background/discussion pertaining to this item includes the statement that it is not unusual for measurements to be made of less than 12 divisions. If this is in fact the case, those using these

devices commercially to take such measurements are violating the minimum measurement requirement in HB 44. OWM would hope that the submitter of this item, knowing this to be true, would take necessary steps to educate users so that accurate measurements can be ensured. OWM believes that there may also be a problem caused by the use of a device with too large a division size for use in measuring small objects rendering that device unsuitable for the purpose intended. Another potential problem may be created when two devices with different division values are needed due to the wide linear range of the different axes needing to be measured.

- The background/discussion portion of this item also indicates an accepted practice for this type of device is for the measurement to be rounded up to the nearest whole division. OWM notes such rounding conflicts with the instructions provided on the Federal Express and United States Postal Service websites for determining DIM weight, that specify the measurements are to be rounded to the nearest inch.

The current 12 d minimum measurement specified in HB 44 is uniform with the same in OIML R 129. Thus, a change to HB 44 requirement would cause conflict with OIML requirements.

OWM's Comments and Recommendation for Item MDM-22.1 Copied from its 2019 Analysis of MDM-2

Summary of Discussions and Actions:

During Committee open hearings at the 2022 NCWM Interim Meeting, Mr. Rick Harshman (NIST OWM) reported this very same proposal had appeared in the S&T Committee's 2019 agenda (as S&T Item MDM-2) and was withdrawn by the Committee in 2019. Additionally, the first two paragraphs included in the Committee's current agenda beneath the heading "Original Justification," are the very same two paragraphs contained in the Committee's 2019 Interim Meeting Agenda in the Background Discussion section of the item. That is, there is no additional information provided in the justification section of this item in the Committee's current agenda to explain the reason for resubmission or why the Committee should reconsider its earlier action to withdraw the item in 2019. Mr. Harshman noted too that the NCWM MDMD work group also reviewed the MDM-2 proposal during its spring 2019 meeting and recommended the item be withdrawn. For these reasons, OWM recommends the item be withdrawn.

Mr. Darrell Flocken (NCWM) acknowledged he too was aware that the proposal is identical to the one that the Committee had withdrawn in 2019. He noted, however, that he had been contacted by a representative of the submitter and that this person had advised him the submitter desired to further pursue adoption of the proposal. Mr. Flocken indicated he expected new information to be made available to Committee from the submitter to provide better justification for it.

During the Committee's work session members of the Committee agreed to maintain the item on the Committee's agenda as a Developing Item to allow the submitter an opportunity to provide additional information that could justify the proposed changes.

Regional Association Reporting:

Western Weights and Measures Association

During the 2021 Annual Meeting Open Hearings the following comments were heard:

Mr. Russell Vires (Mettler Toledo) is opposed to the change proposed here. No reason to eliminate the minimum measurement.

The WWMA S&T Committee recommended that this item be assigned a Developmental status. The Committee recommended that the submitter provide data to support why the devices are unable to meet the 12-division requirement. The Committee also recommended that the submitter consult the MDMD Working Group.

During open hearings, no comments were heard on this item. No additional data or update was received by the Committee.

The WWMA S&T Committee recommended that this item be withdrawn.

Southern Weights and Measures Association

During the 2021 Annual Meeting Open Hearings, Mr. Russ Vires (Mettler Toledo) requested that this item be withdrawn because the justification was invalid.

This Committee recommended this item be Withdrawn due to having no justification provided for the change.

The following comments were received during the 2022 SWMA Annual Meeting:

Dr. Curran (Florida) stated that this item was not needed.

The SWMA S&T Committee recommended this item be Withdrawn.

Northeastern Weights and Measures Association

During the 2021 Interim Meeting Open Hearing the following comments were heard.

Mr. Rick Harshman (NIST OWM) commented that this is a new item and members of NIST OWM's LMDP have not had opportunity to review/consider it. There's little information provided in the background/discussion of this item. If the device has digital indication, by rounding all values up as is specified in the background/discussion, the device would fail to comply with HB 44 paragraph G-S.5.2.2.(c).

Mr. Lou Sakin (Hopkinton/Northbridge, Massachusetts) commented that this item is in-need of further development.

The NEWMA Specifications and Tolerances Committee recommended that this item be given Developing Status.

During the 2022 Annual Meeting Open Hearings the following comments were heard:

Mr. Russ Vires (SMA) rose to oppose the item. He commented that the justification provided by the submitter does not identify issue that is to be resolved. Mr. Vires suggested that the submitter work with MDM Work Group for a solution and referenced the Work Group meets in May and will be discussing this proposal.

NIST OWM Analysis
2023 NCWM Interim S&T Agenda Items
1/5/2023

After hearing comments from the floor, the Committee recognized the need to further develop this item and recommended the item retain Developing status.

During the 2022 Interim Meeting Open Hearings the following comments were heard:

Ms. Diane Lee (NIST OWM) noted that this item has been on the agenda before and NIST OWM recommended withdrawing.

Mr. Jason Flint (New Jersey) indicated that in the past, the submitter has not been available to answer questions regarding this proposal, and he recommended that the item be withdrawn.

After hearing comments from the floor, the Committee does not believe that this item has merit. The Committee is recommending that this item be Withdrawn.

Central Weights and Measures Association

During the 2021 Interim Meeting Open Hearing the Committee heard no comments from the floor.

CWMA S&T Committee has no recommendation for this item.

During the 2022 Annual Meeting Open Hearings, the Committee received the following comments:

Mr. Russ Vires (SMA) - the SMA opposes this item. The justification provided by the submitter does not adequately identify the issue this item is attempting to resolve, and why mobile tape-based MDMD devices should be exempted compared to all other MDMD devices. The SMA recommended that the submitter work with the MDMD Work Group to develop a suitable solution to this issue.

The CWMA S&T Committee recommends this item to be withdrawn.

During the 2022 Interim Meeting Open Hearing the following comments were heard from the floor:

Mr. Loren Minich (Kansas): withdraw.

The CWMA S&T Committee recommended this item be withdrawn.

SMA

During the 2021 Fall Meeting the SMA opposed this item. The justification provided by the submitter does not adequately identify the issue this item is attempting to resolve, and why mobile tape-based MDMD devices should be exempted compared to other MDMD devices. The SMA recommended that the submitter work with the MDMD Work Group to develop a suitable solution to this issue.

During the 2022 Spring Meeting the SMA opposed this item. The rationale was the same as during the 2021 Fall Meeting.

During the 2021 Fall Meeting the SMA opposed this item. The rationale was the same as during the 2021 Fall Meeting and the 2022 Spring Meeting. The SMA recommended that the submitter work with the MDMD Work Group to develop a suitable solution to this issue, otherwise remove it.

OTH – Other Items

OTH-16.1 D Electric Watthour Meters Code under Development

Source: NIST Office of Weights and Measures

Submitter’s Purpose and Justification:

- 1) Make the weights and measures community aware of work being done within the NIST U.S. National Work Group (USNWG) on Electric Vehicle Fueling and Submetering to develop proposed requirements for electric watthour meters used in submeter applications in residences and businesses;
- 2) Encourage participation in this work by interested regulatory officials, manufacturers, and users of electric submeters.
- 3) Allow an opportunity for the USNWG to provide regular updates to the S&T Committee and the weights and measures community on the progress of this work;
- 4) Allow the USWNG to vet specific proposals as input is needed.

OWM Executive Summary for OTH-16.1 – Electric Watthour Meters Code Under Development

<p>OWM Recommendation: Although, the EWG SG is open to discussion on points addressed in the OWM detailed technical analysis we agree with a Voting status for this item.</p>
--

- | |
|---|
| <ul style="list-style-type: none">● Over the past several years, has been developing a proposed NIST Handbook 44 code for EWH-type meters.<ul style="list-style-type: none">○ The SG held eighteen meetings in 2021 and twelve meetings in 2022 in addition to meetings of small Task Groups focused on specific issues.● This item has been on the S&T Committee’s agenda since 2016 as a Developing Item to allow the USNWG to inform the weights and measures community of progress on the draft code.● The EWH SG appreciates the Committee’s willingness to maintain the item on the agenda as a mechanism for and to encouraging input and participation from those interested in the draft code and associated work.● The EWH SG is pleased to submit a draft NIST HB44 code for “Non-Utility Electricity Measuring Systems” for consideration at the 2023 NCWM Interim Meeting.● The EWH SG submitted a draft code to the S&T Committee Chair on November 12, 2022, and this draft appears in the Committee’s 2023 NCWM Publication 15 agenda.● The EWH SG believes the draft code is ready for consideration as a voting item and asks the Committee to consider assigning this item Voting status. |
|---|

OWM Executive Summary for OTH-16.1 – Electric Watthour Meters Code Under Development	
<ul style="list-style-type: none"> • As noted in OWM’s more detailed analysis below, there are several areas of the code in which the Subgroup is continuing to develop some additional language; however, this work need not delay consideration of the Code. These areas include the following paragraphs: <ul style="list-style-type: none"> ○ S.1.4.2. Test Output <ul style="list-style-type: none"> ▪ The Subgroup would particularly like input on this paragraph. Though the majority of members supported the proposed language, regulatory members of the subgroup disagreed with the proposed language. ○ Table S.3.2.3.b., Note 7 <ul style="list-style-type: none"> ▪ The work group is considering a future proposal to add a corresponding User Requirement. ○ N.3. Minimum Test Duration <ul style="list-style-type: none"> ▪ The subgroup is considering alternative language to describe full and light load tests. ○ N.5.(a) Test of NUEMS <ul style="list-style-type: none"> ▪ The subgroup is considering moving this paragraph from the Notes section and placing it into the User Requirement section. • Although the most recent draft of the code was not available until after the Fall 2022 regional meetings, the regions and others will have adequate opportunity to review and comment on the draft in the period between the Interim and Annual Meetings. • Thus, the EWH SG believes that designating this item with a Voting status is still an appropriate course of action. 	

Table 3. Summary of Recommendations							
OTH-16.1 – Electric Watthour Meters Code under Development							
	V	D	W	A	I	Notes*	Comments
Submitter							• Initial Draft Code for Non-Utility Electricity-Measuring Systems (09-01-2021)
OWM							
WWMA		✓					
SWMA		✓					
NEWMA		✓					
CWMA		✓					
NCWM							

Table 3. Summary of Recommendations							
OTH-16.1 – Electric Watthour Meters Code under Development							
	V	D	W	A	I	Notes*	Comments
	Letters of Support		Letters of Opposition		Notes		
Industry							
Manufacturers							
Retailers and Consumers							
*Notes Key: 1 - Submitted modified language 2 - Item not discussed 3 - No meeting held 4 - Not submitted on agenda 5 - No recommendation or not considered							

Item Under Consideration:

This item was added to the NCWM S&T Committee’s agenda as a “Developing Item” to allow a forum in which progress of the USNWG can be reported as it develops legal metrology requirements for electric watthour meters and continues work to develop test procedures and test equipment standards.

Mrs. Tina Butcher (NIST OWM), Chair of the USNWG on Electric Refueling & Submetering, has continued to provide regular updates to the Committee on this work and to encourage input and participation from the weights and measures community since the addition of this item to the Committee’s agenda in 2016. See the Committee’s 2016 through 2021 Final Reports and 2022 Interim Report for details.

The SG is nearing completion of a draft NIST Handbook code for “Non-Utility Electricity-Measuring Systems.” Work continues on a few sections of the draft code; however, the SG would like to begin getting feedback from the weights and measures community on the draft code. The SG requested that the Committee post an early draft of the code on the NCWM website.

The draft code was posted in Fall 2021 and is available for download at <https://www.ncwm.com/publication-15>.

The Subgroup asks the NCWM S&T Committee to consider (and the regional associations to support) the following.

1. Permitting the item to remain in a Developing status on its agenda to allow for further development and input on the draft Handbook 44 Code.
2. Permitting the SG to post the draft code along with other supporting documents on the NCWM S&T Committee’s web page. Areas under review and development by the SG will be noted in yellow highlighted text.
3. Encouraging weights and measures officials and industry to study the draft code and provide input to the SG, including proposed changes along with rationale for such changes and any indication of support or opposition.

NIST OWM Analysis
2023 NCWM Interim S&T Agenda Items
1/5/2023

The SG requested comments be submitted to the SG Chair or Technical Advisor by the end of March 2022. The above approach was intended to allow the SG the opportunity to solicit input and incorporate comments from the weights and measures community on the draft code in advance of proposing it for a vote more broadly.

The SG has continued to meet and revise specific areas of the code and still hopes to finalize a draft for submission in the 2022-2023 NCWM cycle.

The Electric Watthour Meter Subgroup (EWH SG) of the USNWG on Electric Vehicle Fueling & Submetering has held multiple in-person and web meetings since the 2017 NCWM Annual Meeting. This SG has held 15 virtual meetings since January 2021 focused on finalizing a draft code on “Non-Utility Electricity-Measuring Systems.”

Those interested in participating in this work are asked to contact SG Chair, Ms. Lisa Warfield, or Technical Advisor, Mrs. Tina Butcher. Contact information is included in the “Background” section of this item.

NIST OWM Detailed Technical Analysis:

- The USNWG on Electric Vehicle Fueling & Submetering is divided into two subgroups; one to address electric vehicle fueling and one to address utility-type watt hour meters.
- This item addresses work being done by the latter subgroup, the “Electric Watthour Meter Subgroup (EWH SG).”
- Over the past several years, has been developing a proposed NIST Handbook 44 code for EWH-type meters.
 - The SG held eighteen meetings in 2021 and twelve meetings in 2022 in addition to meetings of small Task Groups focused on specific issues.
- This item has been on the S&T Committee’s agenda since 2016 as a Developing Item to allow the USNWG to inform the weights and measures community of progress on the draft code.
- The EWH SG appreciates the Committee’s willingness to maintain the item on the agenda as a mechanism for and to encouraging input and participation from those interested in the draft code and associated work.
- The EWH SG is pleased to submit a draft NIST HB44 code for “Non-Utility Electricity Measuring Systems” for consideration at the 2023 NCWM Interim Meeting.
- The EWH SG submitted a draft code to the S&T Committee Chair on November 12, 2022, and this draft appears in the Committee’s 2023 NCWM Publication 15 agenda.
- The EWH SG believes the draft code is ready for consideration as a voting item and asks the Committee to consider assigning this item “Voting” status.
- There are some areas of the code in which the Subgroup is continuing to develop some additional language; however, this work need not delay consideration of the Code.

- The Subgroup would also like to call attention to some specific areas of the Code as noted below and is open to suggested changes by the Committee as comments are received on this item.
 - Paragraph S.1.4.2. Test Output.
 - The Subgroup voted several times on the language in this paragraph and the majority of members supported this language. However, the regulatory members of the Subgroup disagreed with this language. Thus, the Subgroup would especially appreciate review and comments on this paragraph.
 - Table S.3.2.3.b., Note 7:
 - The Subgroup is considering the development of an accompanying new User Requirement related to the marking of the service voltage. This would be presented as a future recommendation to the draft code.
 - N.3. Minimum Test Duration:
 - The Subgroup is considering alternative language for this paragraph that would include more specificity regarding the full and light load tests. The Subgroup will offer any such recommendations for changes to the Committee to consider along with any other comments the Committee might receive from NCWM members.
 - N.5.(a) Test of NUEMS:
 - The Subgroup is considering moving N.5.(a) out of the Notes section and moving it to a User Requirement (with corresponding changes to present it as a User Requirement) as follows and is interested in input on this suggestion:
 - UR.X.X. Each NUEMS submitted for testing shall have all necessary components assembled, connected, and configured as intended for use. Components may include, but are not limited to, meter, sensor(s), indicator(s), etc.
- All the regional associations reviewed this item at their fall meetings and recommended a Developing status; however, this assessment was based on the prior version of the draft code and comments received up to that point.
- Although the most recent draft of the code was not available until after the Fall 2022 regional meetings, the regions and others will have adequate opportunity to review and comment on the draft in the period between the Interim and Annual meetings.
- Thus, the EWH SG believes that designating this item with a Voting status is still an appropriate course of action.
- Those interested in participating in this work please contact:
 - Subgroup Chair, Ms. Lisa Warfield (NIST OWM)
Email (lisa.warfield@nist.gov) or phone (301) 975-3308
 - Technical Advisor, Mrs. Tina Butcher (NIST OWM)

Email (tbutcher@nist.gov) or phone (301) 975-2196.

NCWM 2022 Interim Meeting

Mr. Matt Douglas (California – DMS) stated that California supports the development of this item but has concerns about identity marking requirements being on a separate document. Also, the devices should be easy to test before and after instillation. This device should allow for electronic data logger. Ms. Juana Williams (NIST OWM) commented that the subgroup had provided a draft code that is on the website. Ms. Williams requested comments be submitted to Mrs. Tina Butcher (NIST OWM) or Ms. Lisa Warfield (NIST OWM) by March 22, 2022. Ms. Williams stated these comments will be used to provide and updated draft for the 2022-2023 submission cycle and the item remain in developing status. The Committee agreed that the item be given a Developing status.

NCWM 2022 Annual Meeting

The Committee heard an update from Mrs. Tina Butcher (NIST OWM), Technical Advisor to the NIST USNWG Electric Watthour Meter Sub Group (SG), who highlighted the points in the Executive Summary to this item. Mrs. Butcher acknowledged this item has been on the agenda for several years, during which time the SG has been continually working to develop a draft code for submission to the NCWM for consideration. The SG shared a draft with the Committee in August 2021 and asked that it be posted to the NCWM website. The SG had identified specific sections of the draft code which was still being refined by the SG. The SG had asked that those interested in this work review the remainder of the code and provide input that would allow the SG an opportunity to modify the draft to reflect their comments prior to submitting a final recommendation to the NCWM.

Mrs. Butcher reported that the SG is diligently continuing to work on this item, holding eighteen meetings in 2021 and seven meetings in 2022. She thanked those who provided comments during the regional and national meetings, noting in particular the Committee heard from California Division of Measurement Standards who noted that additional work is needed on the marking requirements. She noted that California and others have raised questions about the provision that would allow required markings to appear on a separate document and asked for clarifications on how this would work. Other concerns raised included making sure that testing capabilities are readily achievable both before and after installation and refining requirements for audit trail requirements to ensure that hard copies of any event loggers are available to the inspector. The SG appreciates this input and is working to resolve the remaining areas of concern identified and hopes present a draft to the NCWM in the coming fall.

The Committee agreed to retain this item on its agenda with a Developing status while the SG continues its work.

Regional Association Reporting:

Western Weights and Measures Association

During the 2022 WWMA Annual Meeting no comments were heard on this item.

During open hearings, no comments were heard on this item. The WWMA S&T Committee recommended that this item should remain Developing to allow the USNWG to continue development of the model code.

Southern Weights and Measures Association

The following comments were received during the 2022 SWMA Annual Meeting:

Ms. Lisa Warfield (NIST OWM) stated the workgroup planned to have an item in NCWM Publication 15 before the 2023 NCWM Interim Meeting.

The SWMA S&T Committee recommended this item remain as a Developing Item.

Northeastern Weights and Measures Association

At the 2022 Interim Meeting Ms. Lisa Warfield (NIST OWM) commented that NIST is still working on this item. An update will be available for the NCWM Interim Meeting.

The Committee is recommending that this item retain a Developing status. After hearing comments from the floor, the Committee recognized the need to further develop this item and recommended the item retain Developing status.

Central Weights and Measures Association

At the 2022 Interim Meeting no comments were heard from the floor.

The CWMA S&T Committee recommended this as a Developing Item.

Block 1 Items (B1) Minimum Draft Size When Using a Field Standard Meter

B1: LMD-23.1 N.3.5. Wholesale Devices

B1: VTM-23.1 N.3. Test Drafts

B1: MLK-23.1 N.3. Test Drafts

Source: Endress+Hauser Flow USA, Inc.

Submitter's Purpose and Justification:

Define the minimum test draft size when using a field standard meter.

The proposal describes the minimum quantity test draft size, using a field standard meter, when testing a Liquid-Measuring Device.

This proposal to amend the 3.30 Liquid-Measuring Devices Code, 3.31 Vehicle Tank Meters Code, 3.35 Milk Meters Code, and provides a clear recommendation for the test draft size using a field standard meter which is significantly less than the draft size needed for fixed volume provers. The use of field standard meters offers accurate traceable commissioning and enforcement testing of metering systems in a fraction of the time needed when using fixed volume proving standards or scales.

Test drafts recommendations using field standard meters (master meters) are presently described in code sections 3.34. Cryogenic Liquid-Measuring Devices, 3.38 Carbon Dioxide Liquid-Measuring Devices, and 3.39. Hydrogen Gas-Measuring Devices.

There are similar proposals to amend Mass Flow Meter and Liquefied Petroleum Gas codes to include field standard meters and describe the necessary test draft size.

The devices used as field standard meters are calibrated to traceable national standards and the process and equipment used for the calibration has been audited by nationally accredited organizations. Documentation supporting the calibration and validation is supplied with the devices.

The American Petroleum Institute and the American Gas Association have standard documents describing the use of master meters.

State Directors have stated that the addition of language for field standard meters (master meters) is useful for them to support adoption in their jurisdictions.

There has been opposition to the proposed Mass Flow Meter and Liquid Petroleum Gas codes Test Draft amendments for field standard meters. Those cite that Appendix A gives the Director authority to choose testing standards. They have initiated several proposals to amend language in Appendix A. There is a proposal to add language to the General Code. They have remained silent regard to the description of test drafts and master meters in the other sections of Handbook 44 and the confusing references in Appendix D definitions.

NIST has not written a 105 Series standard for field standard meters (master meters). In 2018, NIST began conducting a long-term test program of master meters.

Requested Status by Submitter: Voting Item

OWM Executive Summary for Block 1 Items (B1) – Minimum Draft Size When Using a Field Standard Meter

OWM Recommendation: NIST OWM believes that test draft criteria should be non-technology specific when addressed in NIST HB44. It is suggested that other proposal on the agenda may be a better approach for current changes to the test draft sections in Handbook 44. We encourage that future consideration be given to removing the test draft sections from the individual codes and placing them in the General Code as a suitability requirement with further guidance on selecting an appropriate test draft maybe in the Fundamental Considerations and/or EPOs.

- The submitter of this item is the same submitter of Items LPG-15.1 and MFM-15.1 which are changes to the test draft paragraphs in the LPG and MFM Codes.
- The items in Block 1 are the same proposal made in Items LPG-15.1 and MFM-15.1, but the proposals are for the test draft paragraphs in different sections of the Handbook (LMD-23.1 N.3.5. Wholesale Device, VTM-23.1 N.3. Test Draft, MLK-23.1 N.3. Test Draft).
- The purpose statement for Block 1 items which is “to define the minimum test draft size when using a field standard meter” are different than LPG-15.1 and MFM-15.1 likely due to comments received concerning these items.
- The test draft items on the 2022 Interim agenda are seeking to establish test draft criteria for various test methods in use for testing commercial devices. The Test draft items on the 2022 Interim Agenda are LMD-23.4, LPG-15.1, MFM-15.1, Block 1, and Block 5.
- LPG-15.1, MFM-15.1, and Block 1 items are proposals to add a separate paragraph to the code to address the test method using field standard meters. As noted in other comments to these item, NIST HB 44 was written to be non-technology specific so that requirements in the handbook would

OWM Executive Summary for Block 1 Items (B1) – Minimum Draft Size When Using a Field Standard Meter

apply to any device or method used to test a device. This prevents separate code requirements for the different test methods or devices under test.

- There are three items on the 2022 Interim agenda that are proposals to change the same LMD paragraph N.3.5 Wholesale Devices which are:
 - LMD-23.4 N.3.5. Wholesale Devices,
 - B1: LMD-23.1 N.3.5 Wholesale Devices, and
 - B5: N.3.5. LMD-23.2 Wholesale Devices.

Since two of the above items are not proposal to add another paragraph to N.3.5 and are in-line with creating requirements that are non-technology specific by editing the existing paragraph such that the paragraph is more encompassing of other test methods, we encourage that the submitters of these items, LMD-23.4 N.3.5 and B5: LMD-23.2 N.3.5. work together to combine the changes that are being proposed to the same paragraph, N.3.5. Wholesale Devices. If the submitters are in agreement with combining these changes a proposed change for the combined items LMD-23.4 N.3.5 Wholesale Device and B5: N.3.5. LMD-23.2 Wholesale Device is provided for consideration:

N.3.5. Wholesale Devices – The total delivered quantity for any required accuracy test shall be equal to, or is recognized as being representative of, a volume equivalent to at least the amount delivered by the device in one minute at its the meter's maximum discharge rate and shall in no case be less than 200 L (50 gal).

(Amended 1987, ~~and~~ 1996, and 2023)

- There are two items on the 2022 Interim Meeting Agenda that are proposals for changes to the same paragraph, VTM code N.3. Test draft which are:
 - B1: VTM-23.1 N.3. Test Drafts
 - B5: VTM-23.2 N.3. Test Draft

Since B5 VTM-23.2. N.3. Test Drafts adds clarification to the existing paragraph we encourage the committee to look at the proposed change in B5: VTM-23.2. N.3. Test Draft

- NIST OWM has similar comments for Block 1 items as is provided for LPG-15.1, MFM-15.1 since the proposals in Block 1 are the same proposals in LPG-15.1 and MFM-15.1, that add a separate paragraph for N.3 Test Drafts. As mentioned, in other comment although the purpose statement has changed for Block 1 items there are still concerns with providing different requirements for test draft based on different test method and confusion this may cause and number of paragraphs that will be added based on different technology.
- Technology will continue to change and evolve, and we will need to respond to the number of changes, such as the different standards that will be in use, and the factors associated with different technologies. We will need to ensure an appropriate test draft is selected so that the errors of test method and device under test do not contribute greatly to the test of the device. Coupled with what is already in the fundamental considerations for responsibility for selecting a test standard and what is being proposed in Items Gen-23.1 and Block 8, we believe a solution may be to add a general code requirement with additional guidance in the fundamental consideration or EPOs for Test draft

OWM Executive Summary for Block 1 Items (B1) – Minimum Draft Size When Using a Field Standard Meter
and consider removing Test Draft from the individual codes and addressing it in the general code in test notes as a suitability requirement.

Table 3. Summary of Recommendations							
Block 1 Items (B1) – Minimum Draft Size When Using a Field Standard Meter							
	V	D	W	A	I	Notes*	Comments
Submitter							
OWM							
WWMA			✓				
SWMA	✓						
NEWMA			✓				
CWMA	✓						
NCWM							
	Letters of Support		Letters of Opposition			Notes	
Industry							
Manufacturers			Comments from Seraphin (06-29-2018) Comments from Seraphin (07-31-2018) Comments from Seraphin (07-31-2018) Comments from Weights and Measures Consulting and Seraphin Test Measure Co. (01-13-2021)				
Retailers and Consumers						Comments from Ross Andersen (12-12-2018)	
Regulators							
*Notes Key: 1 – Submitted modified language 2 – Item not discussed 3 – No meeting held 4 – Not submitted on agenda 5 – No recommendation or not considered							

B1: LMD-23.1 N.3.5. Wholesale Devices

Item Under Consideration:

Amend Handbook 44, Liquid Measuring Devices Code as follows:

N.3.5 Wholesale Devices

N.3.5.1 Wholesale Devices – The delivered quantity should be equal to at least the amount delivered by the device in one minute at its maximum discharge rate and shall in no case be less than 200 L (50 gal).

N.3.5.2. Field Standard Meter Test. – The minimum quantity for any test draft shall be equal to or greater than the amount delivered in one minute at the flow rate being tested. (Added 20XX, Nonretroactive as of January 1, 20XX)

B1: VTM-23.1 N.3. Test Drafts

Item Under Consideration:

Amend Handbook 44, Vehicle Tank Meters Code as follows:

N.3. Test Drafts

N.3.1. Test Drafts - The delivered quantity should be equal to at least the amount delivered by the device in 1 minute at its maximum discharge rate and shall in no case be less than 180 L (50 gal) or 225 kg (500 lb).

N.3.2. Field Standard Meter Test. – The minimum quantity for any test draft shall be equal to or greater than the amount delivered in one minute at the flow rate being tested. (Added 20XX) (Added 20XX, Nonretroactive as of January 1, 20XX)

B1: MLK-23.1 N.3. Test Drafts

Item Under Consideration:

Amend Handbook 44, Milk Meters Code as follows:

N.3. Test Drafts

N.3.1. Test Drafts - The delivered quantity should be equal to at least the amount delivered by the device in one minute at its maximum discharge rate, and shall in no case be less than 400 L or 400 kg (100 gal or 1 000 lb).

N.3.2. Field Standard Meter Test. – The minimum quantity for any test draft shall be equal to or greater than the amount delivered in one minute at the flow rate being tested. (Added 20XX) (Added 20XX, Nonretroactive as of January 1, 20XX)

NIST OWM Detailed Technical Analysis:

The submitter of this item is the same submitter of Items LPG-15.1 and MFM-15.1 which are changes to the test draft paragraphs in the LPG and MFM Codes.

The items in Block 1 are the same proposal made in Items LPG-15.1 and MFM-15.1, but the proposal are to the test draft paragraphs in different sections of the Handbook which are LMD-23.1 N.3.5. Wholesale Device, VTM-23.1 N.3. Test Draft, MLK-23.1 N.3. Test Draft. The purpose statement for Block 1 items which is “to define the minimum test draft size when using a field standard meter” are different than LPG-15.1 and MFM-15.1 likely due to comments received concerning these items.

The test draft items on the 2022 Interim agenda are seeking to establish test draft criteria for various test methods in use for testing commercial devices. The Test draft items on the 2022 Interim Agenda are LMD-23.4, LPG-15.1, MFM-15.1, Block 1, and Block 5.

- LPG-15.1, MFM-15.1, and Block 1 items are proposals to add a separate paragraph to the code to address the test method using field standard meters. As noted in other comments to these item, NIST HB 44 was written to be non-technology specific so that requirements in the handbook would apply to any device or method used to test a device. This prevents separate code requirements for the different test methods or devices under test.
- There are three items on the 2022 Interim agenda that are proposals to change the same LMD paragraph N.3.5 Wholesale Devices which are:
 - LMD-23.4 N.3.5. Wholesale Devices,
 - B1: LMD-23.1 N.3.5 Wholesale Devices, and
 - B5: LMD-23.2 N.3.5. Wholesale Devices.

Since two of the above items are not proposal to add another paragraph to N.3.5. and are in-line with creating requirements that are non-technology specific by editing the existing paragraph such that the paragraph is more encompassing of other test methods, we encourage that the submitters of these items, LMD-23.4 N.3.5. and B5: LMD-23.2 N.3.5. work together to combine the changes that are being proposed to the same paragraph, N.3.5. Wholesale Devices. If the submitters are in agreement with combining these changes a proposed change for the combined items LMD-23.4 N.3.5 Wholesale Device and B5: N.3.5. LMD-23.2 Wholesale Device is provided for consideration:

N.3.5. Wholesale Devices – The **total** delivered quantity **for any required accuracy test shall** be equal to, **or is recognized as being representative of, a volume equivalent to** at least the amount delivered by the device in one minute at **its the meter’s** maximum discharge rate **and shall in no case be less than 200 L (50 gal).**

(Amended 1987, ~~and~~ 1996, **and 2023**)

- There are two items on the 2022 Interim Meeting Agenda that are proposals for changes to the same paragraph, VTM code N.3. Test draft which are:
 - B1: VTM-23.1 N.3. Test Drafts
 - B5: VTM-23.2 N.3. Test Draft

Since B5 VTM-23.2. N.3. Test Drafts adds clarification to the existing paragraph we encourage the Committee to look at the proposed change in B5: VTM-23.2. N.3. Test Draft.

- NIST OWM has similar comments for Block 1 items as is provided for LPG-15.1, MFM-15.1 since the proposals in Block 1 are the same proposals in LPG-15.1 and MFM-15.1, that add a separate paragraph for N.3 Test Drafts. As mentioned, in other comment although the purpose statement has changed for Block 1 items there are still concerns with providing different requirements for test draft based on different test method and confusion this may cause and number of paragraphs that will be added based on different technology.

Technology will continue to change and evolve, and we will need to respond to the number of changes, such as the different standards that will be in use, and the factors associated with different technologies. We will need to ensure an appropriate test draft is selected so that the errors of test method and device under test do not contribute greatly to the test of the device. Coupled with what is already in the fundamental considerations for responsibility for selecting a test standard and what is being proposed in Items Gen-23.1 and Block 8, we believe a solution may be to add a general code requirement with additional guidance in the fundamental consideration or EPOs for Test draft and consider removing Test Draft from the individual codes and addressing it in the general code in test notes as a suitability requirement.

Regional Association Reporting:

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting Mr. Michael Keilty (Endress+Hauser) referred to previous comments regarding LPG-15.1 and MFM-15.1 items. He stated that the language is similar to the test draft language. The goal is to aid the States and this one is good. This applies to fuels and neck provers. Many systems are going unchecked due to the rarity of dedicated provers for milk for example. He recommended that Block 1 items be passed forward as a Voting Item.

Mr. Robert Murnane (Seraphin Test Measure Company) stated that he was opposed to this for the same reasons as stated in the discussion about LPG-15.1 and MFM-15.1 items. He did not think that we need a different code for a mass flow or LPG meter. He recommended changing N.3. to include test drafts “one minute at the flow rate being tested” .

During open hearings, the Committee heard conflicting comments about these items. The Committee takes the positions that the purpose of this item is better addressed in Block 8. WWMA S&T Committee recommended that this item be withdrawn with the recommendation that the submitter combine their efforts with the submitters of Block 8.

Southern Weights and Measures Association

The following comments were received during the 2022 SWMA Annual Meeting: Mr. Keilty, (Endress+Hauser) stated that this block contained the same changes as LPG 15.1, which has already been approved. He also stated that electronic devices have changed a lot since 1989, and they still comply with the Fundamental Considerations.

Mr. Searles (American Petroleum Institute) stated that he supported this item moving forward as Developing, and that devices should not be pointed out separately.

Mr. Murnane (Seraphin) stated that he supported this moving forward as a Developing Item.

Mr. Nicholas Suemnick (Marathon Petroleum) stated that he supported this moving forward as Developing.

Mr. Prince (Florida) stated that the membership needs to make a decision on how we want to handle this issue.

The SWMA S&T Committee recommended this item move forward as a Voting Item.

Northeastern Weights and Measures Association

During the 2022 Interim Meeting Mr. Michael Keilty (Endress Hauser) reported that the language in this item is similar to LPG-15.1 and MFM-15.1 Mr. Henry Opperman (Weights & Measures Consulting) has concerns that are related to the test notes that he believes have not been thought through. Will any meter that passes Fundamental Considerations be used? Mr. Opperman noted that a normal test of a LMD includes test of air eliminator and the test of a VTM includes a product depletion test, which would not be able to be performed. Any standard has to provide reproducible results under field conditions. Mr. Bob Murnane (Seraphin Test Measure) pointed out that some meters already meet 1/3 requirement and can already be used as a field standard. Ms. Diane Lee (NIST OWM) noted that the members have already withdrawn similar items that contain this same language. Ms. Tisha Arriaga (Marathon Petroleum) commented that she is not in favor of the proposal and doesn't want to keep creating a list of test devices. Would like to see them in one simple statement. Mr. Michael Keilty (Endress Hauser) commented that fixed volume provers are different than master meters and SVP, with separate benefits or disadvantages. Mr. Keilty stated that it is more important and beneficial to list different types of technologies and performance requirements. Mr. Lou Sakin (Holliston, MA) requested that the item be withdrawn. Mr. Prentiss Searles (API) commented that he is not in favor of the proposal. Mr. Jason Flint (New Jersey) noted the language in this proposal mirrored LPG-15.1 and MFM-15.1, which were already recommended for withdrawal by the body. Mr. Flint suggested that those items be merged into this Block or this Block be withdrawn as well.

After hearing comments from the floor, the Committee does not believe this item has merit. The Committee recognizes that the language in this item is the same as other items that have been previously recommended for withdrawal. The Committee recommended that this item be withdrawn.

Central Weights and Measures Association

During the 2022 Interim Meeting Mr. Michael Keilty (Endress+Hauser) stated that these three items were initially submitted separately, but then blocked together. All submittals for each item have the same language, which is the same language from LPG-15.1 and MFM-15.1 that was approved by CWMA in May. Nebraska has been using a similar system for years and has positive feedback related to speed of testing. The same language was previously accepted by multiple regional associations. Provers for milk meters are getting harder to find and is affecting business owners. Move to Voting status.

The CWMA S&T Committee believes this item is fully developed and recommends Voting status. The Committee also believes that LPG-15.1 and MFM-15.1 should be added to Block 1.

Item Block 2 (B2) Define True Value for Use in Error Calculations

- | | | |
|----------------|---|--|
| B2: A SCL-20.3 | A | S.5.4. Relationship of Minimum Load Cell Verification Interval to the Scale Division |
| B2: A SCL-20.4 | A | Table 3. Parameters of Accuracy Classes. |
| B2: A SCL-20.5 | A | Table S.6.3.a. Marking Requirements, Note 3. |
| B2: A SCL-20.6 | A | T.N.1.2. Accuracy Classes and T.N.1.3. Scale Division. |
| B2: A SCL-20.7 | A | Table 7. Maintenance Tolerances |

B2: A SCL-20.8 A Table 8. Recommended Minimum Load

NOTES:

1. At the 2020 NCWM Interim Meeting the Committee agreed that GEN-20.1, SCL-20.1 and SCL-20.2 should be removed from Block 2 and given individual consideration. The items included in this Block 2 are SCL-20.3, SCL-20.4, SCL-20.5, SCL-20.6, SCL-20.7, and SCL-20.8.
2. While this item was carried over from the 2020 Interim Meeting, it was not a Voting Item and therefore not discussed during the continuation of the 2020 Annual Meeting. Instead, it was placed on the 2021 Interim Meeting's agenda and was discussed during that meeting.

Source: Mr. Ross Andersen (Retired)

Submitter's Purpose and Justification:

This proposal has four parts:

1. Clarify the concepts in determining error in verification,
2. Correct Code references to ensure correct reference to either e or d, as appropriate,
3. Correct Code references regarding issues of scale suitability Table 8, and
4. Explain why e and d are not connected

OWM Executive Summary for Item Block 2 (B2) – Define True Value for Use in Error Calculations
--

<p>OWM Recommendation: That the Committee reconcile the entries proposed in new item SCL-23.3 with those in this block and then withdraw this block of items from its agenda to be replaced by new item SCL-23.3 (additional details included in the paragraph below).</p>

- | |
|---|
| <ul style="list-style-type: none">• The different proposals in this block of items were recently amended, reorganized, and resubmitted to the NCWM by the NCWM's Verification Scale Division (e) Task Group (TG) to reflect changes agreed to by members of the TG and included in its 2nd Final report. The NCWM agreed to consolidate these proposals into a single new item (i.e., Item SCL-23.3) on the Committee's 2023 Interim Meeting agenda. The NCWM also agreed to maintain the Block 2 items on the Committee's 2023 Interim Meeting agenda so that the Committee could reconcile the entries during the upcoming 2023 NCWM Interim Meeting.• The items in this block and the proposals included in new Item SCL-23.3 represent very significant changes to the Scales Code of NIST HB 44 in that they are an attempt to clarify which value: the value of the scale division (d) or verification scale division (e), are the paragraph requirements to be based. It is important that everyone agree with the changes proposed.• OWM participates on the TG and looks forward to sharing its perspective with its members on the proposed changes. |
|---|

Table 3. Summary of Recommendations							
B2 – Define True Value for Use in Error							
	V	D	W	A	I	Notes*	Comments
Submitter							
OWM							
WWMA							
SWMA							
NEWMA							
CWMA							
NCWM							
	Letters of Support			Letters of Opposition			Notes
Industry							
Manufacturers							
Retailers and Consumers							
*Notes Key: 1 - Submitted modified language 2 - Item not discussed 3 - No meeting held 4 - Not submitted on agenda 5 - No recommendation or not considered							

Item Under Consideration:

B2: SCL-20.3 A S.5.4. Relationship of Minimum Load Cell Verification Interval to the Scale Division

Amend Handbook 44, Scales Code as follows:

S.5.4. Relationship of Minimum Load Cell Verification Interval Value to the Scale Division – The relationship of the value for the minimum load cell verification scale interval, v_{min} , to the **verification** scale division, $\underline{t e}$, for a specific scale using National Type Evaluation Program (NTEP) certified load cells shall comply with the following formulae where N is the number of load cells in a single independent¹ weighing/load-receiving element (such as hopper, railroad track, or vehicle scale weighing/load-receiving elements):

$$(a) v_{min} \leq \frac{\underline{t e}}{\sqrt{N}} \text{ for scales without lever systems; and}$$

$$(b) v_{min} \leq \frac{\underline{t e}}{\sqrt{N} \times (\text{scale multiple})} \text{ for scales with lever systems.}$$

¹“Independent” means with a weighing/load-receiving element not attached to adjacent elements and with its own A/D conversion circuitry and displayed weight.

~~[*When the value of the scale division, d , is different from the verification scale division, e , for the scale, the value of e must be used in the formulae above.]~~

This requirement does not apply to complete weighing/load-receiving elements or scales, which satisfy all the following criteria:

- the complete weighing/load-receiving element or scale has been evaluated for compliance with T.N.8.1. Temperature under the NTEP;
- the complete weighing/load-receiving element or scale has received an NTEP Certificate of Conformance; and
- the complete weighing/load-receiving element or scale is equipped with an automatic zero-tracking mechanism which cannot be made inoperative in the normal weighing mode. (A test mode which permits the disabling of the automatic zero-tracking mechanism is permissible, provided the scale cannot function normally while in this mode.

[Nonretroactive as of January 1, 1994]

(Added 1993) (Amended 1996, ~~and~~ 2016, and 20XX)

B2: SCL-20.4 A Table 3. Parameters of Accuracy Classes.

Amend Handbook 44, Scales Code as follows:

Table 3. Parameters for Accuracy Classes			
Class	Value of the Verification Scale Division e^1 (d or e^1)	Number of Scale⁴ Divisions (n)	
		Minimum	Maximum
SI Units			
<i>I</i>	equal to or greater than 1 mg	50 000	--
<i>II</i>	1 to 50 mg, inclusive	100	100 000
<i>III^{2,5}</i>	equal to or greater than 100 mg	5 000	100 000
	0.1 to 2 g, inclusive	100	10 000
<i>III L³</i>	equal to or greater than 5 g	500	10 000
	equal to or greater than 2 kg	2 000	10 000
<i>III</i>	equal to or greater than 5 g	100	1 200
U.S. Customary Units			
<i>III⁵</i>	0.0002 lb to 0.005 lb, inclusive	100	10 000
	0.005 oz to 0.125 oz, inclusive	100	10 000
	equal to or greater than 0.01 lb	500	10 000
	equal to or greater than 0.25 oz	500	10 000
<i>III L³</i>	equal to or greater than 5 lb	2 000	10 000
<i>III</i>	greater than 0.01 lb	100	1 200
	greater than 0.25 oz	100	1 200

¹ **For Class I and II devices equipped with auxiliary reading means (i.e., a rider, a vernier, or a least significant decimal differentiated by size, shape, or color), the value of the verification scale division “e” is the value of the scale division immediately preceding the auxiliary means. The manufacturer may design a scale such that the verification scale division e does not be equal to the scale division d. To ensure the correct value for e is used, refer to marking requirements in footnotes 3 and 4 to Table S.6.3.a. and Table S.6.3.b.**

(Amended 20XX)

² A Class III scale marked “For prescription weighing only” may have a verification scale division (e) not less than 0.01 g.

(Added 1986) (Amended 2003)

³ The value of ~~a~~ **the verification** scale division (**e**) for crane and hopper (other than grain hopper) scales shall be not be less than 0.2 kg (0.5 lb). The minimum number of scale divisions shall not be less than 1000.

(Amended 20XX)

⁴ On a multiple range or multi-interval scale, the number of divisions for each range independently shall not exceed the maximum specified for the accuracy class. The number of scale divisions, n, for each weighing range is determined by dividing the scale capacity for each range by the verification scale division, e, for each range. On a scale system with multiple load-receiving elements and multiple indications, each element considered shall not independently exceed the maximum specified for the accuracy class. If the system has a summing indicator, the n_{max} for the summed indication shall not exceed the maximum specified for the accuracy class.

(Added 1997)

⁵ The minimum number of scale divisions for a Class III Hopper Scale used for weighing grain shall be 2000.)

[Nonretroactive as of January 1, 1986]

(Amended 1986, 1987, 1997, 1998, 1999, 2003, ~~and~~ 2004, and 20XX)

B2: SCL-20.5 A Table S.6.3.a. Marking Requirements, Note 3.

Amend Handbook 44, Scales Code as follows:

3. The device shall be marked with the nominal capacity. *The nominal capacity shall be shown together with the value of the scale division “d” (e.g., 15×0.005 kg, 30×0.01 lb, or capacity = 15 kg, $d = 0.005$ kg) in a clear and conspicuous manner and be readily apparent when viewing the reading face of the scale indicator unless already apparent by the design of the device. Each scale division value ~~or weight unit~~ **with its associated nominal capacity** shall be marked on multiple range or multi-interval scales. **In the absence of a separate marking of the verification scale division “e” (see Note 4), the value of the verification scale division e shall be equal to the value of the scale division d.***

[Nonretroactive as of January 1, 1983]

(Amended 2005 and 20XX)

B2: SCL-20.6 A T.N.1.2. Accuracy Classes and T.N.1.3. Scale Division.

Amend Handbook 44, Scales Code as follows:

T.N.1.2. Accuracy Classes. – Weighing devices are divided into accuracy classes according to the number of scale divisions (n) and the value of the verification scale division (~~d~~) (e).

T.N.1.3. Scale Division. – This Code contains references to two types of scale divisions, the verification scale division (e) and the scale division (d) (see definitions in Appendix D.). The tolerance for a weighing device is in the order of magnitude of related to the value of the scale division (d) or the value of the verification scale division (e) and is generally expressed in terms of d or e. Other technical requirements may reference either the verification scale division (e) or scale division (d) as appropriate. The values of (e) and (d) are chosen by the manufacturer and are marked on the device pursuant to S.6.3., except that d is not used in reference to an analog device, such as an equal-arm balance, where the graduations do not correspond to units of weight.

B2: SCL-20.7 A Table 6. Maintenance Tolerances

Amend Handbook 44, Scales Code as follows:

Table 6.				
Maintenance Tolerances				
(All values in this table are in <u>verification</u> scale divisions)				
Tolerance in <u>Verification</u> Scale Divisions				
	1	2	3	5
Class	Test Load			
I	0 - 50 000	50 001 - 200 000	200 001 +	
II	0 - 5 000	5 001 - 20 000	20 001 +	
III	0 - 500	501 - 2 000	2 001 - 4 000	4 001 +
IIII	0 - 50	51 - 200	201 - 400	401 +
III L	0 - 500	501 - 1 000	(Add 1 ϵ ϵ for each additional 500 ϵ ϵ or fraction thereof)	

B2: SCL-20.8 A Table 8. Recommended Minimum Load

Amend Handbook 44, Scales Code as follows:

Table 8.		
Recommended Minimum Load		
Class	Value of Scale Division (d or e\pm)*	Recommended Minimum Load (d or e\pm)*
I	equal to or greater than 0.001 g	100
II	0.001 g to 0.05 g, inclusive	20
	equal to or greater than 0.1 g	50
III	All**	20
III L	All	50

Table 8.		
Recommended Minimum Load		
III	All	10
<p>*For Class I and II devices equipped with auxiliary reading means (i.e., a rider, a vernier, or a least significant decimal differentiated by size, shape or color), the value of the verification scale division “e” is the value of the scale division immediately preceding the auxiliary means. For Class III and III devices the value of “e” is specified by the manufacturer as marked on the device; “e” must be less than or equal to “d.” <u>Scales manufacturers are permitted to design scales where the value a verification scale division e differs from the displayed scale division d. If the marked value of e is less than the value of d, use e in interpreting the Table. In all other cases use the value of d. Refer to marking requirements for d and e in footnotes 3 and 4 to Table S.6.3.a. and Table S.6.3.b.</u></p> <p><u>(Amended 20XX)</u></p> <p>**A minimum load of 10 g <u>g</u> is recommended for a weight classifier marked in accordance with a statement identifying its use for special applications.</p>		

(Amended 1990) (Amended 20XX)

NIST OWM Detailed Technical Analysis:

The following was copied from OWM’s analysis of the Block 2 items for the 2022 NCWM Annual Conference and remains unchanged for the 2023 NCWM Interim Meeting:

OWM looks forward to reviewing updates to the various items in this block once the NCWM Verification Scale Division (e) Task Group (TG) has completed its work amending the current proposals to reflect the agreed upon changes reported by the TG in its second report. Since there have been no updates to the different items in Block 2 since they were first submitted, OWM’s analysis of this group of items remains unchanged from the 2022 NCWM Interim Meeting as follows:

It remains clear that not everyone agrees with the changes proposed by this block of items given that none of the four regional weights and measures associations, nor the SMA, all of which met in the fall of 2021, could recommend to the national S&T Committee advancement of this block of items to a Voting status. Two of the regional associations recommended the block be reassigned to the Verification Scale Division Task Group. The other two regional associations recommended the block be developing. The SMA supported further development and the work of the Verification Scale Division (e) Task Group. We too disagree with some of the changes proposed. Consequently, as a group of items considered together, OWM cannot support them.

Although we are aware of the existence of a second draft report from the Verification Scale Division (e) Task Group that we think proposes, or at least suggests, additional changes/updates to the items in this block, we do not believe any of the items in Block 6 have changed since that report was first made available to us. We are hopeful, however, that some of the proposals in this block have been updated (but not yet published) or will be updated in the very near future and those updates will resolve, at least some concerns. We base this hope on comments made by Mr. Henry Oppermann (Weights and Measures Consulting, LLC) during Committee open hearings at the 2021 NEWMA Interim Meeting. Mr. Oppermann reported during open hearings that he had talked to the submitter of this block of items and the two had reached agreement on some needed changes to the proposals. Mr. Oppermann commented also, that he thought those agreed upon changes had perhaps already been made. Consequently, the draft of Block 2 items in NEWMA’s 2021 S&T Interim Meeting agenda was not, in Mr. Oppermann’s opinion, the most recent draft. We are

somewhat encouraged by this news because we share at least some of Mr. Oppermann's concerns with respect to the current items in this block.

Further evidence that the proposals in the Committee's 2022 Interim Meeting agenda (i.e., NCWM Publication 15) may have been updated, but not yet published or widely distributed, are comments made by the Chairman of the Verification Scale Division (e) Task Group during Committee open hearings at the 2021 CWMA Annual meeting. That is, the CWMA's S&T 2021 Annual Report indicates that Mr. Doug Musick, who was Chairman of the Verification Scale Division (e) Task Group during its existence, provided updates from the Task Group and would be providing changes to the item to NCWM S&T Committee before the July NCWM Annual meeting. Based on our review and comparison of the Block 2 items in the CWMA's 2021 S&T Annual Meeting Agenda and the Committee's 2022 Interim Meeting agenda (i.e., NCWM Publication 15) none of the proposals have changed.

If there does, in fact, exist a more current draft of the proposals in Block 2 and that draft gets introduced on or before the 2022 NCWM Interim Meeting, we encourage the Committee to provide adequate time for review and discussion opposed to simply advancing any new draft for vote during the 2022 NCWM Interim Meeting. There are many changes proposed by this block of items (i.e., there are six individual items in all) and their significance should be of great enough concern to warrant, in our opinion, sufficient time for review and discussion, especially in light of the fact there still exists disagreement on the current proposals. As noted in earlier OWM comments and recommendations, the different proposals included in this block present several very significant changes to the Scales code of HB 44 with respect to the application of HB 44 requirements to scales having different values of e and d. Given these two values most often differ by a factor of ten, it is of utmost importance that everyone agree on which value is the application of the different HB 44 requirements to be based.

Summary of Discussions and Actions:

During the 2022 NCWM Interim Meeting, Mr. Rick Harshman (NIST OWM) commented that the items in this block represent very significant changes to the Scales Code of NIST HB 44 in that they are an attempt to clarify which value, the value of the scale division (d), or verification scale division (e), are the paragraph requirements to be based. It is important that everyone agree; however, but this has not yet been the case. Mr. Harshman noted that OWM disagreed with several of the changes proposed by the different items in this block as shown in the Committee's current agenda. Mr. Harshman also reported that the various Block 2 items in the Committee's current agenda fail to reflect changes agreed to by members of the NCWM's Verification Scale Division (e) Task Group (TG) as indicated in its second report to the Committee. That is, the proposals hadn't been updated following the TG's submission of its second report to the Committee. There seemed to be a misunderstanding between the TG and Committee on who would perform this work and it never got done. OWM looked forward to reviewing the proposals once this updating had been completed.

Mr. Doug Musick (Kansas) Chair of the Verification Scale Division (e) TG acknowledged the accuracy of Mr. Harshman's reporting of the misunderstanding between the TG and Committee. He then requested the Committee either reassign the Block 2 items to the TG, or, if the Committee preferred, the Committee could perform the updating itself based on the TG's most recent report. Mr. Musick also noted that the TG's second report was included in Appendix A of the Committee's 2022 Interim Agenda (NCWM Publication 15).

Mr. Russ Vires (Mettler Toledo, LLC) speaking on behalf of the SMA stated that the SMA supports the further development of this item and the work of the Verification Scale Division (e) Task Group. The SMA

NIST OWM Analysis
2023 NCWM Interim S&T Agenda Items
1/5/2023

would also like to encourage the use of the terminology “Verification Interval” for “e” and “Scale Division” for “d” in every instance that it appears in this item.

The Committee also received several comments in support of reassigning the block of items to the TG for further revision.

The Committee, in consideration of the comments received, agreed to reassign the block of items to the Verification Scale Division (e) TG for additional updating.

During Committee open hearings at the NCWM 2022 Annual Meeting, the Committee received an update from the Task Group Chair Doug Musick (Kansas). Mr. Musick indicated that the Task Group created a report in 2021 that had been added to Publication 15 and 16 as an Appendix. This report contains an analysis of the items under consideration, as well as recommendations for language changes to those items. Mr. Musick requested a joint meeting with the Task Group and the S&T and L&R Committees for coordinating moving the recommended changes to the items under consideration. The Committee recommends this remains Assigned and is requesting the Task Group facilitate joint meeting and work on moving the recommended changes from the report into the items under consideration.

Regional Association Reporting:

Western Weights and Measures Association

During the 2021 Annual Meeting Open Hearing the following comments were heard:

Mr. Matt Douglas (California - DMS) remarked the language is not clear, recommend that this item be withdrawn (the whole block).

Mr. Russell Vires (Scale Manufacturers Association) stated this is a carryover item. SMA supports further development of this item, recommend that the SMA encourage the use of term: Verification Scale Interval for (e) and Scale Division for (d). (He can send info.) States that his comments are the same from the Annual Meeting.

Ms. Diane Lee (NIST OWM) remarked that the NIST OWM comments are posted on NCWM website.

The WWMA S&T Committee recommended that this item remain Informational with concern given to the comments given during the WWMA open hearings. During the Committee work session, clarification was given regarding Committee member Mr. Matt Douglas’ (California - DMS) testimony questioned whether or not the item provides assistance to an Inspector in the field in the performance of their job.

Due to timing constraints during open hearings at the 2022 WWMA meeting, the Committee did not take comments on Assigned Items. The Committee did allow the source to provide updates on these items. No update was provided to the Committee. The WWMA S&T Committee recommended that this item remain Assigned and looks forward to a future update.

Southern Weights and Measures Association

During the 2021 Annual Meeting Open Hearing Mr. Russ Vires (SMA) supported further development of this item and recommended the descriptive name changes for “e” and “d” as posted on the NCWM website.

This Committee recommended this item move forward with an Assigned status.

Northeastern Weights and Measures Association

During the 2021 Interim Meeting Open Hearing the following comments were heard.

Mr. Rick Harshman (NIST OWM) recommended keeping this item in Informational status due to the fact that the National S&T Committee has taken ownership and interpretations have been provided at NTEP and weighing sector meetings. Meeting notes are available on NCWM website.

Mr. Henry Opperman (Weights and Measures Consulting) objected to many of the blocked items and recommend to keep this item in Informational status.

Mr. Lou Staub (SMA) suggested the use of the term “verification scale interval” for “e” and “scale division” for “d”.

Mr. John McGuire (New Jersey) recommended keeping the item in Informational status.

The NEWMA Specifications and Tolerances Committee recommends that this item be kept in Informational status.

During the 2022 Annual Meeting Open Hearings, Mr. Russ Vires (Mettler Toledo, LLC), speaking on behalf of the SMA, recommended the identical changes to the individual items in Block 2 as shown in the SMA reporting contained within this report for the SMA’s Spring 2022 meeting. Mrs. Tina Butcher (NIST OWM) indicated she believes the latest revisions from task group have addressed concerns.

After hearing comments from the floor, the Committee recognized the need to further develop this block and recommended the block retain Assigned status.

Central Weights and Measures Association

During the 2021 Interim Meeting Open Hearing the Committee heard comments from the floor. Mr. Lou Straub (SMA) supports item. Would like to see it written that “scale division” will have value of “d” and “verification scale interval” for “e”.

CWMA S&T Committee recommended that the item be assigned back to the Verification Scale Division Task Group.

During the 2022 CWMA Annual Meeting Open Hearings the Committee received the following comments:

Mr. Russ Vires (SMA): the SMA supports the further development of this item and the work of the Verification Scale Division (e) Task Group. Recommendation: the SMA would also like to encourage the use of the terminology “Verification Interval” for “e” and “Scale Division” for “d” in every instance that it appears in this item.

Mr. Loren Minich (Kansas): items shown under consideration are not the items the Task Group has submitted. The SMA recommendations conflict with current task group verbiage.

Mr. Doug Musick (Kansas): this proposal got put into the National Committee Agenda Appendix for some reason. Hope to rebuild the task group and get cleaned up before 2022 national. “verification interval” should be “verification scale division” (e), and “displayed scale division” (d). Having (d) and (e) in the same original table was confusing to inspectors. The current Task Group changes won’t be in Pub 16 for the 2022 National Meeting.

Mr. Loren Minich (Kansas): prefers the S&T Committee to evaluate the Appendix since it's more up to date.

The CWMA S&T Committee recommended this item remain as Assigned.

During the 2022 CWMA Interim Meeting, the Committee received no comments on this block of items and recommended this block remain in an Assigned status.

SMA

During the 2021 Fall Meeting the SMA supports the further development of this item and the work of the Verification Scale Division (e) Task Group. The SMA would also like to encourage the use of the terminology "Verification Interval" for "e" and "Scale Division" for "d" in every instance that it appears in this item. The following changes are recommended to the individual items in this block:

B2: SCL-20.3 S.5.4 Relationship of Minimum Load Cell Verification Interval: No change

B2: SCL-20.4 Table 3. Parameters of Accuracy Classes

Recommendation: The SMA recommends the following change to Table 3, Footnote 1: **The manufacturer may design a scale such that the ~~verification scale division~~ verification interval e does not be equal to the scale division d.**

B2: SCL-20.5 Table S.6.3.A. Marking Requirements, Note e: No Change

B2: SCL-20.6 T.N.1.1. Accuracy Classes and T.N.1.3. Scale Division

Recommendation: The SMA recommends the following change: **"... except that (d) is not used in reference..."**

B2: SCL-20.7 Table 7. Maintenance Tolerances

Recommendation: The SMA recommends the following change: **Table 6. Maintenance Tolerances**

B2: SCL-20.8 Table 8 Recommended Minimum Load

Recommendation: The SMA recommends the following change: **Scales manufacturers are permitted may have to design scales where the value a verification scale interval division e differs not equal to from the displayed scale division d.**

During the 2022 Spring Meeting, the SMA reported it supported the further development of this item and the work of the Verification Scale Division (e) Task Group. The SMA would also like to encourage the use of the terminology "Verification Interval" for "e" and "Scale Division" for "d" in every instance that it appears in this item.

The SMA recommended the following changes to the individual items in Block 2:

B2: SCL-20.3 S.5.4 Relationship of Minimum Load Cell Verification Interval: No change

B2: SCL-20.4 Table 3. Parameters of Accuracy Classes

Recommendation: The SMA recommends the following change to Table 3, Footnote 1: **Class I and II scales may be designed such that the ~~verification scale division~~ verification interval e does not be equal to the scale division d.**

B2: SCL-20.5 Table S.6.3.A. Marking Requirements, Note 3: No Change

B2: SCL-20.6 T.N.1.2. Accuracy Classes and T.N.1.3. Scale Division

Recommendation: The SMA recommends the following change: **"... except that (d) is not used in reference..."**

B2: SCL-20.7 Table 7. Maintenance Tolerances

Recommendation: The SMA recommends the following change: **Table 6. Maintenance Tolerances**

B2: SCL-20.8 Table 8. Recommended Minimum Load

Recommendation: The SMA recommends striking the following language from the submitter's proposal: ~~Scales manufacturers are permitted to design scales where the value a verification scale division e differs from the displayed scale division d.~~

Rationale: When taken with the SMA's recommendation for SCL-20.4, this will avoid duplication in the HB44 code.

During the 2022 Fall Meeting, the SMA continued to support the further development of this block of items and the work of the Verification Scale Division (e) Task Group. The SMA would encourage the work group to make the final changes to this block of Assigned Items and present it to the S&T Committee and Membership, otherwise remove it.

Recommendation: the SMA encourages the use of the terminology "Verification Interval" for "e" and "Scale Division" for "d" in every instance that it appears in the Handbook.

The SMA recommended the following changes to the individual items in Block 2:

B2: SCL-20.3 S.5.4 Relationship of Minimum Load Cell Verification Interval: No change

B2: SCL-20.4 Table 3. Parameters of Accuracy Classes

Recommendation: The SMA recommends the following change to Table 3, Footnote 1: ~~Class I and II scales may be designed such that the verification scale division verification interval e does not be equal to the scale division d.~~

B2: SCL-20.5 Table S.6.3.A. Marking Requirements, Note 3: No Change

B2: SCL-20.6 T.N.1.2. Accuracy Classes and T.N.1.3. Scale Division

Recommendation: The SMA recommends the following change: ~~... except that (d) is not used in reference...~~

B2: SCL-20.8 Table 8. Recommended Minimum Load

Recommendation: The SMA recommends striking the following language from the submitter's proposal: ~~Scales manufacturers are permitted to design scales where the value a verification scale division e differs from the displayed scale division d.~~

Rationale: When taken with the SMA's recommendation for SCL-20.4, this will avoid duplication in the HB44 code.

Item Block 3 (B3) Tolerances for Distance Testing in Taximeters and Transportation Network Systems

B3: TXI-20.1 D T. Tolerances

B3: TNS-20.1 D T. Tolerances

Source: New York Department of Agriculture and Markets

Submitter's Purpose and Justification:

Provide the same distance-measurement tolerances for the Taximeters Code and Transportation Network Systems Code.

OWM Executive Summary for Item Block 3 (B3) – Tolerances for Distance Testing in Taximeters and Transportation Network Systems TXI-20.1 T. Tolerances and TNS-20.1 T. Tolerances
<p>OWM Recommendation:</p> <ul style="list-style-type: none"> • OWM concurs with the submitter's recommendation during NEWMA October 25-26, 2022 Interim Meeting to withdraw the proposal. OWM continues to encourage stakeholders to work with the USNWG to ensure that future modifications to the NIST HB 44 Taximeters and TNMS Codes fully consider the technology used in both applications. • The work to update the taximeters and TNMS codes may need to be stepped up to address issues identified in the areas of design and function of indicating elements, provisions for sealing, and location services signal loss so that these provisions are in the code for properly operating this newer technology in taxis.

Table 3. Summary of Recommendations							
Item B3 – TXI-20.1 T. Tolerances and TNS-20.1 T. Tolerances							
	V	D	W	A	I	Notes*	Comments
Submitter			✓				
OWM			✓				
WWMA		✓					
SWMA		✓					
NEWMA			✓				
CWMA		✓					
NCWM							
	Letters of Support			Letters of Opposition			Notes
Industry							
Manufacturers							
Retailers and Consumers							
<p>*Notes Key:</p> <ul style="list-style-type: none"> 1 - Submitted modified language 2 - Item not discussed 3 - No meeting held 4 - Not submitted on agenda 5 - No recommendation or not considered 							

Item Under Consideration:

The Item Under Consideration published in the Committee’s 2023 Interim Report is shown below.

B3: TXI-20.1 D T. Tolerances

Amend Handbook 44, Taximeters Code as follows.

T. Tolerances

T.1. Tolerance Values.

T.1.1. On Distance Tests. – Maintenance and acceptance tolerances for taximeters shall be as follows:

- (a) On Overregistration: 1 % of the interval under test when the distance is 1.6 km (1 mile) or less. 2.5 % of the interval under test when the distance is greater than 1.6 km (1 mile).

B3: TNS-20.1 D T. Tolerances

Amend Handbook 44, Transportation Network Systems Code as follows:

T. Tolerances

T.1.1. Distance Tests. – Maintenance and acceptance tolerances shall be as follows:

- (a) On Overregistration: ~~2.5 %~~ 1 % of the interval under test when the distance is 1.6 km (1 mile) or less. 2.5 % of the interval under test when the distance is greater than 1.6 km (1 mile).
- (b) On Underregistration: ~~2.5 %~~ 4 % of the interval under test.

On March 23, 2022, the submitter requested the Committee replace the Item Under Consideration shown in the 2022 S&T Interim Report with the following.

Modify NIST Handbook 44 Section 5.54 Taximeters Code as follows:

T.1. Tolerance Values.

T.1.1. On Distance Tests. – Maintenance and acceptance tolerances for taximeters shall be as follows:

T.1.1.1. Meters Using Distance generated from sources physically connected to the vehicle (e.g OBD sensor).

- (a) On Overregistration: 1 % of the interval under test.
- (b) On Underregistration: 4 % of the interval under test, with an added tolerance of 30 m or 100 ft whenever the initial interval is included in the interval under test.

T.1.1.2. Meters Using Distance generated from sources not physically connected to the vehicle (e.g navigation satellite system such as GPS and /or other location services).

(a) On Overregistration: 2.5 %

(b) On Underregistration: 2.5 %

Withdraw the TNMS portion of the original proposal and leave the existing TNMS Code as it currently appears in NIST Handbook 44.

NIST OWM Detailed Technical Analysis:

Background: OWM appreciates the efforts of the submitter to harmonize the tolerance requirements in the Taximeters Code and the TNMS Code although, we did not believe it is necessary to increase the tolerance allowed since taximeters have been required to comply with the existing tolerances for decades.

OWM also noted that TNMS do not typically assess fare charges based on intervals as do taximeters. Taximeters will accumulate fare charges by summing the number of intervals comprising the trip's distance traveled and time elapsed and multiplying by the appropriate rate. In contrast, TNMS typically base the fare charges on the total distance (and time in some cases) for the trip. For this reason, we did not believe it is necessary to amend paragraphs T.1.1.(a) and (b) to refer to "interval under test" as is shown in the proposal. OWM recommended that this proposal be further developed with the assistance of the NIST USNWG on Taximeters in such a way that will better align the HB 44 Taximeters and TNMS Codes.

The NIST led U.S. National Work Group (USNWG) on Taximeters has held virtual meetings in May, June, and October 2020 and June 2021 to further develop standards for both taximeters and TNMS. The focus of these meetings was the merger of the existing HB 44 Taximeters Code and the tentative TNMS Code. Those members attending these meetings were in general agreement that this is the appropriate direction the work group should take. The USNWG also began discussions on some of the areas to be addressed in a unified "Transportation-for-Hire Systems" Code that could present challenges in the development of appropriate requirements. Those areas included the design and function of indicating elements, provisions for sealing, and location services signal loss.

The submitter of the proposal (New York or NYS) agreed to work with the USNWG to further develop this proposal and is actively participating in those meetings. The submitter explained to the USNWG that some of the more recent systems submitted to the state of New York for type approval had not been able to comply with the existing taximeter tolerances. This failure was seen in systems that attempted to use location services (i.e., GPS) to measure distance. In response to that point, it was noted that other systems have been able to meet those tolerances and to expand the tolerances would be an approach that is not supported by most in the weights and measures community.

Also included as a topic in the meetings was this proposal submitted to the NCWM S&T Committee to amend the HB 44 Taximeters and TNMS Codes. The USNWG agreed that the two HB 44 Codes should be merged and that this could be accomplished by continuing its efforts in the future.

NIST OWM is aware that the developer of the proposal was not able to provide updates to the proposal in January 2022 because of technical difficulties with audio-visual equipment at the NCWM Interim Meeting. The NYS alternate proposal modified only the Taximeter Code tolerances and was made available on March 23, 2022 on the NCWM website. This update was later noted in the May 2022 CWMA and NEWMA Annual Meeting summaries. The NYS alternate proposal established a new set of taximeter over- and

under-registration tolerances at 2.5 % which are equivalent to those applied to TNMS. The current tolerances remain in place when the taximeter source for distance measurements is connected to the vehicle. The proposed new tolerances apply when the taximeter's source for distance measurement is generated from equipment not physically connected to the vehicle such as a GPS. This mechanism for generating measurement data from sources not physically connected to the vehicle is similar in the operation of a TNMS.

On March 23, 2022, NYS also withdrew the portion of Block 3 designated as B3: TNS-20.1 T. Tolerances, and no longer recommended modifying Transportation Network Measurement Systems -Tentative Code paragraph T.1.1. Distance Tests maintenance and acceptance tolerances for over- and under-registration and to reestablish the limits of permissible error of the TNMS under test as a percentage of the interval under test and distance traveled over the test course.

Based on the methodology used to determine distance traveled the proposal would permit a dual tolerance structure for vehicles within a single company or operating in the same geographic area. Work may need to be stepped up to address issues identified in the areas of design and function of indicating elements, provisions for sealing, and location services signal loss so that these provisions are in the code for properly operating this newer technology in taxis.

In conclusion: By December 2022 NIST OWM agreed with the submitter's recommendation during the NEWMA October 25-26, 2022 Interim Meeting to withdraw the proposal. OWM continues to encourage stakeholders to work with the USNWG to ensure that future modifications to the NIST HB 44 Taximeters and TNMS Codes fully consider the technology used in both applications.

The work to update the taximeters and TNMS codes may need to be stepped up to address issues identified in the areas of design and function of indicating elements, provisions for sealing, and location services signal loss so that these provisions are in the code for properly operating this newer technology in taxis.

Summary of Discussions and Actions:

NCWM 2022 Annual Meeting: During open hearings, the Committee received an update from submitter Mr. Jim Willis (New York). Based on feedback, Mr. Willis has made language changes which will be updated for the fall meetings. Mr. Willis requested that the item retain its Developing status.

Regional Association Reporting:

Central Weights and Measures Association

Mr. Craig VanBuren (Michigan): trying to make two measurements of the same device category equal in tolerance values. i.e. GPS and taxis have the same tolerance. Concerns regarding errors in the customer's favor shouldn't be a problem. But on pages 284-285, depending on physical vehicle or GPS, there are different tolerances? Why is the tolerance conflicting within the same block? Haven't heard any input from transportation companies. Recommend withdrawal.

The CWMA S&T Committee recommended this remains as a Developing Item.

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received:

Mr. Matt Douglas (California Division of Measurement Standards) wanted to hear if this update addressed some of the concerns raised particularly by Mr. Floren. Did see the merit in how this was developed. Thought this is close to being ready if not already ready for a vote.

Mr. Kurt Floren (County of Los Angeles, California) was opposed to the original item and is against lowering the bar when there is technology out there that is meeting the tolerances. Didn't think that the verbiage of "physically connected to the vehicle" is sufficient. Thought the item needs to be developed to clarify that the drive is what is connected to the vehicle.

During open hearings, members in attendance were notified that the language in the agenda did not reflect the updated Item Under Consideration. Membership was not fully aware of the new language at the time of open hearings. Concerns were heard that terms such as "physically connected" are not specific enough to enforce. The WWMA S&T Committee recommended that this item should remain Developing to allow membership to review the updated proposal.

Southern Weights and Measures Association

No comments were received on this item during the 2022 SWMA Annual Meeting.

The SWMA S&T Committee recommended this item remain as a Developing Item.

Northeastern Weights and Measures Association

Mr. Jim Willis (New York), submitter, requested that this item be withdrawn.

At the request of the submitter, the Committee recommended that this item be withdrawn.

Item Block 4 (B4) Electronically Captured Tickets or Receipts

(**Note:** The Item Under Consideration reflects changes that were received by the committee from the submitter of the item and that the Committee agreed to during its 2021 Interim Meeting work session. The changes are highlighted.)

B4: CLM-21.1 D S.1.4.1. ~~Printed Ticket~~ Recorded Representation., UR.2.6.3. ~~Printed Ticket~~ Recorded Representation.

B4: MLK-XX-X D S.1.4.2 ~~Printed Ticket~~ Recorded Representation., UR.2.2. ~~Printed Ticket~~, Recorded Representation.

B4: MFM-21.2 D S.6. ~~Printer~~ Recorded Representations., UR.2.6. ~~Ticket Printer~~, Customer Ticket, Recorded Representation., UR.3.4. ~~Printed Ticket~~. Recorded Representation.

B4: CDL-21.1 D S.1.4.1. ~~Printed Ticket~~ Recorded Representations., UR.2.4.2. ~~Tickets or Invoices~~. Recorded Representation.

B4: HGM-21.1 D S.2.6. Recorded Representations, Point of Sale Systems., S.6. ~~Printer~~. Recording Element., UR.3.2. Vehicle-mounted Measuring Systems ~~Ticket Printer~~ Recording Element., UR.3.3. ~~Printed Ticket~~. Recorded Representation.

B4: OTH-21.2 D Appendix D - Definitions.: recorded representations, recording element.

Source: Kansas Department of Agriculture, Division of Weights and Measures

Submitter’s Purpose and Justification:

Allow recorded values to be captured electronically as an alternative to a printed ticket or receipt.

In 2014 G-S.5.6. was added to Handbook 44 to allow for the issuance of electronic receipts. At that time the use of the term “print”, and all variations on the word “print” was not fully addressed.

The Oxford Dictionary defines print as “a mechanical process involving the transfer of text, images, or designs to paper.”

The Oxford Dictionary defines record as: to “set down in writing or some other permanent form for later reference, especially officially.”

Values that are delivered via electronic means are recorded values and not necessarily printed vales. Printed indicates that a value has been transferred on to a hard document. While the intent of the 2014 amendment was to allow for the use of electronic receipts the terminology used is incorrect. In addition to receipts, there are instances where other information may be transmitted electronically.

When applying G-A.2. to weighing and measuring devices,

G-A.2. Code Application. – This General Code shall apply to all classes of devices as covered in the specific codes. The specific code requirements supersede General Code requirements in all cases of conflict.

(Amended 1972)

Multiple conflicts arise in the implementation of the 2014 Amendment of G-S.5.6. This is to clarify the terminology in Handbook 44 and to recognize the changing technology in how transactions are recorded, and the information is disseminated.

OWM Executive Summary for Item Block 4 (B4) – Electronically Captured Tickets or Receipts
<p>OWM Recommendation: Although NIST OWM feels that all proposed changes would benefit from additional review, NIST OWM believes that the additional changes made to G-S.5.6 provides clarity. NIST OWM supported a Developing status so that changes to the B4 specific codes are carefully reviewed to ensure the proposed changes did not change the original intent of the specific section. Barring no additional specific changes to Block 4 items NIST OWM supports this item moving forward with a Voting status with the suggested change below.</p> <ul style="list-style-type: none"> • Most of the changes proposed by NIST OWM are included in the proposal, except for the recommendation that “However” be removed from the General Code requirement in this proposal. We recommend that “However” be removed.

Table 3. Summary of Recommendations							
Item Block 4 – Electronically captured tickets or receipts							
	V	D	W	A	I	Notes*	Comments
Submitter							<ul style="list-style-type: none"> • Proposed Revisions by Submitter (09-28-2020) • Further Comments (01-13-2021)
OWM							

Table 3. Summary of Recommendations							
Item Block 4 – Electronically captured tickets or receipts							
	V	D	W	A	I	Notes*	Comments
WWMA		✓					
SWMA		✓					
NEWMA	✓						
CWMA		✓					
NCWM							
		Letters of Support		Letters of Opposition		Notes	
Industry							
Manufacturers							
Retailers and Consumers							
*Notes Key: 1 – Submitted modified language 2 – Item not discussed 3 – No meeting held 4 – Not submitted on agenda 5 – No recommendation or not considered							

Item Under Consideration:

B4: GEN-21.2 D G-S.5.6. Recorded Representations.

Amend Handbook 44, General Code as follows:

G-S.5.6. Recorded Representations. – Insofar as they are appropriate, the requirements for indicating and recording elements shall also apply to recorded representations. All recorded values shall be ~~printed~~ ~~provided~~ presented digitally. In applications where recorded representations are required by a specific code, the customer may be given the option of not receiving the recorded representation. Unless otherwise specified, recorded representations referenced in specific codes shall be made available to the customer as a minimum in hard copy form. However, for systems equipped with the capability of issuing an electronic receipt, ticket, or other recorded representation, the customer may be given the option to receive any required information electronically (e.g., via cell phone, computer, etc.) in lieu of or in addition to a hard copy.

(Amended 1975, 2014 and ~~20XX~~)

B4: LMD-21.2 D S.1.6.5. Money Value Computations., UR.3. Use of a Device.

Amend Handbook 44, Liquid Measuring Devices Code as follows:

S.1.6.5. Money-Value Computations

...

S.1.6.5.6. Display of Quantity and Total Price, Aviation Refueling Applications.

(a) *The quantity shall be displayed throughout the transaction.*

(b) *The total price shall also be displayed under one of the following conditions:*

(1) *The total price can appear on the face of the dispenser or through a controller adjacent to the device.*

(2) *If a device is designed to continuously compute and display the total price, then the total price shall be computed and displayed throughout the transaction for the quantity delivered.*

(c) *The total price and quantity shall be displayed for at least five minutes or until the next transaction is initiated by using controls on the device or other customer-activated controls.*

(d) *A **printed** receipt shall be available and shall include, at a minimum, the total price, quantity, and unit price.*

[Nonretroactive as of January 1, 2008]

*(Added 2007) (**Amended 20XX**)*

S.1.6.7. Recorded Representations. – *Except for fleet sales and other price contract sales and for transactions where a post-delivery discount is provided, a **printed** receipt providing the following information shall be available through a built-in or separate recording element for all transactions conducted with point-of-sale systems or devices activated by debit cards, credit cards, and/or cash:*

(a) *the total volume of the delivery;**

(b) *the unit price;**

(c) *the total computed price;**

(d) *the product identity by name, symbol, abbreviation, or code number;* and*

(e) *the dispenser designation by either an alphabetical or numerical description.***

**[Nonretroactive as of January 1, 1986] **[Nonretroactive as of January 1, 2021]*

*(Added 1985) (Amended 1997, 2012, 2014, 2018 and **20XX**)*

S.1.6.8. Recorded Representations for Transactions Where a Post-Delivery Discount(s) is Provided. – *Except for fleet sales and other price contract sales, a **printed** receipt providing the following information shall be available through a built-in or separate recording element that is part of the system for transactions involving a post-delivery discount:*

(a) *the product identity by name, symbol, abbreviation, or code number;*

(b) *transaction information as shown on the dispenser at the end of the delivery and prior to any post-delivery discount(s), including the:*

- (1) total volume of the delivery;
 - (2) unit price; and
 - (3) total computed price of the fuel sale.
- (c) an itemization of the post-delivery discounts to the unit price;
- (d) the final total price of the fuel sale after all post-delivery discounts are applied; and

(e) the dispenser designation by either an alphabetical or numerical description.
[Nonretroactive as of January 1, 2021]

(Added 2012) (Amended 2014, ~~and 2018~~, and 20XX)

...

UR.3. Use of a Device

...

UR.3.3. Computing Device – Any computing device used in an application where a product or grade is offered for sale at one or more unit prices shall be used only for sales for which the device computes and displays the sales price for the selected transaction.

(Became retroactive 1999)

(Added 1989) (Amended 1992)

The following exceptions apply:

- (a) Fleet sales and other price contract sales are exempt from this requirement.
- (b) A truck stop dispenser used exclusively for refueling trucks is exempt from this requirement provided that:
 - (1) all purchases of fuel are accompanied by a **printed** receipt of the transaction containing the applicable price per gallon, the total gallons delivered, and the total price of the sale; and
(Added 1993)
 - (2) unless a dispenser complies with S.1.6.4.1. Display of Unit Price, the price posted on the dispenser and the price at which the dispenser is set to compute shall be the highest price for any transaction which may be conducted.
(Added 1993)
- (c) A dispenser used in an application where a price per unit discount is offered following the delivery is exempt from this requirement, provided the following conditions are satisfied:
 - (1) the unit price posted on the dispenser and the unit price at which the dispenser is set to compute prior to the application of any discount shall be the highest unit price for any transaction;

(Amended 2014)

- (2) all purchases of fuel are accompanied by a receipt recorded by the system. The receipt shall contain:
- a. the product identity by name, symbol, abbreviation, or code number;
 - b. transaction information as shown on the dispenser at the end of the delivery and prior to any post-delivery discount including the:
 1. total volume of the delivery;
 2. unit price; and
 3. total computed price of the fuel sale prior to post-delivery discounts being applied.
 - c. an itemization of the post-delivery discounts to the unit price; and
 - d. the final total price of the fuel sale.
- (Added 2012) (Amended 2014)

(Added 1989) (Amended 1992, 1993, 2012, ~~and~~ 2014, and 20XX)

UR.3.4. ~~Printed Ticket. Recorded Representation.~~ – The total price the total volume of the delivery; the price per liter or gallon; *and a corresponding alpha or numeric dispenser designation** shall be ~~shown, either printed recorded~~ by the device ~~or in clear hand script~~, on any ~~printed ticket issued by a device and recorded representation~~ containing any one of these values and shall comply with G-S.5.6. Establishments where no product grades are repeated are exempt from the dispenser designation requirement.

**[Nonretroactive as of January 1, 2021]*

(Amended 2001, 2018, ~~and~~ 2019, and 20XX)

B4: VTM-21.1 D S.1.1. Primary Elements., UR.2. User Requirements

Amend Handbook 44, Vehicle Tank Meter Code as follows:

S.1.1. Primary Element

S.1.1.1. General. – A meter shall be equipped with a primary indicating element. ~~and may also be equipped with a primary recording element.~~ Except for systems used solely for the sale of aviation fuel into aircraft and for aircraft-related operations, a meter shall be equipped with a primary recording element.

(Amended 1993 and 20XX)

~~Note: Except for systems used solely for the sale of aviation fuel into aircraft and for aircraft-related operations, vehicle tank meters shall be equipped with a primary recording element as required by paragraph UR.2.2. Ticket Printer; Customer Ticket. Recorded Representation~~

~~(Amended 1993 and 20XX)~~

...

S.1.4.2. ~~Printed Ticket, Recorded Representation.~~ – If a computing-type device issues a ~~printed ticket~~ **recorded representation** which displays the total computed price, the ~~ticket~~ **recorded representation** shall ~~also have printed clearly thereon~~ **record** the total quantity of the delivery, the appropriate fraction of the quantity, and the price per unit of quantity.

(Amended 1989, and 20XX)

...

UR.2. User Requirements.

...

UR.2.2. ~~Ticket Printer, Customer Ticket Recording Element.~~ – Vehicle-Mounted metering systems shall be equipped with a ~~ticket printer which shall be used for~~ **means to record** all sales where product is delivered through the meter **and shall comply with G-S.5.6.** A copy of the ticket issued by the device shall be ~~left with~~ **provided to** the customer at the time of delivery or as otherwise specified by the customer.

(Added 1993) (Amended 1994, and 20XX)

B4: LPG-21.1 D S.1.1. Primary Elements., UR.2. User Requirements

Amend Handbook 44, LPG and Anhydrous Ammonia Liquid-Measuring Devices Code as follows:

S.1.1. Primary Elements.

S.1.1.1. General. – A meter shall be equipped with a primary indicating element and may also be equipped with a primary recording element.

Note: Vehicle-mounted metering systems shall be equipped with a primary recording element as required by paragraph UR.2.6. ~~Ticket Printer, Customer Ticket~~ **Recorded Representation**

(Amended 20XX)

...

S.1.1.6. ~~Printed Ticket, Recorded Representation~~ – Any ~~printed ticket issued~~ **recorded representation created** by a device of the computing type ~~on which there is printed~~ **includes** the total computed price, shall ~~have printed clearly~~ **also include** thereon the total volume of the delivery in terms of liters or gallons, and the appropriate decimal fraction of the liter or gallon, and the corresponding price per liter or gallon.

(Added 1979) (Amended 1987, and 20XX)

...

S.1.5.5. Recorded Representations for Transactions Where a Post-Delivery Discount(s) is Provided. – Except for fleet sales and other price contract sales, a ~~printed receipt~~ **recorded representation** providing the following information shall be available through a built-in or separate recording element that is part of the system for transactions involving a post-delivery discount:

- (a) the product identity by name, symbol, abbreviation, or code number;

- (b) transaction information as shown on the dispenser at the end of the delivery and prior to any post-delivery discount(s), including the:
 - (1) total volume of the delivery;
 - (2) unit price; and
 - (3) total computed price of the fuel sale.
- (c) an itemization of the post-delivery discounts to the unit price; and
- (d) the final total price of the fuel sale after all post-delivery discounts are applied.

(Added 2016) **(Amended 20XX)**

...

UR.2. User Requirements.

...

UR.2.6. ~~Ticket Printer, Customer Ticket, Recorded Representation~~– Vehicle-Mounted metering systems shall be equipped with ~~a ticket printer which shall be used for~~ **means to record** all sales where product is delivered through the meter **and shall comply with G-S.5.6.** A copy of the ~~ticket recorded representation~~ issued by the device shall be ~~left with~~ **provided to** the customer at the time of delivery or as otherwise specified by the customer.

(Added 1993²) (Amended 1994, **and 20XX**)

...

UR.2.7.2. Computing Device. – Any computing device used in an application where a product or grade is offered for sale at one or more unit prices shall be used only for sales for which the device computes and displays the sales price for the selected transaction. The following exceptions apply:

- (a) Fleet sales and other price contract sales are exempt from this requirement.
- (b) A truck stop dispenser used exclusively for refueling trucks is exempt from this requirement provided that:
 - (1) all purchases of fuel are accompanied by a ~~printed receipt~~ **recorded representation** of the transaction containing the applicable price per unit of measure, the total quantity delivered, and the total price of the sale; and
 - (2) unless a dispenser complies with S.1.5.1. Display of Unit Price, the price posted on the dispenser and the price at which the dispenser is set to compute shall be the highest price for any transaction which may be conducted.
- (c) A dispenser used in an application where a price per unit discount is offered following the delivery is exempt from this requirement, provided the following conditions are satisfied:

- (1) the unit price posted on the dispenser and the unit price at which the dispenser is set to compute shall be the highest unit price for any transaction;
- (2) all purchases of fuel are accompanied by a receipt recorded by the system for the transaction containing:
 - a. the product identity by name, symbol, abbreviation, or code number;
 - b. transaction information as shown on the dispenser at the end of the delivery and prior to any post-delivery discount including the:
 1. total volume of the delivery;
 2. unit price; and
 3. total computed price of the fuel sale prior to post-delivery discounts being applied.
 - c. an itemization of the post-delivery discounts to the unit price; and
 - d. the final total price of the fuel sale after all post-delivery discounts are applied.

(Added 2016) (Amended 20XX)

B4: CLM-21.1 D S.1.4.1. ~~Printed Ticket~~Recorded Representation., UR.2.6.3. ~~Printed Ticket~~Recorded Representation.

Amend Handbook 44, Cryogenic Liquid-Measuring Devices Code as follows:

S.1.4.1 ~~Printed Ticket~~ Recorded Representation – Any ~~printed ticket recorded representation~~ issued by a device of the computing type ~~on~~ which ~~there is printed~~ includes the total computed price shall ~~have printed clearly thereon~~ also include the total quantity of the delivery, and the price per unit.

(Amended 20XX)

And

UR.2.6.2. ~~Tickets or Invoices. Recorded representation~~ – Any ~~written invoice, or printed ticket,~~ recorded representation based on a reading of a device that is equipped with an automatic temperature or density compensator shall have shown thereon that the quantity delivered has been adjusted to the quantity at the NBP of the specific cryogenic product or the equivalent volume of gas at NTP.

(Amended 20XX)

UR.2.6.3. ~~Printed Ticket. Recorded Representation.~~ – Any ~~printed ticket issued recorded representation provided~~ by a device of the computing type ~~on~~ which ~~there is printed~~ includes the total computed price, the total quantity of the delivery, or the price per unit, shall also ~~show~~ include the other two values. ~~(either printed or in clear hand script).~~ and shall comply with G-S.5.6.

(Amended 20XX)

B4: MLK-21.1 D S.1.4.2. ~~Printed Ticket~~ Recorded Representation., UR.2.6.3. ~~Printed Ticket~~Recorded Representation.

Amend Handbook 44, Milk Meter Code as follows:

S.1.4.2. ~~Printed Ticket~~ Recorded Representation – If a computing-type device issues a ~~printed ticket~~ recorded representation which ~~displays~~ includes the total computed price, the ~~ticket recorded representation~~ shall ~~also have printed clearly thereon~~ include the total quantity of the delivery, the appropriate fraction of the quantity, and the price per unit of quantity.
(Amended 1989 and 20XX)

UR.2.2. ~~Printed Ticket.~~ Recorded Representation. – Any ~~printed ticket issued~~ recorded representation created by a device of the computing type ~~on which there is printed~~ includes the total computed price, the total quantity, or the price per unit of quantity, shall also ~~show~~ include the other two values (~~either printed or in clear hand script~~). and shall comply with G-S.5.6.
(Amended 1989 and 20XX)

B4: MFM-21.2 D S.6. ~~Printer~~Recorded Representations., UR.2.6. ~~Ticket—Printer,~~ Customer Ticket, ~~Recorded Representation.~~, UR.3.4. ~~Printed Ticket.~~ Recorded Representation.

Amend Handbook 44, Mass Flow Meter Code as follows:

S.6. ~~Printer.~~ Recording Element – When an assembly is equipped with means for ~~printing~~ recording the measured quantity, the following conditions apply:

- (a) the scale interval shall be the same as that of the indicator;
- (b) the value of the ~~printed~~ recorded quantity shall be the same value as the indicated quantity;
- (c) *the ~~printed~~ recorded quantity shall also include the mass value if the mass is not the indicated quantity;*
[Nonretroactive as of January 1, 2021]
- (d) a quantity for a delivery (other than an initial reference value) cannot be recorded until the measurement and delivery has been completed;
- (e) the ~~printer~~ recording element is returned to zero when the resettable indicator is returned to zero; and
- (f) the ~~printed~~ recorded values shall meet the requirements applicable to the indicated values.

(Amended 2016, and 20XX)

S.6.1. ~~Printed Receipt~~ Recorded Representations. – ~~Any~~ When a quantity is delivered, ~~printed quantity~~ the recorded representation shall include an identification number, the time and date, and the name of the seller. This information may be printed by the device or pre-printed on the ticket.

(Amended 20XX)

And

UR.3.3 ~~Ticket Printer, Customer Ticket,~~ Recorded Representation. – Vehicle-Mounted metering systems shall be equipped with ~~a ticket printer which shall be used for~~ means to record all sales where product is delivered through the meter and shall comply with G-S.5.6. A copy of the ~~ticket~~ recorded representation issued by the device shall be ~~left with~~ provided to the customer at the time of delivery or as otherwise specified by the customer.

(Added 19934) (Amended 20XX)

...

UR.3.4. ~~Printed Ticket.~~ Recorded Representation. – The total price, the total quantity of the delivery, and the price per unit shall be printed provided on any ~~ticket~~ recorded representation issued by a device of the computing type and containing any one of these values.

(Added 1993) (Amended 20XX)

B4: CDL-21.1 D S.1.4.1. ~~Printed Ticket~~Recorded Representations., UR.2.4.2. Tickets or Invoices. Recorded Representation.

Amend Handbook 44, Carbon Dioxide Liquid-Measuring Devices Code as follows:

S.1.4.1. ~~Printed Ticket.~~ Recorded Representation– Any ~~printed ticket~~ recorded representation issued by a device of the computing type ~~on which there is printed~~ includes the total computed price shall ~~have printed clearly thereon~~ also include the total quantity of the delivery and the price per unit.

(Amended 20XX)

UR.2.4.2. ~~Tickets or Invoices~~ Recorded Representation. – Any ~~written invoice or printed ticket~~ recorded representation based on a reading of a device that is equipped with an automatic temperature or density compensator shall ~~have shown thereon~~ include that the quantity delivered has been temperature or density compensated.

(Amended 20XX)

B4: HGM-21.1 D S.2.6. Recorded Representations, Point of Sale Systems., S.6. Printer. Recording Element., UR.3.2. Vehicle-mounted Measuring Systems Ticket Printer Recording Element., UR.3.3. Printed Ticket. Recorded Representation.

Amend Handbook 44, Hydrogen Gas-Measuring Devices Code as follows:

S.2.6. Recorded Representations, Point of Sale Systems. – A printed receipt shall be available through a built-in or separate recording element for transactions conducted with point-of-sale systems or devices activated by debit cards, credit cards, and/or cash. The printed receipt shall contain the following information for products delivered by the dispenser:

- (a) the total mass of the delivery;
- (b) the unit price;
- (c) the total computed price; and

(d) the product identity by name, symbol, abbreviation, or code number.

(Amended 20XX)

...

S.6. ~~Printer.~~ Recording Element – When an assembly is equipped with means for ~~printing~~ recording the measured quantity, the ~~printed~~ recorded information must agree with the indications on the dispenser for the transaction and the ~~printed~~ recorded values shall be clearly defined.

(Amended 20XX)

S.6.1. ~~Printed Receipt.~~ Recorded Representation – ~~Any~~ When a quantity is delivered, printed quantity the recorded representation shall include an identification number, the time and date, and the name of the seller. ~~This information may be printed by the device or pre-printed on the ticket.~~

(Amended 20XX)

And

UR.3.2. ~~Vehicle-mounted Measuring Systems Ticket Printer~~ Recording Element.

(Amended 20XX)

UR.3.2.1. ~~Customer Ticket~~ Recording Element. – Vehicle-Mounted metering systems shall be equipped with ~~a ticket printer which shall be used for~~ means to record all sales where product is delivered through the device and shall comply with G-S.5.6. A copy of the ~~ticket recorded representation~~ issued by the device shall be ~~left with~~ provided to the customer at the time of delivery or as otherwise specified by the customer.

(Amended 20XX)

...

UR.3.3. ~~Printed Ticket.~~ Recorded Representation. – The total price, the total quantity of the delivery, and the price per unit shall be ~~printed~~ provided on any ~~ticket recorded representation~~ issued by a device of the computing type and containing any one of these values.

~~(Added 1993)~~ (Amended 20XX)

B4: OTH-21.2 D Appendix D – Definitions.: recorded representations, recording element.

Amend Handbook 44, Appendix D – Definitions as follows:

recorded representation. – The printed, embossed, electronic, or other representation that is recorded as a quantity, unit price, total price, product identity or other information required by a weighing or measuring device. [1.10, 2.20, 2.21, 2.22, 2.24, 2.25, 3.30, 3.31, 3.32, 3.33, 3.34, 3.35, 3.36, 3.37, 3.38, 3.39, 3.40, 5.54, 5.55, 5.56(a), 5.56(b), 5.57, 5.58, 5.60]

recording element. – An element incorporated in a weighing or measuring device by means of which ~~its~~ the device's performance relative to quantity or money value is permanently recorded electronically ~~or~~ on a tape, ticket, card, or the like, in the form of a printed, stamped, punched, or perforated representation or recorded electronically in instances where that option is permitted by specific

code. [1.10, 2.20, 2.21, 2.22, 2.24, 2.25, 3.30, 3.31, 3.32, 3.33, 3.34, 3.35, 3.36, 3.37, 3.38, 3.39, 3.40, 5.54, 5.55, 5.56(a), 5.56(b), 5.57, 5.58, 5.60]

NIST OWM Detailed Technical Analysis:

Although NIST OWM feels that all proposed changes would benefit from additional review, NIST OWM believes that the additional changes made to G-S.5.6 provides clarity. NIST OWM believes a Developing status is appropriate so that changes to the B4 specific codes are carefully reviewed to ensure the proposed changes do not change the original intent of the specific section before moving these items forward for a vote.

NIST OWM provided the previous comments. The key purpose of this block of proposals is to broaden the requirements by eliminating the term “print/printed” in specific NIST HB 44 codes and clarifying that providing an electronic recorded representation in lieu of a printed recorded representation is an acceptable option as was adopted in G-S.5.6. Recorded Representations in 2014. NIST OWM provides the following technical points for consideration.

Paragraph G-S.5.6. Recorded Representation addresses multiple points relative to recorded representations:

1. Any NIST Handbook 44 requirement applicable to indicating and recording elements also apply to recorded representations.
2. Recorded values must be printed in a numerical or “digital” form. The reference to the term “digitally” refers to the use of that term as described in the definition for “digital type,” which describes “digitally” as being presented in numbers.
3. Providing the customer with an option of “not receiving a receipt” is acceptable, so long as the *customer* is making that choice to not receive a receipt.
4. For systems that are capable of issuing an electronic receipt, the customer may be given the option of receiving the receipt in an electronic form. However, providing the option for an electronic receipt does not negate any requirement for the system to provide the customer with the option of a hard copy receipt for those specific codes where a hard copy receipt is required. That is, the system may offer additional options beyond the hard copy form; however, the hard copy form must remain an option for the customer to choose. The first part of this also sentence recognizes that not all systems are capable of providing an electronic option (though this would not preclude some codes from requiring such an option), but when such an option is available, the customer may choose that option over other options provided.

The current Item Under Consideration presents the recommended changes to G-S.5.6. Recorded Representations as follows:

Current Item Under Consideration in 2021 S&T Committee Interim Report:

G-S.5.6. Recorded Representations. – Insofar as they are appropriate, the requirements for indicating and recording elements shall also apply to recorded representations. All recorded values shall be ~~printed~~ **provided** **presented** digitally. In applications where recorded representations are required **by a specific code**, the customer may be given the option of not receiving the recorded representation. **Unless otherwise specified, recorded representations referenced in specific codes shall be made available to the customer as**

a minimum in hard copy form. However, for systems equipped with the capability of issuing an electronic receipt, ticket, or other recorded representation, the customer may be given the option to receive any required information electronically (e.g., via cell phone, computer, etc.) in lieu of or in addition to a hard copy.
(Amended 1975, 2014 **and 20XX**)

With regard to the specific changes proposed to G-S.5.6., NIST OWM offers the following technical comments:

- **Sentence 2:** “All recorded values shall be ~~printed~~ **provided** **presented** digitally.”

OWM believes the proposed change to the second sentence in G-S.5.6. are appropriate. The original intent of the second sentence was to address the need for a numerical format. As noted above, the reference in that sentence to the term “digitally” refers to the use of that term as described in the definition for “digital type,” which describes “digitally” as being presented in numbers. The definition from NIST HB 44 Appendix D:

- o **digital type.** – A system of indication or recording of the selector type or one that advances intermittently in which all values are presented digitally, or in numbers. In a digital indicating or recording element, or in digital representation, there are no graduations. [1.10]

The word “printed” reflects the technology that was available at the time the requirements were written; the use of the word “printed” was not intended to limit recorded representations to only hard copy form. Thus, the use of the word “presented” in place of “printed” does not change the original intent of that statement and helps to recognize that other forms of recorded representations are now available.

As an editorial comment, OWM notes that the word “provided” is not part of the current language in G-S.5.6. Although the intent of showing the term as struck was to distinguish it from earlier versions of the proposal, this term should be struck from the proposal when presenting it for consideration.

- **Sentence 3:** “In applications where recorded representations are required **by a specific code,** the customer may be given the option of not receiving the recorded representation.”
OWM believes the proposed change to the third sentence by adding the term “by a specific code” is appropriate and simply emphasizes that individual codes may specify the need for a recorded representation.
- **Sentence 4:** “**Unless otherwise specified, recorded representations referenced in specific codes shall be made available to the customer as a minimum in hard copy form.**”

OWM believes the addition of this new fourth sentence clarifies that the *customer* must have the option of receiving the recorded representation in hard copy form but recognizes there may be some codes (such as the tentative code 3.40 for Electric Vehicle Fueling Systems) in which offering only an electronic form is acceptable.

- **Sentence 5:** “**However,** for systems equipped with the capability of issuing an electronic receipt, ticket, or other recorded representation, the customer may be given the option to receive any required information electronically (e.g., via cell phone, computer, etc.) in lieu of or in addition to a hard copy.”

OWM believes the addition of the word “However” is unnecessary and may cause confusion. The current form of the sentence is appropriate. Thus, OWM recommends striking the proposed addition of the word “However” at the start of that sentence.

Based on the assessment above OWM recommended the final proposal be modified to recommend the following:

G-S.5.6. Recorded Representations. – Insofar as they are appropriate, the requirements for indicating and recording elements shall also apply to recorded representations. All recorded values shall be ~~printed~~ **presented** digitally. In applications where recorded representations are required **by a specific code**, the customer may be given the option of not receiving the recorded representation. **Unless otherwise specified, recorded representations referenced in specific codes shall be made available to the customer as a minimum in hard copy form.** For systems equipped with the capability of issuing an electronic receipt, ticket, or other recorded representation, the customer may be given the option to receive any required information electronically (e.g., via cell phone, computer, etc.) in lieu of or in addition to a hard copy.

(Amended 1975, 2014 **and 20XX**)

These changes are represented in the 2022 Interim Meeting Report, Item Under Consideration with the exception of striking “However” as recommended above.

At the 2021 CWMA Annual Meeting, a suggestion was made to simplify G-S.5.6 by removing changes that were added to G-S.5.6 in 2014 to address systems with the capability of issuing an electronic receipt and, instead, specify the electronic receipt option as an acceptable form of receipt in each specific code. Although NIST OWM agrees that the General Code requirement may benefit from a restructuring of the paragraph to improve its use, NIST OWM believes there is value in providing information on options for recorded representation in the general code requirements. The specific intent of the decision made in 2014 to include this language in the General Code was to avoid the need to add specific language to each code. By doing so, this avoids a situation in which a given code is inadvertently overlooked and the potential option for an electronic form of recorded representation may be in question. Thus, OWM does not believe the reference to electronic receipts should be removed from the General Code.

Nevertheless, if there is a desire to streamline the paragraph, the Submitter and the Committee may wish to consider using an alternate format such as sub-paragraphs or bulleted points to help clarify the various sections of the paragraph. For example, G-S.5.6. might be restructured as follows:

G-S.5.6. Recorded Representations. – The following shall apply to recorded representations.

- (a)** Insofar as they are appropriate, the requirements for indicating and recording elements shall also apply to recorded representations.
- (b)** All recorded values shall be ~~printed~~ **presented** digitally.
- (c)** In applications where recorded representations are required **by a specific code**, the customer may be given the option of not receiving the recorded representation.

(d) Unless otherwise specified, recorded representations referenced in specific codes shall be made available to the customer as a minimum in hard copy form. For systems equipped with the capability of issuing an electronic receipt, ticket, or other recorded representation, the customer may be given the option to receive any required information electronically (e.g., via cell phone, computer, etc.) in lieu of or in addition to a hard copy.

(Amended 1975, 2014 and **20XX**)

In addition to its comments regarding the proposed changes to paragraph G-S.5.6. Recorded Representations, NIST OWM also recommends the following editorial changes to this block of items:

B4: LMD-21.2 - UR.3.4. ~~Printed Ticket~~. Strike out “Printed Ticket”

B4: VTM-21.1 - S.1.4.2. ~~Printed Ticket~~—Strike out “Printed Ticket”

These changes are represented in the 2022 Interim Meeting Report, Item Under Consideration.

Summary of Discussions and Actions:

At the 2021 Interim Meeting Mr. Charles Stutesman (Kansas), submitter of the item, agreed that the item should be Developing and noted that updates to the Item Under Consideration were provided to the S&T Committee based on reviews that he had with NIST OWM. Mr. Dmitri Karimov (MMA) commented that the proposed changes to recognize electronically captured tickets are needed, editorial corrections are needed to some parts of the proposal, and he agreed with a Developing status for this item. Ms. Diane Lee (NIST OWM) commented that there are two proposed changes to HB 44, Mass Flow Meter Code, Paragraph U.R.3.3 in the 2021 Interim Agenda. One proposal is Block 4 MFM-21.2 UR.3.3. (which was incorrectly number as UR.2.6 in the Item Under Consideration in the 2021 Interim Meeting agenda) and the other is item MFM-21.1. UR.3.3. on the 2021 Interim Meeting agenda. The submitters should work together to provide one proposed change.

During the Committee work session, the Committee assigned a Developing status to Item Block 4.

At the 2021 Annual Meeting Mr. Charles Stutesman (Kansas) stated that he looks forward to maintaining Developing status between now and the 2022 Interim. Mr. Stutesman explained that when the electronic receipt provision was added to NIST HB 44 General Code requirements, a change to the specific Codes were needed because the specific Codes supersede the General Code. All the code sections included in this block have printer requirements. As such, it was not the goal to remove printers but to add the option for electronic receipts if customer wants it. Mr. Stutesman would appreciate comments and suggestions for changes to the proposal.

During the Committee work session, the Committee assigned a Developing status to Item Block 4.

At the 2022 Interim Meeting Mr. Stutesman noted that some editing and additional work is needed before forwarding as a Voting item. Mr. Stutesman recommended that the item remain Developing. California DMS recommended a Developing status for this item. Mr. Dmitri Karimov (MMA) commented that proposed changes to recognize electronically captured tickets are needed and that editorial corrections are needed to some parts of the proposal. Mr. Karimov agreed with a Developing status for this item. An SMA representative also commented on support for this item because it recognizes the importance of providing flexible options for recorded representations to customers. SMA sees value in the item and agreed with a Developing status for this item. NIST OWM agreed with the need to address current language in the proposal and supports development.

NIST OWM Analysis
2023 NCWM Interim S&T Agenda Items
1/5/2023

During the Committee work session, the Committee assigned a Developing status to Item Block 4. The Committee supports the work and recommends the continued work of all stakeholders. For more information or to provide comment, please contact:

Mr. Charles Stutesman
Kansas Department of Agriculture
(785) 564-6683, charles.stutesman@ks.gov

At the 2022 Annual Meeting open hearings Mr. Charles Stutesman (Kansas) commented that he worked with NIST OWM to add changes to the item and he also requested additional feedback from interested parties. Mr. Stutesman requested a Developing status for this item.

During the Committee work session, the Committee agreed to a Developing status for this item to allow for additional comments from interested parties.

Regional Association Reporting:

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting no comments were heard on this item. During open hearings, no comments were heard on this item.

The WWMA S&T Committee recommended that this item remain Developing which would allow the submitter to ensure the edits are applicable for the identified sections. The Committee looks forward to an update on this Block.

Southern Weights and Measures Association

No comments were received on this item during the 2022 SWMA Annual Meeting. The SWMA S&T Committee recommended this item remain as a Developing Item.

Northeastern Weights and Measures Association

Ms. Diane Lee (NIST OWM) noted that NIST is working with the State of Kansas on this item. The item has been on agenda and recommends that it stays on as it is addressing all codes and tickets. Mr. John McGuire (New Jersey) is in favor of voting but noted that the item conflicts with New Jersey law. Mr. Jim Willis (New York), Mr. Walt Remmert (Pennsylvania), and Ms. Cheryl Ayer (New Hampshire) recommend a Voting status.

After hearing comments from the floor, the Committee believes this item has merit and is fully developed. The Committee recommended that this item be give a Voting status.

Central Weights and Measures Association

No comments were made from the floor.

The CWMA S&T Committee recommended this remains as a Developing Item.

Block 5 Items (B5) Test Drafts

B5: LMD-23.2 N.3.5. Wholesale Devices
B5: VTM-23.2 N.3. Test Drafts

Source: Murray Equipment, Inc./Total Control Systems.

Submitter's Purpose and Justification:

Change the word “should” to “shall” to clarify the importance of using a calibrated container of adequate size to accept a “test draft of at least the amount delivered by the device in 1 minute at its maximum discharge rate” where it is referenced in Handbook 44 Vehicle-Tank Meters and the Liquid Measuring Devices codes.

In some locations, the largest available prover for fuel field testing is 100 gallons. In high flow situations over 100 gpm, the 100-gallon prover does not meet requirement of HB44. Inspectors are using what they have and doing the best they can. However, using a proving can smaller than what is recommended in HB44 can lead to errors in the field including failing an accurate metering system that would have been approved if the draft size was the correct size. In fact, we have experienced situations where mechanical registers are favored over electronic registers when smaller than recommended size test drafts are used due to inspectors visually estimating fractions of gallons on a mechanical register that reads out in whole gallons while only reading in whole gallons on electronic registers set to read in whole gallons.

In the following example, there is an aircraft refueler that normally operates at 300 GPM through a standard aircraft underwing fueling nozzle. The inspector is using the over-wing nozzle at 100 GPM in the available 100-gallon proving can to test the system. The customer wants the meter to display in whole gallons due to the high delivery speed and large volume of delivered fuel per transaction when fueling aircraft at 300 GPM. Because the VTM code says the test draft “should” be equal to at least the amount delivered by the device in 1 minute at its maximum discharge rate, the inspector felt comfortable using the 100-gallon proving can rather than securing a 300-gallon or larger proving can.

Besides feeling empowered to use a proving can smaller than the recommended size, the inspector also interpreted the text from N.4.1 Normal Tests. – “...under the conditions of the installation” to mean that the meter display could not be changed to indicate decimal points, but rather must be left on whole gallons. Most likely the meter with electronic display would have passed this “non-normal” test if the display would have been set to tenths or hundredths of gallons for the test draft. The ½ gallon of potential rounding error caused by the whole gallon display introduced an additional system error of up to 0.5% on a 100-gallon prover, which make is nearly impossible to pass a test with $\pm 0.2\%$ of allowable error.

In the example above, the inspector set conditions that encouraged high variability in the system accuracy and precision. When questioned about the test draft conditions, the inspector referred to the Handbook 44 code, interpreting it to allow the undersized proving can and not allow meter display decimal changes. Changing Handbook 44 text from “should” to “shall” will prevent undersize test drafts. It is also important to clarify what “...under the conditions of the installation” specifically refers to; that is, the fluid path elements such as hose length, hose type, nozzle setting, system valve settings, etc. Metering systems with electronic digital displays should not be handicapped due to being set for whole gallons or tenths of gallons especially if the proving can used is smaller than what is required or recommended by Handbook 44.

One of the technological advancements of electronic registers over mechanical registers is the option of quickly and easily changing the number of decimal points shown on the display. Something that literally takes seconds to do on an electronic register is cumbersome, time consuming, and generally not recommended outside of a factory on mechanical registers. With very few exceptions, customers,

distributors, and manufacturers favor electronic registers due to improved features, improved durability and accuracy. Mechanical registers, on the other hand, are becoming obsolete and should not be given preference due to a misunderstanding of the meaning of the phrase "...under the conditions of the installation."

The submitter acknowledges the following arguments:

- 1) **Some locations don't have access to calibration containers large enough to hold the required test draft size.** In this case, the correct size calibration container should be borrowed or rented to meet HB44 requirements.
- 2) **Everything is fine with the current code text, don't change it.** The problem is that everything is NOT fine now. Due to the soft "should" language rather than the un-negotiable "shall" language, inspectors do from time to time use smaller than recommended proving cans that can lead to failing an accurate metering system or approving an inaccurate system.
- 3) **Inspectors know it is OK to change the decimal points for testing when using a calibration container that is smaller than is recommended.** In the example above, the inspector would NOT allow the decimal points to be changed for testing, so not all inspectors seem to agree.
- 4) **Inspectors may have to break the calibration seal to change the decimal point settings in some situations.** That is why the inspectors have calibration seals.

Requested Status by Submitter: Not Specified

OWM Executive Summary for Block 5 Items (B5) – Test Drafts

OWM Recommendation: NIST OWM Supports this proposed change to remove "should" and replace it with "shall" in the N.3.5. and N.3 paragraphs of the LMD Code. We also suggest that the submitters work together to develop one proposal for changes to LMD N.3.5.

- To ensure that an inspector is required to use the correct size test draft, the submitter is recommending that "should" in LMD-23.2 N.3.5. Wholesale Devices and VTM-23.2 N.3. Test Drafts be changed to "shall"
- Item LMD-23.4 on the 2022 Interim Meeting agenda is another proposal for changes to the LMD N.3.5 paragraph. These changes are to ensure that the paragraph is more encompassing of other test methods, specifically when testing SVPs.
- We encourage the submitters of LMD-23.4 and Block 5 to work together to combine the changes that are being proposed to the same paragraph, N.3.5. Wholesale Devices. If the submitters are in agreement with combining these changes a proposed change for the combined items LMD-23.4 and B5: LMD N.3.5 is provided below:

N.3.5. Wholesale Devices.– The **total** delivered quantity **for any required accuracy test** ~~should~~ **shall** be equal to, **or is recognized as being representative of, a volume equivalent to** at least the amount delivered by the device in one minute at ~~its~~ **the meter's** maximum discharge rate **and shall in no case be less than 200 L (50 gal).**

(Amended 1987, ~~and~~ 1996, **and 2023**)

Table 3. Summary of Recommendations							
Block 5 Items (B5) – Test Drafts							
	V	D	W	A	I	Notes*	Comments
Submitter							
OWM							
WWMA		✓					
SWMA			✓				
NEWMA		✓					
CWMA			✓				
NCWM							
	Letters of Support			Letters of Opposition		Notes	
Industry							
Manufacturers							
Retailers and Consumers							
Regulators							
<p>*Notes Key:</p> <ul style="list-style-type: none"> 1 – Submitted modified language 2 – Item not discussed 3 – No meeting held 4 – Not submitted on agenda 5 – No recommendation or not considered 							

B5: LMD-23.2 N.3.5. Wholesale Devices

Item Under Consideration:

Amend Handbook 44, Liquid Measuring Devices Code as follows:

N.3.5. Wholesale Devices. - The delivered quantity ~~should~~**shall** be equal to at least the amount delivered by the device in one minute at its maximum discharge rate and shall in no case be less than 200L (50 gal).

B5: VTM-23.2 N.3. Test Drafts

Item Under Consideration:

Amend Handbook 44, Vehicle Tank Meters Code as follows:

N.3. Test Drafts. (VTM Code) – Test drafts ~~should~~**shall** be equal to at least the amount delivered by the device in 1 minute at its maximum discharge rate and shall in no case be less than 180 L (50 gal) or 225 kg (500 lb).

NIST OWM Detailed Technical Analysis:

To ensure that an inspector is required to use the correct size test draft, the submitter is recommending that “should” in LMD-23.2 N.3.5. Wholesale Devices and VTM-23.2 N.3. Test Drafts be changed to “shall”.

Item LMD-23.4 on the 2022 Interim Meeting agenda is another proposal for changes to the LMD N.3.5 paragraph. These changes are to ensure that the paragraph is more encompassing of other test methods, specifically when testing SVPs.

We encourage the submitters of LMD-23.4 and Block 5 to work together to combine the changes that are being proposed to the same paragraph, N.3.5. Wholesale Devices. If the submitters are in agreement with combining these changes a proposed change for the combined items LMD-23.4 and B5: LMD N.3.5 is provided below:

N.3.5. Wholesale Devices – The **total** delivered quantity **for any required accuracy test shall** be equal to, **or is recognized as being representative of, a volume equivalent to** at least the amount delivered by the device in one minute at **its the meter’s** maximum discharge rate **and shall in no case be less than 200 L (50 gal).**

(Amended 1987, ~~and~~ 1996, and 2023)

NIST OWM supports this proposed change to remove “should” and replace it with “shall” in the N.3.5. and N.3 paragraphs of the LMD Code. We also suggest that the submitters work together to develop one proposal for changes to LMD N.3.5.

Regional Association Reporting:

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received: Mr. Brent Price (Gilbarco, Inc.) - Supported the item. The word “shall” expresses more importance.

Mr. Michael Keilty (Endress + Hauser Flow USA, Inc.) did not see why this is necessary to change from “should” to “shall” to fix one particular instance where there was a problem. Recommended withdrawal.

Mr. Jose Arriaga (Orange County, California) stated that “Shall” is becoming a bit antiquated. The modern legal interpretation would be to change “shall” to “must” .

The WWMA S&T Committee recommended that this item be assigned a Developing status. The Committee also recommended that the submitter of this item take into consideration the testimony heard during open hearings and work together with the submitter of item LMD-23.4 to develop language that will support both of their purposes.

Southern Weights and Measures Association

During the 2022 Interim Meeting the following comments were received during the 2022 SWMA Annual Meeting Mr. Keilty (Endress+Hauser) stated that this item represented the confusion over this issue and is a misapplication. He recommended withdrawal.

Mr. Searles (API) stated that he has no issue with should to shall, and that he wasn't sure if this correction would address the submitters problem.

The SWMA S&T Committee recommended that this item be Withdrawn.

Northeastern Weights and Measures Association

During the 2022 Interim Meeting, Mr. John Hathaway (Total Control Systems/Murray Equipment) believes that this proposal would solve issues of inspectors using undersized provers for testing. Mr. Keilty believed that this proposal was drafted for a single instance where a meter under test was indicating in whole gallons, delivering at 300 gallons per minute and tested using a 100 gallon prover. This does not warrant a change to the whole code due to one instance. Mr. Searles commented that the change to the code would not bother API but agrees with Mr. Keilty's point. Mr. Bob Murnane (Seraphin Test Measure) commented that he understands the reason for the proposal, but it doesn't make sense commonsense wise. He hopes inspectors would use the correct equipment. Mr. Hathaway noted that changing "should" to "shall" is making it a non-debatable position. Mr. Jim Willis (New York) commented that empowering inspectors in the field, where it is appropriate, to test with a smaller prover is an advantage if that's all they have at their disposal. Mr. Willis recommended withdrawal. Mr. James Cassidy (Massachusetts) concurred with Mr. Willis. Mr. Jason Flint (New Jersey) commented that New Jersey relies on "should" versus "shall" due to inspectors trying to use a 25 gallon prover to test 800 gal/min meter and recommended a Developing status.

After hearing comments from the floor, the Committee believes the item has merit, but more discussion needs to be had. The Committee recommended this time be given a Developing status.

Central Weights and Measures Association

Mr. Keilty stated that this item conflicts with B1 and he does not support. Mr. Searles recommended the item be withdrawn. Mr. Dmitri Karimov (Liquid Controls) stated that the item stemmed from field inspectors trying to test 100-gal flow rate with 50 gal provers. This item conflicts with an API proposal. He recommended that the item be Withdraw.

The CWMA S&T Committee recommended this item be withdrawn.

Item Block 6 (B6) Commercial and Law Enforcement, Axle and Axle Group Weights

B6: SCL-22.1 S.1.14. Recorded Representation of Axle or Axle Group Weights

B6: SCL-22.3 UR.3.3. Single-Draft Vehicle Weighing., and UR.3.4. Axle and Axle Group Weight Values.

Source: NIST Office of Weights and Measures

Submitter's Purpose and Justification:

This proposed change is intended to add clarification regarding the implications of using weighing and measuring devices for transactions that may be considered by some as commercial while there is no clear guidance provided.

OWM has noted a number of inquiries submitted to our office for explanation on the many and various issues involved with the use of weighing or measuring devices as commercial devices when there is charge for doing so. Law enforcement devices may be regulated in a different manner than commercial devices

(e.g., allows highway weight limit enforcement through multi-draft weighing) when commercial devices are not allowed to be used in that way.

The submitter pointed out that there seems to be a difference in opinions regarding this practice constitutes a commercial transaction.

The submitter requested Voting status for these items in 2022.

OWM Executive Summary for Item Block 6 (B6) – Commercial and Law Enforcement, Axle and Axle Group Weights

OWM Recommendation: That the Committee maintain the current Developing status of these items on its agenda.

Reason: The SMA, during its Fall 2022 meeting, proposed additional changes to paragraph S.1.15.1. Axle and Axle Group Loads in item B6:22.1 and also indicated additional work is needed to the B6:SCL-22.3 item.

- When item SCL-22.1 was originally proposed there was a lag in the publication process for 2020 and 2021; so, the numbering of the paragraph in the Item Under Consideration in this document has been updated to S.1.15. Not so, however, in the Committee’s 2023 NCWM Interim Agenda (i.e., NCWM 2023 Publication 15) where it is still appears today as paragraph S.1.14. Consequently, OWM requests the Committee change the paragraph references S.1.14., S.1.14.1., and S.1.14.2. in SCL-22.1 to S.1.15., S.1.15.1., and S.1.15.2., respectively, when completing its Interim Meeting Report (2023 NCWM Publication 16.)
- The first proposed sub-paragraph of SCL-22.1 (i.e., S.1.15.1) requires the ticket to clearly identify the particular independent scale platform associated with each printed weight value.

The second proposed sub-paragraph of SCL-22.1 (i.e., S.1.15.2.) requires the summed total of all platforms to be identified as the vehicle’s total weight in instances where all axle and axle groups of the vehicle being weighed fit onto a live portion of the scale system and are weighed simultaneously as a single draft. In instances where the vehicle being weighed cannot be weighed as a single draft (e.g., oversized vehicles that do not fit onto the scale) thus necessitating weighing the vehicle in two drafts, the ticket must provide clear indication that the total weight is “not legal-for-trade” or similar text to make known the gross vehicle weight is not valid for use in commercial sales transactions.

- SCL-22.3 proposes amending the text in the “Note” of existing HB-44 Scales Code paragraph UR.3.3. Single-Draft Vehicle Weighing and removing the “Note” reference. These proposed changes are needed because in 2022 the NCWM agreed to amend paragraph G-A.1. Commercial and Law-Enforcement Equipment of NIST Handbook 44 to explicitly make clear weighing and measuring equipment used for the purpose of providing a weight or measure for a fee constitutes commercial use of that equipment. Paragraph UR.3.3. currently requires a vehicle or vehicle combination to be weighed “commercially” on a vehicle scale only as a single draft except as noted in subparts (a) and (b) of the paragraph. The “Note” in UR.3.3. currently exempts highway-law-enforcement scales and scales used for the collection of statistical data from having to comply. Multi-independent platform vehicle scale systems typically weigh vehicles and vehicle combinations in multiple drafts yet comply with paragraph UR.3.3. because subpart (b) makes this permissible. When installed at a truck stop, the predominant commercial use of these vehicle scale systems is to weigh vehicles and vehicle combinations for a fee. All axles and axle groups of some

OWM Executive Summary for Item Block 6 (B6) – Commercial and Law Enforcement, Axle and Axle Group Weights

oversized vehicles, however, are not able to fit onto one of the live platforms of a vehicle scale system and be weighed simultaneously. This necessitates the weighing of the portion of the vehicle that doesn't fit separately from the rest of the vehicle (i.e., split weighing). Weights and Measures officials have typically allowed this practice when the only use of those weight determinations is to verify compliance with highway legal load limits. Because a fee is charged, this too constitutes commercial use of the scale systems, but violates current paragraph UR.3.3. It is for this reason OWM is proposing the change to paragraph UR.3.3.

- SCL-22.3 also adds a new HB 44 Scales Code user requirement to make clear the acceptable use of multi-platform vehicle scale systems to charge a fee for the commercial service of providing customers (usually truckers) axle weights, axle group weights, and total weight of their vehicles to enable them to determine compliance with state and federal legal load limits.
- OWM amended the proposal in SCL-22.3. prior to the 2022 NCWM Annual Meeting and recommended during S&T open hearings that the Committee update the proposal to the revised version. The Committee, in consideration of the comments received during open hearings, agreed to replace the Block 6 SCL-22.1 proposal in its Interim Meeting agenda (2022 NCWM Publication 15) with the updated version provided by OWM. Unfortunately, the National S&T Committee neglected to update the proposal in its addendum sheets for the 2022 NCWM Annual Meeting and the version of the proposal appearing on the 2023 regional S&T Committee agendas wasn't the updated version. OWM recently resubmitted the updated version to the National S&T Committee so the version now appearing in the Committee's current agenda is correct.
- OWM can support the changes recommended by the SMA during its Fall 2022 meeting to the first sentence of proposed new paragraph S.1.14.1. as shown in shaded text below:

S.1.14.1. Axle and Axle Group Loads. – All recorded representations of the different axle and axle group loads of a vehicle when weighed in a single draft on a multi-independent platform vehicle scale system shall be identified by providing indication of either:

As noted earlier, however, this proposed paragraph should be referenced S.1.15.1 in the Committee's current agenda.

- With respect to the SMA's Fall 2022 position statement for item B6: SCL-22.3, OWM is very interested in learning more specifically the additional work SMA believes is necessary.

Table 3. Summary of Recommendations

Block 6 Items (B6) – Commercial and Law enforcement, Axle and Axle Group Weights							
	V	D	W	A	I	Notes*	Comments
Submitter (OWM)		✓					
WWMA		✓				1	
SWMA		✓					
NEWMA	✓						

Table 3. Summary of Recommendations							
Block 6 Items (B6) – Commercial and Law enforcement, Axle and Axle Group Weights							
	V	D	W	A	I	Notes*	Comments
CWMA		✓					
NCWM							
	Letters of Support		Letters of Opposition		Notes		
Industry							
Manufacturers (SMA)					The SMA supports paragraph S.1.15 Axle and Axle Group Loads with changes. The SMA supports the intent of SCL-22.3 and believes additional development is needed.		
Retailers and Consumers							
*Notes Key: 1 – Submitted modified language 2 – Item not discussed 3 – No meeting held 4 – Not submitted on agenda 5 – No recommendation or not considered							

Item Under Consideration:

B6: SCL-22.1 Recorded Representation of Axle or Axle Group Weights

Amend NIST Handbook 44, Scales Code as follows:

S.1.15. Recorded Representations, Multi-Independent Platform¹ Vehicle Scale Systems

S.1.15.1. Axle and Axle Group Loads. - All recorded representations of the different axle and axle group loads of a vehicle weighed on a multi-independent platform vehicle scale system shall be identified by providing indication of either:

(a) the portion of the vehicle to which they represent (e.g., “axle-group 1, axle group 2, axle group 3,” or if using axle and axle group descriptions, “steering axle, drive axles, trailer axles”), or

(b) the particular independent scale platform from which they were obtained (e.g., “Platform 1, Platform 2, Platform 3”).

S.1.15.2. Total Vehicle Weight. - If a summed total of all axle and axle group loads of a vehicle weighed on a multi-independent platform vehicle scale system is recorded, the recorded value shall be clearly identified as:

- (a) “Total Vehicle Weight,” “Vehicle Weight,” (or other similar terms that clearly identify the value as the vehicle’s total weight) providing all axle(s) and axle groups of the vehicle weighed were positioned on a live portion of the weighing/load-receiving elements and weighed simultaneously when the summed total was determined², or
- (b) “Not-Legal-For-Trade” unless all axle and axle groups of the vehicle weighed were simultaneously positioned on a live portion of the weighing/load-receiving elements when the summed total was determined, or the vehicle was weighed using the alternative method described in footnote 2 of this paragraph.

¹Multi-independent platform means each platform of the scale is a single independent weighing/load-receiving element unattached to adjacent elements and with its own A/D conversion circuitry and displayed weight.

²Alternatively, the individual components of the vehicle being weighed may be uncoupled, positioned completely on the live elements of the scale, weighed separately, and then totaled.

B6: SCL-22.3 D UR.3.3. Single-Draft Vehicle Weighing., and UR.3.4. Axle and Axle Group Weight Values.

Amend Handbook 44, Scales Code as follows:

UR.3.3. Single-Draft Vehicle Weighing – A vehicle or a coupled-vehicle combination shall be commercially weighed on a vehicle scale only as a single draft. That is, the total weight of such a vehicle or combination shall not be determined by adding together the results obtained by separately and not simultaneously weighing each end of such vehicle or individual elements of such coupled combination. However, the weight of:

- (a) a coupled combination may be determined by uncoupling the various elements (tractor, semitrailer, trailer), weighing each unit separately as a single draft, and adding together the results; or
- (b) a vehicle or coupled-vehicle combination may be determined by adding together the weights obtained while all individual elements are resting simultaneously on more than one scale platform.

Note: This paragraph does not apply to highway-law-enforcement scales, ~~and~~ scales used for the collection of statistical data, or scales used to charge a fee for the service of providing weights of the different axle-, axle-group loads, and total weight of vehicles and coupled-vehicle combinations when the only use of those values is to determine compliance with highway legal load limits and safe distribution of the load.

(Added 1992) (Amended 20XX)

UR.3.4. Weighing of Axle- and Axle-Group Loads – Establishing weight values for the different individual axle- and axle-group loads of a vehicle or coupled-vehicle combination is oftentimes necessary to verify compliance with state and federal highway load limits. When a fee is charged for the use of an axle-load scale or vehicle scale to determine such values, the transaction is considered “commercial” under the provisions of the General Code paragraph G-A.1. Commercial and Law Enforcement Equipment and the scale shall comply with all applicable NIST Handbook 44 requirements for commercial weighing systems.

When weight values for axle- and/or axle-group loads are obtained using multiple-independent platform vehicle scales systems where all parts of the vehicle or coupled-vehicle combination being weighed are simultaneously positioned on live elements of the scale, the values for the different axle- and axle-group loads may be summed to establish the commercial gross weight.

In no case, however, shall a summed result of the different axle- and axle-group loads of a vehicle or coupled vehicle combination weighed in multiple drafts be used for commercial purposes except as provided in subparts (a) and (b) of paragraph UR.3.3. Single-Draft Vehicle Weighing

Renumber existing paragraphs UR.3.4 through UR.3.12.

NIST OWM Detailed Technical Analysis:

OWM developed the two proposals in SCL-22.1 and SCL-22.3 to address perceived gaps in HB 44 Scales Code requirements pertaining to the design and use of multi-independent platform vehicle scale systems commercially used to charge a fee for the service of providing axle- and axle-group weights, as well as total vehicle weight to those needing them (typically commercial truck drivers). These systems are most often used commercially to verify compliance with federal and state vehicle load limits but at times may also be used to establish the net loads of products that are bought and sold by weight, establish transportation charges, and for other commercial purposes.

These proposals were developed as the result of an OWM inquiry from a state questioning the permissible use of a multi-independent platform vehicle scale system (each platform having its own A/D conversion circuitry and weight indicator) that printed total vehicle weight from summing the axle- and axle-group loads of vehicles weighed when not all parts of those vehicles were able to fit onto a live portion of the scale and be weighed simultaneously. That is, the scale was being used on occasion to “split weigh” in two different drafts the different axle and axle groups of “over-sized” coupled-vehicle combinations because not all axle and axle groups would fit onto a live portion of the scale at the same time, which thus necessitated weighing those particular vehicles in multiple drafts. Even though the printed ticket for those weight determinations provided clear indication that the total vehicle weight value recorded was “non certifiable,” it is questionable whether or not a scale system is permitted to record this weight since HB 44 Scales Code paragraph UR.3.3. Single-Draft Vehicle Weighing currently requires a vehicle or coupled-vehicle combination to be commercially weighed on a vehicle scale only as a single draft. Note: The manufacturer of this particular scale system advised us that most vehicles and coupled-vehicle combinations that are weighed on the scale can be weighed as a single draft. That is, all axle and axle groups can be positioned onto a live portion of the scale to be weighed simultaneously. It is only the occasional oversized vehicle or coupled-vehicle combination that exceeds the length of the scale that must therefore be split weighed.

We purposely chose to simplify these proposals to only address multi-independent platform vehicle scale systems. These systems have been installed at truck stops (and perhaps other locations) throughout the US for many years and are used primarily to determine axle loads, axle-group loads, and total vehicle weight of vehicles and coupled-vehicle combinations for a fee. Although we recognize that single-platform vehicle scales may also sometimes be used for this same purpose, we don’t view them as being suitable for the application. This is because the approach requirements for vehicle scales and axle-load scales in NIST HB44 are very different and few vehicle scales in commercial service have approaches that comply with the approach requirements for axle-load scales. Axle-load scales are required to have a straight paved approach in the same plane as the platform on each end of the platform. The approaches must be the same width as the platform and of sufficient length to ensure the level positioning of vehicles during weight determinations. If vehicles aren’t level when the different axle and axle groups are weighed, a portion of

the force of the load transfers to other axle and axle groups that aren't positioned on the scale resulting in false indication. It is important to recognize that not all multi-independent platform vehicle scale systems may be installed with approach requirements meeting the HB 44 approach requirements for an axle-load scale. Many do, but we are unable to confirm that all do. We view this somewhat of an important concern given that these proposals, if adopted, would make it permissible to split weigh vehicles and coupled-vehicle combinations for a fee providing the only use of the weighing results from doing so is to verify whether or not the different axle-, axle-group loads, and total vehicle weight are compliant with highway weight limits.

Another reason we elected to limit these proposals to only address multi-independent platform vehicle scale systems is that we do not believe it to be a very common practice to use single-platform vehicle scales to determine axle loads and axle-group loads of vehicles and coupled-vehicle combinations to verify compliance with federal and state vehicle load limits. Those that are using them for this purpose usually don't charge a fee, i.e., the weighing is usually done as a complimentary service.

NIST HB 44 does not currently require a multi-independent platform vehicle scale system to be equipped with a ticket printer and whether or not one should be required, is something to be considered. We have not proposed it, but perhaps others will conclude this would be an important HB 44 addition. We believe most (perhaps all) of the multi-independent platform vehicle scale systems currently in commercial service have been equipped with a ticket printer and this is likely because the few scale manufacturers of these systems recognize the need for the multiple indications displayed by these systems to be made available in printed form to the operator and customer. We also believe most of the systems currently in service comply with both newly proposed sub-paragraphs of S.1.14. We developed these two new sub-paragraphs (S.1.14.1. and S.1.14.2.) because it is important for scale operators, customers, and enforcement officials to be able to clearly identify from a weigh ticket the different scale platforms utilized at the time a vehicle was weighed and their corresponding scale indications so that the accuracy of those values (including the summed total) can be verified. It is also important to clearly specify on a weigh ticket generated from one of these scale systems that any recorded total vehicle weight value determined from summing the different axle- and axle-group loads of a vehicle or coupled-vehicle combination weighed in multiple drafts (i.e., split weighed) is "Not-Legal-For-Trade."

Paragraph UR.3.3. needs to be amended to address the current use of multi-independent vehicle scale systems to split weigh oversized vehicles for a fee. The current paragraph does not take into consideration both the past and present use of these scales to provide a total vehicle weight that's most often only used to verify compliance with maximum legal load limits and safe distribution of the load. These systems have been in existence at truck stops for many years and their primary commercial use is to provide axle weights, axle group weights, and total vehicle weight to commercial haulers for a fee so that those haulers are able to determine whether or not their loads are distributed safely and within legal load limits. Years ago, (prior to the existence of multi-independent platform vehicle scale systems) axle-load scales served this same purpose at truck stops throughout the US and summing of the different axle and axle groups to determine total vehicle weight undoubtedly occurred to ensure total vehicle weight didn't exceed maximum legal load limits when using those scales. It is also important to recognize that the weight values corresponding to the different axle- and axle-group loads of vehicles weighed on a multi-independent platform vehicle scale system are not constant; but rather fluctuate/change depending on the position of those axles and axle groups on the different platforms of the system when the vehicle is weighed. That is, a change of the scale indication of one platform is offset by a change in the opposite direction of the indication from one or both of the other platforms if the position of a vehicle being weighed is changed slightly forward or backwards from its initial position. It is only the summed total of all indications that is constant; although it too changes minimally since not all sections of all platforms are typically adjusted the same. For these reasons, OWM has provided the Committee an updated proposal to amend Scales Code paragraph UR.3.3., which would make it permissible to weigh in multiple drafts (i.e., split weigh) a vehicle or coupled-vehicle

combination and charge a fee for the service of providing weights of the different axle- and axle-group loads when the only use of those values is to determine compliance with highway legal load limits.

Summary of Discussions and Actions:

Mr. Rick Harshman (NIST OWM) provided the Committee a high-level summary of its analysis of the two remaining items in Block 6, which included much of background information that had led OWM to submit the two proposals in Block 6 as well as the GEN-22.1 G.A.1. Commercial and Law-Enforcement Equipment item, which the Committee had previously removed from Block 6. Mr. Harshman reported that OWM had recently provided the Committee an updated version of the proposal in SCL-22.1 and requested the Committee replace the version of SCL-22.1 in its current agenda with the updated version recently received. Mr. Harshman also reported that OWM planned to revise the proposal in SCL-22.3 and would later (sometime following the 2022 NCWM Interim Meeting) submit the revised version to the Committee in hopes it could be reviewed by one or more of the regional weights and measures associations meeting in the Spring and/or Fall of 2022. Mr. Harshman recommended both items remain in a Developing status to allow stakeholders time to review and recommend any changes they felt necessary.

Mr. Russ Vires (Mettler Toledo LLC) speaking on behalf of the SMA reported that the SMA recommends Block 6 be broken apart into three individual items (i.e., GEN-22.1 Commercial and Law-Enforcement Equipment, SCL-22.1 Recorded Representation of Axle or Axle Group Weights, and SCL-22.3 UR.3.3. Single-Draft Vehicle Weighing and UR.3.4. Axle and Axle Group Weight Values). Mr. Vires then provided the SMA's position and rationale for each of these items speaking verbatim from the SMA's November 2, 2021 report titled "SMA Positions on the NCWM Specification and Tolerances Committee Report (For the NCWM Interim Meeting, January 2022, Developed November 2, 2021). *NIST Technical Advisors note: Refer to the subheading shown below titled, "Scale Manufacturers Association (SMA-Fall 2021 Meeting)" to view the different positions and rationales provided by Mr. Vires on behalf of the SMA for the items in Block 6.* Mr. Vires also reported that the SMA had had the opportunity during its Fall 2021 meeting to review the updated version of the proposal in SCL-22.1 that OWM had provided the Committee for replacement of the one in its current agenda and that the SMA supported the changes OWM had made.

These were several officials who spoke in support of further development of the two items in Block 6.

Mr. Lou Straub (Fairbanks Scale) reported that Fairbanks Scale had been manufacturing the multi-platform "CAT" vehicle scale system for over forty years and the systems had been installed in approximately 2,000 locations. He also reported that he fully supported the GEN-22.1 item that the Committee had earlier removed from Block 6. Referencing the proposal in SCL-22.1, Mr. Straub stated he agreed that the recorded representation of weights from individual axle or axle groups need to be clearly identified as "not-legal-for-trade" on the printed ticket unless the entire vehicle is positioned on live elements of the vehicle scale system and all axles/axle groups are weighed simultaneously. He voiced disagreement with the second sentence proposed in paragraph S.1.14. noting that when one considers a truck with six to eight axle groups that cannot fit onto the different independent platform and be weighed simultaneously, identifying which platform weighed each of these axle and axle groups becomes unnecessary.

The Committee, in consideration of the comments received during open hearings, agreed to replace the Block 6 SCL-22.1 proposal in its Interim Meeting agenda (2022 NCWM Publication 15) with the updated version provided by OWM just prior to the 2022 NCWM Interim Meeting and maintain a Developing status on the two remaining items in Block 6. The following proposal represents the Block 6 SCL-22.1 item appearing in the 2022 version of NCWM Publication 15 that the Committee agreed to replace with the Item Under Consideration now shown in SCL-22.1:

Item Under Consideration:

Amend Handbook 44, Scales Code as follows:

S.1.14. Recorded Representation of Axle or Axle Group Weights. – **The recorded representation of weights from individual axle or axle group weights shall clearly be identified as “not legal for trade” or “non-commercial” weight values unless the entire vehicle is positioned on live elements of a multiple-platform vehicle scale and where all axles/axle groups are weighed simultaneously. All recorded weights of axles/axle groups shall be identified as representing only a portion of the vehicle’s total gross weight (e.g., by axle groupings such as: “axle group 1,” “axle group 2,” “axle group 3,” or by individual axle description such as: “steering axle,” “drive axles,” “trailer axles”).**

Any total gross weight of the vehicle included in the recorded representations determined by summing axle weights shall be clearly identified as “not-legal-for trade” or “non-commercial” unless those axle weights were recorded when all parts of the vehicle rested simultaneously on live portions of the scale, or the individual components were uncoupled, positioned completely on the live elements, and weighed separately on the scale.

[subsequent requirements to be renumbered as appropriate]

On May 19, 2022, OWM provided S&T Committee Chair Mr. Bradford Bachelder an electronic file containing the following revised version of the B6: SCL-22.3 proposal as replacement for the current proposal in 2022 NCWM Publication 16. OWM requested he share it with the Committee to be considered as replacement for the current proposal in the Committee’s agenda.

OWM’s Revised Replacement Proposal for B6: SCL-22.3 UR.3.3. Single-Draft Vehicle Weighing, and UR.3.4. Axle and Axle Group Weight Values.

Amend NIST Handbook 44, Scales Code as follows:

UR.3.3. Single-Draft Vehicle Weighing – A vehicle or a coupled-vehicle combination shall be commercially weighed on a vehicle scale only as a single draft. That is, the total weight of such a vehicle or combination shall not be determined by adding together the results obtained by separately and not simultaneously weighing each end of such vehicle or individual elements of such coupled combination. However, the weight of:

- (a) a coupled combination may be determined by uncoupling the various elements (tractor, semitrailer, trailer), weighing each unit separately as a single draft, and adding together the results; or
- (b) a vehicle or coupled-vehicle combination may be determined by adding together the weights obtained while all individual elements are resting simultaneously on more than one scale platform.

Note: This paragraph does not apply to highway-law-enforcement scales, **and** scales used for the collection of statistical data, **or scales used to charge a fee for the service of providing weights of the different axle-, axle-group loads, and total weight of vehicles and coupled-vehicle combinations when the only use of those values is to determine compliance with highway legal load limits and safe distribution of the load.**

(Added 1992)

UR.3.4. Weighing of Axle- and Axle-Group Loads – Establishing weight values for the different individual axle- and axle-group loads of a vehicle or coupled-vehicle combination is oftentimes necessary to verify compliance with state and federal highway load limits. When a fee is charged for the use of an axle-load scale or vehicle scale to determine such values, the transaction is considered “commercial” under the provisions of the General Code paragraph G-A.1. Commercial and Law Enforcement Equipment and the scale shall comply with all applicable NIST Handbook 44 requirements for commercial weighing systems.

When weight values for axle- and/or axle-group loads are obtained using multiple-independent platform vehicle scales systems where all parts of the vehicle or coupled-vehicle combination being weighed are simultaneously positioned on live elements of the scale, the values for the different axle- and axle-group loads may be summed to establish the commercial gross weight.

In no case, however, shall a summed result of the different axle- and axle-group loads of a vehicle or coupled vehicle combination weighed in multiple drafts be used for commercial purposes except as provided in subparts (a) and (b) of paragraph UR.3.3. Single-Draft Vehicle Weighing

Renumber existing paragraphs UR.3.4 through UR.3.12.

Regional Association Reporting:

Western Weights and Measures Association

During the 2021 Annual Meeting Open Hearing the following comments were heard:

Mr. Kurt Floren (Los Angeles County, California) offered up some language changes for the last part of subsection A and breaking into bullet points. He wants to break out equipment that is commercial, then the other types. It's titled “Commercial and Law Enforcement” then “other commercial” and it becomes confusing. Is it all commercial and subject to our jurisdiction? Rephrase GA-1 : apply “to commercial equipment as follows”: ... explains that everything under is commercial. (strike “commercial” from A and B). Between apply and as in the first line, insert commercial equipment. Mr. Kurt Floren stated that he will submit a written statement to the Committee as presented during open hearings.

Mr. Ivan Hankins (Iowa) wanted clarification as to what is being changed to make it better. It looks like it's already there, and he wants more definition on why this is changing.

Ms. Cadence Matijevich (Nevada) agreed with Mr. Floren but cautioned that we consider how the heading reads if we add commercial to the opening statement then there might be some interpretation that what is or is not commercial law enforcement equipment. (Is there a fine assessed?) Does not want to narrow the subsection of law enforcement devices only to commercial purposes.

Mr. Floren offered a modification to Ms. Matijevich’s recommendation. Restructure under GA-1: insert subsection under 1: commercial as follows, then insert A,B,C then 2 for law enforcement.

Ms. Matijevich stated that Mr. Floren is much better at this, and his fix is good.

Mr. Lou Straub (Fairbanks Scales) agreed with Mr. Hankins, that the original language is satisfactory. Language needs to say that its NTEP approved and meet handbook requirements.

Mr. Eric Golden (Cardinal Scale) asked if a commercial transaction includes just getting a weight: he says yes. Change the wording that that transaction is commercial. No suggestions at this time. Mr. Floren missed a typo: in B2: "Basis".

Mrs. Tina Butcher (NIST OWM) stated that OWM submitted this Item. This was seeking to clarify commercial transactions. Agreed with previous testimony. They have submitted other proposals to amend method of sale reg. and uniform law. They have determined that HB 44 and 2 sections in HB 130 are slightly different. Uniform Reg. for service persons also needs to be aligned. Wants this to remain Developing so that they can continue to align the language and make it more uniform.

Mr. Russell Vires (Scale Manufacturers Association) remarked that this a new item, the SMA has not vetted this yet. They will do so at November meeting. This should remain Developing so that there's no unintended consequences.

Mrs. Tina Butcher (NIST OWM) clarified that in the agenda, this is blocked with two other "companions". She feels that the block should continue, however, if others think that other items in the block are ready (SCL-22.1 and SCL-22.3) those items can move forward.

Mr. Don Onwiler (NCWM): SCL-22.3 is the name of the next item.

Mr. Russell Vires (Scale Manufacturers Association) stated he is looking at it as a block and is commenting as an entire block. Wants all three to remain Developing so that they can research.

Mr. Lou Straub (Fairbank Scales) for SCL-22.1 he has concern about what the second sentence. Talks about the entire truck on the scale = not legal for trade: this is ok. Second part about axle identifications (axle groups) this gets difficult to identify group notifications. Wants the ticket that has already been marked as not legal for trade to not have to identify all axels. Wants this re-worded. They will put down axle weight and gross weight. Preprinted labels don't allow enough space.

Mr. Eric Golden (Cardinal Scales) agreed with Mrs. Butcher to split the items. "Blow the block apart." The second two items introduce additional items and topics. Wants to pull the second two items out.

The WWMA S&T Committee recommended that this be assigned a Developmental status. The Committee recommended following the submitter's request to remove GEN-22.1 from the Block. Based on testimony heard the Committee agreed to submit the following language for item GEN-22.1. The Committee noted that SCL-22.1 (UR.3.3.) item was reassigned as SCL-22.3.

G-A.1. Commercial and Law-Enforcement Equipment. – These specifications, tolerances, and other technical requirements apply as follows:

(1) To commercial weighing and measuring equipment

- (a) ~~To commercial weighing and measuring equipment; that is, †~~To weights and measures and weighing and measuring devices commercially used or employed in establishing the size, quantity, extent, area, composition (limited to meat and poultry), constituent values (limited to grain), or measurement of quantities, things, produce, or articles for distribution or consumption, purchased, offered, or submitted for sale, ~~hire, or award, or in computing any basic charge or payment for services rendered on the basis of weight or measure.~~

(Amended 2008 and 20XX)

(b) **To other commercial weighing and measuring equipment:**

i. when there is a fee assessed for the use of the equipment to determine a weight or measure;

ii. used to determine the bases of an award using count, weight, or measure; or

iii. used in computing any basic charge or payment for services rendered on the basis of weight or measure

(Added 20XX)

~~(bc)~~ To any accessory attached to or used in connection with a commercial weighing or measuring device when such accessory is so designed that its operation affects the accuracy of the device.

~~(ed)~~(2) To weighing and measuring equipment in official use for the enforcement of law or for the collection of statistical information by government agencies.

(These requirements should be used as a guide by the weights and measures official when, upon request, courtesy examinations of noncommercial equipment are made.)

During the WWMA 2022 Annual Meeting, the following comments were received: Mr. Jan Konijnenburg (NIST Associate) – Stated that information is available on the website. During open hearings the Committee received an update from NIST OWM indicating that new language for this proposal was submitted to NCWM. This language was not available for review at the time of open hearings by the committee or membership. The WWMA S&T Committee recommended that this item should remain developing to allow membership to review the updated proposal.

Southern Weights and Measures Association

During the 2021 Annual Meeting Open Hearing Mr. Russ Vires (Mettler Toledo) stated that this item needs work on the wording and further review by stakeholders. Its current language could have unintended consequences, and recommended it continue with a Developing status.

This Committee would like clarification on the purpose and use of axle weight scale values allowed by this proposal beyond law enforcement use.

This Committee recommended that this item move forward with a Developing status.

The following comments were received during the 2022 SWMA Annual Meeting S&T open hearings:

- Mr. Huff (Delaware) questioned whether this would allow law enforcement officials to split weigh.
- The SWMA S&T Committee asked how legal split weighing would be initiated, how it would be recorded on the ticket, would scale operators be required to mark the tickets where split weighing had taken place, or would that be automatically done?

The SWMA S&T Committee recommended this item remain as a Developing Item.

Northeastern Weights and Measures Association

During the 2021 Interim Meeting Open Hearing the following comments were heard.

GEN-22.1

Mr. Rick Harshman (NIST OWM) commented that the language is in-need of some changes and NIST will be providing changes for the NCWM.

Mr. Eric Golden (Cardinal Scale) supported the intent of this item, but it may need some wordsmithing.

Mr. Lou Straub (SMA), Cheryl Ayer (New Hampshire), and John McGuire (New Jersey) all support this as a Developing Item.

SCL 22.1

Mr. Eric Golden (Cardinal Scale) supports this item moving forward as Developing.

Mr. Lou Straub (Fairbanks Scale) agreed with language in general. But questioned the benefit of including all the language on a scale ticket and the large amount of information would be difficult to fit on the ticket.

Mr. Eric Golden (Cardinal Scale) and Ms. Cheryl Ayer (New Hampshire) agreed with comments from Mr. Straub.

Mr. John McGuire (New Jersey) recommended keeping this item in Developing status.

SCL 22.3

Mr. Eric Golden (Cardinal Scale) suggested to strike “non-commercial” and additional wordsmithing to align with paragraph UR3.4.

Mr. John McGuire (New Jersey) supported keeping this item in Developing status.

The NEWMA Specifications and Tolerances Committee recommended that this item be given a Developing Status.

During NEWMA’s 2022 Annual Meeting Open Hearings, the Committee heard the following comments: Mr. Russ Vires (SMA) recommended Block 6 be broken into two separate items. Mr. Vires indicated he supports this item with the following language change: S.1.14.1. Axle and Axle Group Loads. - All recorded representations of the different axle and axle group loads of a vehicle when weighed in a single draft on a multi-independent platform vehicle scale system shall be identified by providing indication of either. Mrs. Tina Butcher (NIST OWM) commented that this item needs development.

After hearing comments from the floor, the Committee recognized the need to further develop this block and recommended the block retain Developing status.

During NEWMA’s 2023 Interim Meeting, Mr. Rick Harshman (NIST OWM) gave updates on a NIST analysis for SCL-22.1. He noted that SCL-22.3 has changed from what is in the agenda, which was shared with the body. Mr. Lou Sakin (Holliston, Massachusetts), Mr. Walt Remert (Pennsylvania), Mr. John McGuire (New Jersey), Mr. Jim Willis (New York), Mr. James Cassidy (Massachusetts), and Ms. Cheryl Ayer (New Hampshire) recommended that this item be assigned a Voting status. After hearing comments from the floor, the Committee believes this item has merit and is fully developed. The Committee recommended that this item be give a Voting status.

Central Weights and Measures Association

During the 2021 Interim Meeting Open Hearing the Committee heard comments from the floor. Mr. Loren Minnich (Kansas) suggested change he sent to the Committee (in green).

B6: GEN-22.1

G-A.1. Commercial and Law-Enforcement Equipment. – These specifications, tolerances, and other technical requirements apply as follows:

- (a) To commercial weighing and measuring equipment; that is, to weights and measures and weighing and measuring devices commercially used or employed in establishing the size, quantity, extent, area, composition (limited to meat and poultry), constituent values (limited to grain), or measurement of quantities, things, produce, or articles for distribution or consumption, purchased, offered, or submitted for sale, ~~hire, or award, or in computing any basic charge or payment for services rendered on the basis of weight or measure.~~

(Amended 2008 and 20XX)

(c) To other commercial weighing and measuring equipment:

i. when there is a fee assessed for the use of the equipment to determine a weight or measure;

ii. ~~used to determine the bases of an award using count, weight, or measure~~ when using weight, measure, or count as the basis to determine an award; or

iii. used in computing any basic charge or payment for services rendered on the basis of weight or measure

(Added 20XX)

Mr. Loren Minnich (Kansas) also asked NIST for clarification on G-A.1. because different states already interrupt rule different ways. Ms. Diane Lee (NIST OWM) agreed with Mr. Minnich and suggested it be Developing. Mr. Eric Golden (Cardinal Scales) agreed with the spirit of the proposal; it is indeed a “commercial transaction” to charge a person a fee solely for the purpose of obtaining a weight of a vehicle – it is not required to have to undergo a sales transaction of weighed product in order for it to be considered a commercial transaction. Mr. Golden also recommended striking out the following (in red) stating the reasoning behind this is by leaving the “non-commercial” language in the proposal, it defeats the purpose of the proposal, which is to officially clarify what a non-commercial transaction is.

B6: SCL-22.1 S.1.14. Recorded Representation of Axle or Axle Group Weights

S.1.14. Recorded Representation of Axle or Axle Group Weights. – The recorded representation of weights from individual axle or axle group weights shall clearly be identified as “not legal for trade” ~~or “non-commercial” weight values~~ unless the entire vehicle is positioned on live elements of a multiple-platform vehicle scale and where all axles/axle groups are weighed simultaneously. All recorded weights of axles/axle groups shall be identified as representing only a portion of the vehicle’s total gross weight (e.g., by axle groupings such as: “axle group 1,” “axle group 2,” “axle group 3,” or by individual axle description such as: “steering axle,” “drive axles,” “trailer axles”).

Any total gross weight of the vehicle included in the recorded representations determined by summing axle weights shall be clearly identified as “not-legal-for trade” or “non-commercial” unless those axle weights were recorded when all parts of the vehicle rested simultaneously on live portions of the scale, or the individual components were uncoupled, positioned completely on the live elements, and weighed separately on the scale.

Mrs. Tina Butcher (NIST OWM) agreed G-A.1. needed more work and had no objection to Mr. Golden’s suggestion of splitting SCL-22.1 and SCL-22.3. Mr. Lou Straub (Fairbanks) says current G-A.1. is already correct. He also agreed with Mr. Golden from Cardinal Scales on SCL 22.1. Mr. Doug Musick (Kansas) agreed with Mr. Straub. Says that item is not practical for all vehicles out there. Keep as Developing. Mr. Ivan Hankins (Iowa) feels G-A.1. is already correct. Mr. Charles Stutesman (Kansas) stated original language is good as written.

CWMA S&T Committee recommended that GEN 22.1 be withdrawn and SCL-22.1 and SCL 22.3 remain Developing.

During the 2022 CWMA Annual Meeting Open Hearing the Committee heard the following comments:

Mr. Russ Vires (SMA): the SMA recommended that Block 6 be broken apart into two (2) individual items. Each of these items deals with a separate topic that needs to be discussed individually. Regarding SCL-22.1: The SMA supports this item with the following changes: **“S.1.14.1. Axle and Axle Group Loads. - All recorded representations of the different axle and axle group loads of a vehicle when weighed in a single draft on a multi-independent platform vehicle scale system shall be identified by providing indication of either:”**

Identifying the recorded weight values for the axle/axle groups as required in S.1.14.1.(a) is only necessary when the vehicle can be weighed in a single draft.

The CWMA agreed to recommend further development of this block of items.

During CWMA’s 2023 Interim Meeting, no comments were received on the block of items and the CWMA recommended a Developing status.

Scale Manufacturers Association (SMA-Fall 2021 Meeting)

The SMA recommended that Block 6 be broken apart into three (3) individual items.

Rationale: Each of these items deals with a separate topic that needs to be discussed individually.

B6: GEN-22.1 G.A.1. COMMERCIAL AND LAW-ENFORCEMENT EQUIPMENT

Position: The SMA supports this item.

Rationale: The proposed item provides clarity to define what constitutes a “commercial transaction”.

B6: SCL-22.1 S.1.14. RECORDED REPRESENTATION OF AXLE OR AXLE GROUP WEIGHTS

Position: The SMA supports this item with the following changes:

S.1.14. Recorded Representation of Axle or Axle Group Weights. – The recorded representation of weights from individual axle or axle group weights shall clearly be identified as “not legal for trade”

~~or “non-commercial” weight values unless the entire vehicle is positioned on live elements of a multiple-platform vehicle scale and where all axles/axle groups are weighed simultaneously. All recorded weights of axles/axle groups shall be identified as representing only a portion of the vehicle’s total gross weight (e.g., by axle groupings such as: “axle group 1,” “axle group 2,” “axle group 3,” or by individual axle description such as: “steering axle,” “drive axles,” “trailer axles”).~~

Any total gross weight of the vehicle included in the recorded representations determined by summing axle weights shall be clearly identified as “not-legal-for trade” or “non-commercial” unless those axle weights were recorded when all parts of the vehicle rested simultaneously on live portions of the scale, or the individual components were uncoupled, positioned completely on the live elements, and weighed separately on the scale.

Rationale: the item attempts to define what constitutes a “commercial transaction”, but the words “non-commercial” reduces its clarity. Secondly, it is not necessary to label each weight value of axle/axle group weights as “not legal for trade”; putting the words “not legal for trade” on the recorded representation once is adequate.

B6: SCL-22.3 UR.3.3. SINGLE-DRAFT VEHICLE WEIGHING., AND UR.3.4. AXLE AND AXLE GROUP WEIGHT VALUES

Position: the SMA supports this item.

SMA-Spring 2022 Meeting

The SMA recommended that Block 6 be broken apart into three (3) individual items.

Rationale: each of these items deals with a separate topic that needs to be discussed individually.

B6: SCL-22.1 D S.1.14. RECORDED REPRESENTATION OF AXLE OR AXLE GROUP WEIGHTS

Position: the SMA supports this item with the following changes:

S.1.14.1. Axle and Axle Group Loads. All recorded representations of the different axle and axle group loads of a vehicle when weighed in a single draft on a multi-independent platform vehicle scale system shall be identified by providing indication of either:

Rationale: identifying the recorded weight values for the axle/axle groups as required in S.1.14.1.(a) is only necessary when the vehicle can be weighed in a single draft.

B6: SCL-22.3 D UR.3.3. SINGLE-DRAFT VEHICLE WEIGHING., AND UR.3.4. AXLE AND AXLE GROUP WEIGHT VALUES

Position: the SMA supports the intent of this item and believes that additional work is necessary.

SMA-Fall 2022 Meeting

NIST Technical Advisors Note: There were originally three items in this block, however, currently there are only two as the third item (GEN-22.1 Commercial and Law-Enforcement Equipment) was previously removed from the block, voted on at the 2022 NCWM Annual Meeting, and adopted.

The SMA recommended that Block 6 be broken apart into three (3) individual items.

Rationale: each of these items deals with a separate topic that needs to be discussed individually.

B6:SCL-22.1 D S.1.14. RECORDED REPRESENTATION OF AXLE OR AXLE GROUP WEIGHTS

The SMA supports this item with the following changes (shown shaded):

S.1.14.1. Axle and Axle Group Loads. – All recorded representations of the different axle and axle group loads of a vehicle when weighed in a single draft on a multi-independent platform vehicle scale system shall be identified by providing indication of either:

Rationale: identifying the recorded weight values for the axle/axle groups as required in S.1.14.1.(a) is only necessary when the vehicle can be weighed in a single draft.

B6:SCL-22.3 D UR.3.3. SINGLE-DRAFT VEHICLE WEIGHING., AND UR.3.4. AXLE AND AXLE GROUP WEIGHT VALUES

The SMA supports the intent of this item and believes that additional work is necessary.

Item Block 7 (B7) Tolerances on Tests Using Transfer Standards

B7: CLM-22.1 D T.3. On Tests Using Type 2 Transfer Standards
B7: CDL-22.1 D T.3. On Tests Using Type 2 Transfer Standards
B7: HGM-22.1 D T.4. Tolerance Application on Tests Using Type 2 Transfer Standard Test Method

(Note: The Item Under Consideration was revised by the submitter based on comments from the 2022 Interim Meeting.)

Source: Seraphin Test Measure Company, A Division of Pemberton Fabricators, Inc.

Submitter's Purpose and Justification:

The purpose of these proposals is to change the language in the tolerance paragraphs to provide consistency with the changes in the combined amended proposals of 2022 S&T Agenda Item Block 8 (GEN-19.1. and OTH-22.1). In the codes mentioned below, the current language of Handbook 44 states that when transfer standards are used, the basic tolerances to be applied to the devices under test are to be increased by the uncertainty of the transfer standard (i.e., two times the standard deviation of the transfer standard). The proposed language simply states that the formula given in the General Code (the proposed G-T.5.) be used, rather than repeat the formula in each of the specific codes listed below.

In the codes mentioned above, when transfer standards are used, the basic tolerances to be applied to the devices under test are to be increased by the uncertainty of the transfer standard (i.e., two times the standard deviation of the transfer standard). The proposed changes incorporate the OIML R117 formula to state how the tolerance is to be increased when transfer standards are used. The formula effectively places an upper limit on how large the uncertainty associated with the transfer standard can be.

This item has been assigned to the submitter for further development. For more information or to provide comment, please contact:

Mr. Bob Murnane

NIST OWM Analysis
 2023 NCWM Interim S&T Agenda Items
 1/5/2023
 Seraphin Test Measure Co.
 (609) 267-922, rmurnane@pemfab.com

The current paragraphs already state that, when transfer standards are used, the tolerances are to be increased by two standard deviations for the repeatability of the transfer standard. One can argue that effect of the proposed changes is small and not necessary. The proposed changes are intended to provide consistency with the changes proposed in the amended proposals of 2021 S&T Agenda Block 1 Item GEN-19.1.

The submitter requested that this be a Voting Item in 2022.

OWM Executive Summary for Item Block 7 (B7) – Tolerances on Tests Using Transfer Standards
<p>OWM Recommendation: When the S&T Committee presents Block 8 for a vote, OWM agrees that Block 7 should also go forward for a vote.</p> <ul style="list-style-type: none"> • Block 7 Items are proposed changes to NIST HB 44 Codes that have transfer standard tolerance requirements. • Because of the larger uncertainties associate with the use of transfer standards, the current Code requirement increases the tolerance to account for the uncertainties in the tolerance. • The proposal is to revise the transfer standard tolerance requirements with an equation to calculate the tolerances for Type 2 Transfer standards and to clarify that these standards are considered Type 2 standards. • The equation places an upper limit on how large the uncertainty associated with the transfer standard can be.

Table 3. Summary of Recommendations							
Block 7 Items (B7) – Tolerances on Tests Using Transfer Standards							
	V	D	W	A	I	Notes*	Comments
Submitter							<ul style="list-style-type: none"> • Updated Proposal from Seraphin Test Measure Co requesting Block 7 be designated as a Voting item when Block 8 is designated as Voting. • (01-06-2022)
OWM							<ul style="list-style-type: none"> • When Block 8 is voting
WWMA		✓					
SWMA		✓					
NEWMA	✓						
CWMA	✓						
NCWM							
	Letters of Support			Letters of Opposition			Notes

Table 3. Summary of Recommendations							
Block 7 Items (B7) – Tolerances on Tests Using Transfer Standards							
	V	D	W	A	I	Notes*	Comments
Industry							Comments from Emerson-Micro Motion (09-27-21)
Manufacturers							
Retailers and Consumers							
*Notes Key: 1 – Submitted modified language 2 – Item not discussed 3 – No meeting held 4 – Not submitted on agenda 5 – No recommendation or not considered							

B7: CLM-22.1 D T.3. On Tests Using Type 2 Transfer Standards.

Amend Handbook 44, Cryogenic Liquid-Measuring Devices Code as follows:

T.3. On Tests Using Type 2 Transfer Standards. – ~~To the basic tolerance values that would otherwise be applied, there shall be added an amount equal to two times the standard deviation of the applicable transfer standard when compared to a basic reference standard.~~ **When commercial meters are tested using a Type 2 transfer standard, the tolerance applied to the meter under test shall be calculated using the formula specified in the General Code Tolerance section.**
(Amended 202X)

B7: CDL-22.1 D T.3. On Tests Using Type 2 Transfer Standards.

Amend Handbook 44, Carbon Dioxide Liquid-Measuring Devices Code as follows:

T.3. On Tests Using Type 2 Transfer Standards. – ~~To the basic tolerance values that would otherwise be applied, there shall be added an amount equal to two times the standard deviation of the applicable transfer standard when compared to a basic reference standard.~~ **When commercial meters are tested using a Type 2 transfer standard, the tolerance applied to the meter under test shall be calculated using the formula specified in the General Code Tolerance section.**
(Amended 202X)

B7: HGM-22.1 D T.4. Tolerance Application on Tests Using Type 2 Transfer Standard Test Method.

Amend Handbook 44, Hydrogen Gas-Measuring Devices Code as follows:

T.4. Tolerance Application on Tests Using Type 2 Transfer Standard Test Method. – ~~To the basic tolerance values that would otherwise be applied, there shall be added an amount equal to two times the standard deviation of the applicable transfer standard when compared to a basic reference standard.~~ **When commercial meters are tested using a Type 2 transfer standard, the tolerance applied to**

the meter under test shall be calculated using the formula specified in the General Code Tolerance section.

(Amended 202X)

NIST OWM Detailed Technical Analysis:

Seraphin proposed Block 7 Items to address the changes that are proposed in Block 8 concerning transfer standards. Block 7 items in the Interim Meeting Report were revised based on comments heard during the 2022 Interim Meeting.

Transfer standards are address in the Cryogenic Liquid-Measuring Devices Code, the Carbon Dioxide Liquid-Measuring Devices Code and the Hydrogen Gas-Measuring Devices Code. These codes already specify that a larger tolerance be used when transfer standards are used to account for the higher uncertainty associated with these types of standards and the fact that they will not likely meet the fundamental considerations paragraph 3.2 tolerances for Standards.

The proposed changes in Block 8 define the different types of standards (Field Standard, Type 1 Transfer Standard and Type 2 Transfer Standard). Block 8 also proposes to add a General code requirement with an equation that should be used to determine the tolerance for type 2 transfer standards because Type 2 transfer standards will not likely meet the fundamental considerations concerning the error and uncertainty. The equation places an upper limit on how large the uncertainty associated with the transfer standard can be.

Block 7 makes changes to the aforementioned codes to reference the General Code requirement with the equation that will be used to calculate the tolerance when using type 2 transfer standards in these codes.

When the S&T Committee presents the combined item GEN-19.1 and OTH-22.1, Block 8 item for a vote, then this item, Block 7 may also go forward for a vote.

Summary of Discussions and Actions:

At the 2022 Interim Meeting the Committee recommended that this item be given a Developing status for further development by the submitter based on comments heard during the 2022 Interim Meeting. Since the 2022 Interim Meeting, the submitter made additional changes to the items under consideration which are currently reflected in Block 7 above. These changes add "Type 2" to clarify the type of transfer standard and references the revised equation in the proposed Block 8 item of this report.

At the 2022 Annual Meeting the submitter provided no comments and as a Developing Item no additional comments were heard on this this item.

During the Committee work session the committee agreed to maintain a Developing status for this item.

Regional Association Reporting:

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received: Mr. Robert Murnane (Seraphin Test Measure Company) - wanted everyone to look at the version that was posted to the WWMA website, the most current version. Addressed multiple changes present in the updated language. Asked that this item be a voting item, only if Block 8 passes.

Mr. Michael Keilty (Endress + Hauser Flow USA, Inc.) didn't see where there is a formula to be calculated, in the HB44 general code. Also affirmed that Block 7 is dependent on Block 8.

Mr. Robert Murnane (Seraphin Test Measure Company) clarified that the formula is in Block 8, that is why Block 7 should only move forward if Block 8 is passed.

During open hearings, members in attendance were notified that the language in the agenda did not reflect the updated Item Under Consideration. Membership was not fully aware of the new language at the time of open hearings. The WWMA S&T Committee recommended that this item should remain Developing to allow membership to review the updated proposal. The Committee further recommended that this item be blocked with Block 8 as the items in Block 7 are contingent on Block 8 items.

Southern Weights and Measures Association

The following comments were received during the 2022 SWMA Annual Meeting: Mr. Keilty (Endress+Hauser) stated that Block 7 is dependent on Block 8, and both blocks should receive the same status. He had no recommendation on it. This is an example where meters are being added into three codes.

The SWMA S&T Committee recommended this item remain as a Developing Item.

Northeastern Weights and Measures Association

During the 2022 Interim Meeting Mr. Murnane commented that the item that appears in the agenda is not what has been proposed as there are many typos. A true version of the item was submitted to the NEWMA S&T Chair and shared with the body. Mr. Murnane asks that the same status be given to Block 7 and Block 8 as they are directly linked.

Mr. Keilty indicated that he drafted LPG-15.1 and MFM-15.1 based on these codes. The standards are meters, but they have 2x the deviation, which do not meet 1/3 requirement recommended in the Fundamental Considerations. Mr. Keilty recommended a developing status. (Mr. Keilty was experiencing internet connection problems during his comments and the Committee may not have been able to hear his entire testimony).

After hearing comments from the floor, the Committee believes this item has merit and is full developed. The Committee recommended that this item be assigned a Voting status.

Central Weights and Measures Association

During the 2022 Interim Meeting, Bob Murnane (Seraphin) stated that Block 7 cannot stand alone without Block 8 moving forward.

The CWMA S&T Committee believes this item is fully developed and recommends Voting status.

Item Block 8 (B8) G-T.5. Tolerances on Tests When Transfer Standards are Used., Appendix A, Section 3.2. Tolerances for Standards., and Appendix D – Definitions: standards, field., transfer standard. and standard, transfer. Appendix A: Fundamental Considerations, 3. Testing Apparatus

B8: GEN-19.1 D G-T.5. Tolerances on Tests When Transfer Standards are Used., Appendix A, Section 3.2. Tolerances for Standards., and Appendix D – Definitions: standards, field., transfer standard. and standard, transfer.

B8: OTH-22.1 D Appendix A: Fundamental Considerations, 3. Testing Apparatus

(Note: These proposals are a combined modification of the 2021 S&T Agenda Block 1 Items GEN-19.1 and OTH-22.1. Since the S&T Committee has changed item GEN-19.1 from “assigned” to “developing,” the submitter has worked with NIST OWM to revise and combine the original proposals of GEN-19.1 and OTH-22.1 to address discussions within the NCWM Field Standards Task Group and other comments received at the regional weights and measures meetings on the proposals. These items are related, so they are presented together. These OWM and Seraphin proposals were submitted to the S&T Committee just before the 2022 Interim Meeting.

Note: The joint OWM and Seraphin proposals submitted to the S&T Committee just before the 2022 Interim Meeting were updated with two changes at the request of the Submitters following the 2022 Interim Meeting. The first change is in the definition of “Standard, Field.” The words “(typically one year)” were replaced with “(as determined by the Director)”. The second change was to add the words “to the International System of Units (SI)” in the section 3.1.3. of the Fundamental Considerations. These two changes are reflected in the items below.)

Note: The current Item Under Consideration represents additional changes made by the submitters in November 2022 based on comments received from the regional meetings in 2022.

Source: The NIST Office of Weights and Measures and Seraphin Test Measure Company have combined their previously separate proposals into a single proposal.

Submitter’s Purpose and Justification:

- (a) Add a tolerance statement to the General Code that applies whenever a Type 2 transfer standard is used;
- (b) Clarify in the Fundamental Considerations (Appendix A of Handbook 44) that the authority to approve field test standards rests with the regulatory official and that specific types of field test standards need not be identified in the body of a Handbook 44 Code in order to be approved by the weights and measures director;
- (c) Add text to Section 3.2. Tolerances for Standards of the Fundamental Considerations (Appendix A of Handbook 44) to recognize the wide range of transfer standards already recognized in Handbook 44, explain the critical differences between field standards and transfer standards, and to specify the formula to be used to calculate the device tolerance when the uncertainty of the transfer standard exceeds the one-third requirement; and
- (d) Add definitions to Appendix D of Handbook 44 for field standard and Type 1 and Type 2 transfer standards that identify the critical characteristics for field and transfer standards.

Footnote 2 in the Fundamental Consideration of NIST Handbook 44 already provides a statement regarding the authority of the Director to approve field test standards or equipment, OWM believes including additional information regarding the essential elements of traceability and a reference to specific measurement practices would be helpful to both emphasize that authority and provide guidance to Directors and industry regarding the selection of appropriate field test standards.

NIST OWM recommends the guidance originally included in Footnote 2 along with the additional references to the “Essential Elements” described above are best included in the body of Section 3 for clarity and ease of use. Consequently, OWM recommends deleting the existing Footnote 2 and incorporating its contents into the body of Section 3.

OWM also believes that some may erroneously believe that field test standards must be specifically listed within a NIST Handbook 44 code in order to be used in the inspection and testing of devices covered by that code. Providing a clear statement that this is not the case along with a reference to the required criteria may help alleviate this misunderstanding.

A tolerance statement is added to the general code that addresses uncertainties of Type 2 Transfer standards since they do not meet the NIST Handbook 44 Fundamental Consideration that state “When the standard is used without correction, its combined error and uncertainty must be less than one-third of the applicable device tolerance”. Several equations were considered to included an OIML equation. After discussion an alternative equation was agreed upon. An assessment of the two equations, the 2/3 Formula: Increased $MPE = (2/3 \times MPE + U)$ with an upper limit of $U_{MAX} = 2/3 MPE$ and the OIML Formula: Reduced $MPE = (4/3 \times MPE - U)$ are provided below:

The OIML formula and the 2/3 formula are similar, but they take different approaches to establish the tolerances for the device under test. The 2/3 formula is more logical, more technically consistent with the Handbook 44 concept of Type 2 transfer standards, and it is easier to understand. The 2/3 formula combines the tolerance that remains to be used by the commercial device with the growing uncertainty of the T2TS into one total tolerance value, whereas the OIML Reduced MPE calculates only the tolerance applied to test of the commercial meter under test. When Type 2 transfer standards are used in the field, the uncertainties associated with the T2TS should be recorded on the report form or a copy of the calibration certificate should be left with the test report, so the uncertainty values are available on site and can be used in an analysis should the tests with another T2TS generate different results.

The most accurate reference standard that is available should always be used for any field test. However, when the only practical option for a field test that is available is a Type 2 transfer standard, the 2/3 formula will err in favor of the commercial device to avoid failing a device that should have passed. Conversely, the OIML Reduced MPE might result in failing a commercial device that would have passed had a more accurate (e.g., Type 1 transfer or field) reference standard been available to use for the test.

Field standards are intended to have an error and uncertainty less than or equal to 1/3 of the tolerance applied to the commercial device under test. When a Type 2 transfer standard has an uncertainty slightly greater than 1/3 of the tolerance, then, using the 2/3 formula, the total tolerance applied to the device under test increases above the H44 tolerance by the amount that the uncertainty associated with the Type 2 transfer standard exceeds the 1/3 limit, thereby establishing a total tolerance slightly greater than the NIST Handbook 44 tolerances specified in the applicable codes and keeping the portion of the tolerance that remains allocated to the device under test at a constant level equal to 2/3 of the NIST Handbook 44 tolerance.

Type 2 Transfer Standards: Uncertainty is Added to the Tolerance

When the uncertainty associated with a T2TS exceeds 1/3 of the tolerance applied to the device under test, the uncertainty of the T2TS is recognized in the field test result by increasing the tolerance that is applied to the device under test. The OIML formula and the 2/3 formula take different approaches to increasing the tolerance for the device under test.

	Field Standard	Field Standard	OIML Formula	OIML Formula	2/3 Formula	2/3 Formula
Uncertainty of Standard (as % of Tolerance)	% of MPE (Tolerance) Applied to the Device	% MPE (Tolerance) Allocated to Device	% of MPE Applied to the Difference in the Test Results Using a T2TS	OIML Reduced MPE and Uncertainty of T2TS (%)	% of Combined Tolerance and Uncertainty Applied to the Device	% of Combined Tolerance and Uncertainty Allocated to the Device
0%	100	100				
10%	100	90				
20%	100	80				
30%	100	70				
33%	100	67				
34%			99	133	101	67
40%			93	133	107	67
50%			83	133	117	67
60%			73	133	127	67
67%			67	133	133	67
70%			63	133	137	67
80%			53	133	147	67
90%			43	133	157	67
100%			33	133	167	67

<p>OWM Executive Summary for Item Block 8 (B8) – G-T.5. Tolerances on Tests When Transfer Standards Are Used, Appendix A, Section 3.2. Tolerances for Standards., and Appendix D – Definitions: Standards, Field., and Standard, Transfer. Appendix A: Fundamental Considerations, 3. Testing Apparatus</p>
<p>OWM Recommendation: The submitters agree that these items, GEN-19.1 and OTH-22.1 are fully developed and requested that this S&T committee consider that Block 8 item be a Voting Item in 2023.</p> <ul style="list-style-type: none"> • State and industry have a need to use various types of test standards to evaluate commercial devices installed in the marketplace. NIST OWM recognizes the need to use various standards to test commercial devices and support the use of these standards when test data supports its use. • Block 8 clarifies the use and definition of three types of standards to be included in NIST HB 44: (1) Fields Standards, (2) Type 1 Transfer Standards and (3) Type 2 Transfer Standards; it provides an equation that should be used to calculate the tolerances when Type 2 transfer standards are used; provides definitions for Field Standards, Type 1 Transfer Standards and Type 2 Transfer Standards,

and provides clarification that the State Director has the authority to approve the use of standard and that specific requirements in NIST HB 44 code are not necessary to approve a standard for use.

- Two items, LPG-15.1 and MFM-15.1 in the Interim Meeting Report (Publication 16), include a purpose statement that the proposals are added to allow field standard meters to be used to test and place into service dispensers and delivery system flow meters. Block 8 items clarify what has always been recognized in NIST HB 44 concerning the responsibility for acceptance of a standard and notes that specific code changes are not necessary for a field standard to be adequate for use. If Block 8 is adopted it accomplishes the same goal as LPG-15.1 and MFM-15.1. and the objectives of Micheal Keilty are met with Block 8. The adoption of Block 8 would not only accomplish the same goal it also provides for a broad criteria and provide for the acceptance of other standards.
- In addition to the changes in Block 8, GEN-23.1 adds a General Code requirement so that rather than revising a specific code in Handbook 44 every time a new field or transfer standard is proposed or developed, an overall statement in the General Code recognizes the use of other field and transfer standards that meet the requirements for use as field or transfer standards.
- NIST OWM also observed that the definitions in Block 8 should include appropriate references to the NIST HB 44 codes.
- It was noted that the term “Standard, Field” has a different definition in NIST HB 130. It appears that the definition in NIST HB 130 describes the standard from a laboratory perspective and hierarchy of testing. As such, some future effort may be needed to harmonize the terms across all NIST handbooks.

Table 3. Summary of Recommendations							
BLOCK 8 ITEM (B8) – G-T.5. Tolerances on Tests When Transfer Standards are Used., <u>Appendix A, Section 3.2. Tolerances for Standards., and Appendix D – Definitions: standards, field., transfer standard. and standard, transfer.</u> Appendix A: Fundamental Considerations, 3. Testing Apparatus							
	V	D	W	A	I	Notes*	Comments
Submitter							
OWM							
WWMA		✓					
SWMA		✓					
NEWMA	✓						
CWMA	✓						
NCWM							
	Letters of Support			Letters of Opposition		Notes	
Industry	Updated Proposal from Seraphine Test Measure Co. (01-06-2022)						

Table 3. Summary of Recommendations							
BLOCK 8 ITEM (B8) – G-T.5. Tolerances on Tests When Transfer Standards are Used., <u>Appendix A, Section 3.2. Tolerances for Standards., and Appendix D – Definitions: standards, field., transfer standard. and standard, transfer.</u> Appendix A: Fundamental Considerations, 3. Testing Apparatus							
	V	D	W	A	I	Notes*	Comments
Manufacturers							
Retailers and Consumers							
*Notes Key: 1 – Submitted modified language 2 – Item not discussed 3 – No meeting held 4 – Not submitted on agenda 5 – No recommendation or not considered							

Item Under Consideration:

B8: GEN-19.1 D G-T.5. Tolerances on Tests When Transfer Standards are Used., Appendix A, Section 3.2. Tolerances for Standards., and Appendix D – Definitions: standards, field., transfer standard. and standard, transfer.

Amend Handbook 44, General Code as follows:

G-T.5. Tolerances on Tests When Type 2 Transfer Standards Are Used. – When Type 2 transfer standards are used, the following formula shall be used to compute the tolerance applicable to the device under test:

Increased MPE = (2/3 x MPE + U)

with an upper limit of $U_{MAX} = 2/3 MPE$

Where MPE is the basic tolerance that applies when using a basic reference standard; and

U = uncertainty associated with the Type 2 transfer standard.

The increase in the applied tolerance when using a Type 2 transfer standard applies only to the basic tolerances for devices as defined in Handbook 44; that is acceptance, maintenance and minimum tolerances. Note that the repeatability tolerance and the special test tolerances are NOT increased.

Codes 5.56.(a) Grain Moisture Meters, 5.56.(b) Grain Moisture Meters, and 5.57. Near-Infrared Grain Analyzers are exempt from this requirement because NIST Handbook 159 has requirements for monitoring and retesting grain samples to ensure adequate stability and the tolerances for the devices under test already incorporate the uncertainty associated with the use of grain samples as transfer standards. The code 2.21. Belt-Conveyor Scale Systems Code is also exempt because relative and absolute tolerances are included in the code.

Amend Handbook 44 Appendix D – Definitions as follows.

Standard, Field. – A physical artifact, static or dynamic measurement devices, such as scales, meters, etc., or a reference material that (a) meets the requirements of the Fundamental Considerations, Section 3.2., (b) is stable (accurate and repeatable) over an extended period of time (as determined by the Director), (c) is valid (corrections that may be used) over the range of environmental and operational parameters in which the commercial measuring devices are used, and (d) is traceable to the reference or working standards through comparisons, using acceptable laboratory procedures. [1.10]

(Added 202X)

~~transfer standard. — A measurement system designed for use in proving and testing cryogenic liquid measuring devices. [3.38]~~

Standard, Transfer, Type 1 and Type 2. – A physical artifact, static or dynamic measurement devices, such as scales, meters, etc., or a reference material that is proven to be stable (accurate and repeatable) for a short time under the limited environmental and operational conditions during which the transfer standard is used. A Type 1 transfer standard is a transfer standard that meets the one-third accuracy requirement for a short time over a limited range of environmental conditions and/or a limited range of operating conditions in which it is used. A Type 2 transfer standard is one that does not meet the one-third requirement and may not be stable or valid over an extended time period or over wide ranges of environmental or operating conditions. [1.10]

(Added 202X)

B8: OTH-22.1 D Appendix A: Fundamental Considerations, 3. Testing Apparatus

Amend Handbook 44, Appendix A: Fundamental Considerations as shown below. Delete Footnote 2 referenced in Section 3. Testing Apparatus of NIST Handbook 44 Appendix A, Fundamental Considerations, moving portions of the footnote into Section 3.1 as part of the proposed changes to Section 3.1 shown above. Note that no changes are proposed to Footnote 1.

~~²Recommendations regarding the specifications and tolerances for suitable field standards may be obtained from the Office of Weights and Measures of the National Institute of Standards and Technology. Standards will meet the specifications of the National Institute of Standards and Technology Handbook 105 Series standards (or other suitable and designated standards). This section shall not preclude the use of additional field standards and/or equipment, as approved by the Director, for uniform evaluation of device performance.~~

3.1. Adequacy.² – Tests can be made properly only if, among other things, adequate testing apparatus is available. Testing apparatus may be considered adequate only when it is properly designed for its intended use, when it is so constructed that it will retain its characteristics for a reasonable period under conditions of normal use, when it is available in denominations appropriate for a proper determination of the value or performance of the commercial equipment under test, and when it is accurately calibrated.

3.1.1. Essential Elements of Traceability. To ensure that field test standards and test methods provide for measurements that are traceable to the International System of Units (SI), through NIST or other National Metrology Institutes, they must satisfy the “Essential Elements of Traceability.” As explained in NIST IR6969 GMP-13 Good Measurement Practice for Ensuring Metrological Traceability, these elements include the following.

- Realization of SI Units
- Unbroken Chain of Comparisons
- Documented Calibration Program
- Documented Measurement Uncertainty
- Documented Measurement Procedure
- Accredited Technical Competence
- Measurement Assurance

3.1.2. Specifications for Standards. Standards will meet the specifications of the National Institute of Standards and Technology Handbook 105-Series standards or other appropriate designated documentary standards (e.g., ASTM, ASME, etc.). Recommendations regarding the specifications and tolerances for suitable field standards may be obtained from the Office of Weights and Measures of the National Institute of Standards and Technology.

3.1.3. Authority for Approving Field Test Standards and/or Equipment. This section shall not preclude the use of additional field standards and/or equipment, as approved by the Director, for uniform evaluation of device performance. Specific types of field test standards are not required to be identified in a NIST Handbook 44 code in order to be considered suitable. Provided the standards meet the “Essential Elements of Traceability” (described in Section 3.1.1. above) that help ensure the standards are suitable and capable of supporting measurements traceable to the International System of Units (SI) through NIST or other National Metrology Institutes, they need only be approved by the Director.

3.2. Tolerances for Standards. – Except for work of relatively high precision, it is recommended that the accuracy of standards used in testing commercial weighing and measuring equipment be established and maintained so that the use of corrections is not necessary. When the standard is used without correction, its combined error and uncertainty must be less than one-third of the applicable device tolerance.

Device testing is complicated to some degree when corrections to standards are applied. When using a correction for a **field standard or a transfer standard**, the uncertainty associated with the corrected value must be less than one-third of the applicable device tolerance. The reason for this requirement is to give the device being tested as nearly as practicable the full benefit of its own tolerance.

Whenever possible and practical, field standards should be used to test commercial weighing and measuring devices. However, where it is impractical or unduly cumbersome to use field standards, transfer standards may be used. There are two categories of transfer standards. The critical criteria that distinguish between these standards are: (1) the accuracy and uncertainty of the standard; (2) the stability as a standard over an extended period; and (3) proven validity or performance of the standard over the range of environmental and operational conditions in which the standard may be used.

A “field standard” is one that meets the one-third requirement mentioned earlier in this section. Additionally, the field standard maintains its validity or stability as a standard over an extended period (defined based on data of the standard’s stability by an authorized metrology lab or as

specified by the Director) and is known to maintain its value as a standard over the full range of environmental conditions and the range of operating conditions in which the standard may be used to test commercial weighing and measuring devices.

Transfer standards do not meet one or more of these critical criteria. One category of transfer standards, which is referred to here as a “Type 1 transfer standard,” is a transfer standard that meets the one-third accuracy requirement for a short time, under a limited range of environmental conditions and/or a limited range of operating conditions. The accuracy of a Type 1 transfer standard may have to be verified through testing each time it is used to verify that the desired accuracy and performance can be achieved when the Type 1 transfer standard is used under the limited environmental and operating conditions. When a Type 1 transfer standard is used, the basic tolerances specified for the commercial weighing and measuring devices are applied as specified in the applicable codes.

The second category of transfer standard, which is referred to here as a “Type 2 transfer standard,” is one that does not meet the one-third requirement. The Type 2 transfer standard must be stable and valid under the environmental or operating conditions in which it is used. The performance characteristics must be confirmed with sufficient data to properly characterize the uncertainty associated with the Type 2 transfer standard. When a Type 2 transfer standard is used, the tolerances applicable to the commercial weighing and measuring device must be increased to recognize the large uncertainty associated with the Type 2 transfer standard. When commercial weighing and measuring devices are tested using a Type 2 transfer standard, the tolerance applied to the commercial weighing and measuring devices meter under test shall be determined as specified in the General Code.

(Added 202X)

3.3. Accuracy of Field Standards. – Prior to the official use of testing apparatus, its accuracy should invariably be verified. Field standards should be calibrated as often as circumstances require. ~~By their nature, metal volumetric field standards are more susceptible to damage in handling than are standards of some other types.~~ A field standard should be calibrated whenever damage is known or suspected to have occurred or significant repairs have been made. In addition, field standards, ~~particularly volumetric standards,~~ should be calibrated with sufficient frequency to affirm their continued accuracy, so that the official may always be in an unassailable position with respect to the accuracy of his testing apparatus. ~~Secondary field standards, such as special fabric testing tapes, should be verified much more frequently than such basic standards as steel tapes or volumetric provers to demonstrate their constancy of value or performance.~~

Accurate and dependable results cannot be obtained with faulty or inadequate field standards. If either the service person or official is poorly equipped, their results cannot be expected to check consistently. Disagreements can be **avoided** and the servicing of commercial equipment can be expedited and improved if service persons and officials give equal attention to the adequacy and maintenance of their testing apparatus.

NIST OWM Detailed Technical Analysis:

State and industry have a need to use various types of test standards to evaluate commercial devices installed in the marketplace. NIST OWM recognizes the need to use various standards to test commercial devices and support the use of these standards when test data supports its use. Several proposals for changes to NIST HB 44 have been considered to address the use of these standards. Some were to address terminology for various types of standards in NIST HB 44. Other proposals were to provide specific requirements for

some codes in NIST HB 44 for the purpose of recognizing these standards in the handbook, but the responsibility for recognition of standards is already address in the fundamental consideration section in NIST HB 44. These proposals also included varying terms used to describe these standards and were subsequently all combined as a Block item and assigned to a task group. With limited success as a block item, it was decided to separate these items into their original block and individual items for consideration, some of the items were withdrawn. Block 8 items are a combined modification of the 2021 S&T Agenda Block 1 Item GEN-19.1 and OTH-22.1. With the S&T Committee changes to the status of item GEN-19.1 from “assigned” to “developing,” the submitter, Seraphin and NIST OWM seeing the need to add clarification to NIST HB 44 for the different terms used to address standards that are used to test commercial devices and the need to provide clarification as to what is needed for States to accept various types of standards, worked together to develop Item Block 8. These proposals were revised to address discussions within the NCWM Field Standards Task Group and other comments received at the regional weights and measures associations meetings and the 2022 Interim Meeting. There is also a companion item Block 7 that helps to clarify the use of the term transfer standards in NIST HB 44.

Block 8 clarifies the use and definition of three types of standards to be included in NIST HB 44: (1) Fields Standards, (2) Type 1 Transfer Standards and (3) Type 2 Transfer Standards; it provides an equation that should be used to calculate the tolerances when Type 2 transfer standards are used; provides definitions for Field Standards, Type 1 Transfer Standards and Type 2 Transfer Standards, and provides clarification that the State Director has the authority to approve the use of standard and that specific requirements in NIST HB 44 code are not necessary to approve a standard for use.

Although 3 types of standards are to be specified in NIST HB 44, language has been added in Block 8 such that whenever possible and practical, field standards should be used to test commercial devices. Definitions are provided for the three different types of standards. Separating the standards into 3 types helps to determine what specifications should be used for the standards combined error and uncertainty or whether the tolerances should be increased to account for the error in the standard. Both Field Standards and Type 1 Transfer standards must comply with the current Fundamental Considerations in NIST HB 44 that state “When a Standard is used without correction, its combined error and uncertainty must be less than one-third of the applicable device tolerance”. This allows the device under test to have more than 2/3 of the tolerance associated with the test. Type 2 Transfer Standards do not meet the one-third requirement and may not be stable or valid over an extended time-period or over wide ranges of environmental or operating conditions. With the inability to meet the one-third requirements for the uncertainty in the standard that Field Standards and Type 1 Transfer Standard are required to meet, an equation was added to the general code for all Type 2 Transfer Standards in NIST HB 44 to multiply the basic tolerance (the applicable tolerance, maintenance, acceptance, or special test tolerances by 2/3 and adding the uncertainty of the standard. This increases the total tolerance when using a Type 2 transfer standard to account for the uncertainty of the standard.

Although a larger tolerance is used to account for the uncertainty in Type 2 standards, allowing an unlimited amount of uncertainty to be added to the tolerance adds an open-ended amount of uncertainty to the tolerance and the larger the tolerance that is allowed the more lead way is given to the device under test and the more disadvantage to the customer. As such a stipulation was added that the maximum limit for the uncertainty of type 2 standards must be 2/3 of the MPE. The proposed equation provides a uniform method for considering the uncertainties associated with Type 2 Standards. An example of calculating the equation is provided below.

$$\text{Increased MPE} = (2/3 \times \text{MPE} + U)$$

with an upper limit of $U_{\text{MAX}} = 2/3 \text{ MPE}$

Example Calculation

$$\begin{aligned} \text{Increased MPE} &= (2/3 \times 0.01 + 0.005) \\ &= 0.01166 \end{aligned}$$

In this example the U_{MAX} does not exceed $2/3$ MPE which = 0.007

Mr. Henry Oppermann (Seraphin) provided an analysis of the equation which is provided in the Justification of this Technical Analysis.

This Block also helps to clarify that the Director has the authority to approve Standards for use within a jurisdiction. This information is already included in a footnote in the Fundamental Considerations but has been moved to Section 3 in the Fundamental Considerations. Language was also added to clarify that specific language is not needed in various NIST HB Codes in order that these standards be accepted. Two items, LPG-15.1 and MFM-15.1 in the Interim Meeting Report (Publication 16), include a purpose statement that the proposals are added to allow field standard meters to be used to test and place into service dispensers and delivery system flow meters. Block 8 items clarify what has always been recognized in NIST HB 44 concerning the responsibility for acceptance of a standard and notes that specific code changes are not necessary for a standard to be adequate for use. Please see additional NIST OWM concerns with items LPG-15.1 and MFM-15.1 in the NIST OWM Technical Analysis for these items.

In addition to the changes in Block 8, a new Form 15 for the 2023 cycle which is not included in the 2022 Publication 16 and has not been addressed separately in the 2022 NIST OWM Technical Analysis, has been circulated to the Spring 2022 Regional Associations (NEWMA and CWMA) that will also impact LPG-15.1 and MFM-15.1 and Block 7 items. This proposal adds a General Code requirement so that rather than revising a specific code in Handbook 44 every time a new field or transfer standard is proposed or developed, an overall statement in the General Code recognizes the use of other field and transfer standards that meet the requirements for use as field or transfer standards is proposed as follows:

G-N.3. Test Methods. – Permissible test methods for verifying compliance of weighing and measuring systems with the provisions of the General Code and Specific Codes include, but are not limited to, test methods and apparatus that have been approved by the State Director of weights and measures as outlined in Appendix A - Fundamental Considerations, Section 3. Testing Apparatus.

For those who believe a specific statement in Handbook 44 is needed to recognize additional field and transfer standards, the proposed addition of G-N.3. will provide the reference they want without the need to change individual codes on a regular basis to recognize each particular field or transfer standard.

The submitters agree that these items, GEN-19.1 and OTH-22.1 are fully developed and requested that this S&T Committee consider that this combined item be a Voting Item in 2023.

Summary of Discussions and Actions:

At the 2022 Interim Meeting there was discussion concerning specifying a 1-year length of time for the stability of a field standard. The concern was whether or not this was an appropriate length of time and how a specific length of time for a standards stability could change due to many factors. Some expressed concerns with more time needed to review the latest edition of the proposal. NIST and Seraphin agreed to further develop the item and NIST OWM requested that both GEN-19.1 and the OTH-22.1 be combined.

NIST OWM Analysis
2023 NCWM Interim S&T Agenda Items
1/5/2023

During their work session, the Committee agreed to combine both GEN-19.1 and OTH-22.1 and agreed to a Developing status for this item. For more information or to provide comment, please contact:

Mr. Robert Murnane
Seraphin Test Measure Company
A Division of Pemberton Fabricators, Inc.
(609) 267-0922, rmurnane@pemfb.com

or

Ms. G. Diane Lee
NIST Office of Weights and Measures
diane.lee@nist.gov

At the 2022 Annual Meeting Open hearings the Committee heard comments for Mrs. Tina Butcher, the submitter of this item. Mrs. Butcher provided the NIST OWM technical analysis for this item as provided in the executive summary of the report. Mrs. Butcher noted that this item is ready to move forward as voting for the 2023 NCWM cycle.

During the Committee work session since the item status was Developing it remained Developing.

Regional Association Reporting:

Western Weights and Measures Association

During the WWMA 2022 Annual Meeting the following comments were received. Mr. Robert Murnane (Seraphin Test Measure Company) asked if they had the updated proposal online? The September 1st version was so that we didn't have to hunt and peck to find words to change. 3.2: Tolerance for Standards: in the first paragraph, where it says accuracy of standards it should say "field standards". On S&T agenda page 309, line 42, it should say "field standard or transfer standard". It is up to the discretion of the State Director.

Mr. Matt Douglas (S&T Committee) commented that the equation, it looks like when the error of the transfer standard is less than 1/3 the applicable tolerance, you would end up with a lower tolerance for the device - even though it looks like the intention would be to give an extended tolerance.

Mr. Murnane stated that the equation gives the benefit to the meter, I'll ask you to look at that paper.

Mr. Michael Keilty (Endress+Hauser) remarked that adding "Weighing and Measuring" is a good idea. If you were testing a type 1 then you don't use the formula. When you have a type 2 device then you would use the formula to calculate the corrections allowed. I recommend Developing.

Mr. Kurt Floren (County of Los Angeles) stated he did not want to be a hurdle to this. I'm still struggling. I'm picturing myself in a courtroom because we've taken formal enforcement action. We aren't equipped to test all "field conditions" in a Metrology lab. Is there any way for us to clarify certain things? What is an extended time and what is a short time with regard to how long a device remains accurate? I cannot define that, and I have continued questions.

Mr. Brent Price (Gilbarco) commented that S&T Page 310, line 8: I'm questioning if we need that last sentence.

Mr. Keilty wondered what does long-term vs short-term mean? I recommend that the item continue to be developing and answer Mr. Floren's questions.

Mr. Murnane stated this is our current attempt at this. There needs to be definitions, there is no real definition. What are you guys doing now to defend yourselves with no definition (referencing transfer standard vs field standard). I look for input but haven't had much. I think this could be a Voting Item.

Mr. Floren stated that field standard encompasses everything imaginable. It suggests that we have to evidence that every block weight that we have has been tested and proven to be stable under every possible scenario. We need to be very specific about what is a transfer standard.

During open hearings, Mr. Murnane provided testimony with changes to the proposed language which is now posted on the WWMA website. The WWMA S&T Committee recommended that this item should remain Developing, and that the submitter provides the updated language to NCWM to allow membership to review the updated proposal. The Committee further recommended that this item be blocked with Block 7 as the items in Block 7 are contingent on Block 8 items.

Southern Weights and Measures Association

The following comments were received during the 2022 SWMA Annual Meeting: Mr. Murnane stated that you can't always define every environmental issue, and we must be able to use judgment.

Mr. Keilty stated that Block 8 adds a definition for Type 1 and 2 Transfer Standards into the code, and he recommends this item move forward as Developing.

The SWMA S&T Committee questioned why the submitter wants to move some of these items into code when they have been traditionally covered by the Fundamental Considerations. Additionally, the Committee questioned the open-ended nature of the timeframe component in defining the type of standard, and section 3.1.1. Essential Elements of Traceability potentially restricting the Directors authority in allowing certain standards to be used. The Committee also requests documentation of specific standards in use and which type of standard they would be based on these definitions.

The SWMA S&T Committee recommended this item move forward as a Developing Item.

Northeastern Weights and Measures Association

During the 2022 Interim Meeting, Mr. Murnane commented that the item that appears in the agenda is not what has been proposed as there are many typos. A true version of the item was submitted to the NEWMA S&T Chair and shared with the body. Mr. Murnane asks that the same status be given to Block 7 and Block 8 as they are directly linked. Mr. Murnane indicated that this proposal draws from the Fundamental Considerations and clarifies that State Directors have the authority to use any standards. Mr. Michael Keilty (Endress Hauser) questioned Section 3.2 that was shaded, regarding corrections by a metrology lab and clarification was given by Mr. Murnane. Mr Keilty stated that he understands what is being done to introduce type 1 and type 2 transfer standards, but transfer standards are not always stable and type 2 standards do not meet 1/3 requirement in the Fundamental Consideration and has questions about "time" and "environmental conditions".

After hearing comments from the floor, the Committee believes this item has merit and is full developed. The Committee recommended that this item be assigned a Voting status.

Central Weights and Measures Association

During the 2022 Interim Meeting, Mr. Murnane stated that the nomenclature has been cleaned up since previous version. The intent has not changed, simply clarifications. Former contended point was referring to only measuring devices instead of weighing and measuring devices. Wants this change, which was provided to the Committee in writing, to be included and moved forward with this item.

The CWMA S&T Committee believes this item is fully developed and recommend Voting status with the following changes which were provided by the submitter:

Whenever possible and practical, field standards should be used to test commercial weighing and measuring devices. However, where it is impractical or unduly cumbersome to use field standards, transfer standards may be used. There are two categories of transfer standards. The critical criteria that distinguish between these standards are: (1) the accuracy and uncertainty of the standard; (2) the stability as a standard over an extended period; and (3) proven validity or performance of the standard over the range of environmental and operational conditions in which the standard may be used.

A “field standard” is one that meets the one-third requirement mentioned earlier in this section. Additionally, the field standard maintains its validity or stability as a standard over an extended period (defined based on data of the standard’s stability by an authorized metrology lab or as specified by the Director) and is known to maintain its value as a standard over the full range of environmental conditions and the range of operating conditions in which the standard may be used to test commercial weighing and measuring devices. Corrections, as documented by an authorized metrology laboratory, may be used.

Transfer standards do not meet one or more of these critical criteria. One category of transfer standards, which is referred to here as a “Type 1 transfer standard,” is a transfer standard that meets the one-third accuracy requirement for a short time, under a limited range of environmental conditions and/or a limited range of operating conditions. The accuracy of a Type 1 transfer standard may have to be verified through testing each time it is used to verify that the desired accuracy and performance can be achieved when the Type 1 transfer standard is used under the limited environmental and operating conditions. When a Type 1 transfer standard is used, the basic tolerances specified for the commercial weighing and measuring devices are applied as specified in the applicable codes.

The second category of transfer standard, which is referred to here as a “Type 2 transfer standard,” is one that does not meet the one-third requirement. The Type 2 transfer standard must be stable and valid under the environmental or operating conditions in which it is used. The performance characteristics must be confirmed with sufficient data to properly characterize the uncertainty associated with the Type 2 transfer standard. When a Type 2 transfer standard is used, the tolerances applicable to the commercial weighing and measuring devices must be increased to recognize the large uncertainty or corrections associated with the Type 2 transfer standard. When commercial meters weighing and measuring devices are tested using a Type 2 transfer standard, the tolerance applied to the commercial weighing and measuring devices meter under test shall be determined as specified in the General Code.

(Added 202X)

3.2. Tolerances for Standards. – Except for work of relatively high precision, it is recommended that the accuracy of ~~field~~ standards used in testing commercial weighing and measuring equipment be

established and maintained so that the use of corrections is not necessary. When the **field** standard is used without correction, its combined error and uncertainty must be less than one-third of the applicable device tolerance.

Device testing is complicated to some degree when corrections to standards are applied. When using a correction for a **field** standard **or a transfer standard**, the uncertainty associated with the corrected value must be less than one-third of the applicable device tolerance. The reason for this requirement is to give the device being tested as nearly as practicable the full benefit of its own tolerance.

References:

- [1] NIST OWM Analysis and Executive Summary reports <https://www.nist.gov/pml/weights-and-measures/publications/owm-technical-analysis>
- [2] National Conference on Weights and Measures Publication 15 (2023) and 16 (2022)
<https://www.ncwm.com>
- [3] 1905-2022 NCWM Annual Conference reports <https://www.nist.gov/pml/owm/publications/ncwm-annual-reports>