



OIML Working DRAFT

Date: 19 November, 2015

Reference number: OIML R60-3, 1WD

Supersedes document: OIML R60 (2000)

OIML TC9 project 1

Title: Metrological Regulation for Load Cells
Part 3: Report Format for Type Evaluation

Secretariat:
John Barton
National Institute of Standards and Technology, USA

Circulated to P- and O-members and liaison international bodies and external organizations for:

discussion at (date and place of meeting):

comments by: 28 February, 2016

vote (P-members only) and comments by

TITLE OF THE CD (English):

OIML R 60-3

Metrological Regulation for Load Cells

Part 3: Report Format for Type Evaluation

TITRLE DU CD (French):

OIML R 60-3

Réglementation métrologique des cellules de pesée

Partie 3 : Format de rapport pour l'Examen de Type

Original version in: English

Part 3 Test report format - General

1. Introduction

- 1.1 This Report Format applies to any kind of load cell (independent of its technology). It presents a standardized format for the results of the various tests and examinations, described in Part 2 of R 60 (20XX), to which a type of load cell shall be submitted for the purpose of its approval based on this OIML Recommendation.
- 1.2 It is recommended that all metrology services or laboratories evaluating and/or testing types of load cells according to OIML R 60-1 20XX, or to national or regional regulations based on that Recommendation, use this Report Format, directly or after translation into a language other than English or French. In case of a translation, it is highly recommended to leave the structure and the numbers of the clauses unchanged: in this case, most of the content is also understandable for those who can not read the language of the translation.
- 1.3 Some of the tests may have to be repeated several times and reported using several identical sheets; therefore, report pages must be numbered in the space provided at the top of each page, completed by the indication of the total number of pages.
- 1.4 In the practical application of the Report Format, in addition to a cover page by the Issuing Authority, as a minimum clauses A–F (as necessary) shall be included

2. Applicability of this Report Format

In the framework of the *OIML Certificate System for Measuring Instruments*, and the *OIML Mutual Acceptance Arrangement (MAA)* applicable to load cells in conformity with OIML R 60-1 20XX, use of this report format is mandatory, in French and/or in English with translation into the national languages of the countries issuing such certificates, if appropriate.

Implementation of this Report Format is informative with regard to the implementation of OIML Recommendation R 60 parts 1 20XX in national regulations.

2.1. Calculation procedures

- 2.1.1. In order to facilitate a comparison of the reports established in English and in French, the same abbreviations (those of the English language) are used in both versions; the meanings of these abbreviations is given whenever appropriate.

In testing and evaluating load cells for pattern evaluation, it is recognized that the test apparatus and practices used by the various laboratories will be different. OIML R 60 allows for these variations and still provides a method for testing, recording and calculating results that are readily understandable by other knowledgeable parties reviewing the data.

In order to achieve this ease of comparability it is necessary that those persons conducting the tests use a common system for recording data and calculating results.

Thus, it is essential that the calculation procedures below be reviewed and followed closely in the completion of this test report.

2.1.2. Load cell errors (E_L = Error Load test)

- 2.1.2.1. Complete a Table 6.3 for each test temperature, calculate the averages and record in the right hand column. When five runs are necessary, use Table 6.4.
- 2.1.2.2. Determine the conversion factor, f , which is the number of indicated units per load cell verification interval, v , and is used to convert all “indicated units” to “ v ”. It is determined from the test data averages of the increasing load tests at the initial 20 °C nominal test temperature.
- 2.1.2.3. If a test load corresponding to 75% of the measuring range for the load cell under test (i.e., 2 250 divisions for a 3 000 division cell, which is D_{\min} plus 75 % of the difference between D_{\max} and D_{\min}) is not included in the test loads used in Table 4.10.1, interpolate between the adjacent upper and lower values of the averages of all three test runs and record in Table 4.10.3 (see R60-1: 8.8.2).
- 2.1.2.4. Calculate the difference between the average indication on the increasing load test runs at 75 % of the difference between D_{\max} and D_{\min} and the indication at D_{\min} . Divide the result (to five significant figures) by the number of verification intervals (75% of n) for that load to obtain the conversion factor, f , and record in the tables that follow.

$$f = \frac{\text{average indication at } [D_{\min} + 0.75 \cdot (D_{\max} - D_{\min})]}{0.75 \cdot n}$$

The units of conversion factor f are indicated units (e.g. digits or counts) per load cell verification interval v .

- 2.1.2.5. Enter the average test indications of the tests at the temperatures following the initial test at a nominal 20 °C in Table 6.5. In recording this data, indicate a “no test load” indication (at D_{\min}) as “0”. This may require subtracting the “no load indication at D_{\min} ” from the “test load indication” so that the first entry in the column is “0”. These “0’s” have been preprinted on the form to clarify that a dead load condition is recorded as “0”.
- 2.1.2.6. Calculate the reference indication, R_i , by converting the net test load, in mass units, to indicated units (e.g., counts or digits), by multiplying by the conversion factor, f , for each test load and recording in the 2nd column in Table 6.5.

$$R_i = \frac{(\text{test load } i - D_{\min})}{(D_{\max} - D_{\min})} \cdot n \cdot f$$

2.1.2.7. In Table 6.5 calculate the difference between the average test indication and the reference indication for each test load at each test temperature and divide the result by the conversion factor f to obtain the error, E_L , for each test load in terms of v .

$$E_L = (\text{average test indication for test load } i - \text{reference indication } R_i) / f$$

2.1.2.8. Compare E_L with the corresponding MPE for each test load.

2.1.3. Repeatability error (E_R in terms of verification interval v)

2.1.3.1. Enter data in Table 6.6.

2.1.3.2. Calculate the maximum difference between the indications of the on Form 6.3 and divide it by f to obtain the repeatability error, E_R , in terms of the load cell verification interval v .

$$E_R = (\text{maximum indication of the test load} - \text{minimum indication}) / f$$

2.1.3.3. Compare E_R with the absolute value of the corresponding MPE for each test load.

2.1.4. Temperature effects on minimum dead load output (MDLO) (C_M = Change MDLO)

2.1.4.1. Enter in Table 6.7 the average indication for the initial minimum test load, D_{\min} , for each test temperature from Table 6.3.

2.1.4.2. Calculate the difference between the average test indications for each temperature T_i in sequence and divide the result by the conversion factor f to obtain the change in terms of the load cell verification interval v .

$$C_M = (\text{average test indication at } T_2 - \text{average indication at } T_1) / f$$

2.1.4.3. Divide C_M by $(T_2 - T_1)$ and multiply the result by 5 for class B, C, and D load cells or 2 for class A load cells. This gives the change in v per 5 °C for class B, C, and D load cells or in v per 2 °C for class A load cells.

2.1.4.4. Multiply the result by $[(D_{\max} - D_{\min}) / n] / v_{\min}$ to give the final result $C_M(v_{\min})$ in units of v_{\min} per 5°C for class B, C, and D load cells, or in units of V_{\min} per 2°C for class A load cells. $C_M(v_{\min})$ must not exceed p_{LC} .

$$C_M(v_{\min}) = \frac{C_M \cdot (D_{\max} - D_{\min})}{n \cdot v_{\min}}$$

$$P_{LC} \leq C_M(v_{\min})$$

2.1.5. Creep magnitude $C_C(t)$ and minimum dead load output return (C_{DR})

($C_C(t)$) = Creep, expressed in terms of the load cell verification interval, v)

($C_{DR} = DR$, expressed in terms of the load cell verification interval, v)

Remark: Contrary to the minimum dead load output return DR in terms of mass the minimum dead load output C_{DR} is expressed in terms of the verification interval v).

From the test indications recorded in Table 6.8, calculate the difference between the initial indication obtained at the minimum creep test load after the stabilization period and any indication obtained over the 30 minute test period with the maximum creep test load of 90% to 100% of E_{max} and divide by the conversion factor the conversion factor f .

$$C_C = (\text{indication} - \text{initial indication}) / f$$

Remark: If the minimum creep test load or the maximum creep test load differ from D_{min} or D_{max} according to 2.1.2 "Load cell errors E_L " the conversion factor f must be recalculated with the minimum and maximum creep test loads (see 2.1.2.4).

2.1.5.1. $C_C(t)$ must not exceed 0.7 times the absolute value of the MPE for the maximum creep test load at any time t over the 30 minute creep test period.

2.1.5.2. Calculate the difference between the test indications obtained at $t = 20$ minutes and $t = 30$ minutes after the initial indication at $t = t_0$ and divide by f to obtain the creep error, $CC(30 - 20)$, in terms of the load cell verification interval v .

$$C_C(30 - 20) = (\text{indication at time } t = 30 \text{ minutes} - \text{indication at time } t = 20 \text{ minutes}) / f$$

2.1.5.3. $C_C(30 - 20)$ shall not exceed 0.15 times the absolute value of the MPE for the applied load.

2.1.5.4. Calculate the difference between the initial indication obtained at the minimum creep test load after the stabilization period ($t_0 = 0$ min) and the indication at the minimum creep test load after the creep test and after a time interval for stabilization ($t > 30$ min) and divide the result by conversion factor f to obtain the minimum dead load output return, C_{DR} , in terms of v .

$$C_{DR} = (\text{indication at the minimum creep test load indication} - \text{initial indication at the minimum creep test load indication}) / f$$

2.1.5.5. If the time intervals specified in R60-1: Table 7 have been met, C_{DR} must not exceed 0.5 v .

2.1.5.6. If the actual time is between 100 % and 150 % of the specified time in R60-1: Table 7, then the following applies:

$$C_{DR} \leq 0.5 (1 - (x - 1))$$

with

$x = \text{actual time/specified time}$

- 2.1.5.7. Whereas C_{DR} expresses the minimum dead load output return in terms of v , the value of D_R as used in the OIML R76 is expressed in units of mass (g, kg or t).
- 2.1.5.8. Calculate the minimum dead load output return, DR , expressed in units of mass (g, kg or t) as follows: $DR = (E_{\max} - E_{\min} \times C_{DR}) / n_{\max}$
- 2.1.5.9. Regardless of the value declared by the manufacturer for the apportionment factor, p_{LC} , the MPE for creep shall be determined from R60-1: Table 4 using the apportionment factor, $p_{LC} = 0.7$ (see R60-1: 5.5.1).

2.1.6. Barometric pressure effects¹ (CP = Change Due to Barometric Pressure)

- 2.1.6.1. From the test indications recorded in Table 6.9, calculate the difference between the indications for each pressure and divide the result by conversion factor f to obtain the change, C_P , in terms of v .

$$C_P = (\text{indication at } P_2 - \text{indication at } P_1) / f$$

- 2.1.6.2. Divide C_P by $(P_2 - P_1)$ to determine the change due to barometric pressure in terms in terms of v per kilopascal (kPa).
- 2.1.6.3. Multiply the result by $[(E_{\max} - E_{\min}) / n_{\max}]$ to obtain the result in units of mass (g, kg, or t) per kPa (as stated by the manufacturer). The result must not exceed v_{\min} .

$$C_P(v_{\min}) = \frac{C_P}{(P_2 - P_1)} \cdot \frac{(E_{\max} - E_{\min})}{n_{\max}} \leq v_{\min}$$

2.1.7. Humidity effects² (CH or no mark)

($C_{H\min}$ = Change in terms of v due to Humidity effects on the indication of the minimum test load D_{\min})

($C_{H\max}$ = Change due to Humidity effect on the indication of the maximum test load D_{\max})

Remark: If the minimum or maximum test load used for this test differ from the minimum test load D_{\min} or maximum test load D_{\max} according to 2.1.2 "Load cell errors E_L " the conversion factor f must be recalculated with the minimum and maximum test loads of this test (see 2.1.2.4).

- 2.1.7.1. From the test indications recorded in Table 6.10.1, calculate the difference between the initial indications for the minimum test load, D_{\min} , before and after the damp heat test and divide the result by conversion factor f to obtain the change, $C_{H\min}$, in terms of verification interval v (see R60-1: 5.6.3.1).

¹ This test may not be necessary depending on the design of the load cell.

² This test is not necessary if the load cell is marked NH or SH.

C_{Hmin} must not exceed $0.04 \cdot n$.

- 2.1.7.2. Calculate the average indications $\bar{I}\{D_{max}\}$ and $\bar{I}\{D_{min}\}$ at D_{min} and D_{max} (see R60-1: 8.10.5) for the required number of test indications, before and after the damp heat test. Subtract $\bar{I}\{D_{max}\}$ from $\bar{I}\{D_{min}\}$ for the tests before and after damp heat test and then calculate the difference between the results. Divide the result by the conversion factor f to obtain the change, C_{Hmax} , in terms of v .

$$C_{Hmax} = \frac{[(\bar{I}\{D_{max}\} - \bar{I}\{D_{min}\})_{after} - (\bar{I}\{D_{max}\} - \bar{I}\{D_{min}\})_{before}]}{f}$$

- 2.1.7.3. C_{Hmax} must not exceed the MPE (see table 4 in 5.3.1.1).

2.1.8. Humidity effects³ (SH)

Report load test errors at different temperatures and humidity conditions using Forms 6.3, then indicate the results in Table 6.10.2 utilizing the procedure contained within “load cell errors” procedure, 2.1.2, in a manner similar to that used for the preparation of Table 6.5.

2.2. Additional tests for load cells equipped with electronics

2.2.1. Warm-up time

- 2.2.1.1. Enter data on Form 6.11.
- 2.2.1.2. Span is the result of subtraction of the indication at the minimum test load, D_{min} , from the indication at the maximum test load, D_{max} .
- 2.2.1.3. Change is the difference between the span and the initial run span.

2.2.2. Power voltage variations

- 2.2.2.1. Enter data on Form 6.12.
- 2.2.2.2. Perform load tests and record results utilizing Form 6.12.
- 2.2.2.3. Calculate reference indications in accordance with the “load cell errors” procedure, 2.1.2.
- 2.2.2.4. Indicate results on Form 6.12.

2.2.3. Short-time power reductions

- 2.2.3.1. Enter data on Form 6.13.
- 2.2.3.2. Calculate the difference, which is:

³ This test is not necessary if the load cell is marked NH or CH or has no humidity marking.

$$\text{difference} = \frac{(\text{indication with disturbance, in units} - \text{indication without disturbance, in units})}{\text{conversion factor, } f}$$

2.2.3.3. Indicate results on Form 6.13.

2.2.4. Bursts (electrical fast transients)

2.2.4.1. Enter data on Forms 6.14.1 and 6.14.2.

2.2.4.2. Calculate the difference, which is:

$$\text{difference} = \frac{(\text{indication with disturbance, in units} - \text{indication without disturbance, in units})}{\text{conversion factor, } f}$$

2.2.4.3. Indicate results on Forms 6.14.1 and 6.14.2.

2.2.5. Surge

2.2.5.1. Enter data on Forms 6.15

2.2.5.2. **Data needed. PG 1 to provide instructions for calculation of results if necessary**

2.2.5.3. Indicate results on Forms 6.15

2.2.6. Electrostatic discharge

2.2.6.1. Enter data on Forms 6.16.1, 6.16.2 and 6.16.3.

2.2.6.2. Calculate the difference, which is:

$$\text{difference} = \frac{(\text{indication with disturbance, in units} - \text{indication without disturbance, in units})}{\text{conversion factor, } f}$$

2.2.6.3. Indicate results on Forms 6.16.1, 6.16.2.1, and 6.16.2.2.

2.2.6.4. Provide test point information on Form 6.16.3.

2.2.7. Electromagnetic susceptibility

2.2.7.1. Enter data on Form 4.10.15(a).

2.2.7.2. Calculate the difference, which is:

$$\text{difference} = \frac{(\text{indication with disturbance, in units} - \text{indication without disturbance, in units})}{\text{conversion factor, } f}$$

2.2.7.3. Indicate results on Form 6.17.1.

2.2.7.4. Provide test set-up information on Form 6.17.2.

2.2.8. Immunity to conducted electromagnetic fields

2.2.8.1. Enter data on Form 6.18.

2.2.8.2. **Data needed. PG 1 to provide instructions for calculation of results if necessary**

2.2.8.3. Indicate results on Form 6.18.

2.2.8.4. Provide test set-up information on Form 6.18.

2.2.9. Span stability

2.2.9.1. Enter data on Forms 6.19.1 (3 runs) to 6.19.2 (5 runs).

2.2.9.2. Calculate averages and record on Forms 6.19.1 (3 runs) to 6.19.2 (5 runs).

2.2.9.3. Indicate results on Form 6.19.3

2.3. General notes

2.3.1. Absolute (not relative) time shall be recorded.

2.3.2. The testing laboratory may submit any graphs or plots depicting the test results on the following pages of this report.

Note: For example, Figure 1 gives a sample plot depicting the combined errors versus applied load.

2.3.3. When reporting values for individual test data, the data should be truncated to two significant digits to the right of the decimal place and reported in load cell verification intervals, v.




Figure 1 Example of an error envelope

2.4. Formula signs and list of symbols

| <i>Symbol</i> | <i>Description</i> | <i>Reference</i> |
|----------------|--------------------------------------------------------------------------------------------------------------------------------------|------------------|
| $C_C(t)$ | creep magnitude, expressed in terms of v at time t obtained over the 30 minutes creep test | 2.1.5 |
| $C_C(30 - 20)$ | difference between output at $t = 30$ minutes and at $t = 20$ minutes during creep test | 2.1.5.2 |
| C_{DR} | minimum dead load output return, expressed in terms of v | 2.1.5 |
| C_{Hmax} | humidity effect on maximum test load output, expressed in terms of v | 2.1.7 |
| C_{Hmin} | humidity effect on minimum test load output, expressed in terms of v | 2.1.7 |
| C_M | temperature effect on minimum dead load output, expressed in terms of v | 2.1.4 |
| $C_M(v_{min})$ | temperature effect on minimum dead load output, expressed in terms of v_{min} per 5°C for class B, C and D or per 2°C for class A. | 2.1.4 |
| C_P | barometric pressure effect, expressed in terms of v | 2.1.6 |
| $C_P(v_{min})$ | barometric pressure effect, expressed in terms of mass (g, kg, t) per kPa. | 2.1.6 |
| D_{max} | maximum test load | R60-1, 3.5.6 |
| D_{min} | minimum test load | R60-1, 3.5.12 |
| DR | minimum dead load output return, expressed in mass units (g, kg, t) | R60-1, 3.5.10 |
| E_L | load cell error, expressed in terms of v | 2.1.2 |
| E_{max} | maximum capacity of the load cell | R60-1, 3.5.5 |
| E_{min} | minimum dead load of the load cell | R60-1, 3.5.9 |
| E_R | repeatability error, expressed in terms of v | 2.1.3 |
| f | conversion factor, number of indicated units per verification interval, v | 2.1.2.4 |
| mpe | maximum permissible error | R60-1, 3.7.10 |
| n | number of load cell verification intervals into which the load cell measuring range is divided | R60-1 3.5.13 |
| n_{max} | maximum number of load cell verification intervals | R60-1, 3.5.8 |
| plc | apportionment factor | R60-1, 3.7.2 |
| R_i | reference indication (net test load), expressed in indication units | 2.1.2.6 |
| t_0 | Time $t_0 = 0$ min when the initial indication at minimum test load is measured | 2.1.5 |
| t | Time over the 30 minute creep test period after the initial indication ($t_0 = 0$ min) at minimum test load | 2.1.5 |
| T_1, T_2 | temperature1, temperature2 | 2.1.4.2 |
| v | load cell verification interval | R60-1, 3.5.4 |
| v_{min} | minimum load cell verification interval | R60-1, 3.5.11 |
| Y | relative v_{min} , $Y = E_{max}/v_{min}$ | R60-1, 3.5.15, |
| Z | relative DR, $Z = E_{max}/(2 \times DR)$ | R60-1, 3.5.14 |

2.5. Summary of formulae contained within calculation procedures

| <i>Symbol</i> | <i>Formula</i> |
|----------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| C_C | $C_C = (\text{indication} - \text{initial indication}) / f$ |
| $C_C(30 - 20)$ | $C_C(30 - 20) = (\text{test indication at 30 minutes} - \text{test indication at 20 minutes}) / f$ |
| C_{DR} | $C_{DR} = (\text{minimum test load indication}_2 - \text{minimum test load indication}_1) / f$ |
| C_{Hmin} | $C_{Hmin} = [(\text{indication at } D_{min})_{after} - (\text{indication at } D_{min})_{before}] / f$ |
| C_{Hmax} | $C_{Hmax} = [(\text{indication at } D_{max} - \text{indication at } D_{min})_{after} - (\text{indication at } D_{max} - \text{indication } D_{min})_{before}] / f$ |
| C_M | $C_M = (\text{indication at } T_2 - \text{indication at } T_1) / f$ |
| C_P | $C_P = (\text{indication at } P_2 - \text{indication at } P_1) / f$ |
| DR | $DR = E_{max} \times C_{DR} / n_{max}$ |
| E_L | $E_L = (\text{average test indication} - \text{reference indication}) / f$ |
| E_R | $E_R = (\text{maximum indication} - \text{minimum indication}) / f$ |
| f | $f = [\text{indication at 75 \% of } (D_{max} - D_{min}) - \text{indication at } D_{min}] / (0.75 \times n)$ [see Note 2] |
| R_i | $R_i = [(\text{test load} - D_{min}) / (D_{max} - D_{min})] \times n \times f$ |

Notes: 1 Observe extreme caution by referring to calculation procedure for correct application of these formulae.

2 Use with initial 20 °C ascending load run only. Refer to R60-1: 8.8.2.

3. Guidance for the application of this Test Report Format

In case a prescribed test is not relevant for the type of instrument to be tested, the reason why the test is omitted shall be clearly stated in the field “Remarks” (for instance surge tests on signal lines shorter than 30 m, tests related to AC mains supply in case of an instrument only powered by batteries, or partial testing after modification of a previously tested type).

The number of the report and the page numbers shall be completed in the heading.

Page 1 of this Report Format may be replaced by a cover page by the Issuing authority.

Enter “NA” or “/” for “the test is not applicable.”

4. The Evaluation Report

Cover page
by the
Issuing Authority

4.1. Authority, responsible for this Report:

| | |
|----------------------------------------------|--|
| Name | |
| Address | |
| Report number | |
| Application number | |
| Period of tests | |
| Date of issuing this Report | |
| Name and signature of the responsible person | |
| Stamp(s) (if applicable) | |

4.2. Synopsis of the results of the examination and tests

| | | |
|---------------------------------------------------------------------------------------------------------------|------------------------------|-----------------------------|
| The load cell under test fulfills <u>ALL</u> the applicable requirements according to OIML R60 (201X): | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Remarks: | | |

4.3. Summary of the results of the examination and tests

(To be completed by the Issuing Authority)

4.3.1. Examinations

For details, refer to the tests as indicated in the last column.

| General requirements: | Passed | Failed | Details in R60-1 |
|-------------------------------------------------------|--------|--------|------------------|
| Documentation | | | 8.5 |
| Inscription and presentation of load cell information | | | 6.2 |

4.3.2. Performance tests *(Refer to 9.7 of OIML R60-1)*

For details, refer to the tests as indicated in the last column.

Tests performed at (20°C / X₁°C / X₂°C / 20°C):

| Test procedure | Passed | Failed | Details in R60-1 |
|-------------------------------------------------------|--------|--------|-------------------------|
| Maximum permissible measurement errors | | | 5.3 / 8.10.1 |
| Repeatability error | | | 5.4 / 8.10.1 |
| Temperature effect on minimum dead load output return | | | 5.6.1.3 / 8.10.1 |
| Creep test | | | 5.5.1 / 8.10.2 |
| Minimum dead load output return (DR) | | | 5.5.2 / 8.10.3 |
| Barometric pressure effects at ambient temperature | | | 5.6.2 / 8.10.4 |
| Humidity effects (CH, SH) | | | 5.6.3 / 8.10.5 / 8.10.6 |

Additional tests performed for load cells equipped with electronics:

| Test procedure | Passed | Failed | Details in R60-1 |
|----------------------------------------------|--------|--------|-------------------------------------------|
| Warm-up time | | | 5.7.2.1 / 8.10.7.3 |
| Power Voltage Variations | | | 5.7.2.2 / 5.7.2.3 / 5.7.2.4 / 8.10.7.4 |
| Short-time power reductions | | | 5.7.2.5 / 8.10.7.5 |
| Bursts (electrical fast transients) | | | 5.7.2.5 / 8.10.7.6 |
| Surge | | | 5.7.2.5 / 8.10.7.7 |
| Electrostatic discharge | | | 5.7.2.5 / 8.10.7.8 |
| Electromagnetic susceptibility | | | 5.7.2.5 / 8.10.7.9 |
| Immunity to conducted electromagnetic fields | | | 5.7.2.5 / 8.10.7.10 |
| Span stability | | | 6.7.2.6 / 8.10.7.11 |
| Software | | | 6.1 |

4.4. General Information regarding the evaluation process

4.4.1. Manufacturer of the specimen

| | |
|---------------------|--|
| Company | |
| Address | |
| Contact Information | |

4.4.2. Applicant

| | |
|--------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------|
| Company | |
| Representative (name, telephone) | |
| Address | |
| Contact Information | |
| Reference | |
| Date of application | |
| Application number | |
| Applicant authorized by the manufacturer (documented) | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Statement that no concurrent application for OIML type evaluation has been made to any other OIML Issuing Authority (see OIML B3, 5.1.2 b) | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Remarks: | |

4.4.3. Testing laboratories involved in the tests
(This table has to be completed for each test laboratory)

| | | | |
|-------------------------------------------------------------------------------------------------------------|------------------------------|-------------------------------|-----------------------------|
| Name | | | |
| Address | | | |
| Application number | | | |
| Tests by this laboratory | | | |
| Date/period of tests | | | |
| Name(s) of test engineer(s) | | | |
| Accredited by | | Number: | Expires (date): |
| Accreditation includes R60 | <input type="checkbox"/> Yes | Edition: <input type="text"/> | <input type="checkbox"/> No |
| Details of relevant peer assessment or assessment by other means | | | |
| In case tests have been performed at locations other than the address of this laboratory, give details here | | | |
| Name of the responsible person | | | |
| Date of signature | | | |
| Stamp (if applicable) and signature of the responsible person | | | |
| Remarks: | | | |

4.5. General information concerning the load cell type*(as provided by the manufacturer prior to the evaluation)*

| | |
|----------------------------------------------------------------|--|
| Manufacturer's name/trade mark | |
| Manufacturer's type designation (or load cell model number) | |

| | Unit | Range |
|-------------------------------------------------------------------|------------------|-------|
| Accuracy classes | | |
| Maximum number of verification intervals n_{\max} | | |
| Maximum capacity E_{\max} | (g, kg, t) | |
| Minimum capacity E_{\min} | (g, kg, t) | |
| Minimum load cell verification interval $v_{\min}=(E_{\max} / Y)$ | (g, kg, t) | |
| Minimum dead load output return $DR = (1/2 \cdot E_{\max} / Z)$ | (g, kg, t) | |
| Rated output | (mV/V or counts) | |
| Input Impedance | Ω | |

4.6. Accessories, supplied with the test pattern by the applicant

| Accessory | Remarks and specifications |
|-----------------------------------------------------------------|----------------------------|
| Analog data processing device <i>(see OIML R76, T.2.2.3)</i> | |
| Cables | |
| Load cell mounting hardware: | |
| Load introduction elements: | |
| Main power supply | |
| Battery (type, voltage) | |
| Indicator <i>(see OIML R76, T.2.2.2)</i> | |
| Data printer | |
| Other accessories: | |

Further remarks concerning accessories:

4.7. Selection of sample(s) tested

4.7.1. Definition of the test pattern (*supplied by the applicant for this test report*)

This test report is issued for the following load cell:

| Model designation | Serial number | Maximum capacity | Maximum number of load cell intervals | Minimum load cell verification interval | Minimum dead load output return |
|-------------------|---------------|----------------------------|---------------------------------------|-----------------------------------------|---------------------------------|
| | | E_{\max} (g, kg or t) | n_{\max} | V_{\min} (g, kg or t) | DR (g, kg or t) |
| | | | | | |

4.7.2. Justification of the selection of the test sample(s) (*refer to R60-1: 8.3, 8.4 and Annex D*):

| Model designation | Serial number | Justification / Remark | Test Report No. (if available) |
|-------------------|---------------|------------------------|-----------------------------------|
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

4.8. Adjustments and modifications made to the samples during the testing:

Justification of the selection of the test sample(s) (*refer to R60-1: 8.3*):

| Model designation | Serial number | Adjustments and modifications made to the samples | Test Report No. (<i>if available</i>) |
|-------------------|---------------|---------------------------------------------------|-----------------------------------------|
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

Further information concerning adjustments:

4.9. Additional information concerning the type

4.9.1. General information of the load cell under test (specified by the manufacturer)

| | | |
|--------------------------------------------------------------------------|------------------|-----------------|
| Manufacturer's name/trade mark | | |
| Manufacturer's type designation (or load cell model number) | | |
| Serial number | | |
| Load cell construction (<i>e.g. S-type, ring type, bending beam</i>) | | |
| Load cell material | | |
| Sealing of strain gauge application (<i>e.g. hermetically, potted</i>) | | |
| Load cell equipped with electronics (<i>Yes / no</i>) | | |
| Accuracy classes | | |
| Maximum number of verification intervals n_{\max} | | |
| Maximum capacity E_{\max} | (g, kg, t) | |
| Minimum capacity E_{\min} | (g, kg, t) | |
| Minimum load cell verification interval $v_{\min} = (E_{\max} / Y)$ | (g, kg, t) | |
| Minimum dead load output return $DR = (1/2 \cdot E_{\max} / Z)$ | (g, kg, t) | |
| Rated output | (mV/V or counts) | |
| Input Impedance ¹ | Ω | |
| Cable connection ¹ | | 4-wire / 6-wire |
| Cable length ² | m | |

¹ mandatory for strain gauge load cells

² mandatory for strain gauge load cells with 4-wire connection

Additional information concerning the type (connection equipment, interfaces, etc.):

4.9.2. Additional information for the performance tests

(ref. R60-1, clauses 6.2.2, 6.2.3, and 6.2.4)

| | | | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------|-----------------------------|-------------------------------------------|----------------------------|
| Accuracy class | <input type="checkbox"/> A | <input type="checkbox"/> B | <input type="checkbox"/> C | <input type="checkbox"/> D |
| Working temperature (if other than -10°C to +40°C): | Upper _____°C, Lower _____°C | | | |
| Humidity symbol | <input type="checkbox"/> NH | <input type="checkbox"/> SH | <input type="checkbox"/> CH or no marking | |
| Loading designation: (ref. R60-1 clause 6.2.4.2) | | | | |
| Tension <input type="checkbox"/> Compression <input type="checkbox"/> Universal <input type="checkbox"/> Beam (shear) <input type="checkbox"/> Beam (bending) <input type="checkbox"/> | | | | |
| Minimum dead load as: $E_{min} =$ | | | | |
| Safe load limit as: $E_{lim} =$ | | | | |
| Excitation Voltage: | <input type="checkbox"/> AC | <input type="checkbox"/> DC | | |
| Value of the apportionment factor, p_{LC} , if not equal to 0.7 | | | | |

4.9.3. Additional information of the test pattern if equipped with electronics

| | |
|------------------------------------------------------------------------|--|
| Power Voltage: <input type="checkbox"/> AC <input type="checkbox"/> DC | |
| Interfaces: | |
| Output signal: | |
| Software Identification: | |
| Value of the apportionment factor, p_{LC} , if not equal to 0.7 | |

4.9.4. Relevant photographs taken during the examinations and tests:

| |
|--|
| |
|--|

4.9.5. Documentation supplied with the test pattern by the applicant

| Name of the document | Content | Version-No. / date of issue |
|----------------------|---------|-----------------------------|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

4.9.6. Inscriptions and presentations of load cell information
(according to manufacturer statement, *see OIML R60-1, 6.2*)

| R60-1 reference | Information | On the load cell | Accompanying document | In the Data sheet |
|------------------------|---------------------------------------------------------------|-------------------------|------------------------------|--------------------------|
| 6.2.1 / 6.2.2 | Name or trademark of manufacturer | | | |
| 6.2.1 / 6.2.2 | Manufacturer's own designation or load cell model | | | |
| 6.2.1 | Serial number | | | <i>Not applicable</i> |
| 6.2.1 | Year of production | | | <i>Not applicable</i> |
| 6.2.1 | OIML certificate number | | | |
| 6.2.2 / 6.2.4.1 | Accuracy class(es) and their symbols | | | |
| 6.2.4.5 | Maximum number of load cell verification intervals, n_{max} | | | |
| 6.2.2 / 6.2.4.2 | Type of load | | | |
| 6.2.2 / 6.2.4.3 | Working temperature designation | | | |
| 6.2.2 / 6.2.4.4 | Humidity symbol "NH" | | | |
| 6.2.2 / 6.2.4.4 | Humidity symbol "SH" | | | |
| 6.2.2 / 6.2.4.4 | No humidity symbol or "CH" | | | |
| 6.2.2 | Minimum dead load, $E_{min}^{1)}$ | | | |
| 6.2.1 / 6.2.2 | Maximum capacity, $E_{max}^{1)}$ | | | |
| 6.2.2 | Safe load limit, $E_{lim}^{1)}$ | | | |
| 6.2.2 | Minimum load cell verification interval ($v_{min}^{1)}$ | | | |
| 6.2.3, a | Relative v_{min} (Y) | | | |
| 6.2.3, b | Minimum dead load return DR $^{1)}$ | | | |
| 6.2.3, b | Relative DR (Z) | | | |
| 6.2.2, 1 | Rated output | | | |
| 6.2.2, 1 | Excitation voltage | | | |
| 6.2.2, 1 | Input impedance | | | |
| 6.2.2, 1 | Cable connection $^{2)}$ | | | |
| 6.2.2, 1 | Cable length $^{3)}$ | | | |
| 6.2.2, k | Apportionment factor, p_{LC} (if not equal to 0.7) | | | |
| 6.2.2, l, 6.2.3, c | Further information | | | |

¹⁾ In units of (g, kg, t)

²⁾ E.g. 4-wire / 6-wire cable


³⁾ mandatory for strain gauge load cells with 4-wire connection

Further load cell information given by the manufacturer:

4.9.7. Various designs within the model range:

| Model designation | Maximum capacity | Minimum dead load | Maximum number of load cell intervals | Minimum load cell verification interval | Minimum dead load output return |
|-------------------|---------------------------|---------------------------|---------------------------------------|-----------------------------------------|---------------------------------|
| | E_{max} (g, kg or t) | E_{min} (g, kg or t) | n_{max} | v_{min} (g, kg or t) | DR (g, kg or t) |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

4.9.8. Relevant photographs / documentation of the model range:



4.9.9. Definition of load cell families / construction
(This table to be completed by the manufacturer for each load cell family within the model range)


| Type / Model designation | specification | OIML R60-1 (201X) | Remark |
|---------------------------------|--------------------------------------|--------------------------|--------------------------------------------|
| | Application of load | 3.2.1 | <i>(e.g. tension / compression)</i> |
| | Load cell construction | 3.3 | <i>(e.g. bending beam)</i> |
| | Material or combination of materials | 3.4.2 | |
| | Shape | 3.4.2 | See 4.9.10 |
| | Design of measuring technique | 3.3.1 | <i>(e.g. strain gauge bonded to metal)</i> |
| | Sealing of strain gauges | 3.4.2 | |
| | Mounting method | Annex E | |
| | Load transmission | Annex E | See 4.9.11 |
| | Output rating | 3.4.2 | |
| | Supply voltage | 3.4.2 | |
| | Input impedance | 3.4.2 | |
| | Cable connection | 3.4.2 | |
| | Cable length ¹ | 3.4.2 | |

Further remarks concerning the definition of load cell families / construction *(see table above)*

¹ mandatory for strain gauge load cells with 4-wire connection


4.9.10. Load cell dimensions within the load cell family

Pictures / Drawings of the load cell dimensions of the load cell family



4.9.11. Recommended load transmissions of the manufacturer

Pictures / Drawings of the recommended load transmissions



4.9.12. Results of previous tests that were taken into account

| Model designation | Serial number | Justification / Remark | Test Report No. <i>(if available)</i> |
|-------------------|---------------|------------------------|------------------------------------------|
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

4.10. Information concerning the test equipment used for the tests

(including details of simulations and the way uncertainties are taken into account, including the level of "risk." For instance 95% or $k=2$)

The following tables have to be completed for each individual piece of test equipment used for the tests.

General information:

For each of the following pieces of test equipment, indicate for which of the following test procedures the test equipment is used:

| R60-1 reference | Test procedure |
|-----------------|-------------------------------------------------------------------------------------------|
| 8.10.1 | Measurement error, repeatability error and temperature effect on minimum dead load output |
| 8.10.2 | Determination of creep error |
| 8.10.3 | Minimum dead load output return (DR) |
| 8.10.4 | Barometric pressure effects (Atmospheric pressure) |
| 8.10.5 | Humidity effects for load cells marked with CH or no marked |
| 8.10.6 | Humidity effects for load cells marked SH |
| 8.10.7 | Additional tests for load cells equipped with electronics |

Example:

A test equipment is used for determination the measurement error (R60-1: 8.10.1), the creep error (R60-1: 8.10.2), the minimum dead load (R60-1: 8.10.3) and humidity effect marked with SH (R60-1: 8.10.6):

| R60-1 reference | 8.10.1 | 8.10.2 | 8.10.3 | 8.10.4 | 8.10.5 | 8.10.5 | 8.10.6 | 8.10.7 |
|-----------------|--------|--------|--------|--------|--------|--------|--------|--------|
| Used for | X | X | X | | | | X | |

4.10.1. Force generating system (if a force generating system or force generating machine is used)

| | Description | Remark |
|------------------------------|-------------|--------|
| Designation | | |
| Type | | |
| Manufacturer | | |
| Identification Number | | |
| Load Range | | |
| Load Steps | | |
| Unit | | |
| Preload | | |
| Rel. uncertainty (k=2) | | |
| Last calibration | | |
| Certificate No. / report No. | | |
| Recalibration interval | | |

The force generating system is used for the following test procedures:

| | | | | | | | | |
|-----------------|--------|--------|--------|--------|--------|--------|--------|--------|
| R60-1 reference | 8.10.1 | 8.10.2 | 8.10.3 | 8.10.4 | 8.10.5 | 8.10.5 | 8.10.6 | 8.10.7 |
| Used for | | | | | | | | |

Remarks / picture of the force generating system:

4.10.2. Weights

(if the load cell is tested manually with weights)

| Number / identification | Weight (g, kg, t) | Class ¹ / rel. uncertainty (k=2) | Last calibration | Recalibration interval | Certificate No. / report No. |
|-------------------------|-------------------|---------------------------------------------|------------------|------------------------|------------------------------|
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

The Weights are used for the following test procedures:

| | | | | | | | | |
|-----------------|--------|--------|--------|--------|--------|--------|--------|--------|
| R60-1 reference | 8.10.1 | 8.10.2 | 8.10.3 | 8.10.4 | 8.10.5 | 8.10.5 | 8.10.6 | 8.10.7 |
| Used for | | | | | | | | |

Remarks / picture of the weights:

¹ according to OIML R111

4.10.3. Temperature chamber (without humidity control)

| | Description | Remark |
|-----------------------------------|--------------------|---------------|
| Designation | | |
| Type | | |
| Manufacturer | | |
| Identification Number | | |
| height x width x length dimension | | |
| Temperature range | | |
| Temperature stability | | |
| Rel. uncertainty (k=2) | | |
| Last calibration | | |
| Certificate No. / report No. | | |
| Recalibration interval | | |

The temperature chamber is used for the following test procedures:

| | | | | | | | | |
|-----------------|--------|--------|--------|--------|--------|--------|--------|--------|
| R60-1 reference | 8.10.1 | 8.10.2 | 8.10.3 | 8.10.4 | 8.10.5 | 8.10.5 | 8.10.6 | 8.10.7 |
| Used for | | | | | | | | |

Remarks / picture of the temperature chamber:

4.10.4. Climate chamber (with temperature and humidity control)

| | Description | Remark |
|-----------------------------------|--------------------|---------------|
| Designation | | |
| Type | | |
| Manufacturer | | |
| Identification Number | | |
| height x width x length dimension | | |
| Temperature range | | |
| Temperature stability | | |
| Humidity range | | |
| Humidity stability | | |
| Rel. uncertainty (k=2) | | |
| Last calibration | | |
| Certificate No. / report No. | | |
| Recalibration interval | | |

The climate chamber is used for the following test procedures:

| | | | | | | | | |
|-----------------|--------|--------|--------|--------|--------|--------|--------|--------|
| R60-1 reference | 8.10.1 | 8.10.2 | 8.10.3 | 8.10.4 | 8.10.5 | 8.10.5 | 8.10.6 | 8.10.7 |
| Used for | | | | | | | | |

Remarks / picture of the climate chamber:

4.10.5. Temperature chamber (without humidity control)

| | Description | Remark |
|-----------------------------------|--------------------|---------------|
| Designation | | |
| Type | | |
| Manufacturer | | |
| Identification Number | | |
| height x width x length dimension | | |
| Temperature range | | |
| Temperature stability | | |
| Rel. uncertainty (k=2) | | |
| Last calibration | | |
| Certificate No. / report No. | | |
| Recalibration interval | | |

The temperature chamber is used for the following test procedures:

| | | | | | | | | |
|-----------------|--------|--------|--------|--------|--------|--------|--------|--------|
| R60-1 reference | 8.10.1 | 8.10.2 | 8.10.3 | 8.10.4 | 8.10.5 | 8.10.5 | 8.10.6 | 8.10.7 |
| Used for | | | | | | | | |

Remarks / picture of the temperature chamber:

4.10.6. Indicator / Indicating instrument
(for testing analog load cells)

| | Description | Remark |
|--------------------------------|--------------------|---------------|
| Designation | | |
| Type | | |
| Manufacturer | | |
| Identification / Serial Number | | |
| Measurement range | | |
| Rel. uncertainty (k=2) | | |
| Last calibration | | |
| Certificate No. / report No. | | |
| Recalibration interval | | |

Settings of the indicator / indicating instrument used for the tests

| | Description | Remark |
|------------------------|--------------------|---------------|
| Measurement range | | |
| Supply voltage (AC/DC) | | |
| Filter settings | | |
| Cable connections | | |
| | | |
| | | |

The indicator / indicating instrument is used for the following test procedures:

| | | | | | | | | |
|--------------------|--------|--------|--------|--------|--------|--------|--------|--------|
| R60-1 reference | 8.10.1 | 8.10.2 | 8.10.3 | 8.10.4 | 8.10.5 | 8.10.5 | 8.10.6 | 8.10.7 |
| Used for | | | | | | | | |

Remarks / picture of the indicator / indicating instrument:

4.10.8. Terminal / Digital data processing device
(for testing load cells equipped with electronics)

| | Description | Remark |
|--------------------------------|--------------------|---------------|
| Designation | | |
| Type | | |
| Manufacturer | | |
| Identification / Serial Number | | |
| Measurement range | | |
| Last calibration | | |
| Certificate No. / report No. | | |
| Recalibration interval | | |

Settings of the indicator / indicating instrument used for the tests

| | Description | Remark |
|------------------------|--------------------|---------------|
| Measurement range | | |
| Supply voltage (AC/DC) | | |
| Filter settings | | |
| Cable connections | | |
| | | |
| | | |

The terminal / digital data processing device is used for the following test procedures:

| | | | | | | | | |
|-----------------|--------|--------|--------|--------|--------|--------|--------|--------|
| R60-1 reference | 8.10.1 | 8.10.2 | 8.10.3 | 8.10.4 | 8.10.5 | 8.10.5 | 8.10.6 | 8.10.7 |
| Used for | | | | | | | | |

Remarks / picture of the terminal / digital data processing device:

4.10.9. Barometric pressure meter

| | Description | Remark |
|--------------------------------|--------------------|---------------|
| Type | | |
| Manufacturer | | |
| Identification / Serial Number | | |
| Measurement range | | |
| Rel. uncertainty (k=2) | | |
| Last calibration | | |
| Certificate No. / report No. | | |
| Recalibration interval | | |

The barometric pressure meter is used for the following test procedures:

| | | | | | | | | |
|-----------------|--------|--------|--------|--------|--------|--------|--------|--------|
| R60-1 reference | 8.10.1 | 8.10.2 | 8.10.3 | 8.10.4 | 8.10.5 | 8.10.5 | 8.10.6 | 8.10.7 |
| Used for | | | | | | | | |

4.10.10. Thermometer

| | Description | Remark |
|--------------------------------|--------------------|---------------|
| Type | | |
| Manufacturer | | |
| Identification / Serial Number | | |
| Measurement range | | |
| Rel. uncertainty (k=2) | | |
| Last calibration | | |
| Certificate No. / report No. | | |
| Recalibration interval | | |

The thermometer is used for the following test procedures:

| | | | | | | | | |
|-----------------|--------|--------|--------|--------|--------|--------|--------|--------|
| R60-1 reference | 8.10.1 | 8.10.2 | 8.10.3 | 8.10.4 | 8.10.5 | 8.10.5 | 8.10.6 | 8.10.7 |
| Used for | | | | | | | | |

4.10.11. Moisture analyzer

| | Description | Remark |
|--------------------------------|--------------------|---------------|
| Type | | |
| Manufacturer | | |
| Identification / Serial Number | | |
| Measurement range | | |
| Rel. uncertainty (k=2) | | |
| Last calibration | | |
| Certificate No. / report No. | | |
| Recalibration interval | | |

The moisture analyzer is used for the following test procedures:

| | | | | | | | | |
|-----------------|--------|--------|--------|--------|--------|--------|--------|--------|
| R60-1 reference | 8.10.1 | 8.10.2 | 8.10.3 | 8.10.4 | 8.10.5 | 8.10.5 | 8.10.6 | 8.10.7 |
| Used for | | | | | | | | |

4.10.12. Additional test equipment

(e.g. burst generator for testing of load cells equipped with electronics)

| | Description | Remark |
|--------------------------------|--------------------|---------------|
| Test equipment | | |
| Type | | |
| Manufacturer | | |
| Identification / Serial Number | | |
| Measurement range | | |
| Rel. uncertainty (k=2) | | |
| Last calibration | | |
| Certificate No. / report No. | | |
| Recalibration interval | | |

The equipment is used for the following test procedures:

| | | | | | | | | |
|-----------------|--------|--------|--------|--------|--------|--------|--------|--------|
| R60-1 reference | 8.10.1 | 8.10.2 | 8.10.3 | 8.10.4 | 8.10.5 | 8.10.5 | 8.10.6 | 8.10.7 |
| Used for | | | | | | | | |

4.10.13. Remarks (settings, pictures, further information)

5. Examination*(To be completed by the Evaluating Authority)***5.1. Marking requirements (R60-1,6.2)****5.1.1. Mandatory markings on the load cell (R60-1: 6.2.1)**

| R60 reference | Information | Fulfills requirements | |
|------------------|---------------------------------------------------|--------------------------|----|
| | | Yes | No |
| 7.2.1 / 7.2.2 | Name or trademark of manufacturer | | |
| 7.2.1 / 7.2.2 | Manufacturer's own designation or load cell model | | |
| 7.2.1 | Serial number | | |
| 7.2.1 / 7.2.2 | Maximum capacity, E_{\max} ¹⁾ | | |
| 7.2.1 | Year of production | | |
| 7.2.1 | OIML certificate number | | |

¹⁾ In units of (g, kg, t)

5.1.2. Mandatory markings on the load cell or an accompanying document
(R60-1: 6.2.2)

| R60-1 reference | Mandatory information | On load cell | In document | Fulfills requirements | |
|--------------------|---------------------------------------------------------------|-----------------|----------------|--------------------------|----|
| | | | | Yes | No |
| 6.2.4.1 | Accuracy classes and their symbols | | | | |
| 6.2.4.5 | Maximum number of load cell verification intervals, n_{max} | | | | |
| 6.2.4.2 | Loading designation (if necessary) | | | | |
| 6.2.4.3 | Working temperature designation | | | | |
| 6.2.4.4 | Humidity symbol "NH" | | | | |
| 6.2.4.4 | Humidity symbol "SH" | | | | |
| 6.2.2 | Minimum dead load, E_{min} | | | | |
| 6.2.2 | Safe load limit, E_{lim} | | | | |
| 5.1.3, 6.2.2 | Minimum load cell verification interval (v_{min}) | | | | |
| 6.2.2 | Other pertinent conditions | | | | |
| 3.7.2, 5.3.2 | Apportionment factor, p_{LC} (if not equal to 0.7) | | | | |
| 5.1.6 | Standard classification | | | | |
| 5.1.7 | Multiple classifications | | | | |

5.1.3. Non-mandatory, additional information (R60-1: 6.2.3)

| R60-1 reference | Non-mandatory additional information | On load cell | In document | Fulfills requirements | |
|--------------------|--------------------------------------|-----------------|----------------|--------------------------|----|
| | | | | Yes | No |
| 5.6.3.1 | Humidity symbol "CH" | | | | |
| 3.5.15 | Relative v_{min} , Y | | | | |
| 3.5.14 | Relative DR, Z | | | | |

5.4. Documentation for type approval (8.5)

| | Yes | No | Remarks |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----|----|------------------------------------|
| a) Description of the general principle of measurement (R60-1: 8.5, a) | | | |
| b) List and characteristics of essential components + details | | | |
| c) Mechanical drawings (R60-1: 8.5, b) | | | |
| d) Electric/electronic diagrams (R60-1: 8.5, c) | | | |
| e) Installation requirements (R60-1: 8.5, d) | | | |
| f) Sealing plan | | | |
| g) Panel layout | | | |
| h) General information of the software (R60-1: 8.5, g) | | | <i>For details, see R60-1, 6.1</i> |
| i) Operating instructions (R60-1: 8.5, e) | | | |
| j) Information supporting the manufacturer's assumption of compliance (R60-1: 8.5, f) | | | |
| Other relevant information pertaining to identification of the instrument, diagrams, results of previous tests etc.: (attach photograph(s) and/or outline-drawing(s) here if available): | | | |
| Remarks: | | | |

| | | | | |
|--------|--------------------------|-----|--------------------------|----|
| Passed | <input type="checkbox"/> | Yes | <input type="checkbox"/> | No |
|--------|--------------------------|-----|--------------------------|----|

6. Performance tests

6.1. Results of the Performance tests

| Clause R60-1 | Performance tests | Temperature in °C | report page No. | Maximum error in v | Passed | Failed | remark |
|-----------------|---------------------------------------------------------------|-------------------|-----------------|--------------------|--------|--------|--------|
| 5.3 8.10.1 | Load cell errors (E_L) (see OIML R60-3, No. 2.1.2) | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| 5.4 8.10.1 | Repeatability errors (E_R) (see OIML R60-3, No. 2.1.3) | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| 5.5.1 8.10.2 | Creep ($C_C(t)$) (see OIML R60-3, 2.1.5) | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| 5.5.1 8.10.2 | Creep ($C_C(30-20)$) (see OIML R60-3, 2.1.5.2) | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

| Clause R60-1 | Performance tests | Temperature in °C | report page No. | Maximum error in v | Passed | Failed | remark |
|-----------------|-------------------------------------------------------------------------------------|-------------------|-----------------|--------------------|--------|--------|---------------------|
| 5.5.2 8.10.3 | Minimum dead load output return (C_{DR}) / (see OIML R60-3, 2.1.5.4) | | | | | | (See note 1) DR= |
| | | | | | | | (See note 1) DR= |
| | | | | | | | (See note 1) DR= |
| | | | | | | | (See note 1) DR= |
| 5.6.3 810.5 | Humidity effects (CH_{min}) / (CH or no mark) (see OIML R60-3, 2.1.7.1) | | | | | | |
| 5.6.3 8.10.5 | Humidity effects (CH_{max}) / (CH or no mark) (see OIML R60-3, 2.1.7.2) | | | | | | |
| 5.6.3.2 | Humidity effects (SH) / (see OIML R60-3, 2.1.8) | | | | | | |
| 5.6.1.3 | Temperature effects on minimum dead load output (C_M) / (see OIML R60-3, 2.1.4) | | | (See note 2) | | | |
| 5.6.2 | Barometric pressure effects ($C_{p(v_{min})}$) / (see OIML R60-3, 2.1.6) | | | (See note 2) | | | |

- 1) DR is the minimum dead load output return in units of (g, kg, t) and determined according to OIML R60-3, No. 2.1.5.8
- 2) Maximum error in unit v_{min}

Remarks:

6.1.1. Results of the Performance tests for load cells equipped with electronics

| Clause R60-1 | Performance tests | Temperature in °C | report page No. | Maximum error in v | Passed | Failed | remark |
|----------------------|---------------------------------------------------------------------------|-------------------|-----------------|--------------------|--------|--------|--------|
| 5.7.2.1 8.10.7.3 | Warm-up time / (see OIML R60-3, 2.2.1) | | | | | | |
| 5.7.2.2 8.10.7.4 | Power voltage variations / (see OIML R60-3, 2.2.2) | | | | | | |
| 5.7.2.5 8.10.7.5 | Short time power reductions / (see OIML R60-3, 2.2.3) | | | | | | |
| 5.7.2.5 8.10.7.6 | Bursts (electrical fast transients) (see OIML R60-3, 2.2.4) | | | | | | |
| 5.7.2.5 8.10.7.7 | Surge / (see OIML R60-3, 2.2.5) | | | | | | |
| 5.7.2.5 8.10.7.8 | Electrostatic discharge / (see OIML R60-3, 2.2.6) | | | | | | |
| 5.7.2.5 8.10.7.9 | Electromagnetic susceptibility / (see OIML R60-3, 2.2.7) | | | | | | |
| 5.7.2.5 8.10.7.10 | Immunity to conducted electromagnetic fields / (see OIML R60-3, 2.2.8) | | | | | | |
| 5.7.2.6 8.10.7.11 | Span stability / (see OIML R60-3, 2.2.9) | | | | | | |

Remarks:

6.2. Initial tests and general notes concerning performance tests*(To be completed or under the responsibility of the Evaluating Authority)***6.2.1.Units***Unit (e.g. counts, digits, g, kg, t) in which the measurement result is displayed.*

| R60-1 reference | Test procedure | Unit |
|-----------------|-------------------------------------------------------------------------------------------|------|
| 8.10.1 | Measurement error, repeatability error and temperature effect on minimum dead load output | |
| 8.10.2 | Determination of creep error | |
| 8.10.3 | Minimum dead load output return (DR) | |
| 8.10.4 | Barometric pressure effects (Atmospheric pressure) | |
| 8.10.5 | Humidity effects for load cells marked with CH or no marked | |
| 8.10.6 | Humidity effects for load cells marked SH | |
| 8.10.7 | Additional tests for load cells equipped with electronics | |

6.2.2.Measurement range (OIML R60, 5.2, 5.5.2)

| Test procedure (R60 reference) | D_{\max} | D_{\min} | Conversion factor f [indication / v] (see OIML R60-3, 2.1.2.4) | Fulfills requirements | |
|--------------------------------|------------|------------|-------------------------------------------------------------------|-----------------------|----|
| | | | | yes | no |
| 8.10.1 | | | | | |
| 8.10.2 | | | | | |
| 8.10.3 | | | | | |
| 8.10.4 | | | | | |
| 8.10.5 | | | | | |
| 8.10.6 | | | | | |
| 8.10.7 | | | | | |

| | | |
|--------|------------------------------|-----------------------------|
| Passed | <input type="checkbox"/> Yes | <input type="checkbox"/> No |
|--------|------------------------------|-----------------------------|

6.2.3. Conditions

(see OIML R60-1, 8.8.1)

(To ensure that these requirements are met, the calculations should be carried out using lower n values than the n_{max} specified. The calculations made do not include the application of 8.8.1.)

Check that

$$V_{\min} \leq \frac{D_{\max} - D_{\min}}{n}$$

It should be sufficient to carry out the calculations with $n = n_{\max}$, $n_{\max} - 500$ and $n = n_{\max} - 1\ 000$ if applicable.

| Test procedure (R60 Reference) | D _{min} | D _{max} | n _{max} | Is the requirement $v_{\min} \leq \frac{D_{\max} - D_{\min}}{n}$ fulfilled with | | | | | |
|--------------------------------|------------------|------------------|------------------|---------------------------------------------------------------------------------|----|-----------------------|----|------------------------|----|
| | | | | n _{max} | | n _{max} -500 | | n _{max} -1000 | |
| | | | | Yes | No | Yes | No | Yes | No |
| 8.10.1 | | | | | | | | | |
| 8.10.2 | | | | | | | | | |
| 8.10.3 | | | | | | | | | |
| 8.10.4 | | | | | | | | | |
| 8.10.5 | | | | | | | | | |
| 8.10.6 | | | | | | | | | |
| 8.10.7 | | | | | | | | | |

Passed Yes No

6.2.4. Input impedance

Measure the input impedance and compare the result with the input impedance in OIML R60-3, 4.5

| Input impedance | | Fulfills the requirements | |
|-----------------------------------------------------------|----------------|---------------------------|----|
| Manufacturer specification According to OIML R60-3, 4.1.1 | Measured value | yes | no |
| | | | |

Report number _____

Report page ___ of ___

Report date: _____

6.4. Load test data (Load cell error E_L) 5 runs

R60-1 Ref.: 8.10.1.1 to 8.10.1.11. Complete one sheet for each test temperature, one for each humidity (SH) test in 8.10.6, and when applicable, one for each electronics power voltage in 8.10.7.4.

Application no.: _____

Load cell model: _____

Serial no.: _____

E_{max} : _____

n_{max} : _____

PLC: _____ DR: _____

Evaluator: _____

Force-generating system: _____

Indicating instrument: _____

| | At start | At end |
|------------------------|----------|--------|
| Date: | | |
| Temperature: | | |
| Relative humidity: | | |
| Barometric Pressure: | | |
| Indicator temperature: | | |

°C

%

kPa

°C

Electronics power voltage (when applicable): _____ V

Table 6.4 (5 runs)

| Test load (units) | Run no.1 | | Run no.2 | | Run no.3 | | Run no.4 | | Run no.5 | | Average indication (counts) | Repeatability error (counts) |
|-------------------|---------------------|---------------|---------------------|---------------|---------------------|---------------|---------------------|---------------|---------------------|---------------|-----------------------------|------------------------------|
| | Indication (counts) | Time hh:mm:ss | Indication (counts) | Time hh:mm:ss | Indication (counts) | Time hh:mm:ss | Indication (counts) | Time hh:mm:ss | Indication (counts) | Time hh:mm:ss | | |
| 0 | | | | | | | | | | | | |
| 0 | | | | | | | | | | | | |
| 0 | | | | | | | | | | | | |
| 0 | | | | | | | | | | | | |
| 0 | | | | | | | | | | | | |
| 0 | | | | | | | | | | | * | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |

Notes: 1) * = Average initial minimum test load indication.
 2) Absolute (not relative) time shall be recorded.

6.7. Temperature effects on minimum dead load output return (MDLO)

R60-1 Ref.: 5.5.2; 8.10.1.16;

R60-3: 2.1.4.

Application no.: _____ Force-generating system: _____
 Load cell model: _____ Indicating instrument: _____
 Serial no.: _____ Evaluator: _____
 Emax: _____
 nmax: _____
 vmin: _____ Conversion factor, f: _____
 PLC: _____ DR: _____

Table 6.7.

| Temperature °C | Indication () | Change (C _M) (v) | Change (v _{min} / °C) | mpc (v _{min} / °C) |
|-------------------|-------------------|---------------------------------|-------------------------------------------|-------------------------------------------|
| | | | | |
| | | | | PLC |
| | | | | PLC |
| | | | | PLC |

PASS: FAIL:

- Notes:*
- 1 MDLO: minimum dead load output.
 - 2 Indication: the average initial minimum test load indication obtained from Table D.1.
 - 3 The maximum permissible change (mpc) allowed is: (v_{min} / 5 °C) for classes B, C, and D; (v_{min} / 2 °C) for class A.
 - 4 Change, C_M (v): the difference between the observed indications, and the indications at the prior temperature, divided by the conversion factor, f.

| | | | | | | |
|---------------------|----------------------|-----------------------------------------------|--------------------------|--------------------------|--------------------------|--------------------------|
| DR (v): | <input type="text"/> | 30 minute creep: PASS: | <input type="checkbox"/> | FAIL: | <input type="checkbox"/> | |
| actual time (s): | <input type="text"/> | 20 – 30 minute creep difference (< 0.15*mpe): | PASS: | <input type="checkbox"/> | FAIL: | <input type="checkbox"/> |
| specified time (s): | <input type="text"/> | DR < 0.5 v: | PASS: | <input type="checkbox"/> | FAIL: | <input type="checkbox"/> |
| mpe for DR (v): | <input type="text"/> | DR within manuf. Specified DR requirements: | PASS: | <input type="checkbox"/> | FAIL: | <input type="checkbox"/> |

- Notes: 1 Change (v) for creep: the observed indication minus the initial "load" indication (**) divided by the conversion factor, f.
 2 Determine the difference between the reading obtained at 20 minutes and the reading obtained at 30 minutes (see 5.5.1).
 3 Change (v) for DR: the initial indication (***) minus the initial "no load" indication (*) divided by the conversion factor, f.
 4 Absolute (not relative) time shall be recorded.

6.9. Barometric pressure effects (C_P)

R60-1 Ref: 5.6.2; 8.7.3.7; 8.10.4
 R60-3: 2.1.6.

Complete one sheet for each test temperature.

Application no.: _____
 Load cell model: _____
 Serial no.: _____
 E_{max}: _____ E_{min}: _____
 n_{max}: _____ PLC: _____
 Y: _____ Z: _____
 V_{min}: _____ DR: _____
 Force-generating system: _____
 Test load, D_{max}: _____ D_{min}: _____
 Indicating instrument: _____
 Evaluator: _____

| | At start | At end | |
|------------------------|----------|--------|-----|
| Date: | | | |
| Temperature: | | | °C |
| Relative humidity: | | | % |
| Barometric pressure: | | | hPa |
| Indicator temperature: | | | °C |

Conversion factor, f: _____

Table 6.9

| Pressure (hPa) | Indication (counts) | Time hh:mm | Change (v) | Change (v _{min} / kPa) | mpc (v _{min} / kPa) |
|----------------|---------------------|------------|------------|---------------------------------|------------------------------|
| | | | 0 | 0 | 0 |
| | | | | | 1 |
| | | | | | 1 |
| | | | | | 1 |
| | | | | | |
| | | | | | |
| | | | | | |

PASS: FAIL:

6.10. Humidity effects

6.10.1. Humidity effects (CH or no mark)

R60-1 Ref: 5.6.3; 8.7.3.8; 8.10.5

R60-3: 2.1.7

Form 6.10.1.(a): Humidity effects summary (CH or no mark)

Application no.: _____
 Load cell model: _____
 Serial no.: _____
 E_{max}: _____ E_{min}: _____
 n_{max}: _____ p_{LC}: _____
 Y: _____ Z: _____
 V_{min}: _____ DR: _____
 Force-generating system: _____
 Test load, D_{max}: _____ D_{min}: _____
 Indicating instrument: _____
 Evaluator: _____

| | At start | At end | |
|------------------------|----------|--------|-----|
| Date: | | | |
| Temperature: | | | °C |
| Relative humidity: | | | % |
| Barometric pressure: | | | hPa |
| Indicator temperature: | | | °C |

Conversion factor, f: _____

Report number _____

Report page ____ of ____

Report date: _____

Form 6.10.1.(b): Load test data (EL) - 3 runs

R60-1 Ref.: 8.10.1.1 to 8.10.1.11. Complete this form if the measurement error is determined **before** the humidity test (CH) is carried out (not mandatory)

Application no.: _____

Load cell model: _____

Serial no.: _____

E_{max} : _____ E_{min} : _____

n_{max} : _____ PLC : _____

Y: _____ Z: _____

v_{min} : _____ DR: _____

Force-generating system: _____

Test load, D_{max} : _____ D_{min} : _____

Indicating instrument: _____

Evaluator: _____

| | At start | At end |
|------------------------|----------|--------|
| Date: | | |
| Temperature: | | |
| Relative humidity: | | |
| Barometric pressure: | | |
| Indicator temperature: | | |

°C

%

hPa

°C

Electronics power voltage

(when applicable): _____

Report number _____

Report page ____ of ____

Report date: _____

Form 6.10.1.(c): Load test data (EL) - 3 runs

R60-1 Ref.: 8.10.1.1 to 8.10.1.11. Complete this form if the measurement error is determined **after** the humidity test (CH) is carried out (not mandatory)

Application no.: _____

Load cell model: _____

Serial no.: _____

E_{max} : _____ E_{min} : _____

n_{max} : _____ p_{LC} : _____

Y: _____ Z: _____

v_{min} : _____ DR: _____

Force-generating system: _____

Test load, D_{max} : _____ D_{min} : _____

Indicating instrument: _____

Evaluator: _____

| | At start | At end |
|------------------------|----------|--------|
| Date: | | |
| Temperature: | | |
| Relative humidity: | | |
| Barometric pressure: | | |
| Indicator temperature: | | |

°C

%

hPa

°C

Electronics power voltage

(when applicable): _____

Report number _____

Report page ____ of ____

Report date: _____

Form 6.10.1(d): Load test data (E_L) - 5 runs

R60-1 Ref.: 8.10.1.1 to 8.10.1.11. Complete this form if the measurement error is determined **before** the humidity test (CH) is carried out (not mandatory)

Application no.: _____

Load cell model: _____

Serial no.: _____

E_{max}: _____ E_{min}: _____

n_{max}: _____ p_{LC}: _____

Y: _____ Z: _____

v_{min}: _____ DR: _____

Force-generating system: _____

Test load, _ D_{max}: _____ D_{min}: _____

Indicating instrument: _____

Evaluator: _____

| | At start | At end | |
|------------------------|----------|--------|-----|
| Date: | | | |
| Temperature: | | | °C |
| Relative humidity: | | | % |
| Barometric pressure: | | | hPa |
| Indicator temperature: | | | °C |

Electronics power voltage
(when applicable): _____

Table 6.10.1.(d) 5 runs

| Test load (unit) | Run no. 1 | | Run no. 2 | | Run no. 3 | | Run no. 4 | | Run no. 5 | | Average indication counts | Repeatability error counts |
|------------------|-------------------|---------------|-------------------|---------------|-------------------|---------------|-------------------|---------------|-------------------|---------------|---------------------------|----------------------------|
| | Indication counts | Time hh:mm:ss | Indication counts | Time hh:mm:ss | Indication counts | Time hh:mm:ss | Indication counts | Time hh:mm:ss | Indication counts | Time hh:mm:ss | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| * | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |

| | | | | | | | | | | | | |
|--|--|--|--|--|--|--|--|--|--|--|--|--|
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |

Notes: *Average initial minimum test load indication

Form 6.10.1(e): Load test data (E_L) - 5 runs

R60-1 Ref.: 8.10.1.1 to 8.10.1.11. Complete this form if the measurement error is determined **after** the humidity test (CH) is carried out (not mandatory)

Application no.: _____

Load cell model: _____

Serial no.: _____

E_{max}: _____ E_{min}: _____

n_{max}: _____ PLC: _____

Y: _____ Z: _____

v_{min}: _____ DR: _____

Force-generating system: _____

Test load, D_{max}: _____ D_{min}: _____

Indicating instrument: _____

Evaluator: _____

| | At start | At end | |
|------------------------|----------|--------|-----|
| Date: | | | |
| Temperature: | | | °C |
| Relative humidity: | | | % |
| Barometric pressure: | | | hPa |
| Indicator temperature: | | | °C |

Electronics power voltage
(when applicable): _____

Table 6.10.1.(e) 5 runs

| Test load (unit) | Run no. 1 | | Run no. 2 | | Run no. 3 | | Run no. 4 | | Run no. 5 | | Average indication counts | Repeatability error counts |
|------------------|-------------------|---------------|-------------------|---------------|-------------------|---------------|-------------------|---------------|-------------------|---------------|---------------------------|----------------------------|
| | Indication counts | Time hh:mm:ss | Indication counts | Time hh:mm:ss | Indication counts | Time hh:mm:ss | Indication counts | Time hh:mm:ss | Indication counts | Time hh:mm:ss | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| * | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |

Report number _____

Report page ____ of ____

Report date: _____

| | | | | | | | | | | | | |
|--|--|--|--|--|--|--|--|--|--|--|--|--|
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |

Notes: *Average initial minimum test load indication

Notes:

1. Load/Reference indications: if at 75% load point was not obtained, a straight line interpolation between the adjacent higher and lower load point indication is used.
2. Error, E_L : the difference between the test reference and the reference indication divided by the conversion factor, f .
3. Test load values are values above minimum test load, D_{min} .
4. Conditioning period: the time period for exercising the load cell.
5. For family certification this test is not necessary, if a pattern with a smaller capacity and the same or better metrological characteristics has passed this test.

6.11. Warm-up time

Form 6.11 Warm-up time

R60-1 Ref.: 3.5.17; 8.10.7.3
 R60-3: 2.2.1

Application
 no.:

Load cell model: _____

Serial no.: _____

E_{max} : _____ E_{min} : _____

n_{max} : _____ plc : _____

Y: _____ Z: _____

Force-generating
 system:

Test load, D_{max} : _____ D_{min} : _____

Indicating instrument: _____

Evaluator: _____

| | At start | At end |
|----------------------|----------|--------|
| Date: | | |
| Time: | | |
| Temperature: | | |
| Relative humidity: | | |
| Barometric pressure: | | |

°C
 %
 hPa

Conversion factor, f : _____ counts/v
 Duration of disconnection before test: _____

Table 6.11

| Test load (units) | Preloads | |
|----------------------|------------------------|------------------|
| | Indication (counts) | Time hh:mm:ss |
| D _{min} | | |
| D _{max} | | |
| D _{min} | | |
| D _{max} | | |
| D _{min} | | |
| D _{max} | | |

| | | Initial run | | After 5 min. | | After 15 min. | | After 30 min. | | mpc v |
|--------|------------------|------------------------|------------------|------------------------|------------------|------------------------|------------------|------------------------|------------------|----------|
| | | Indication (counts) | Time hh:mm:ss | Indication (counts) | Time hh:mm:ss | Indication (counts) | Time hh:mm:ss | Indication (counts) | Time hh:mm:ss | |
| | D _{min} | | | | | | | | | |
| | D _{max} | | | | | | | | | |
| Span | Counts | | | | | | | | | |
| Span | v | | | | | | | | | |
| Change | v | | | | | | | | | |

PASS:

FAIL:

Notes:

1. Absolute (not relative) time shall be recorded.
2. Span: the result of subtraction of the indication at minimum test load from the indication at maximum test load. All span errors (error at maximum test load minus the error at minimum test load) shall be within the maximum permissible error during the 30 minute test.
3. Change: the difference between the span and the initial run span.
4. Maximum permissible change, mpc: the absolute value of the maximum permissible error for the maximum test load applied.
5. Exercises have to be run before disconnection.

6.12. Power Voltage Variation

Form 6.12 Power Voltage Variation

R60-1 Ref.: 5.7.2.2; 5.7.2.3; 5.7.2.4; 8.10.7.4.

R60-3: 2.2.2

Report number _____

Report page ___ of ___

Report date: _____

Application no.: _____

Load cell model: _____

Serial no.: _____

E_{max}: _____ E_{min}: _____

n_{max}: _____ PLC: _____

Y: _____ Z: _____

Force-generating system: _____

Test load, D_{max}: _____ D_{min}: _____

Indicating instrument: _____

Evaluator: _____

| | At start | At end | |
|----------------------|----------|--------|-----|
| Date: | | | |
| Time: | | | |
| Temperature: | | | °C |
| Relative humidity: | | | % |
| Barometric pressure: | | | hPa |

Conversion factor, f: _____ counts/v

Main voltage: _____

AC: DC:

Table 6.12

| Test load (units) | Preloads | |
|-------------------|---------------------|---------------|
| | Indication (counts) | Time hh:mm:ss |
| D _{min} | | |
| D _{max} | | |
| D _{min} | | |
| D _{max} | | |
| D _{min} | | |
| D _{max} | | |

- Notes: 1) Reference indications: if at 75% load point was not obtained, a straight line interpolation between the adjacent higher and lower indication is used. (see 9.8.2 and calculation procedures in OIML R60-3, 2.1.2)
- 2) Error: the difference between the test indication and the reference indication divided by the conversion factor, f.
- 3) When a voltage range is marked, use the average value as the reference value and determine upper and lower values of applied voltage according to A.4.7.3.
- 4) Upper limit not applicable to battery powered load cells
- 5) At lower limit, battery powered load cells shall function and be within mpe, or cease to function

| | | Initial run with main voltage | | lower limit main voltage - 15% | | upper limit main voltage + 15% | | mpc v |
|--------|------------------|-------------------------------|---------------|--------------------------------|---------------|--------------------------------|---------------|-------|
| | | Indication (counts) | Time hh:mm:ss | Indication (counts) | Time hh:mm:ss | Indication (counts) | Time hh:mm:ss | |
| | D _{min} | | | | | | | |
| | D _{max} | | | | | | | |
| Span | Counts | | | | | | | |
| Span | v | | | | | | | |
| Change | v | | | | | | | |

PASS: FAIL:

If AC power supply is used (not applicable for battery power supply)

| | | Initial run with main voltage | | lower limit frequency - 2% | | upper limit frequency + 2% | | mpc v |
|------------------|--------|----------------------------------|------------------|-------------------------------|------------------|-------------------------------|------------------|----------|
| | | Indication (counts) | Time hh:mm:ss | Indication (counts) | Time hh:mm:ss | Indication (counts) | Time hh:mm:ss | |
| D _{min} | Counts | | | | | | | |
| | v | | | | | | | |
| D _{max} | Counts | | | | | | | |
| | v | | | | | | | |
| Span | v | | | | | | | |
| Change | v | | | | | | | |

PASS: FAIL:

6.13. Short time power reductions

Form 6.13 Short time power reductions

R60-1 Ref: 5.7.2.5, 8.10.7.5.

R60-3: 2.2.3

| | |
|--------------------------------|---------------------------------------------|
| Application no.: _____ | Date: _____ |
| Load cell model: _____ | Time: _____ |
| Serial no.: _____ | Temperature: _____ °C |
| E _{max} : _____ | Relative humidity: _____ % |
| n _{max} : _____ | Barometric pressure: _____ kPa |
| V _{min} : _____ | Conversion factor, f: _____ |
| PLC: _____ DR: _____ | Minimum test load, D _{min} : _____ |
| Force-generating system: _____ | Reference voltage range: _____ V |
| Indicating instrument: _____ | |
| Evaluator: _____ | |

Table 6.14

| Test load (g, kg, or t) | Disturbance | | | | Result | | | |
|----------------------------|------------------|----------------------|---------------------------|----------------------------|-------------------|-------------------|--------------------------------------|---------------|
| | Amplitude (%) | Duration (cycles) | Number of disturbances | Repetition interval (v) | Indication () | Difference (v) | Significant fault > v _{min} | |
| | | | | | | | No | Yes (remarks) |
| Without disturbance | | | | | | | | |
| | 0 | 0.5 | 10 | | | | | |
| | 50 | 1 | 10 | | | | | |

Equipment used (supply sketch if necessary):

PASS: FAIL:

Remarks:

Note: In the case of a voltage range, use the average value as the reference value.

6.14. Burst (electrical fast transients)

Form 6.14.1 Burst (electrical fast transients) – power supply lines

R60-1 Ref: 8.10.7.6, 5.7.2.5

R60-3: 2.2.4

Application no.: _____
 Load cell model: _____
 Serial no.: _____
 E_{max}: _____
 n_{max}: _____
 V_{min}: _____
 PLC: _____ DR: _____

Date: _____
 Time: _____
 Temperature: _____ °C
 Relative humidity: _____ %
 Barometric pressure: _____ kPa

Force-generating system: _____
 Indicating instrument: _____
 Evaluator: _____

Conversion factor, f: _____
 Minimum test load, D_{min}: _____

Table 6.14.1

Power supply lines: test voltage = 1 kV; duration of test = 1 minute at each polarity

| Test load (g, kg, or t) | Connection | | | Polarity | Indication () | Differenc e (v) | Result | |
|----------------------------|---------------------|-------------------|--------------------|----------|-------------------|-----------------------|--------------------------------------|---------------|
| | L to ground | N to ground | PE to ground | | | | Significant fault > v _{min} | |
| | | | | | | | No | Yes (remarks) |
| | without disturbance | | | | | | | |
| | X | | | pos | | | | |
| | | | | neg | | | | |
| | without disturbance | | | | | | | |
| | | X | | pos | | | | |
| | | | | neg | | | | |
| | without disturbance | | | | | | | |
| | | | X | pos | | | | |
| | | | | neg | | | | |

L = phase, N = neutral, PE = protective earth

PASS:

FAIL:

Equipment used (supply sketch if necessary)

Form 6.14.2 Burst (electrical fast transients) – I/O circuits and communications lines

R60-1 Ref: 8.10.7.6, 5.7.2.5

R60-3: 2.2.4

Application no.: _____
 Load cell model: _____
 Serial no.: _____
 E_{max}: _____
 n_{max}: _____
 v_{min}: _____
 PLC: _____ DR: _____

Date: _____
 Time: _____
 Temperature: _____ °C
 Relative humidity: _____ %
 Barometric pressure: _____ kPa
 Conversion factor, f: _____

Force-generating system: _____

Minimum test load, D_{min}: _____

Indicating instrument: _____

Evaluator: _____

Table 6.14.2

| Test load (g, kg, or t) | Cable interface | Polarity | Result | | | |
|----------------------------|---------------------|----------|-------------------|-----------------------|--------------------------------------|---------------|
| | | | Indication () | Differenc e (v) | Significant fault > v _{min} | |
| | | | | | No | Yes (remarks) |
| | without disturbance | | | | | |
| | | pos | | | | |
| | | neg | | | | |
| | without disturbance | | | | | |
| | | pos | | | | |
| | | neg | | | | |
| | without disturbance | | | | | |
| | | pos | | | | |
| | | neg | | | | |
| | without disturbance | | | | | |
| | | pos | | | | |
| | | neg | | | | |
| | without disturbance | | | | | |
| | | pos | | | | |
| | | neg | | | | |
| | without disturbance | | | | | |
| | | pos | | | | |
| | | neg | | | | |

Equipment used (supply sketch if necessary)

PASS:

FAIL:

Remarks:

Note: Explain or make a sketch indicating where the clamp is located on the cable: if necessary use additional page(s).

6.15. Surge

Form 6.15 Surge

R60-1 Ref: 8.10.7.7, 5.7.2.5

R60-3: 2.2.5

Application no.: _____

Load cell model: _____

Serial no.: _____

E_{max} : _____

n_{max} : _____

v_{min} : _____

PLC: _____ DR: _____

Force-generating system: _____

Indicating instrument: _____

Evaluator: _____

Date:

| |
|--|
| |
|--|

Time:

| |
|--|
| |
|--|

Temperature:

| |
|--|
| |
|--|

 °C

Relative humidity:

| |
|--|
| |
|--|

 %

Barometric pressure:

| |
|--|
| |
|--|

 kPa

Conversion factor, f: _____

Minimum test load, D_{min} : _____

Table 6.15

| | | | | | | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------|--------------------------|-------------------------------|--------------------------|---------------------------------------------|--------------------------|--------------------------|
| OIML R 60-2, [unit] <input type="checkbox"/> [g]; <input type="checkbox"/> [kg]; <input type="checkbox"/> [t] | Test conditions Surges on signal, data and control lines | | | | Observer's name: | | |
| | Output gained | <input type="checkbox"/> | using actual loads | | Line to line 1 kV | | |
| | | <input type="checkbox"/> | Test load: simulating loading | | Line to earth 2 kV | | |
| | Cable: | | | | <input type="checkbox"/> Symmetrical line | | |
| | Date: | | Start | Stop | <input type="checkbox"/> Unsymmetrical line | | |
| | Time: | | | | Specimen: | | |
| | Ambient temperature | | °C | °C | <i>f</i> | | |
| | Relative humidity | | % | % | D_{min} | [unit] | |
| | Barometric Pressure | | kPa | kPa | D_{max} | [unit] | |
| | | Cycle phase | Initial | During exposure | After | | |
| | Load | | | | | | |
| Time | Start | | | | | | |
| | Stop | | | | | | |
| Quantity [unit] | reference | | | | | | |
| | indicated | | | | | | |
| Error [unit] | | | | | | | |
| relative error [%] | E_i | | | | | | |
| MPE [%] | | | | | | | |
| | Pass | <input type="checkbox"/> | | <input type="checkbox"/> | | | |
| | Fail | <input type="checkbox"/> | | <input type="checkbox"/> | | | |
| Observed faults after exposure | | | | | | | |
| Fault limit [%] | | | | | | | |
| Line to line (N/A for balanced) | | Fault/Deviation | | Significant | | Acts on fault | |
| ↑■ | ↓■ | | | Yes | No | Yes | No |
| 3x | | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | 3x | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Line to earth | | | | | | | |
| 3x | | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | 3x | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Observations | | | | | | | |
| Result | | | | Pass | <input type="checkbox"/> | Fail | <input type="checkbox"/> |

6.16. Electrostatic discharge

Form 6.16.1 Electrostatic discharge – direct application

R60-1 Ref: 8.10.7.8, 5.7.2.5

R60-3: 2.2.6

Application no.: _____
 Load cell model: _____
 Serial no.: _____
 E_{max}: _____
 n_{max}: _____
 v_{min}: _____
 PLC: _____ DR: _____

Date:

 Time:

 Temperature: _____ °C
 Relative humidity: _____ %
 Barometric pressure:

 kPa

Force-generating system: _____
 Indicating instrument: _____
 Evaluator: _____

Conversion factor, f: _____
 Minimum test load, D_{min}: _____

- Contact discharges
- Paint penetration
- Air discharges

- Polarity (*see Note 2*):
- Positive
 - Negative

Table 6.16.1

| Test load (g, kg, or t) | | | | Result | | | |
|----------------------------|----------------------|---------------------------|----------------------------|-------------------|-------------------|--------------------------------------|---------------|
| | Test voltage (kV) | No. of discharges ≥ 10 | Repetition interval (s) | Indication () | Difference (v) | Significant fault > v _{min} | |
| | | | | | | No | Yes (remarks) |
| | without disturbance | | | | | | |
| | 2 | | | | | | |
| | 4 | | | | | | |
| | 8 (air discharges) | | | | | | |

PASS: FAIL:

Remarks:

- Notes:
- 1 If the load cell fails, the test point at which this occurs shall be recorded.
 - 2 IEC Publication 61000-4-2 (1999-05) Ed 1.1 Consolidated edition specifies that the test be conducted with the most sensitive polarity.

Form 6.16.2 Electrostatic discharge – indirect application

R60-1 Ref: 8.10.7.8, 5.7.2.5

R60-3: 2.2.6

Application no.: _____
 Load cell model: _____
 Serial no.: _____
 E_{max}: _____
 n_{max}: _____
 V_{min}: _____
 PLC: _____ DR: _____

Date: _____
 Time: _____
 Temperature: _____ °C
 Relative humidity: _____ %
 Barometric pressure: _____ kPa

Conversion factor, f: _____

Force-generating system: _____

Minimum test load, D_{min}: _____

Indicating instrument: _____

Evaluator: _____

Polarity (*see Note 2*): Positive Negative

Table 6.16.2.1 – Horizontal coupling plane

| Test load (g, kg, or t) | Test voltage (kV) | No. of discharges ≥ 10 | Repetition interval (s) | Indication () | Difference (v) | Result | |
|----------------------------|----------------------|---------------------------|----------------------------|-------------------|-------------------|--------------------------------------|---------------|
| | | | | | | Significant fault > v _{min} | |
| | | | | | | No | Yes (remarks) |
| | without disturbance | | | | | | |
| | 2 | | | | | | |
| | 4 | | | | | | |
| | 6 | | | | | | |

Table 6.16.2.2 – Vertical coupling plane

| Test load (g, kg, or t) | Test voltage (kV) | No. of discharges ≥ 10 | Repetition interval (s) | Indication () | Difference (v) | Result | |
|----------------------------|----------------------|---------------------------|----------------------------|-------------------|-------------------|--------------------------------------|---------------|
| | | | | | | Significant fault > v _{min} | |
| | | | | | | No | Yes (remarks) |
| | without disturbance | | | | | | |
| | 2 | | | | | | |
| | 4 | | | | | | |
| | 6 | | | | | | |

PASS: FAIL:

Remarks:

- Notes: 1 If the load cell fails, the test point at which this occurs shall be recorded.
 2 IEC Publication 61000-4-2 (1999-05) Ed 1.1 Consolidated edition specifies that the test be conducted with the most sensitive polarity.

Form 6.16.3 Electronic discharge (continued) – specification of test points

R60-1 Ref.: 8.10.7.8, 5.7.2.5

R60-3: 2.2.6

Specify test points utilized on load cell and test equipment used, e.g., by photos or sketches.

a) Direct application

Contact discharges:

Air discharges:

b) Indirect application

6.17. Electromagnetic susceptibility

Form 6.17.1 Electromagnetic susceptibility

R60-1 Ref.: 8.10.7.9, 5.7.2.5

R60-3: 2.2.7

Application no.: _____
 Load cell model: _____
 Serial no.: _____
 E_{max}: _____
 n_{max}: _____
 V_{min}: _____
 p_{LC}: _____ DR: _____

| | | |
|----------------------|--|-----|
| Date: | | |
| Time: | | |
| Temperature: | | °C |
| Relative humidity: | | % |
| Barometric pressure: | | kPa |

Force-generating system: _____
 Indicating instrument: _____
 Evaluator: _____

Conversion factor, f: _____

Minimum test load, D_{min}: _____

Rate of sweep:

Test load:

Test load material:

Table 6.17

| Disturbance | | | | Result | | | |
|---------------------|-----------------------|--------------|------------------|----------------|----------------|--------------------------------------|---------------|
| Antenna | Frequency range (MHz) | Polarization | Facing load cell | Indication () | Difference (v) | Significant fault > v _{min} | |
| | | | | | | No | Yes (remarks) |
| without disturbance | | | | | | | |
| | | Vertical | Front | | | | |
| | | | Right | | | | |
| | | | Left | | | | |
| | | | Rear | | | | |
| | | Horizontal | Front | | | | |
| | | | Right | | | | |
| | | | Left | | | | |
| | | | Rear | | | | |

PASS: FAIL:

Frequency range: 26 – 1 000 MHz
 Field strength: 3 V/m
 Modulation: 80% AM, 1 kHz sine wave

Remarks:

Note: If the load cell fails, the test point at which this occurs shall be recorded.

Form 6.17.2 Electromagnetic susceptibility (continued) – description of the test set-up

Describe the set-up of the test and equipment, e.g., by photos or sketches:

6.18. Immunity to conducted electromagnetic fields

R60-1 Ref.: 8.10.7.10, 5.7.2.5

R60-3: 2.2.8

Form 6.18 Immunity to conducted electromagnetic fields

| | |
|-------------------------------------|-----------------------------------------------|
| Application no.: _____ | Date: <input type="text"/> |
| Load cell model: _____ | Time: <input type="text"/> |
| Serial no.: _____ | Temperature: <input type="text"/> °C |
| E_{max} : _____ | Relative humidity: <input type="text"/> % |
| n_{max} : _____ | Barometric pressure: <input type="text"/> kPa |
| v_{min} : _____ | Conversion factor, f: _____ |
| PLC: _____ DR: _____ | Minimum test load, D_{min} : _____ |
| Force-generating system: _____ | |
| Indicating instrument: _____ | |
| Evaluator: _____ | |
| Rate of sweep: <input type="text"/> | |
| Test load: <input type="text"/> | Test load material: <input type="text"/> |

Table 6.18

| | | | | | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|
| OIML R 60-2, [unit] <input type="checkbox"/> [g]; <input type="checkbox"/> [kg]; <input type="checkbox"/> [t] | Test conditions RF current injection | | | | Observer's name: | |
| | Output gained | <input type="checkbox"/> | using actual loads | | $f_i =$ MHz | |
| | | <input type="checkbox"/> | Test load: | | $f_h =$ MHz | |
| | Cable exposed | <input type="checkbox"/> | simulating loading | | RF voltage V_{emf} | |
| | | <input type="checkbox"/> | using: | | Modulation % AM | |
| | Date: | | Start | Stop | Dwell time s | |
| | Time: | | | | Specimen: | |
| | Ambient temperature | | °C | °C | f | |
| | Relative humidity | | % | % | D_{min} [unit] | |
| | Barometric Pressure | | kPa | kPa | D_{max} [unit] | |
| Frequency cycle | Cycle phase | Initial | During exposure | After | | |
| Time | Load | | | | | |
| Quantity [unit] | Start | | | | | |
| | Stop | | | | | |
| Error [unit] | reference | | | | | |
| | indicated | | | | | |
| relative error [%] E_{ii} | | | | | | |
| MPE [%] | | | | | | |
| | Pass | <input type="checkbox"/> | | <input type="checkbox"/> | | |
| | Fail | <input type="checkbox"/> | | <input type="checkbox"/> | | |
| Observed faults during exposure | | | | | | |
| Fault limit [%] | | | | | | |
| Frequency | | Fault/Deviation | Significant | | Acts on fault | |
| MHz | | | Yes | No | Yes | No |
| | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Observations | | | | | | |
| Result | | | Pass | <input type="checkbox"/> | Fail | <input type="checkbox"/> |

6.19. Span Stability

Form 6.19.1 (3 runs) Span stability – measurement data for classes C and D

R60-1 Ref.: 8.10.7.11, 5.7.2.6

R60-3: 2.2.9

Application no.: _____
 Load cell model: _____
 Serial no.: _____
 Emax: _____
 Nmax: _____
 Vmin: _____

Force-generating system: _____
 Indicating instrument: _____
 pLC: _____ DR: _____
 Conversion factor, f: _____
 Minimum test load, Dmin: _____
 Maximum test load, Dmax: _____

Notes: 1 Span is the result of subtracting the average indication at minimum test load from the average indication at maximum test load.

2 Absolute (not relative) time shall be recorded.

Table 6.19.1. (3 runs)

Measurement no. 1:

| Test load (g, kg, or t) | Run no. 1 | | Run no. 2 | | Run no. 3 | | Average indication () |
|----------------------------|-------------------|------|-------------------|------|-------------------|------|------------------------------|
| | Indication () | Time | Indication () | Time | Indication () | Time | |
| | | | | | | | |
| | | | | | | | |
| span | | | | | | | |

Evaluator: _____ Remarks: _____

| | |
|----------------------|-----|
| Date: | |
| Time: | |
| Temperature: | °C |
| Relative humidity: | % |
| Barometric pressure: | kPa |

Measurement no. 2:

| Test load (g, kg, or t) | Run no. 1 | | Run no. 2 | | Run no. 3 | | Average indication () |
|----------------------------|-------------------|------|-------------------|------|-------------------|------|------------------------------|
| | Indication () | Time | Indication () | Time | Indication () | Time | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | span | |

Evaluator: _____

Remarks:

| | |
|----------------------|-----|
| Date: | |
| Time: | |
| Temperature: | °C |
| Relative humidity: | % |
| Barometric pressure: | kPa |

Measurement no. 3:

| Test load (g, kg, or t) | Run no. 1 | | Run no. 2 | | Run no. 3 | | Average indication () |
|----------------------------|-------------------|------|-------------------|------|-------------------|------|------------------------------|
| | Indication () | Time | Indication () | Time | Indication () | Time | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | span | |

Evaluator: _____

Remarks:

| | |
|----------------------|-----|
| Date: | |
| Time: | |
| Temperature: | °C |
| Relative humidity: | % |
| Barometric pressure: | kPa |

Measurement no. 4:

| Test load (g, kg, or t) | Run no. 1 | | Run no. 2 | | Run no. 3 | | Average indication () |
|----------------------------|-------------------|------|-------------------|------|-------------------|------|------------------------------|
| | Indication () | Time | Indication () | Time | Indication () | Time | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | span | |

Evaluator: _____

Remarks:

| | | |
|----------------------|--|-----|
| Date: | | |
| Time: | | |
| Temperature: | | °C |
| Relative humidity: | | % |
| Barometric pressure: | | kPa |

Measurement no. 5:

| Test load (g, kg, or t) | Run no. 1 | | Run no. 2 | | Run no. 3 | | Average indication () |
|----------------------------|-------------------|------|-------------------|------|-------------------|------|------------------------------|
| | Indication () | Time | Indication () | Time | Indication () | Time | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | span | |

Evaluator: _____

Remarks:

| | | |
|----------------------|--|-----|
| Date: | | |
| Time: | | |
| Temperature: | | °C |
| Relative humidity: | | % |
| Barometric pressure: | | kPa |

Measurement no. 6:

| Test load (g, kg, or t) | Run no. 1 | | Run no. 2 | | Run no. 3 | | Average indication () |
|----------------------------|-------------------|------|-------------------|------|-------------------|------|------------------------------|
| | Indication () | Time | Indication () | Time | Indication () | Time | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | span | |

Evaluator: _____

Remarks:

Measurement no. 7:

| Test load (g, kg, or t) | Run no. 1 | | Run no. 2 | | Run no. 3 | | Average indication () |
|----------------------------|-------------------|------|-------------------|------|-------------------|------|------------------------------|
| | Indication () | Time | Indication () | Time | Indication () | Time | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | span | |

Evaluator: _____

Remarks:

Date:

Time:

Temperature: °C

Relative humidity: %

Barometric pressure: kPa

Date:

Time:

Temperature: °C

Relative humidity: %

Barometric pressure: kPa

Measurement no. 8:

| Test load (g, kg, or t) | Run no. 1 | | Run no. 2 | | Run no. 3 | | Average indication () |
|----------------------------|-------------------|------|-------------------|------|-------------------|------|------------------------------|
| | Indication () | Time | Indication () | Time | Indication () | Time | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | span | |

Evaluator: _____

Remarks:

| | |
|----------------------|-----|
| Date: | |
| Time: | |
| Temperature: | °C |
| Relative humidity: | % |
| Barometric pressure: | kPa |

Form 6.19.2 (5 runs) Span stability measurement data for class B

R60-1 Ref.: 8.10.7.11, 5.7.2.6

R60-3: 2.2.9

Application no.: _____

Load cell model: _____

Serial no.: _____

E_{max}: _____

N_{max}: _____

V_{min}: _____

Force-generating system: _____

Indicating instrument: _____

pLC: _____ DR: _____

Conversion factor, f: _____

Minimum test load, D_{min}: _____

Maximum test load, D_{max}: _____

- Notes:*
- 1 Span is the result of subtracting the average indication at minimum test load from the average indication at maximum test load.
 - 2 Absolute (not relative) time shall be recorded.

Table 6.19.2 (5 runs)

Measurement no. 1:

| Test load (g, kg, or t) | Run no. 1 | | Run no. 2 | | Run no. 3 | | Run no. 4 | | Run no. 5 | | Average indication () |
|----------------------------|-------------------|------|-------------------|------|-------------------|------|-------------------|------|-------------------|------|------------------------------|
| | indication () | Time | indication () | Time | indication () | Time | indication () | Time | indication () | Time | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | Span | |

Evaluator: _____

Remarks:

Date:

Time:

Temperature: °C

Relative humidity: %

Barometric pressure: kPa

Measurement no. 2:

| Test load (g, kg, or t) | Run no. 1 | | Run no. 2 | | Run no. 3 | | Run no. 4 | | Run no. 5 | | Average indication () |
|----------------------------|-------------------|------|-------------------|------|-------------------|------|-------------------|------|-------------------|------|------------------------------|
| | indication () | Time | indication () | Time | indication () | Time | indication () | Time | indication () | Time | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | Span | |

Evaluator: _____

Remarks:

Date:

Time:

Temperature: °C

Relative humidity: %

Barometric pressure: kPa

Measurement no. 3:

| Test load (g, kg, or t) | Run no. 1 | | Run no. 2 | | Run no. 3 | | Run no. 4 | | Run no. 5 | | Average indication () |
|----------------------------|-------------------|------|-------------------|------|-------------------|------|-------------------|------|-------------------|------|------------------------------|
| | indication () | Time | indication () | Time | indication () | Time | indication () | Time | indication () | Time | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | Span | |

Date:

Time:

Temperature: °C

Relative humidity: %

Barometric pressure: kPa

Evaluator: _____

Remarks:

Measurement no. 4:

| Test load (g, kg, or t) | Run no. 1 | | Run no. 2 | | Run no. 3 | | Run no. 4 | | Run no. 5 | | Average indication () |
|----------------------------|-------------------|------|-------------------|------|-------------------|------|-------------------|------|-------------------|------|------------------------------|
| | indication () | Time | indication () | Time | indication () | Time | indication () | Time | indication () | Time | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | Span | |

Date:

Time:

Temperature: °C

Relative humidity: %

Barometric pressure: kPa

Evaluator: _____

Remarks:

Measurement no. 5:

| Test load (g, kg, or t) | Run no. 1 | | Run no. 2 | | Run no. 3 | | Run no. 4 | | Run no. 5 | | Average indication () |
|----------------------------|-------------------|------|-------------------|------|-------------------|------|-------------------|------|-------------------|------|------------------------------|
| | indication () | Time | indication () | Time | indication () | Time | indication () | Time | indication () | Time | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | Span | |

Date:

Time:

Temperature: °C

Relative humidity: %

Barometric pressure: kPa

Evaluator: _____

Remarks:

Measurement no. 6:

| Test load (g, kg, or t) | Run no. 1 | | Run no. 2 | | Run no. 3 | | Run no. 4 | | Run no. 5 | | Average indication () |
|----------------------------|-------------------|------|-------------------|------|-------------------|------|-------------------|------|-------------------|------|------------------------------|
| | indication () | Time | indication () | Time | indication () | Time | indication () | Time | indication () | Time | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | Span | |

Date:

Time:

Temperature: °C

Relative humidity: %

Barometric pressure: kPa

Evaluator: _____

Remarks:

Measurement no. 7:

| Test load (g, kg, or t) | Run no. 1 | | Run no. 2 | | Run no. 3 | | Run no. 4 | | Run no. 5 | | Average indication () |
|----------------------------|-------------------|------|-------------------|------|-------------------|------|-------------------|------|-------------------|------|------------------------------|
| | indication () | Time | indication () | Time | indication () | Time | indication () | Time | indication () | Time | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | Span | |

Date:

Time:

Temperature: °C

Relative humidity: %

Barometric pressure: kPa

Evaluator: _____

Remarks:

Measurement no. 8:

| Test load (g, kg, or t) | Run no. 1 | | Run no. 2 | | Run no. 3 | | Run no. 4 | | Run no. 5 | | Average indication () |
|----------------------------|-------------------|------|-------------------|------|-------------------|------|-------------------|------|-------------------|------|------------------------------|
| | indication () | Time | indication () | Time | indication () | Time | indication () | Time | indication () | Time | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | Span | |

Date:

Time:

Temperature: °C

Relative humidity: %

Barometric pressure: kPa

Evaluator: _____

Remarks:

Form 6.19.3 Span stability – summary of test results

R60-1 Ref.: 8.10.7.11, 5.7.2.6

R60-3: 2.2.9

Application no.: _____

Load cell model: _____

Serial no.: _____

E_{max} : _____

n_{max} : _____

V_{min} : _____

PLC: _____ DR: _____

Force-generating system:

Indicating instrument: _____

Evaluator: _____

Table 6.19.3

| Measurement no. (see Note 3) | Span | | Variation (v) | Maximum allowable variation (v) |
|---------------------------------|------|-----|------------------|---------------------------------------|
| | () | (v) | | |
| 1 | | | | |
| 2 | | | | |
| 3 | | | | |
| 4 | | | | |
| 5 | | | | |
| 6 | | | | |
| 7 | | | | |
| 8 | | | | |

PASS: FAIL:

Remarks: