


MDA HALON Replacement Efforts

HALON Options Technical Working Conference
UNM / NMERI 9 May 1996




Glenn Harper
McDonnell Douglas Aerospace
Advanced Systems & Technology
(314)233-6459


Outline

- o Background
 - » Dry Bays
 - » Engine Bays
- o **Alternate Agent/Technology Penalties**
- o **Corrosion Screening Test for Gas Generator Exhaust Products ("Dust")**
- o **Planned CF3I Ground Testing**
- o **Operating/Test Considerations**
 - » **Impact of Leak Location on Fire Fuel History**
 - » **Representative VS Simplified Operating Conditions**
- o **Recommendations**


All MDC Aircraft Types Require Fire Protection




DRY Bay Protection



Dry Bay Protection Concept



Dry Bay Issues




- Effect of Equivalent Angle of Attack ?
- Time Delay to Discharge ?
- Fire or Explosion Protection ?

Engine Bay Protection

(APU, AMAD, Gearbox, Etc. are Usually Included)


Engine Bay Installation



Alternate Agent/Technology Penalties


(Engine Bay Application)

Weight / Volume Multipliers



Representative F/A Engine Bays Protection Penalties


Estimate Based on 1994 Data




Corrosion Screening Tests

(Trace "Dust" From **Solid**
Propellant Gas Generators)

Solid Propellant Gas Generators



"Dust" Samples




* Interior "Dust" Collected from inside Canister

** Expelled "Dust" Collected by Sweeping or Water Flush & Filtration

Corrosion Screening Test

(Per ASTM F1110-90)



Corrosion Test Results*

Source of "Dust"	Preparation	Results
Interior of Gas Generator	Dry Paste	0 4
Expelled & Collected By Water Rinse & Filtration	Dry Paste (Dust + H ₂ O)	0 0 & 1
Expelled & Collected By Dry "Sweeping"	Dry Paste (Dust + H ₂ O)	0 0 & 1


NOTES

- 0 = No Corrosion
- 1 = Mild Corrosion (Alodine and/or Anodize Penetrated but Base Metal Unaffected)
- 4 = Severe Corrosion (Base Metal Attacked)
- * = Test per ASTM F1110-90


Planned CF3I Ground Testing

(Potential Toxic Impact on
Maintenance Crew)


CF3I Concentration Test




Homogeneous 0.4% CF3I "Cloud"




Homogenous 0.4% CF3I "Cloud"




“Cloud” Shape / Height ?



Engine Bay Dispersion (= 40 Cubic Ft.)



Fuel Leak Location Impact



Location of Leak	Norm Press	Decay Press	Decay Time
A	25 Psi	25-0 Psi	0-2 Sec
B	300 Psi	300-0 Psi	5-60 Sec
C	1500 Psi	1500-0 Psi	5-60 Sec

Recommendations

- Understand the Fire Scenarios & Extinguishing Mechanisms
 - **Define** Various ~~Fire~~ Initiation / Development / Extinguishing / Re-ignition Scenarios
 - High Speed Instrumentation to Improve Understanding
 - Concentration, Pressure, Velocity ?
 - Theoretical Modeling to Mature the Science
 - Experiments to Determine / Verify the Mechanism of **Gas** Generator Extinguishing, Among Others
- ◆ Reduce Weight/Volume Penalties
 - Continue R&D on CF3I and **Gas** Generators, Others
 - DoD / **NIST** / ARPA Next-Generation Program
- ◆ **NOFire** Certification
 - Engine Bays / Dry Bays ?